

## Índice

O1 Introducción y análisis del problema

O3 Estudios y enfoques alternativos


O2 Desarrollo del caso práctico


Onclusiones y posibles mejoras





- Mejorar el rendimiento de sistemas HVAC
- Abordar esta complejidad con lógica difusa.






## Análisis del problema

- IEQ → Interacción de diversos factores.
- Controladores tradicionales operan de forma aislada.

#### Importancia:


- Bienestar y salud de los ocupantes.
- Alineación con objetivos climáticos de la UE.



## **Objetivos**

Diseño de un FLC para optimizar la IEQ, manteniendo niveles adecuados de confort.

Optimizar consumo energético	Reducir el consumo energético	
Integrar múltiples sensores	Varios datos (temperatura, humedad, CO <sub>2</sub> )	
Mejorar estabilidad del sistema	Reducir oscilaciones	





 Controlador difuso unificado

#### Unifying Fuzzy controller for Indoor Environment Quality

Miguel Molina-Solana, Maria Ros, Miguel Delgado
Department of Computer Science and Artificial Intelligence
Universidad de Granada,
Granada, Spain

Email: miguelmolina@ugr.es, marosiz@decsai.ugr.es, mdelgado@ugr.es

Abstract—Optimizing energy consumption while maintaining an appropriate level of comfort is one of the current challenges in the Indoor Environment Quality (IEQ) field. In this paper, we propose an unified fuzzy controller for managing the different aspects involved in IEQ, overcoming the potentially inefficient interactions between several traditional controllers. We also describe the implemented web simulator to test the controller, and the results of applying the controller to a pilot room, measuring the air quality over a period of a month. Even though, further research and experimentation should be done, specially with the experts in order to fine tuning the rules and the controller, initial results are promising enough and the ease of use is quite remarkable by users.

#### I. INTRODUCTION

Indoor Environment Quality (IEQ) has lately emerged as ance once the presence of HVAC (heating, air conditioning) systems has been popularized S. IEQ tries to go beyond traditional control ducing the comfort of the users in the game. energy consumption of those systems, while appropriate comfort level is an issue of great only and the systems of the

energy consumption by the HVAC equipment in residential, commercial and industrial buildings represent about 40%

Although traditional PIDs could provide reasonable solutions, they are not enough to control the uncertainty of the dynamics of HVAC systems, which are more easily characterised using linguistic labels and rules [2], [3]. Fuzzy Logic Controllers (FLCs) appear as a viable alternative to conventional controllers, since they do not required a mathematical modelling [4] and they are prepared to handle different criteria, as they represent the dynamic of the HVAC system according to the knowledge of a human expert. Moreover, their efficiency and lower energy consumption (while satisfying the indoor comfort requirements) comparing to PID controllers, has been completely demonstrated [5].

In the literature, an extensive variety of proposals in this direction can be found. For instance, Calvino et al. [6] focus on the development of a fuzzy controller for the control of the indoor thermal-hygrometry comfort conditions, allowing a better adjustment of the indoor micro-climate conditions.

The focus of the FLC is not only maintaining the thermal environment, but also optimizing other parameters if necessary. Becker et al. [7] propose a fuzzy controller for temperature and relative humidity (RH) in refrigeration systems, by considering their thermodynamic coupling. In [8], authors develop a rule-based fuzzy controller to control and provide thermal comfort


Molina-Solana, M., Ros, M., & Delgado, M. (2013). Unifying fuzzy controller for indoor environment quality. 2013 Joint IFSA world congress and NA FIPS annual meeting (IFSA/NA FIPS), 1080-1085.

#### **Entradas**:

- Temp. interna/externa
- Humedad relativa
- Concentración CO<sub>2</sub>
- Iluminación

#### Salidas:


- Nivel de temperatura
- Nivel de humedad
- Nivel de iluminación
- Programa de aire acondicionado




#### Base de conocimiento:

 Funciones de pertenencia (trapezoidales)

$$\mu_L(x_i) = egin{cases} 0 & ext{si } x_i < a ext{ o } x_i > d, \ rac{x_i - a}{b - a} & ext{si } a \leq x_i \leq b, \ 1 & ext{si } b \leq x_i \leq c, \ rac{d - x_i}{d - c} & ext{si } c \leq x_i \leq d. \end{cases}$$





#### Base de conocimiento:

• Conjunto de reglas difusas (IF-THEN)

IF  $S_{temp_{indoor}}$  IS Medium AND  $S_{temp_{outdoor}}$  IS High THEN  $A_{temp_{level}}$  IS Hold AND  $A_{h_{level}}$  IS Standard IF  $S_{RH}$  IS Low AND  $S_{temp_{indoor}}$  IS Low THEN  $A_{Air}$  IS Hot AND  $A_{h_{level}}$  IS High AND  $A_{temp_{level}}$  IS Up IF  $S_{RH}$  IS Medium AND  $S_{temp_{indoor}}$  IS Medium THEN  $A_{h_{level}}$  IS Standard IF  $S_{RH}$  IS High AND  $S_{temp_{indoor}}$  IS Medium THEN  $A_{Air}$  IS Dry AND  $A_{h_{level}}$  IS Continuous

#### Motor de inferencia:

Mamdani Max-Min


#### Defuzzificación:

- Modo A FATI
- Método del centroide

$$\mu_{R_{i}}(x) = \alpha_{i1} \wedge \alpha_{i2} \wedge \alpha_{i3} \wedge \alpha_{i4} \wedge \alpha_{i5}$$


$$\mu_{Output_{i}}(x) = \max \mu_{R_{1}}(x), \mu_{R_{2}}(x), ..., \mu_{R_{17}}(x)$$


$$d_{CA}(C) = rac{\int_{-c}^{c} C(z)z\,dz}{\int_{-c}^{c} C(z)\,dz}$$






#### Pruebas en el simulador







### Pruebas en un entorno real

- 1) Ventana
- 2) Puerta
- 3) Sistema HVAC
- 4) Sensor de temperatura
- 5) Sensor de humedad
- 6) Ausencia de muebles y personas\*



### Resultados y conclusiones







### FLC optimizado con algoritmos genéticos

 AG para optimizar los parámetros del controlador.



#### Fuzzy Control of HVAC Systems Optimized by Genetic Algorithms

#### RAFAEL ALCALÁ

Department of Computer Science, University of Jaén, 23071 Jaén, Spain alcala@ujaen.es

#### JOSE M. BENÍTEZ, JORGE CASILLAS, OSCAR CORDÓN AND RAÚL PÉREZ

Department of Computer Science and Artificial Intelligence, University of Granada, 18071 Granada, Spain jmbs@decsai.ugr.es casillas@decsai.ugr.es coordon@decsai.ugr.es fgr@decsai.ugr.es

Abstract. This paper presents the use of genetic algorithms to develop smartly tuned fuzzy logic controllers dedicated to the control of heating, ventilating and air conditioning systems concerning energy performance and into This problem has some specific restrictions that make it very particular and complex

Alcalá, R., Benítez, J. M., Casillas, J., Cordón, O., & Pérez, R. (2003). Fuzzy control of HVAC systems optimized by genetic algorithms. Applied Intelligence, 18, 155-177.


of heating, ventilating and air conditioning systems concerning energy performance and ints. This problem has some specific restrictions that make it very particular and complex requirements existing due to the need of considering multiple criteria (which enlarges the I to the long computation time models require to assess the accuracy of each individual. ons, a genetic tuning strategy considering an efficient multicriteria approach has been spic controllers have been produced and tested in laboratory experiments in order to check produced and tested in laboratory exp

test sites) have been provided by experts. Finally, simulations and real experiments were compared determining the effectiveness of the proposed strategy.

Keywords: HVAC systems, fuzzy logic controllers, genetic tuning, multiple criteria



## FLC optimizado con algoritmos genéticos



## FLC optimizado con algoritmos genéticos


#### Motor de inferencia:

Mamdani Max-Min

#### Defuzzificación:

- Modo B FITA
- MOM (Mean of Maxima)

$$\begin{split} \mu_{R_i}(x) &= \alpha_{i1} \wedge \alpha_{i2} \wedge \alpha_{i3} \wedge \alpha_{i4} \wedge \alpha_{i5} \\ \mu_{Output_i}(x) &= max \mu_{R_1}(x), \mu_{R_2}(x), ..., \mu_{R_{17}}(x) \end{split}$$



### FIS centrado en la evaluación de IEQ

- Qué parámetros constituyen y/o afectan a la IEQ.
- Factor humano.

Jabłoński, K., & Grychowski, T. (2018). Fuzzy inference system for the assessment of indoor environmental quality in a room. Indoor and Built Environment, 27(10), 1415-1430.

Original Paper

# Fuzzy inference system for the assessment of indoor environmental quality in a room

Karol Jabłoński and Tomasz Grychowski

#### Indoor and Built Environment

Indoor and Built Environment 2018, Vol. 27(10) 1415–1430 © The Author(s) 2017 Article reuse guidelines: sagepub.com/journals-permissions DD: 10.1177/1420326X17728097 journals-sagepub.com/home/ibe

#### Abstract

The aim of the project presented in this article was to design a system which allows for assessment of indoor environmental conditions, with a special consideration regarding the comfort of occupants. The system consists of two microprocessor devices with numerous sensors, as well as a PC application which includes fuzzy inference module. Fuzzy inference algorithm allows for comfort assessment based on data gathered by sensors. It can also help to analyse the efficiency of HVAC systems. The article includes description of the system's functions and selection criteria for sensors taking into

neasurands. Also described in this paper is the construction of knowledge base, based on from environmental standards and experts' statements. The constructed system was tested ed, to confirm its application in practical comfort assessment and to highlight the advantages by logic in the process of analysing measured parameters and inference, which captures the leings process data.

#### Keywords

Fuzzy logic, Indoor air quality, Environmental comfort, Microcontroller systems, Building control system, Knowledge-based systems, Multisensor system, Measurement system, Fuzzy inference


Accepted: 31 July 2017



### FIS centrado en la evaluación de IEQ


 Pruebas en entornos reales y transitados.

N	Time (min)	Event
0	000	Closing windows after venting and start of measurement
1	006	Leaving room by 1 person
2	020	Return of 1 person
3	022	Beginning of a meal
4	045	End of the meal
5	065	Leaving room by 1 person
6	140	Return of 1 person
7	182	Opening trickle vent in window
8	220	End of measurement



### FIS centrado en la evaluación de IEQ


Encuestas para la percepción humana del confort.



### Comparaciones

• ¿Qué enfoque es el más adecuado?

Aspecto	Controlador difuso unificado	Controlador con algo- ritmos genéticos	Sistema de inferencia difusa	
Variables controladas	Temperatura, humedad, CO2, iluminación	Temperatura, humedad, CO2, consumo energé- tico	Temperatura, humedad, CO2, iluminación, rui- do, olores	
Enfoque me- todológico	Controlador difuso clásico con reglas de- finidas por expertos. FLC supervisa PIDs para HVAC	Integración de algo- ritmos genéticos para optimizar automática- mente reglas y funcio- nes de pertenencia	Arquitectura modular con subsistemas inde- pendientes. Implemen- tación en LabVIEW	
Pruebas y validación	Pruebas en una habita- ción piloto controlada, comparando con con- trolador reactivo	Simulaciones y prue- bas en múltiples en- tornos reales bajo di- ferentes condiciones estacionales	Pruebas en entornos ocupados reales, corre- lacionando resultados con encuestas de usua- rios	
Objetivo principal	Optimizar el confort interior y la eficiencia energética en sistemas HVAC	Equilibrio dinámico entre confort y eficien- cia energética	Evaluación integral del confort interior basado en múltiples índices	
Aplicación recomendada	Escenarios con reglas de confort bien defi- nidas, simplicidad y robustez	Entornos donde se requiere máxima eficiencia energética y optimización precisa	Edificios donde la per- cepción humana del confort es crítica	



## Consecución de objetivos

Optimizar consumo energético	Mejor eficiencia energética del sist. HVAC	~
Integrar múltiples sensores	Temperatura interior y exterior, humedad	
Mejorar estabilidad del sistema	Reducir oscilaciones (suaviza cambios)	~



## Posibles mejoras

Flexibilidad y escalabilidad	Ampliar el número de sensores y variables de estudio	
Control predictivo y preventivo	Anticipar cambios y tomar medidas correctivas	
Personalización del confort	Tener en cuenta preferencias y actividades de los usuarios	

