



INSPECTING PHYSICAL PLANT

POLICY 5-7

PURPOSE: To provide guidelines regarding the inspection, testing, tending, and maintenance of physical plant and other equipment.

INTRODUCTION:

The general physical plant reflects the image of the cooperative, hence, the need for a systematic procedure for inspection, testing, and maintenance of the physical plant. Negligence in its care may mean a financial drain to the cooperative. Keeping in mind its importance, the Board deems it necessary to adopt the following policies:

POLICIES:

1. All physical plant equipment shall be periodically inspected and any defect shall be immediately repaired.
2. It shall be the responsibility of section heads to report to the management any defect of the equipment under their custody or care.
3. Sub-station transformers shall be annually tested and serviced: the testing shall include the following:
 - a. INSULATION TEST
 - b. OIL TEST for DIELECTRIC STRENGTH
4. Oil circuit breakers and reclosers shall be tested and serviced after every SEVENTY-TWO (72) trippings and closing operations.
5. Air break switches shall be inspected and serviced annually to coincide with the testing and servicing of sub-station transformers.
6. Distribution transformers shall be tested and serviced every three (3) years; testing shall include the following:
 - a. INSULATION TEST
 - b. OIL TEST for DIELECTRIC STRENGTH
 - c. LOAD TEST

IMPLEMENTATION:

The General Manager shall be responsible in implementing this policy.

(SGD) MANUEL E. GONZALES
President

(SGD) ABUNDIO M. AWAL
Secretary

APPROVED per Resolution No. 15-78 dated January 31, 1978.