



**PRIVATE ELECTRICAL LINES EXTENSION and/or ENERGIZATION
of PRIVATE HOUSING SUBDIVISIONS WITHIN THE COVERAGE
AREA OF BENECO
POLICY 6-6-A
as amended**

RATIONALE:

It is imperative that power distribution lines should be constructed with quality standard materials and quality workmanship to prevent or minimize occurrences of accidents which usually holds BENECO responsible.

OBJECTIVES:

1. To provide guidelines in the construction of private electrical transmission line extension for energization by BENECO.
2. To ensure the use of quality standard materials and quality workmanship and safety to the general public.
3. To obtain a well-designed electrical transmission line extension that can localize faults in case of systems troubles thereby reducing affected areas for more reliable service and lessen or reduce distribution systems losses.

DEFINITION OF TERMS:

1. PLANS shall refer to the complete electrical design of a system to include but not limited to:

ELECTRICAL PLAN: showing detailed sketches of all necessary structures (blueprint or equivalent) signed and sealed by a Professional electrical Engineer.

ELECTRICAL DESIGN: contains the computations for clearances, sizes, and capacities of all electrical necessities such as wires, crossarms, transformers, poles, guy wires, and others signed and sealed by a Professional Electrical Engineer.

2. BENECO – the Benguet Electric Cooperative, Inc.
3. NEA – the National Electrification Administration
4. CONSTRUCTION – an activity in electrical systems involving the erection of poles.
5. INSTALLATION – an activity in electrical systems including the attachments of pole line materials and conductors.
6. PCAB – the Philippine Contractors Accreditation Board, a body authorized to issue certificates of specialization of a construction firm.



**PRIVATE ELECTRICAL LINES EXTENSION and/or ENERGIZATION
of PRIVATE HOUSING SUBDIVISIONS WITHIN THE COVERAGE
AREA OF BENECO**

POLICY 6-6-A

7. **ACQUISITION COST-** the BENECO's purchase cost including computed expenses like freight, incidental expenses, etc.
8. **ELECTRICAL DISTRIBUTION SYSTEM** – an electrical system intended to distribute power to consumers at a usable voltage level; distribution system included the primary line, distribution transformers and protection, secondary line, service drop, and metering (standard distribution voltage in the Philippines: MERALCO – 34.5kv; BENECO, CEPALCO, Angeles Electric Cooperative, VECO and other co-ops – 23 kv/13.2kv/2.4kv)
9. **PRIMARY LINES** – are BENECO standard lines that are energized at 23kv or 13.2/2,62 kv).
10. **SEOCNDARY LINES** – any line energized at 110, 240, 480 volts.

POLICY:

1. The plans for all private electrical transmission line extension system within the coverage area of BENECO shall be prepared, signed and sealed by a duly-licensed Professional Electrical Engineer and shall be constructed in accordance with the plans, designs, and specifications duly-approved by BENECO.
2. The construction of the electrical distribution line extension system shall be at the expense of the owner and shall be undertaken by any qualified licensed electrical contractor duly accredited by the Philippine Contractors Accreditation Board (PCAB) with appropriate class or category.
3. The materials shall first be inspected by BENECO electrical engineers to ensure that said materials shall meet the standard and quality acceptable to BENECO, NEA, and the end-user to avoid future conflicts on the quality and standards.
4. BENECO engineers shall have access to the project at all times for the purpose of monitoring compliance on the quality of materials and workmanship.
5. In case the owner so desires that BENECO shall undertake the construction and provide the materials needed, the owner shall make a request in writing addressed to the BENECO general manager stating such intention.
6. If BENECO accepts the request, the construction of the project shall be done under the terms and conditions contained in the memorandum of agreement entered into and acceptable to both the papties (the owner and BENECO).



**PRIVATE ELECTRICAL LINES EXTENSION and/or ENERGIZATION
of PRIVATE HOUSING SUBDIVISIONS WITHIN THE COVERAGE
AREA OF BENECO
POLICY 6-6-A
as amended**

7. In case where the construction of such private electrical distribution line is at the expense of the owner, BENECO shall reimburse to the owner the amount of materials used in extending power line from the tapping pole to the perimeter of the subdivision or load without interest based on BENECO's or owner's acquisition cost whichever is lower, excluding labor cost, beginning upon realization of 80 percent of the projected load; BENECO shall refund the cost of the project from the net sales within the subdivision less NPCcost of power up to maximum of 5-year period, or if and when said lines are to be utilized for another BENECO project.
8. All energized electrical distribution lines which were constructed prior to the approval of this policy but without final acceptance, BENECO must first be corrected in accordance with the recommendations of BENECO management.
9. Upon energization of the private subdivision or any portion thereof, the operation and maintenance of the electric system therein shall be the sole responsibility of the subdivision owner and/or developer who shall be solely liable for any damages resulting directly or indirectly from the operation and maintenance of the system, until the system is fully, officially and formally turned-over by any legal means, to and accepted in writing by BENECO.
10. All existing policies contrary to this are hereby amended.

RESPONSIBILITY: The General Manager shall be responsible in implementing this policy.

EFFECTIVITY: This policy shall take effect upon approval by the BENECO Board.

(SGD) RAMON S. DACAWI
Secretary/PRO

(SGD) RUFINO M PANAGAN
President

APPROVED pursuant to Board Resolution No. 146-96 dated December 7, 1996: