



SERVICE CONNECTION REQUIREMENTS and GUIDELINES

POLICY 102 – 98

POLICIES:

1. Only copper conductors shall be used for the service entrance; the lineside portion of the service entrance (from the entrance cap to the meter socket) shall never be concealed or embedded except if the metering required is Current Transformer- (CT) rated.
2. Underground service entrance shall first meet the approval of BENECO before the wiring installation is started.
3. The lineside portion shall be of rigid metallic electrical conduit, rigid steel conduit or electrical metallic tubing; plastic conduit (PVC) and BX cables are NOT ALLOWED; joints and splices inside conduits are NOT ALLOWED.

Lineside and loadside wire or conductor shall not be contained together in the conduit, junction box, accessoria box, wire gutter or wire through.

4. Service entrance conduit shall be properly strapped to the wall of the building.
5. The drip loop (wire protruding at the entrance cap for connection to the service wire) shall not be shorter than 0.6 meters (2 feet).
6. No junction box or accessoria box shall be installed between the entrance cap and the meter socket for single metering installation: standard couplings may be used.
7. Accessoria box, wire gutter or wire through, when installed in the lineside portion of the service entrance shall be of the sealable type.

The meter socket shall be installed facing the street in a clean place free from vibration on the outside wall of the building or on a private pole within 1.53 meters from the ground (reading height).

Only the top and the bottom portion of a meter base socket type shall be allowed as entry/ exit of the conductors.

8. Never connect, tap or splice the service entrance to the service drop and the service drop to the secondary line.

Service drop may be strung to check length but never be tapped by the contractor.

IMPLEMENTATION:

The General Manager shall be responsible for implementing this policy.



SERVICE CONNECTION REQUIREMENTS and GUIDELINES

POLICY 102 – 98

EFFECTIVITY:

This policy shall take effect upon approval by the Board.

(SGD) BORROMEIO P. MELCHOR
President

(SDG) RAMON S. DACAWI
Secretary

APPROVED per Board Resolution No. 75-98 dated August 1, 1998.