Fjordview Kommune

Fjordview Community Centre

Tender Reference FCC-2026-T01

Document 07

Addenda and Tender Query Responses

Revision	Date	Status	Prepared by	Checked by
P02	2026-10-27	Issued for Tender - cumulative	Fjordview Kommune Project Team	Nordvik Rådgivning AS

This document forms part of the tender documents for the above project. It is issued for tendering purposes only and must not be used for construction.

Note: this is a synthetic example tender pack prepared for a technical interview exercise. The project, parties and figures are fictional.

Introduction

This document is issued progressively during the tender period and contains, in Part A and Part B, the addenda issued by the Employer and, in Part C, the anonymised tender queries received from Tenderers with the Employer's responses. Each issue of this document is cumulative and replaces the previous issue.

Addenda form part of the tender documents and, in accordance with Section 5 of the Instructions to Tenderers, take precedence over all other tender documents, the later addendum prevailing over the earlier. Tenderers shall acknowledge receipt of each addendum on the Form of Tender.

Tender query responses in Part C are issued for information only and do not form part of the tender documents or the Contract unless their content is incorporated by an addendum.

Issue	Date	Content
P01	20 October 2026	Addendum No. 1; tender queries TQ-01 to TQ-05
P02	27 October 2026	Addendum No. 2; tender queries TQ-06 to TQ-10

Part A - Addendum No. 1

Issued 20 October 2026 by the Employer's Representative.

Item 1.1 - Tender return date

The tender return date and time in Section 3 of the Instructions to Tenderers is amended from 7 November 2026, 12:00 CET to 14 November 2026, 12:00 CET. The tender validity period runs from the amended date.

Item 1.2 - External wall thermal performance

The maximum U-value for external walls is amended from 0.22 W/m2K to 0.18 W/m2K. This amendment applies to the Employer's Requirements Section 5.3, the Architectural Specification Section 3.1 and drawing A-401 Detail 1. The Contractor shall adjust the insulation thickness or specification as necessary; the 250 mm frame depth shown on A-401 may be increased.

Item 1.3 - Main Hall ventilation rate

In the MEP Specification Section 6.2, the occupancy ventilation rate for the Main Hall is amended from 12 l/s per person to 10 l/s per person.

Item 1.4 - Site visit

A second site visit will be held on 22 October 2026 at 10:00 for Tenderers who were unable to attend on 15 October 2026. Attendance at either visit satisfies the mandatory site visit requirement.

Item 1.5 - Additional provisional sum

Add provisional sum PS7 'Signage and wayfinding scheme' NOK 250,000 to Section 12 of the Instructions to Tenderers and to Section V of the Pricing Schedule. The signage scheme described in the Architectural Specification Section 8 is to be developed by the Contractor; the manufacture and installation of the signs will be instructed against PS7.

Item 1.6 - Information documents

The Stage 3 fire strategy report (September 2026) is now available on the procurement portal. It is issued for information and is to be completed by the Contractor's fire engineer.

Part B - Addendum No. 2

Issued 27 October 2026 by the Employer's Representative.

Item 2.1 - Tender return date

Further to Addendum No. 1 Item 1.1, the tender return date and time is amended to 21 November 2026, 12:00 CET. Addendum No. 1 Item 1.1 is superseded by this item.

Item 2.2 - Main Hall ventilation rate

Addendum No. 1 Item 1.3 is withdrawn. The occupancy ventilation rate for the Main Hall in the MEP Specification Section 6.2 shall be 8 l/s per person with CO2 demand control, consistent with the minimum rate in the Employer's Requirements Section 6.1. The amended table is reproduced below and replaces the table in Section 6.2 in its entirety.

Space	Design occupancy	Rate per person	Control
Main Hall	600	8 l/s	CO2 demand control
Library	120	10 l/s	CO2 demand control
Multi-purpose rooms	40 each	10 l/s	CO2 demand control
Music Room and practice rooms	30 / 4	10 l/s	Presence
Offices and meeting rooms	24 / 12	8 l/s	Presence
Youth Club	60	10 l/s	CO2 demand control
Cafe	60	10 l/s	Presence
Kitchen	8	Per canopy and equipment heat gain	Constant

Item 2.3 - Last date for tender queries

The last date for tender queries in Section 3 of the Instructions to Tenderers is amended from 28 October 2026 to 4 November 2026.

Item 2.4 - Kitchen equipment warranties

For the avoidance of doubt, the 24-month warranty for commercial kitchen equipment in the Particular Conditions of Contract Clause 11.3 applies to the walk-in cold rooms FZ-01 and CH-01 including their remote condensing units.

Item 2.5 - Pricing Schedule

Section R of the Pricing Schedule (commercial kitchen equipment) shall include the supply and installation of the remote condensing units for FZ-01 and CH-01 and the refrigerant pipework between the kitchen and the roof. Section M shall exclude these items.

Item 2.6 - Drawing A-301

Drawing A-301 Elevations is reissued at revision P02 to correct the window reference numbers on the east elevation. No change to the extent or performance of the windows.

Part C - Tender queries and responses

Queries are reproduced with the Tenderer's identity removed. Responses are issued for information only and do not amend the tender documents unless incorporated by an addendum. Where a response appears to conflict with a tender document, Tenderers should raise a further query.

TQ-01

Reference	Instructions to Tenderers 4.2 / Particular Conditions 10
Query	Does the Contract Period include the 12-month seasonal commissioning period?
Response	No. Seasonal commissioning takes place after Completion and does not affect the Date for Completion.

TQ-02

Reference	MEP Specification 2.1
Query	May the Tenderer propose an air-source heat pump in place of the ground-source installation?
Response	The Tenderer may propose this as a departure in its statement of compliance, demonstrating that the energy label and net delivered energy targets are still achieved. The Employer gives no commitment to accept the departure.

TQ-03

Reference	Employer's Requirements 4.4 / Drawing A-100
Query	Please confirm the number of EV charging points to be installed.
Response	Eight 22 kW charging points are to be installed, with ducting to a further 16 bays.

TQ-04

Reference	Particular Conditions 14.3
Query	Please confirm the retention percentage and the timing of its release.
Response	Retention is 3% of each interim payment and is released in full on Completion.

TQ-05

Reference	Employer's Requirements 7.3 / MEP Specification 5.1
Query	Please confirm whether the photovoltaic array is included in the Works and in which section of the Pricing Schedule it is to be priced.
Response	Refer to the Employer's Requirements Section 7.3. Pricing shall be in accordance with the Pricing Schedule structure in the Instructions to Tenderers Section 11.

TQ-06

Reference	Architectural Specification 5.2 / MEP Specification 7.3
Query	Who supplies the doors to the walk-in freezer and chiller, D-G16 and D-G17?
Response	The doors are supplied as part of the cold room equipment by the kitchen equipment Supplier, as noted in the door schedule and MEP Specification Section 7.3.

TQ-07

Reference	Document 06 Part F
Query	Are the dates in the Employer's tender programme binding?
Response	No. The tender programme is indicative. The Contract Period and the Date for Completion are stated in the Particular Conditions of Contract.

TQ-08

Reference	Employer's Requirements 5.9 / MEP Specification 9
Query	Please confirm the number of passenger lifts to be provided.
Response	Refer to the Employer's Requirements Section 5.9 and the MEP Specification Section 9.

TQ-09

Reference	Instructions to Tenderers 13
Query	Will the adjacent school be in use throughout the construction period?
Response	Yes. The school is in use during term time. The delivery and noise restrictions in the Instructions to Tenderers apply on all school days. Term dates are available on the municipality's website.

TQ-10

Reference	Instructions to Tenderers 4.3 / Particular Conditions 8.7
Query	Please confirm the rate of liquidated damages for delay.
Response	The rate of liquidated damages is as stated in the Particular Conditions of Contract.

Part D - Acknowledgement of addenda

Tenderers shall complete the following and include it with the Form of Tender in Envelope B.

Addendum	Date of issue	Received (date)	Initials
No. 1	20 October 2026		
No. 2	27 October 2026		
No. 3 (if issued)			

We confirm that we have taken the above addenda into account in preparing our tender.

Signed: _____ For and on behalf of: _____ Date: _____

Part E - Record of site visit attendance

Site visits were held on 15 October 2026 and 22 October 2026. Six Tenderers attended on 15 October and two on 22 October. Attendance records are held by the Employer's Representative. All Tenderers who registered on the procurement portal have satisfied the mandatory site visit requirement.