Large Load Interconnection Status Update

Large Load Integration Team

February 25, 2026

Current Large Load Interconnection Queue



- **Observed Energized –** Projects that have received Approval to Energize from ERCOT Operations and are fully operational. Represented by all time non-simultaneous peak load consumption.
- **Approved to Energize but Not Operational –** Projects that have received Approval to Energize from ERCOT Operations but are not observed to be operational.
- **Planning Studies Approved –** Projects that have received ERCOT approval of required interconnection studies. Any MWs that were not approved are reclassified as No Studies Submitted.
- **Under ERCOT Review –** Projects that have studies under review by ERCOT.
- **No Studies Submitted –** Projects that are tracked by ERCOT but that have not yet provided sufficient information for ERCOT to begin review. Additionally, MWs that were not approved by ERCOT after review of planning studies are included in this category until a path to interconnect these MWs is identified, or the customer cancels the interconnection request.

Loads Approved to Energize – Observations 1

- Of the 8876 MW that have received Approval to Energize, ERCOT has observed a **non-simultaneous** monthly peak consumption of 3998 MW in February 2025 which is a slight decrease since January 2025.
  - This is calculated as the sum of the maximum value for each individual load per month
  - This value represents how much approved load ERCOT believes is now operational



Loads Approved to Energize – Observations 2

- ERCOT has observed a **simultaneous** monthly peak consumption of 3846 MW in February 2025 which is a slight increase since January 2025.
  - This is the maximum value of the sum of all the individual loads per month
  - This value is the maximum amount of large load that ERCOT has had to serve at a single point in time

