

MAICEN-1125

Masters in AI in Architecture and Construction

Module 7, Unit 5 — Individual Assignment

From EIR to IFC: An IDS-Driven openBIM Validator for MEP Services with LLM-Authored Specifications

Individual Submission by

Mark Shane Haines

Zigurat Global Institute of Technology

Submission Date: 28 June 2026

Reading guide for examiners

This submission maps to the rubric:

- **Functional code execution (40%).** §3 covers the validator and multi-format reporter. §4 covers the two LLM modules, both gated by the XSD. §5 gives the end-to-end results on two real IFC4 MEP models and the 4-test pytest suite that passes in 2.18 s.
- **Correct use of the BIM API (30%).** §2 documents the hand-authored IDS ruleset, constructed via the `ifctester.ids` Python API so the result is XSD-valid by construction. §3 routes validation through `ifctester.ids.Ids.validate()`, the buildingSMART reference implementation. §4 validates every LLM-generated specification against the bundled buildingSMART IDS 1.0 XSD before it touches disk.
- **Documentation and logical explanation (30%).** This report, the architecture and pipeline SVGs in §3, the rubric-mapped README on the GitHub repository, and a logically-staged commit history (Phase 0 through Phase 7, plus the live-LLM end-to-end commit).

Validation reports for every run sit in `results/` on the GitHub repository (JSON, HTML, BCF, summary CSV, failures CSV). Live Claude output from both LLM modules is committed as evidence: `results/eir_translation_three_clauses.ids`, `results/generated_demo.ids`, `results/Ifc4_Revit_MEP_remediated.json`.

§7 adds a future-proofing roadmap that scales the workflow from the nine demonstration specifications to a full MEP&F production library (Mechanical, Electrical, Plumbing and Fire), roughly 100 to 165 specifications across 41 distinct property sets, aligned to AS/NZS and NZBC. That section sits beyond the assignment minimum. §1 through §6 stand on their own as a complete submission.

Why openBIM rather than Revit + pyRevit?

The module's lecture deck points at Revit and pyRevit. I built the submission on `ifcopenshell` and `ifctester` instead. The choice is not an inversion of the lecturer's argument; it is an extension of it. Slides 18 to 24 of Elias's deck make the case that the genuine contract between an Employer's Information Requirements (EIR) and a machine-checkable rule lives in IDS (Information Delivery Specification), not in any one authoring tool. Take that argument seriously and the authoring tool stops mattering. Revit, ArchiCAD, AutoCAD MEP and Tekla all export IFC4. A checker that only runs inside Revit is worth less than half of what I need in front of a client whose disciplines are split across a mixed authoring estate.

I therefore targeted the buildingSMART reference openBIM stack directly: `ifcopenshell` to read IFC, `ifctester` to apply IDS. Both libraries are maintained by the people who write the IDS standard, and the IDS 1.0 XSD ships inside the `ifctester` Python package itself. The

same validation gate buildingSMART publishes is the one my code enforces, on the hand-authored ruleset and on every LLM-generated specification before it persists. When this approach has to stand up in front of a client or a professional indemnity insurer, that pedigree matters.

Why two IFC test models?

The handover plan named two source IFC models from the University of Auckland Open IFC Model Repository ([Trapelo_IFC4_MEP.ifc](#), [Hospital_IFC4_SPR.ifc](#)). On the day, that repository turned out to be a single-page JavaScript application that requires an interactive browser login I could not automate cleanly within the time budget. Rather than abandon the comparative approach, I swept GitHub, the buildingSMART sample-test-files repository, the IfcOpenShell community fixtures and the EnEff:BIM research datasets, and sourced two no-login IFC4 replacements with substantial MEP content:

- [Ifc4_Revit_MEP.ifc](#) (27.8 MB, IFC4): the Autodesk Revit MEP Advanced Sample project ([rme_advanced_sample_project.rvt](#)) exported to IFC4 and republished by youshengCode on GitHub. 302,453 entities, including 8,515 distribution ports, 491 pipe segments, 837 duct segments, 11 flow terminals, 6 fire-suppression terminals, 415 light fixtures and 359 air terminals.
- [BoilerGasRadiatorDomesticHotWater.ifc](#) (1.35 MB, IFC4, MIT-licensed): the VDI 6020 boiler / gas radiator / domestic hot water reference model from the German federal EnEff:BIM research project. 26,030 entities, including 1 pump, 4 valves, 1 boiler, 29 pipe segments and 114 distribution ports.

Between them, the two models exercise seven of the nine specifications in the ruleset. Two specifications ([IfcCableSegment](#), [IfcElectricAppliance](#)) match zero entities in either model. The ruleset keeps them because the contract is written for the building, not the test sample, and the validator reports the unmatched specs as `applicable=0 → SKIP` rather than dressing them as `PASS`. That distinction matters; I return to it in §6.

1. Executive summary

This submission delivers a complete EIR-to-validation pipeline on the buildingSMART reference openBIM stack:

1. A **hand-authored IDS ruleset** ([ids/mep_services_v1.ids](#)) of nine MEP services specifications, constructed via the [ifctester.ids](#) Python API so the result is XSD-valid by construction. A secondary `lxml`-based check against the bundled IDS 1.0 XSD passes as belt-and-braces (9 specifications, zero schema errors).
2. A **validator and multi-format reporter** wrapping [ifctester.ids.Ids.validate\(\)](#). A single CLI command (`python -m src.cli`) produces JSON, HTML, BCF, summary

CSV and per-failure CSV outputs in one invocation. BCF is the format that matters in production: it imports straight into Solibri, BIMcollab, Navisworks Manage and Trimble Connect as a coordination issue tracker, which is how modellers actually receive feedback.

3. **Two LLM modules** built on the Anthropic SDK (Claude Sonnet 4.6).
`src/llm_eir_to_ids.py` translates a natural-language EIR clause into one IDS specification, with the bundled IDS XSD as a hard validation gate.
`src/llm_remediation.py` reads the JSON validation report, batches failed entities into Claude calls, and writes a plain-English remediation paragraph back into the report for each one.

The pipeline ran end-to-end against the two IFC4 test models above. The Revit MEP model passes 5 of 9 specifications (76% of total checks); the Boiler model passes 6 of 9 (62% of total checks). End-to-end timings on a Windows 11 laptop: IFC open 0.11 s to 2.26 s, IDS validation 0.01 s to 0.50 s. Both numbers sit an order of magnitude under the 20-minute slowdown documented in [IfcOpenShell GitHub Discussion #6782](#), which is triggered by complex applicability restrictions rather than the entity-class filters used here.

Live LLM output is committed to the repository as evidence: three EIR clauses translated to three XSD-valid IDS specifications, eight validation failures annotated with remediation paragraphs that name the missing `Pset.Property`, the design-side action, and the downstream impact. Both runs are also embedded in [notebooks/01_demo_validation.ipynb](#) so the cells show real Claude output rather than skipped placeholders.

The complete codebase, IDS ruleset, IFC source links, test suite, technical report, architecture diagrams and live LLM output are public at <https://github.com/markshanehaines-ZIG/m7u5-ids-mep-validator> under MIT licence.

2. The IDS ruleset, definition and rationale

2.1 The nine specifications

`ids/mep_services_v1.ids` carries nine specifications covering the major MEP services entity classes in IFC4. Each specification has an `<applicability>` element (the IFC entity class to target, optionally filtered by predefined type) and a `<requirements>` element listing the property, attribute, material or partOf facets that must be satisfied.

#	Applicability	Requirement	Standards hook
MEP-01	<code>IfcPipeSegment</code>	<code>Pset_PipeSegmentTypeCommon.NominalDiameter</code> populated AND material assigned	AS/NZS 3500.1, IFC4
MEP-02	<code>IfcDistributionPort</code>	<code>FlowDirection</code> attribute in {SOURCE, SINK, SOURCEANDSINK}	IFC4 <code>IfcFlowDirectionEnum</code>

#	Applicability	Requirement	Standards hook
			m
MEP-03	IfcFlowTerminal	Membership of an IfcDistributionSystem group via IfcRelAssignsToGroup	IFC4
MEP-04	IfcFireSuppressionTerminal	Pset_FireSuppressionTerminalSprinkler.CoverageArea populated AND PredefinedType not NOTDEFINED	NZS 4541, BS EN 12845 §10
MEP-05	IfcPump	Pset_ManufacturerTypeInformation.Manufacturer AND .ModelLabel populated	ISO 19650-2
MEP-06	IfcDuctSegment	Pset_DuctSegmentTypeCommon.NominalLengthOrDimension populated AND material assigned	AS 1668.2, AS 4254
MEP-07	IfcValve	Pset_ValveTypeCommon.ValveOperation populated AND PredefinedType not NOTDEFINED	AS 1628
MEP-08	IfcCableSegment	Pset_CableSegmentTypeCommon.CrossSectionalArea populated	AS/NZS 3000 §433
MEP-09	IfcElectricAppliance	Pset_ElectricalDeviceCommon.NominalPower populated	AS/NZS 3000 §4

Each specification carries a human-readable `<instructions>` field that names the regulatory hook. For this academic submission the references blend British (BS EN, BS 7671) and Australasian (AS/NZS, NZS, NZBC) standards; for production use in my consultancy the entire set normalises to the AS/NZS stack. The structural pattern stays the same either way.

2.2 Why the IDS file is the contract surface

The IDS file is the single piece of the workflow a non-developer can read and negotiate. A modeller, a designer, a client representative and a checker can sit in the same room with the IDS open and argue about whether `Pset_PipeSegmentTypeCommon.NominalDiameter` is the right hook for a sprinkler riser, without ever opening Python. That matters because the validator, the reporter, the LLM modules and the CLI are all implementation details that change between projects. The IDS is the artefact that survives across them. Treating the IDS as the contract surface, and the openBIM toolchain as the enforcement mechanism, is the design choice that separates this build from a Revit-button approach.

2.3 The MEP-04 IFC4 schema correction

The handover plan named `IfcSprinkler` as the applicability entity for the sprinkler specification. `IfcSprinkler` exists in IFC2X3 but was **retired in IFC4**. Sprinklers are now

modelled as `IfcFireSuppressionTerminal` with `PredefinedType=SPRINKLER` or `SPRINKLERDEFLECTOR`. The original spec would have matched zero entities in any IFC4 file, a silent false PASS that no automated validator could catch on its own.

I corrected the spec to `IfcFireSuppressionTerminal` and widened the requirement to flag both missing `CoverageArea` and a `NOTDEFINED` `PredefinedType`. The corrected spec then surfaces all six fire-suppression terminals in the Revit MEP sample as failing.

This is the kind of issue every legacy IDS in the industry quietly carries. When a firm migrates a client portfolio from IFC2X3 to IFC4, half their old rules silently match zero entities and nobody notices. The validator's `applicable=0 → SKIP` reporting flags this honestly. A migration audit that runs an old IDS through this pipeline on an IFC4 model finds every spec that needs schema migration. That alone is a billable engagement.

2.4 IDS authoring via the ifctester Python API

The ruleset is generated by `scripts/build_mep_ids.py`, which constructs every specification via the `ifctester.ids` Python constructors. The result is **XSD-valid by construction**: there is no path through the constructor API that emits malformed XML. A secondary `lxml.etree.XMLSchema.assertValid()` check against the bundled buildingSMART IDS 1.0 XSD passes cleanly (9 specifications, zero schema errors).

Hand-writing IDS XML in a text editor is the wrong workflow for production. Property names, `dataType` strings and facet attribute orderings are unforgiving. A Python builder script that wraps the buildingSMART reference constructors is the right workflow, and it is the workflow the LLM generator in §4 uses internally too.

3. The validator and reporter

3.1 Toolchain

Stage	Tool	Version
IFC parsing	<code>ifcopenshell</code>	0.8.5
IDS validation	<code>ifctester</code> (buildingSMART reference)	0.8.5
XSD schema	bundled inside <code>ifctester</code> package	IDS 1.0
Reporter outputs	<code>ifctester.reporter.Json / .Html / .Bcf</code>	0.8.5
Test harness	<code>pytest</code>	9.1.0
LLM client	<code>anthropic SDK</code>	0.109.1
Model	<code>claude-sonnet-4-6</code>	via Anthropic API

Stage	Tool	Version
Environment	Python 3.11 venv on Windows 11	n/a

The pipeline is the openBIM equivalent of the M7U4 ETL pattern: **Load** → **Filter applicability** → **Check requirements** → **Emit reports**, realised in code rather than in a diagram. The four stages are shown in [docs/pipeline.svg](#) with the two LLM extension lanes alongside.

3.2 The validator wrapper

`src/validator.py` is intentionally thin. The buildingSMART stack already does the schema-level work. The wrapper exists to (a) time each stage so this report can quote the numbers, (b) expose a single `ValidationRun` dataclass that the CLI, the test suite and the demo notebook all consume, and (c) log progress so a CI job or interactive caller can follow long-running validations.

The class has one public method, `run()`, that opens the IFC, loads the IDS, calls `doc.validate(model)`, instantiates `ifctester.reporter.Json(doc).report()` to populate the result structure, and returns a `ValidationRun` dataclass carrying the model, the validated IDS, the open and validate timings, and the JSON report.

3.3 The multi-format reporter

`src/reporter.py` produces five output files per IFC, each aimed at a different downstream consumer:

File	Read by	Used when
<code>*_report.json</code>	other software (CDE plugins, dashboards, scripts)	feeding results into a Power BI dashboard or another tool
<code>*_report.html</code>	humans in a browser	sharing with the modelling team, who click each spec to expand failures
<code>*_report.bcf</code>	Solibri / BIMcollab / Navisworks Manage / Trimble Connect	**the production output** ; imports into the CDE as a coordination issue tracker with one BCF topic per failure
<code>*_summary.csv</code>	Excel	dashboards, client weekly reporting, quick scan
<code>*_failures.csv</code>	Excel + Power BI	drill-down, one row per failed entity with GUID for back-trace into the authoring tool

One `ifctester` 0.8.5 subtlety caught me out and is worth recording. The `Json`, `Html` and `Bcf` reporters all read `self.results` inside their `to_file()` methods, but `self.results` is only populated by `.report()`. My wrapper calls `.report()` explicitly before each `.to_file()`.

Without it the JSON output is a 23-byte stub (`{"hide_skipped": false}`), the HTML is a template skeleton, and the BCF writer raises `KeyError: 'title'`. Anyone else building on this stack should know.

A second polish: a specification with zero applicable entities is reported by ifctester as `status=True` (vacuously satisfied). For my dashboard view I rewrote this to `SKIP` when `applicable==0`, so a spec with no entities found is visually distinct from a real PASS. Vacuous satisfaction is not the same as the IDS being met.

3.4 The CLI entry point

```
python -m src.cli --ifc ifc/Ifc4_Revit_MEP.ifc \
                --ids ids/mep_services_v1.ids \
                --out results/
```

`src/cli.py` exposes the validator and reporter via `argparse`. The exit code mirrors validation status so a CI pipeline can gate on it: `0` for pass, `1` for fail. A `--quiet` flag suppresses info-level logs for non-interactive use.

4. LLM modules, natural language at both ends

The two LLM modules are the additive piece. Neither is required by the rubric. Both exist because the EIR-to-IDS gap and the validation-result-to-modeller-advice gap are the actual bottlenecks in Services BIM consulting today, and Claude is good at exactly the structured-text-to-structured-text task that bridges them.

4.1 EIR-to-IDS generator (`src/llm_eir_to_ids.py`)

Workflow:

1. Read a plain-text file of natural-language EIR clauses (blank-line separated, `#` comments).
2. For each clause, build a structured Anthropic API request with a system prompt that constrains Claude to emit one `<specification>` element of IDS 1.0 XML and nothing else. The system prompt includes a one-shot example of (English clause → IDS XML) and the namespace and cardinality rules.
3. Receive the response, strip any markdown code fences, extract the `<specification>` block.
4. Wrap the block in a complete `<ids>` document and validate it against the bundled buildingSMART IDS XSD via `lxml`.
5. If XSD-valid, append to the output `.ids` file. If invalid, report the error and skip. The run cannot silently emit malformed XML.

The XSD gate is the critical design decision. An LLM that occasionally hallucinates a property name or a facet structure is acceptable. An LLM that writes invalid XML into a production IDS file is not. The gate runs in microseconds and rejects anything the buildingSMART validator would reject.

4.2 Remediation generator (`src/llm\_remediation.py`)

Workflow:

1. Read a JSON validation report produced by `src/cli.py`.
2. Iterate `failed_entities` across every requirement in every specification.
3. Batch the failures (default 8 per request) into Anthropic API calls with a system prompt that asks for one 60–90 word paragraph per failure addressed to the BIM author, naming the specific `Pset.Property` that is missing, the GUID and name of the affected entity, the design-side action to take, and the downstream impact.
4. Merge the returned paragraphs back into the JSON report under a new `remediation` key on each failure.
5. Write the annotated JSON to the output path. Failed batches log a warning and continue; the rest of the report is preserved.

The output is a JSON report where every annotated failure carries machine-traceable identity (GUID, IFC class, spec name) **and** human-readable instruction. That is what closes the "modellers don't know what to do with the report" gap that real coordination meetings trip over.

4.3 Demonstration evidence

Both modules ran end-to-end against the real test models (output committed to the repository):

EIR-to-IDS generator translated three natural-language clauses from `queries/sample_eir_clauses.txt`:

All air-handling units shall declare the supply-air design flow rate via Pset_AirHandlingUnitTypeCommon.NominalAirFlowRate so the commissioning team can verify against the room-by-room load schedule.

into three IDS specifications, all of which passed the XSD gate and round-tripped through `ifctester.ids.open()`. Output committed at `results/eir_translation_three_clauses.ids`.

Remediation generator annotated eight failures from `results/Ifc4_Revit_MEP_report.json` with paragraphs of this form:

For the IfcPipeSegment with GlobalId 213f6VCXH5cBojaxiKbfKS (named 'Pipe Types:Standard:513756'), the property set Pset_PipeSegmentTypeCommon is either

absent or does not contain the required NominalDiameter property. Please open this element in your authoring tool, navigate to its type or instance properties, and populate Pset_PipeSegmentTypeCommon.NominalDiameter with the design pipe diameter expressed in millimetres. Without this value, downstream hydraulic sizing and clash-clearance checks cannot be verified against design intent.

Output committed at `results/Ifc4_Revit_MEP_remediated.json`.

Both runs are also embedded in `notebooks/01_demo_validation.ipynb` so the cells show real Claude output rather than skipped placeholders.

5. Results

5.1 Per-model summary

Model	Source	Sche ma	Size	Total entities	Specs pass	Checks pass
Ifc4_Revit_MEP .ifc	Autodesk RME Advanced Sample (youshengCode/IfcSample Files)	IFC4	27.8 MB	302,453	5 / 9	76 %
BoilerGasRadia torDomesticHot Water.ifc	EnEff:BIM VDI 6020 reference, MIT-licensed	IFC4	1.35 MB	26,030	6 / 9	62 %

5.2 Per-specification results

#	Specification	Revit MEP applicable / pass / fail	Boiler applicable / pass / fail
MEP-01	Pipe segment, diameter and material	491 / 0 / 491	29 / 0 / 29
MEP-02	Distribution port, flow direction	8,515 / 8,515 / 0	114 / 114 / 0
MEP-03	Flow terminal, system membership	11 / 0 / 11	0 / 0 / 0 (SKIP)
MEP-04	Fire-suppression terminal, coverage and predef. type	6 / 0 / 6	0 / 0 / 0 (SKIP)
MEP-05	Pump, manufacturer and model	0 / 0 / 0 (SKIP)	1 / 0 / 1
MEP-	Duct segment, nominal size and	837 / 0 / 837	0 / 0 / 0 (SKIP)

#	Specification	Revit MEP applicable / pass / fail	Boiler applicable / pass / fail
06	material		
MEP-07	Valve, operation and predef. type	0 / 0 / 0 (SKIP)	4 / 0 / 4
MEP-08	Cable segment, cross-sectional area	0 / 0 / 0 (SKIP)	0 / 0 / 0 (SKIP)
MEP-09	Electric appliance, nominal power	0 / 0 / 0 (SKIP)	0 / 0 / 0 (SKIP)

5.3 Timings

Stage	Revit MEP (28 MB, 302k entities)	Boiler (1.35 MB, 26k entities)
<code>ifcopenshell.open()</code>	2.26 s	0.11 s
<code>ifctester.ids.Ids.validate()</code>	0.50 s	0.01 s
Full pipeline (open + validate + emit 5 reports)	~3.5 s	~0.4 s
pytest suite (4 tests)	2.18 s	n/a

Both validation times sit an order of magnitude under the 20-minute slowdown documented in IfcOpenShell GitHub Discussion #6782. That issue is triggered when applicability uses complex restrictions across the whole model; my IDS uses entity-class-only applicability filters, which `ifctester` handles efficiently.

5.4 LLM module results

- **EIR-to-IDS generator** translated three sample clauses into three XSD-valid IDS specifications via three Anthropic API calls (Claude Sonnet 4.6), each returning HTTP 200. All three round-tripped through `ifctester.ids.open()`. Total cost: ~NZ\$0.20.
- **Remediation generator** annotated 8 of 2,679 failures from the Revit MEP report in a single batched Anthropic API call, returning HTTP 200. The output JSON carries the original report structure plus a `remediation` key on each of the 8 annotated entities. Total cost: ~NZ\$0.10.

6. Discussion and findings

Three findings matter from this run, in order of how I would brief them to a client.

Flow direction is the only specification that passes cleanly on the Revit MEP sample. All 8,515 `IfcDistributionPort` instances declare a valid `FlowDirection`. Revit's IFC exporter writes that attribute reliably. None of the 491 `IfcPipeSegment`, 837 `IfcDuctSegment` or 11 `IfcFlowTerminal` entities meet the ruleset, because the `Pset_*TypeCommon` property sets the IDS requires are not authored by Revit's exporter at all. That is precisely the authoring gap an IDS exists to surface. It is also the conversation I want to have with a modelling lead at week one of a project, not the week before handover.

The MEP-04 IFC4 schema correction is the kind of issue every legacy IDS in the industry quietly carries. The handover plan was written against an IFC2X3 mental model.

`IfcSprinkler` does not exist in IFC4. A specification that targets a retired entity matches zero instances, returns a vacuous PASS, and convinces the team that sprinkler coverage is being checked when it isn't. The validator's `SKIP` status when `applicable==0` (rather than ifcTester's default `PASS`) is the small reporting change that surfaces the problem. Any consultancy migrating a client portfolio from IFC2X3 to IFC4 should run its existing IDS library through this pipeline first as a migration audit. There is a billable engagement in that finding on its own.

The openBIM choice was vindicated, not defended. Authoring the IDS through `ifcTester.ids` constructors guarantees XSD validity in a way hand-written XML cannot. That guarantee then transfers cleanly to the LLM generator's output, because Claude's reply is wrapped in a complete IDS document and re-validated against the same XSD before persistence. The two LLM modules turn 'natural-language requirement → machine-checkable rule' and 'machine-readable failure → English remediation' into one-call operations rather than two-week workshops and Teams back-and-forth. The pyRevit path could not have produced this; it would have produced one Revit button.

What did not work as planned. The Auckland Open IFC Model Repository proved unreachable without an interactive browser login. The replacement models cover seven of the nine specifications between them. Rather than weaken the IDS to fit the available data, I kept the unmatched specifications in the file and let the validator report them as `SKIP`. A real EIR is written for the building, not the test sample.

Where this goes next. A pyRevit wrapper sitting on top of this codebase would call `validator.run()` exactly as the CLI already does, with the in-session document path passed in. The implementation choice is therefore additive rather than exclusive: openBIM is the right surface for the IDS contract; pyRevit can sit on top of it for firms that want an in-Revit button. The dissertation chapter that grows out of this assignment extends the architecture along the lines in §7: a feedback loop where commissioning evidence (BCF issues carrying measured values) amends the IDS automatically, closing the EIR → IDS → check → evidence circle.

7. Future-proofing the workflow for full MEP&F coverage

The nine specifications in `ids/mep_services_v1.ids` are roughly six per cent of a production catalogue. I chose them to exercise the breadth of IDS facet types (`property`, `attribute`, `material`, `partOf`), not to cover any single service in depth. A production-scale ruleset covering Mechanical, Electrical, Plumbing and Fire (MEP&F) across the entity classes a services consultancy actually verifies on a project is roughly 100 to 165 specifications across 40 to 60 distinct property sets.

The pipeline does not need to change to scale; only the IDS catalogue does. That separation is the entire point of the design.

7.1 Property-set taxonomy by service

The tables below name the IFC4 entity class, the canonical buildingSMART Pset, the properties I would require, and the regulatory hook I would put in the spec's `<instructions>` field for an AS/NZS-aligned ruleset. These are deliberately the Psets I would consider when authoring; not every entry becomes a spec on every project. The right answer at BEP stage is to pick the subset the client genuinely needs to verify and to trim the rest.

Mechanical, ventilation, air conditioning, heating

Entity	Pset	Required properties	Hook
IfcAirHandlingUnit	Pset_AirHandlingUnitTypeCommon	NominalAirFlowRate, NominalSensibleCapacity	AS 1668.2
IfcChiller	Pset_ChillerTypeCommon	NominalCapacity, NominalEER, NominalCOP	NZBC G4, AS/NZS 3823
IfcBoiler	Pset_BoilerTypeCommon	EnergySource, NominalEnergyConsumption	NZS 5261 (gas)
IfcCoolingTower	Pset_CoolingTowerTypeCommon	HeatTransferArea, NominalCapacity	NZBC G4
IfcFan	Pset_FanTypeCommon	NominalAirFlowRate, NominalTotalPressure, MotorDriveType	AS 1668.2
IfcDuctSegment	Pset_DuctSegmentTypeCommon	NominalLengthOrDimension, material	AS 4254
IfcDuctFitting	Pset_DuctFittingTypeCommon	NominalLength, material	AS 4254
IfcDamper	Pset_DamperTypeCommon	OperationTemperatureMax, Operation	AS 1682 (fire dampers)

Entity	Pset	Required properties	Hook
IfcAirTerminal	Pset_AirTerminalTypeCommon	Shape, FaceType, AirFlowrateRange	AS 1668.2
IfcUnitaryEquipment	Pset_UnitaryEquipmentTypeCommon	OperatingMode, NominalCoolingCapacity, NominalHeatingCapacity	NZBC H1

Electrical, distribution, lighting, devices

Entity	Pset	Required properties	Hook
IfcCableSegment	Pset_CableSegmentTypeCommon	CrossSectionalArea, MaximumOperatingTemperature, FireRating	AS/NZS 3000 §3, AS/NZS 3008
IfcCableCarrierSegment	Pset_CableCarrierSegmentTypeCommon	WidthOrDiameter, material	AS/NZS 3000
IfcElectricAppliance	Pset_ElectricalDeviceCommon	NominalPower, NominalVoltage, NominalFrequency	AS/NZS 3000 §4
IfcLightFixture	Pset_LightFixtureTypeCommon	LightFixtureMountingType, MaintenanceFactor, ArticleNumber	AS/NZS 1680
IfcElectricDistributionBoard	Pset_ElectricDistributionBoardTypeCommon	NominalCurrent, NumberOfGangs	AS/NZS 3000 §2
IfcSwitchingDevice	Pset_SwitchingDeviceTypeCommon	SwitchFunction, RatedCurrent	AS/NZS 3947
IfcProtectiveDevice	Pset_ProtectiveDeviceTypeCommon	BreakingCapacity, OperatingMode	AS/NZS 3000 §2.5
IfcTransformer	Pset_TransformerTypeCommon	PrimaryVoltage, SecondaryVoltage, PrimaryCurrent	AS 60076
IfcMotorConnection	Pset_MotorConnectionTypeCommon	MotorConnectionType	AS 60034

Plumbing / Hydraulic, water, sanitary, gas

Entity	Pset	Required properties	Hook
IfcPipeSegment	Pset_PipeSegmentTypeCommon	NominalDiameter, material, FlowDirection	AS/NZS 3500.1, AS/NZS

Entity	Pset	Required properties	Hook
			3500.2
IfcPipeFitting	Pset_PipeFittingTypeCommon	NominalDiameter, JointSize, material	AS/NZS 3500
IfcPump	Pset_PumpTypeCommon	PumpType, FlowRateRange, Pressure, Manufacturer, ModelLabel	NZBC G12, AS/NZS 3500.1
IfcValve	Pset_ValveTypeCommon	ValveOperation, ValveMechanism, Size, PredefinedType	AS 1628, AS 4794
IfcTank	Pset_TankTypeCommon	NominalCapacity, StorageType, PatternType	NZBC G12, AS/NZS 4020
IfcSanitaryTerminal	Pset_SanitaryTerminalTypeCommon	Category, material, WaterConsumptionPerFlush	NZBC G1, AS/NZS 6400 (WELS)
IfcWasteTerminal	Pset_WasteTerminalTypeCommon	WasteTerminalType, material	AS/NZS 3500.2
IfcInterceptor	Pset_InterceptorTypeCommon	InterceptorType, NominalCapacity	NZBC G13
IfcDistributionSystem	(entity-level)	PredefinedType ∈ {DOMESTICCOLDWATER, DOMESTICHOTWATER, SEWAGE, RAINWATERDRAINAGE, FUELGAS}	NZBC G12, NZS 5261

Fire, sprinkler, fire alarm, suppression

Entity	Pset	Required properties	Hook
IfcFireSuppressionTerminal (SPRINKLER)	Pset_FireSuppressionTerminalSprinkler	CoverageArea, Pattern, WaterDistributionType	NZS 4541, NZBC C/AS2
IfcFireSuppressionTerminal (BREECHINGINLET)	Pset_FireSuppressionTerminalBreechingInlet	Pattern	NZS 4510
IfcFireSuppressionTerminal (HOSEREEL)	Pset_FireSuppressionTerminalHoseReel	Pattern, HoseDiameter, HoseLength	NZS 4503

Entity	Pset	Required properties	Hook
IfcAlarm	Pset_AlarmTypeCommon	AlarmType, Application	NZS 4512, AS 1670.1
IfcSensor (smoke / heat)	Pset_SensorTypeCommon + specific	SensorType, MeasurementRange	NZS 4512, AS 1670.1
IfcDamper (FIREDAMPER)	Pset_DamperTypeCommon + Pset_FireSafetyProperties	FireRating, Operation	AS 1682, NZBC C/AS2
IfcCableSegment (fire-rated)	Pset_CableSegmentTypeCommon + Pset_FireSafetyProperties	FireRating	AS/NZS 3013

Common cross-cutting, manufacturer, classification, spatial structure

Not service-specific, but every production IDS should enforce them. Anything that fails these is impossible to hand over cleanly into FM or CAFM.

Applicability	Pset / facet	Required	Hook
Any IfcElementType	Pset_ManufacturerTypeInformation	Manufacturer, ModelLabel, ProductionYear	ISO 19650-2 §6.4
Any IfcElement instance	Pset_ManufacturerOccurrence	BarCode, SerialNumber, AssemblyPlace	COBie
Any FM asset	Pset_AssetManagement	AssetIdentifier, OriginalValue, Owner	ISO 55000
Any element	classification facet	system=Uniclass 2015 or NRM2 or Omniclass, value present	ISO 12006-2
All elements	spatial-structure	contained in IfcSpatialStructureElement via IfcRelContainedInSpatialStructure	IFC4 spatial rules
IfcProject root	attribute facet	references IfcProjectedCRS (georeferenced)	ISO 19111

Counts to plan for

Service area	Distinct Psets	Realistic spec count
Mechanical (HVAC + heating)	10	25–40

Service area	Distinct Psets	Realistic spec count
Electrical (distribution, lighting, devices)	9	20–35
Plumbing / Hydraulic (water, sanitary, gas)	10	25–40
Fire (sprinkler, alarm, suppression, fire-rated)	7	15–25
Common cross-cutting	5	15–25
Total	**41 Psets**	**100–165 specs**

The handover plan's nine specs is roughly six per cent of a production catalogue. That is consistent with the assignment brief (demonstrate the pipeline). It is not consistent with shipping to a client (don't).

7.2 Multi-IDS authoring

The CLI currently accepts one `--ids` flag. For production I would extend it to accept either a single file or a directory of files, validate the IFC against each, and merge the per-IDS reports into a single output. Each IDS file would represent one service area or one cross-cutting concern, organised as:

```
ids/
├─ mechanical_v1.ids
├─ electrical_v1.ids
├─ plumbing_hydraulic_v1.ids
├─ fire_v1.ids
├─ common_cross_cutting_v1.ids
└─ client_overlays/
   └─ <client_name>_overrides.ids
```

The `client_overlays/` pattern lets a client-specific EIR add or tighten rules on top of the base catalogue without forking the whole library. It is the same pattern Solibri rulesets already use, and it is what makes the catalogue maintainable across many concurrent projects.

7.3 IFC4.3 schema scope for infrastructure

The civil and rail entities (`IfcAlignment`, `IfcRoad`, `IfcRailway`, `IfcBridge`, `IfcEarthworksCut`, drainage networks) live in IFC4.3 (IFC4X3_ADD2), not IFC4. `ifctester` already supports IFC4X3_ADD2 as an `ifcVersion` value; my current IDS file declares IFC4 only. The change is one line per spec, plus a column on the catalogue noting which schema version applies. Hospitals, schools and commercial buildings stay on IFC4. Infrastructure work moves to IFC4.3 once authoring tools catch up (Civil 3D 2025 onward).

7.4 bSDD integration for the LLM generator

The biggest single source of LLM error in EIR-to-IDS translation is Claude inventing a Pset name that does not exist. The fix is to give the LLM a tool-call that hits the buildingSMART Data Dictionary (bsdd.buildingsmart.org) for any Pset it wants to reference. If the Pset is not in bSDD, the LLM is told to either re-pick or flag the spec for human review. I would build this as a thin MCP server so the generator becomes an agentic loop rather than a single-shot translation. Estimated effort: two days plus regression testing.

7.5 BCF feedback loop, closing the circle

Today the BCF report is one-way: the validator emits a BCF, the modeller resolves the issues. Closing the loop means the commissioning team pushes measured values (actual cable cross-sectional areas, actual sprinkler coverage tests, actual pump heads) back as BCF topics with structured payloads. A new module would compare measured values to the required values in the IDS, surface discrepancies, and propose draft amendments to the IDS for the next project. That is what turns a one-shot check into an organisation's learning loop, and it is the dissertation chapter direction I will pursue.

7.6 CI integration for weekly client model checks

For every active client project I would set up a scheduled job (GitHub Actions on a private repo, or a Windows Task on the firm's coordination server) that:

1. Pulls the latest IFC from the client's CDE (Trimble Connect, Autodesk Construction Cloud, Asite).
2. Runs the validator against the client-specific IDS suite.
3. Pushes the BCF report back to the CDE as an updated issue set.
4. Pushes the remediation-annotated JSON to a shared drive for the modelling lead to triage on Monday morning.

Estimated effort: a day per client to wire up CDE credentials and tune the scheduler.

7.7 The Pset-aware authoring tool gap

An IDS author has to look up Pset names manually in the bSDD or the IFC4 documentation today. A Pset-aware IDS authoring tool with autocomplete on Pset name and property name, type-checked dataType, and restriction-aware enum suggestions for `PredefinedType` would multiply authoring productivity tenfold. None exists publicly that I am aware of. Building one as a VS Code extension on top of the bSDD API is a small product in its own right, and would be the most useful single addition to the workflow.

8. Repository layout

m7u5-ids-mep-validator/	
├─ README.md	← this submission's entry point
├─ LICENSE	← MIT
├─ .env.template	← template (real .env is gitignored)
├─ requirements.txt	← Python 3.11 pip freeze
├─ ids/	
│ └─ mep_services_v1.ids	← hand-authored 9-spec ruleset
├─ ifc/	
│ └─ Ifc4_Revit_MEP.ifc	← primary test model (gitignored, 27.8 MB)
└─ BoilerGasRadiatorDomesticHotWater.ifc	← secondary test model (gitignored, 1.35 MB)
src/	
├─ __init__.py	
└─ validator.py	← ifctester wrapper + ValidationRun
dataclass	
├─ reporter.py	← JSON/HTML/BCF/CSV multi-format export
└─ cli.py	← python -m src.cli --ifc ... --ids ...
--out ...	
├─ llm_eir_to_ids.py	← EIR clause → IDS spec via Claude + XSD
gate	
└─ llm_remediation.py	← failure JSON → English remediation via Claude
scripts/	
└─ build_mep_ids.py	← rebuilds mep_services_v1.ids via ifctester API
└─ build_report_pdf.py	← this report .md → .pdf via Edge
headless	
├─ notebooks/	
│ └─ 00_ifc_inventory.ipynb	← schema + entity-count sanity check
│ └─ 01_demo_validation.ipynb	← end-to-end demo with Claude output
embedded	
├─ queries/	
│ └─ sample_eir_clauses.txt	← three sample EIR clauses for the LLM
generator	
├─ tests/	
│ └─ test_validator.py	← 4 pytest tests, all passing in 2.18 s
├─ docs/	
│ └─ architecture.svg	← system diagram (Figure 1)
│ └─ pipeline.svg	← 4-stage validation pipeline (Figure 2)
│ └─ technical_report.md	← this report's source
│ └─ technical_report.html	← rendered HTML intermediate
│ └─ technical_report.pdf	← rendered PDF submission
└─ results/	
└─ eir_translation_three_clauses.ids	← live Claude output (3 IDS specs)

```
|— generated_demo.ids          ← live Claude output (1 IDS spec from
notebook)
  |— Ifc4_Revit_MEP_remediated.json ← live Claude output (8 remediation
paragraphs)
```

The five regenerable validator reports per IFC (JSON, HTML, BCF, summary CSV, failures CSV) are produced into [results/](#) at runtime and are gitignored by size policy. The three LLM evidence files in [results/](#) are exempted from the gitignore and committed.

9. How to reproduce

```
git clone https://github.com/markshanehaines-ZIG/m7u5-ids-mep-validator.git
cd m7u5-ids-mep-validator
python -m venv venv
source venv/Scripts/activate          # Windows Git Bash; venv/bin/activate on
macOS/Linux
pip install -r requirements.txt
cp .env.template .env                # then paste your ANTHROPIC_API_KEY into .env
in your editor

# Download the two test models (about 30 seconds on a normal connection)
curl -sL -o ifc/Ifc4_Revit_MEP.ifc \
  https://raw.githubusercontent.com/youshengCode/IfcSampleFiles/main/
Ifc4_Revit_MEP.ifc
curl -sL -o ifc/BoilerGasRadiatorDomesticHotWater.ifc \
  "https://raw.githubusercontent.com/EnEff-BIM/EnEffBIM_UseCases/master/BIM/
1.2%20BoilerGasRadiatorDomesticHotWater_VDI%206020/IFC/
1.2%20BoilerGasRadiatorDomesticHotWater.ifc"

# Run the validator against the primary IFC
python -m src.cli --ifc ifc/Ifc4_Revit_MEP.ifc --ids ids/mep_services_v1.ids --out
results/

# Run the test suite (~2 seconds)
python -m pytest tests/ -v

# Run the LLM modules (requires ANTHROPIC_API_KEY in .env)
python -m src.llm_eir_to_ids --input queries/sample_eir_clauses.txt --out
results/generated.ids
python -m src.llm_remediation --report results/Ifc4_Revit_MEP_report.json \
  --out results/Ifc4_Revit_MEP_remediated.json --limit 20

# Open the demo notebook
jupyter notebook notebooks/01_demo_validation.ipynb
```

```
# Rebuild the IDS file (regenerates ids/mep_services_v1.ids from the Python builder)
python scripts/build_mep_ids.py
```

```
# Rebuild this PDF (uses Microsoft Edge headless on Windows)
python scripts/build_report_pdf.py
```

The validator's CLI exits 0 on PASS and 1 on FAIL, so a CI job can gate on the exit code directly.

10. Standards referenced

buildingSMART / openBIM

- ISO 16739-1:2024, Industry Foundation Classes (IFC4)
- buildingSMART IDS 1.0, Information Delivery Specification (XSD bundled in `ifctester`)
- buildingSMART bSDD, Data Dictionary, at <https://search.bsdd.buildingsmart.org>
- buildingSMART Sample Test Files (CC-BY-4.0)
- BCF 2.1, BIM Collaboration Format

Information management

- ISO 19650-1 / 19650-2, Information management using BIM
- ISO 12006-2, Classification framework
- ISO 55000, Asset management

MEP services standards cited in the IDS (UK + AS/NZS blend)

- BS EN 12845 §10, Sprinkler hydraulic calculation (cited in MEP-04 for the assignment; will normalise to NZS 4541 in production)
- BS 7671 §433, Cable current-carrying capacity (cited in MEP-08 for the assignment; will normalise to AS/NZS 3000 §433)
- AS/NZS 3000, Wiring rules
- AS/NZS 3500, Plumbing and drainage
- AS 1668.2, Mechanical ventilation
- AS 4254, Ductwork
- NZS 4541, Automatic fire sprinkler systems
- NZS 4512, Fire detection and alarm systems
- NZBC C/AS2, Acceptable solutions for fire safety

- NZBC G4 / G12 / G13 / H1, Building Code services clauses

Lecture material

- M7U5 Sessions 1 to 4, Elias Magalhães, Zigurat
- Particular reference to slides 18 to 24 on IDS as the bridge between EIR intent and machine logic

Source IFC datasets

- [Ifc4_Revit_MEP.ifc](#), Autodesk Revit MEP Advanced Sample Project ([rme_advanced_sample_project](#)), © Autodesk Inc., used here for non-commercial academic evaluation under Autodesk's sample-content terms; IFC4 export republished at <https://github.com/youshengCode/IfcSampleFiles>.
- [BoilerGasRadiatorDomesticHotWater.ifc](#), EnEff:BIM project (German Federal Ministry for Economic Affairs and Climate Action research programme), VDI 6020 reference, MIT-licensed at https://github.com/EnEff-BIM/EnEffBIM_UseCases.

End of submission.