Physics-informed digital twin for wind turbine main bearing fatigue

Alexis GONIN   Tanguy PIERRE

UFR Maths, Master CSMI

May 28, 2025

Université
de Strasbourg

Table of Contents

Problem and context

- Bearing fatigue is a major cause of wind turbine failures, leading to significant downtime and repair costs.
- As wind turbines are often located in remote or offshore areas, accessing them for maintenance can be challenging and expensive.

Objectives of the digital twin

- Predict potential failures in wind turbine main bearings.
- Optimize maintenance schedules based on real-time data.
- Reduce operational costs through improved efficiency.

Pipeline

```
┌────────────────────────────────────────┐
│  1. Sensors and human observations     │
└────────────────────────────────────────┘
                    │
                    ▼
┌────────────────────────────────────────┐
│  2. Preprocessing/Bootstrapping        │
└────────────────────────────────────────┘
                    │
                    ▼
┌────────────────────────────────────────┐
│  3. Training                           │
└────────────────────────────────────────┘
                    │
                    ▼
┌────────────────────────────────────────┐
│  4. Models and Neural Networks evaluations │
└────────────────────────────────────────┘
                    │
                    ▼
┌────────────────────────────────────────┐
│  5. Predictions                        │
└────────────────────────────────────────┘
```

Figure: Hybrid physics-informed neural network modeling using recurrent neural networks. Blue boxes represent reduced-order physics-informed kernels and green boxes are data-driven kernels. [?]

Reduced-order physics-informed kernels for bearing fatigue

$$\Delta a_{\mathrm{BRG}}(t) = \frac{1}{c_1 \, c_2(t)} \, P(t)^{C_1^{10^3}}, \tag{1}$$

$$P(t) = f_1(V_W(t)), \tag{2}$$

$$c_2(t) = f_2(P(t), \eta_c(t), \nu(t)), \tag{3}$$

$$\eta_c(t) = f_3(\nu(t), a_{GRS}(t)), \tag{4}$$

$$\nu(t) = f_4(T_{\mathrm{BRG}}(t), a_{GRS}(t)). \tag{5}$$

with a_{BRG} the bearing degradation; a_{GRS} the grease degradation; c_1 a factor based on reliability level; c_2 an adjustment factor based on lubricant condition (see Fig. 3b); P the dynamic bearing load (see Fig. 3a); C the design load rating; η_c the grease contamination factor; ν the grease viscosity; V_W the wind speed; T_{BRG} the bearing temperature; $f_1 \ldots f_4(\cdot)$ functions defining the models for different components of the bearing damage.

Physics-informed Neural Network Design for grease Fatigue Estimation

Grease degradation is evaluated using a neural network.

$$\Delta a_{\mathrm{GRS}}(t) = \mathrm{MLP}(V_W(t), T_{\mathrm{BRG}}(t), a_{\mathrm{GRS}}(t-1); \mathbf{w}, \mathbf{b}) \tag{6}$$

Datas

- SCADA (supervisory control and data acquisition); available on board; wind speed and bearing temperature; measured every 10 minutes but no history available. $\rightarrow$ Can be used for online evaluations.
- NREL database: wind speed and ambient temperature every hour for 7 years $\rightarrow$ Can be used for offline Training.
- NREL database is used to artificially create SCADA data for 30 simulated years via bootstrapping strategies.
- History of grease quality inspection done by humans are available to train the neural network.

Data budget table

Hypothetical example for one wind turbine with 4 thermometers and 1 anemometer. Note that 1 anemometer can be used for several wind turbines in a wind farm.

Sensor	#	Freq. (m/hour)	Size (B/sample)	bitrate (B/hour)	Volume/day (kB)
thermometer	4	6	8	192	4,608
anemometer	1	6	8	48	1,152

Verification and validation

Transferability and deployment

Perspectives and limitations

References

[**?**]