



CLASSIFICATION REPORT

of reaction to fire for electric cables

1 Introduction

This classification report defines the classification assigned to the cable types *DW-6A-UF-LSOH-B2ca* in accordance with the procedures given in EN 13501-6.

CLASSIFICATION OF REACTION TO FIRE FOR ELECTRIC CABLES IN ACCORDANCE WITH EN 13501-6

Sponsor:	TES-SLOVAKIA s.r.o Kragujevska 3754/4 01001 ŽILINA Slovakia
Prepared by:	VDE Prüf- und Zertifizierungsinstitut GmbH* Merianstraße 28, 63069 Offenbach, Deutschland
Notified Body No:	0366*
Product name:	DW-6A-UF-LSOH-B2ca
Classification report No:	5033464/1-1(B) ¹
Issue number:	1
Date of issue:	2025-12-10

This classification report consists of 6 pages and may only be used or reproduced in its entirety.

** To be used for CE marking only*

¹ B-typ report to classification report 5026024/1-1



CLASSIFICATION REPORT

of reaction to fire for electric cables

2 Details of classified product

2.1 General

The product DW-6A-UF-LSOH-B2ca is defined as a *communication cable*^{*2}.

* To be used for CE marking

2.2 Product description

The product DW-6A-UF-LSOH-B2ca is described below or is described in the reports provided in support of classification listed in 3.1.

Product description:

Underlying standard / specification:

Product data sheet. PDT No. DD325
Rev. Nr: 4.2; issued 25.12.2017;
From Zhejiang Ship Electronics
& Technology Co., Ltd.

Rated voltage:

N/A

Relevant constructional information

Conductor (acc. to AWG):	Design:	Solid bare copper, 1/23AWG
	Class:	1

Used materials:	Insulation:	HDPE (SH001)
	Sheath:	LSOH (SDHF09)
	Cross-Filler:	N/A

Screen over pairs:	AL/PET (AF1)
--------------------	--------------

Overall screen:	N/A
-----------------	-----

Number of cores:	8 (4 pairs)
------------------	-------------

Outer sheath thickness (nom.):	0.70 mm
--------------------------------	---------

Concentric shield:	☐ Includes	☒ Does not include
--------------------	-----------------------------------	--

Armouring:	☐ Includes	☒ Does not include
------------	-----------------------------------	--

Constructional elements relevant for defining the cable family: (e.g. metallic tapes, non-combustible tapes...)

N/A

² Definition according to EN 50575.



CLASSIFICATION REPORT

of reaction to fire for electric cables

3 Reports and results in support of this classification

3.1 Reports

Name of Laboratory	Name of sponsor	Report ref. no.	Test method and date
VDE Institute	Zhejiang Ship Electronics & Technology Co., Ltd.	264749-TL6-1	2020-04-21 ☒ EN 60332-1-2 ☒ EN 50399 ☒ EN 61034-2 ☐ EN 60754-2
VDE Institute	Zhejiang Ship Electronics & Technology Co., Ltd.	264749-TL6-9	2020-04-24 ☐ EN 60332-1-2 ☐ EN 50399 ☐ EN 61034-2 ☒ EN 60754-2



CLASSIFICATION REPORT

of reaction to fire for electric cables

3.2 Results

Test method and test number	Parameter	No. tests ³	Results ⁴	
			Continuous parameter – mean m	Compliance with parameters
Test for vertical flame propagation for a single insulated wire or cable (EN 60332-1-2)	H	1	N/A	Compliant
Heat release and smoke production measurement on cables during flame spread test (EN 50399)	Flame spread	1	0.3 m	N/A
	THR ₁₂₀₀		2 MJ	N/A
	HRR _{av}		13 kW	N/A
	FIGRA		126 W/s	N/A
	TSP ₁₂₀₀		14 m ²	N/A
	SPR _{av}		0.07 m ² /s	N/A
	Flaming drop-lets / particles		N/A	Compliant d0
Measurement of smoke density of cables burning under defined conditions (EN 61034-2)	Minimum value of transmission	1	88 %	N/A
Determination of acidity (by pH measurement) and conductivity (EN 60754-2)	Conductivity	1	0.8 µS/mm	N/A
	pH		5.5	N/A

³ According to EN 13501-6: Number of individual measurements necessary to obtain a result value; does not refer to the number of tests through the application of EXAP rules according to EN 50576.

⁴ When applying EXAP rules according to TS 50576, only the results that contribute to the classification are listed.



CLASSIFICATION REPORT

of reaction to fire for electric cables

4 Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with EN 13501-6.

4.2 Classification

The product *DW-6A-UF-LSOH-B2ca* in relation to its reaction to fire behaviour is classified:

B2_{ca}

The additional classification in relation to smoke production is:

s1a

The additional classification in relation to flaming droplets / particles is:

d0

The additional classification in relation to acidity is:

a1

The format of the reaction to fire classification for electric cables is:

Fire behaviour	Smoke production	Flaming droplets	Acidity
B2_{ca}	- s 1a	, d 0	, a 1

i.e.: **B2_{ca}-s1a,d0,a1**



CLASSIFICATION REPORT

of reaction to fire for electric cables

4.3 Field of application

This classification is valid for the following product parameters as determined in the expanded application process according to EN 50576:

No application of EN 50576, the report is only valid for the cable type described in section 2.2.

The classification is valid for all end use applications.

5 Limitations

This classification document does not represent type approval or certification of the product.

SIGNED

A. Idrissi

Creator of the classification report

APPROVED

A. Herzog

Head of the Notified Body
Construction Products Regulation

