

Power decrease

Final presentation SH2705

Quentin Louis Poirier, Jakub Mátl, Atilla Cakir



KTH
Royal Institute of Technology, Stockholm

29. 5. 2023





Event description

- Start of the transient:
- Setpoint value to 0.9 - input for power control
- Rotation speed of recirculation pumps lowered (automation)
- Pressure drop, gets back
- Water level - new asymptotic value



How the power is decreased?





Oscillations



Interesting graphs



Steam generation



- Lower power \rightarrow lower steam flow \rightarrow Steam more dryer

What is (not) activated

- AOO
- Standart procedure
- Adjusted power via recirculation flow
- Adjusted feed water flow
 - Lower heat needed for removal
 - Reactivity coefficients - Cannot go up, but also cannot go down
 - Feed water flow modulated using control logic
- HPI (Auxilliary system) - Not activated
- Relief system - Not activated
- Core spray system (LPI) - Not activated

Thanks for attention!
