Himmel's Architectural Door & Hardware, LLC - PR
16491 Airline Hwy., Prairieville, LA 70769
Tel: (225) 673-8777 Fax: (225) 673-2444

RPL10 - NW - Data Center - Rayville, LA - IFC SET 304688

SCHEDULE OF FINISHED HARDWARE

DATE	November 11, 2025
ARCHITECT	
CONTRACTOR	DPR Construction PA
DETAILED BY	Scott Gee
Note	To keep the project moving in a timely manner, we ask that submittals be returned approved within three (3) weeks from submitted date. Delays in receiving approvals may impact lead times, pricing and material need by dates.

Opening List

DCB-EXTERIOR

Opening	Hdw Set	Hdw Heading	Opening Label	Door Type	Frame Type
10.E1.03	SSE1XL1	SSE1XL1		A	A3
10.E1.04	SSE1XL1	SSE1XL1		A	A3
10.E1.06	SSE1XL1	SSE1XL1.1		A	A3
10.E1.08	SSE1XL1	SSE1XL1.1		A	A3
10.E2.03	SSE1XL1	SSE1XL1.1		A	A3
10.E2.06A	SSE1XL1	SSE1XL1		A	A3
10.E2.06B	SSE1XL1	SSE1XL1		A	A3
10.E2.07	SSE1XL1	SSE1XL1.1		A	A3
10.N1.02	E1XO1	E1XO1		A	A3
10.N1.12	E1XO1	E1XO1.1		A	A3
10.N2.12	SSE1XL1	SSE1XL1.1		A	A3
10.N2.13	E1XO1	E1XO1		A	A3
10.N3.06	E1XO1	E1XO1		A	A3
10.N3.11	SSE1XL1	SSE1XL1.1		A	A3
10.N4.02	E1XO1	E1XO1		A	A3
10.N4.15A	SSE1XL1	SSE1XL1		A	A3
10.N4.15C	SSE1XL1	SSE1XL1.2		A	A3

DCB-INTERIOR

Opening	Hdw Set	Hdw Heading	Opening Label	Door Type	Frame Type
10.E1.01A	SSI2GOXL	SSI2GOXL		H	A1
10.E1.01B	SSI2GOXL	SSI2GOXL		H	A1
10.E1.01C	SSI2GOXM	SSI2GOXM		D	A1
10.E1.01D	SSI2GOXM	SSI2GOXM		D	A1
10.E1.05	SSI2GE1	SSI2GE1		D	A1
10.E2.01A	SSI2GOXM	SSI2GOXM		D	A1
10.E2.01B	SSI2GOXM	SSI2GOXM		D	A1
10.E2.01C	SSI2GOXL	SSI2GOXL		H	A1
10.E2.01D	SSI2GOXL	SSI2GOXL		H	A1
10.E2.05	SI1E2	SI1E2		A	A1
10.E2.08	SSI1FGXL1	SSI1FGXL1	90 MIN	A	A1
10.E2.09	SSI1FGXL1	SSI1FGXL1A	45 MIN	A	A1
10.E2.10	SSI1FGXL1	SSI1FGXL1	90 MIN	A	A1
10.E2.11	SSI1FGXL1	SSI1FGXL1A	45 MIN	A	A1
10.E2.13	SSI1FGXL1	SSI1FGXL1	90 MIN	A	A1
10.E2.14	SSI1FGXL1	SSI1FGXL1	90 MIN	A	A1
10.E2.15	I1B3	I1B3		A	A1
10.E2.16	SI1E3	SI1E3.1		A	A1
10.N1.01A	SSI2FGOXL	SSI2FGOXL1	45 MIN	H	A1
10.N1.01B	SSI2FGOXL	SSI2FGOXL	90 MIN	H	A1
10.N1.01C	SSI2FGOXM	SSI2FGOXM1	90 MIN	D	A1
10.N1.01D	SSI2FGOXM	SSI2FGOXM	45 MIN	D	A1
10.N1.03	SSI1GWE2	SSI1GWE2		C1	A1

Opening	Hdw Set	Hdw Heading	Opening Label	Door Type	Frame Type
10.N1.06	SSI2FGE1	SSI2FGE1.1	90 MIN	B	A1
10.N1.07	SI1E2	SI1E2		A	A1
10.N1.08	SSI1FGXL1	SSI1FGXL1A	45 MIN	A	A1
10.N1.09	SSI1GE3	SSI1GE3.1		A	A1
10.N1.10	SSI1GE3	SSI1GE3.1		A	A1
10.N1.16	SSI2FGE1	SSI2FGE1	45 MIN	B	A1
10.N2.01A	SSI2FGOXM	SSI2FGOXM	45 MIN	D	A1
10.N2.01B	SSI2FGOXM	SSI2FGOXM1	90 MIN	D	A1
10.N2.01C	SSI2FGOXL	SSI2FGOXL	90 MIN	H	A1
10.N2.01D	SSI2FGOXL	SSI2FGOXL1	45 MIN	H	A1
10.N2.06	SSI1GWE2	SSI1GWE2		C1	A1
10.N2.08	SSI1GE3	SSI1GE3.1		A	A1
10.N2.09	SSI1GE3	SSI1GE3.1		A	A1
10.N2.10	SSI1FGXL1	SSI1FGXL1A	45 MIN	A	A1
10.N2.11	SI1GE2	SI1GE2		A	A1
10.N3.01A	SSI2FGOXM	SSI2FGOXM	45 MIN	D	A1
10.N3.01B	SSI2FGOXM	SSI2FGOXM	45 MIN	D	A1
10.N3.01C	SSI2FGOXL	SSI2FGOXL1	45 MIN	H	A1
10.N3.01D	SSI2FGOXL	SSI2FGOXL1	45 MIN	H	A1
10.N3.07	SI1GE2	SI1GE2		A	A1
10.N3.08	SI1GE3	SI1GE3		A	A1
10.N4.01A	SSI2FGOXL	SSI2FGOXL1	45 MIN	H	A1
10.N4.01B	SSI2FGOXL	SSI2FGOXL1	45 MIN	H	A1
10.N4.01C	SSI2FGOXM	SSI2FGOXM	45 MIN	D	A1
10.N4.01D	SSI2FGOXM	SSI2FGOXM	45 MIN	D	A1
10.N4.05	SSI2FGE1	SSI2FGE1	45 MIN	B	A1
10.N4.09	SSI2FGE1	SSI2FGE1	45 MIN	B	A1
10.N4.12	SI1GE3	SI1GE3		A	A1
10.N4.13	I1B3	I1B3		A	A1
10.N4.14	SI1GE2	SI1GE2		A	A1
10.N4.15B				X-OHD	--STL

SSB-EXTERIOR

Opening	Hdw Set	Hdw Heading	Opening Label	Door Type	Frame Type
10.S1.01	SE1SFXL1	SE1SFXL1		AL-GL	ALSF
10.S1.15A	SSE1XL1	SSE1XL1		A	A3
10.S2.01B	SSE2XL1	SSE2XL1		B	A3
10.S2.08	SSE1XL1	SSE1XL1		A	A3
10.S2.09B	SSE1XL1	SSE1XL1		A	A3

SSB-INTERIOR

Opening	Hdw Set	Hdw Heading	Opening Label	Door Type	Frame Type
10.S1.02A	SSI1GXL1	SSI1GXL1.1		AL-GL	ALSF
10.S1.02B	I1SFXL2	I1SFXL2		AL-GL	ALSF
10.S1.03	I1B3	I1B3.1		A	A1-ALF
10.S1.04	SSI1GXL1	SSI1GXL1		E	A1-ALF
10.S1.05A	I2FWSM2	I2FWSM2	90 MIN	D-ICC	A2

Opening	Hdw Set	Hdw Heading	Opening Label	Door Type	Frame Type
10.S1.05B	I1FWSM1	I1FWSM1	90 MIN	A-ICC	A2
10.S1.06	SI1GE3	SI1GE3.2		A	A1
10.S1.07	SI1E3	SI1E3		E	A1-ALF
10.S1.08	SI1GE3	SI1GE3.1		A	A1-ALF
10.S1.09	I1T3	I1T3		A	A1-ALF
10.S1.10	I1T3	I1T3		A	A1-ALF
10.S1.11	I1P4	I1P4		E	A1-ALF
10.S1.12	I1P4	I1P4		E	A1-ALF
10.S1.13	SI1GE3	SI1GE3.1		E	A1-ALF
10.S1.14	SSI1GE3	SSI1GE3		A	A1
10.S1.15B	I2XL1	I2XL1		D	A1
10.S1.16	SI1E3	SI1E3.1		A	A1
10.S1.17	SI1E3	SI1E3.1		A	A1
10.S1.18	SSI2GE2	SSI2GE2.1		D	A1
10.S1.19	SSI2GE2	SSI2GE2.1		D	A1
10.S1.20	SI2GE2	SI2GE2		D	A1
10.S1.21	I1P4	I1P4		E	A1-ALF
10.S1.22	I1P4	I1P4		E	A1-ALF
10.S1.26	I1P2	I1P2		A	A1
10.S2.01A	SSI2GE1	SSI2GE1.1		D	A1
10.S2.01C				Y-OHD	Y-OHD
10.S2.01D				Y-OHD	Y-OHD
10.S2.01E				Y-OHD	Y-OHD
10.S2.01F	SSI2GE1	SSI2GE1		D	A1
10.S2.01G	SSI2GOXM	SSI2GOXM		D	A1
10.S2.01H	SSI2GOXM	SSI2GOXM		D	A1
10.S2.02	SI1GE3	SI1GE3		C	A1
10.S2.03	SSI2GE2	SSI2GE2.1		D	A1
10.S2.05A	SSI2GE2	SSI2GE2		D	A1
10.S2.05B	SSI1GE2	SSI1GE2		C	A1
10.S2.06A	SSI2GE2	SSI2GE2		D	A1
10.S2.06B	SSI1GE2	SSI1GE2		C	A1
10.S2.07A	SSI2GE1	SSI2GE1.1		D	A1
10.S2.07B	SSI2GE1	SSI2GE1		D	A1
10.S2.07C	SSI2GE1	SSI2GE1		D	A1
10.S2.09A	SSI2GXM	SSI2GXM		B	A1
10.S2.10	SSI1FGXL1	SSI1FGXL1	90 MIN	A	A1
10.S2.11	SI1GE3	SI1GE3		A	A1
10.S2.04A				Y-OHD	Y-OHD
10.S2.04B				Y-OHD	Y-OHD
10.S2.04C	SSI1GE1	SSI1GE1		A	A1
10.S2.04D	SSI1GE1	SSI1GE1		A	A1

Manufacturer List

Code	Name
AB	ABH Manufacturing Inc.
GL	Glynn Johnson
IV	Ives
LC	LCN Closers
LO	Schlage Electronics
ME	Medeco
MISC	Miscellaneous Items
SC	Schlage
VO	Von Duprin
ZE	Zero

Finish List

Code	Description
26	Satin Chrome
626	Satin Chromium Plated
628	Satin Aluminum, Clear Anodized
630	Satin Stainless Steel
652	Satin Chromium Plated
689	Aluminum Painted
AL	Aluminum (BHMA 689)
SP28	Lacquer Sprayed Aluminum
US26D	Chromium Plated, Dull
US28	Aluminum - Clear Anodized
US2C	Cadmium Plated
US32D	Stainless Steel, Dull

Option List

Code	Description
03	03 LEVER DESIGN
03SS	03 STAINLESS LEVER DESIGN
223-MSLA-10	10-24 MS/Lead Anchor - Qty 4 (to 36")
223-MSLA-10	10-24 MS/Lead Anchor - Qty 7 (to 72")
24"	24" ROD LENGTH (FB31/FB51)
24VDC	24VDC (for "E" trms)
304L	STANDARD BOTTOM STRIKE - 304L NON-FINISH
36"	36" ROD LENGTH (FB31/FB51)
48"	4 FOOT CROSSBAR
48"	4'0" BAR
50-231	CORE HANDLING CHARGE (Full Size)-SGL
8402 (UL)	UL Approved Kickplate
900-4RL FA	4 Relay Boards with Time Delays w/FA

Code	Description
99GBK-M	1/4" GLASS BEAD KIT-SPRAYED FINISH
B-CS	4 BEVELED EDGES -COUNTERSUNK HOLES (STD)
CON	Molex Connector
CON	Molex Connectors
CON	Molex Electrical Connector
CON	Molex Electrical Connector (EPT 10)
Custom Cut	Custom Cut to Length Charge (HD)
CUSTOM CUT	Custom Cut to Length Charge (XY)
EPT	Electric Power Transfer Prep
ER-ADJ9.8-94	ADJ. EXT. ROD 8'0" to 9'8" DOOR
FSE	FAIL SECURE
FSE	FAIL SECURE-ELECT. UNLOCKING ("E" TRIMS)
ICX	ICX FSIC CONST. CORE (NEW JOBS) 5 Pin
IS-LOC	Locked/Unlocked Indicator (Inside of Dr)
L583-363	DISABILITY T/TURN (Replaces XL11-800)
LBR	LESS BOTTOM ROD
LBR	Less Bottom Rod for 3/35/98/9947/7547
LBRAFL	Less Bottom Rod with Fire Latch Kit
LD	LESS DOGGING
NRP	NRP (Steel&SS HNG - 4-1/2 x 4-1/2 only)
NRP	NRP - All Other Sizes
OS-OCC	Vacant/Occupied Indicator(Outside of Dr)
QEL	Quiet Electric Latch Retraction (94/95)
RX	REQUEST TO EXIT
RX	REQUEST TO EXIT (RX)
ST-	SPECIAL TEMPLATE (Call for Pricing)
TK-TX	Tex & Torx Screws for Kickplates
TW8	Elec.Thru-Wire,(Steel) 8 Wire

Hardware Schedule

Heading #E1XO1 (Set #E1XO1)

1	Single Door #**10.N1.02**	N1	EXTERIOR from NS ELECTRICAL GALLERY 10.N1.02	RHR
1	Single Door #**10.N2.13**	N2	EXTERIOR from NS ELECTRICAL GALLERY 10.N2.13	LHR
1	Single Door #**10.N3.06**	N3	EXTERIOR from NS ELECTRICAL GALLERY 10.N3.06	RHR
1	Single Door #**10.N4.02**	N4	EXTERIOR from NS ELECTRICAL GALLERY 10.N4.02	LHR

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type A x HMF Type A3

12	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP	630	IV
4	Exit Device	LD 9875EO	US32D	VO
4	Closer Note: PUSH SIDE MOUNTED	4040XP SCUSH	AL	LC
4	Lock Guard	LG10	US32D	IV
4	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS		MISC
4	Length of Rain Drip	142AA 40"		ZE
4	Door Sweep	8197AA 36"		ZE
8	Weatherstrip Note: @ HINGE & LOCK JAMB	328AA 84"		ZE
4	Door Seal Note: @ FRAME HEAD (SHORTEST LENGTH AVAILABLE IS 8')	488S-BK 8'		ZE
4	Threshold	625A 36" 223-MSLA-10		ZE

Note: OPERATION:

DOOR POSITION SWITCH MONITORS DOOR STATUS. ALARM WILL SOUND IF OPENING IS USED.

Heading #E1XO1.1 (Set #E1XO1)

1	Single Door #**10.N1.12**	N1	EXTERIOR from CORR. 10.N1.12		LHR
	Opening Description:	4' 0" x 9' 0" x 1 3/4" x HMD Type A x HMF Type A3			
4	Hinges	5BB1 HW 5 x 4 1/2 NRP		630	IV
1	Exit Device	LD 9875EO 48"		US32D	VO
1	Closer	4040XP SCUSH		AL	LC
	Note: PUSH SIDE MOUNTED				
1	Lock Guard	LG10		US32D	IV
1	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
1	Length of Rain Drip	142AA 52"			ZE
2	Weatherstrip	328AA 108"			ZE
	Note: @ FRAME HINGE & LOCK JAMBS				
1	Door Seal	488S-BK 8'			ZE
	Note: @ FRAME HEAD (SHORTEST LENGTH AVAILABLE IS 8')				
1	Door Sweep	8197AA 48"			ZE
1	Threshold	625A 48" 223-MSLA-10			ZE

Note: OPERATION:

DOOR POSITION SWITCH MONITORS DOOR STATUS. ALARM WILL SOUND IF OPENING IS USED.

Heading #I1B3 (Set #I1B3)

1	Single Door #**10.E2.15**	E2	CORR. 10.E2.03 to ALL GENDER RESTROOM 10.E2.15			RH
1	Single Door #**10.N4.13**	N4	CORR. 10.N4.15 to ALL GENDER RESTROOM 10.N4.13			RH
	Opening Description:	3' 0" x 7' 0" x 1 3/4" x HMD Type A x HMF Type A1				
6	Hinges	5BB1 HW 4 1/2 x 4 1/2			652	IV
2	Mortise Privacy Set	L9040 03N L583-363 OS-OCC		RH	630	SC
2	Closer	4040XP RWPA			AL	LC
	Note: PULL SIDE MOUNTED					
2	Protection Plate	8400 24" x 34" B-CS TK-TX			US32D	IV
2	Wall Stop	WS406/407CCV			US32D	IV
2	Door Seal	488S-BK 17'				ZE

Heading #I1B3.1 (Set #I1B3)

1	Single Door #**10.S1.03**	S1	ENTRY LOBBY 10.S1.01 to ALL GENDER RESTROOM 10.S1.03			RH
	Opening Description:	3' 0" x 7' 0" x 1 3/4" x WD Type A-WD Type A1-ALF				
3	Hinges	5BB1 4 1/2 x 4 1/2			652	IV
1	Mortise Privacy Set	L9040 03N L583-363 OS-OCC		RH	630	SC
1	Closer	4040XP RWPA			AL	LC
	Note: PULL SIDE MOUNTED					
1	Protection Plate	8400 24" x 34" B-CS TK-TX			US32D	IV
1	Wall Stop	WS406/407CCV			US32D	IV
1	Door Seal	488S-BK 18'				ZE

Heading #I1FWSM1 (Set #I1FWSM1)

1	Single Door #**10.S1.05B**	S1	SHIPPING & RECEIVING 10.S2.10 from CORR. 10.S1.05			LHR
	Opening Description:	3' 0" x 7' 0" x 1 3/4" x HMD Type A-ICC x HMF Type A2 x 90 MIN				
3	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP			652	IV
1	Latch Guard	WS-LGO-3		LHR	US32D	VO
1	Exit Device	WS-T-9857L-BE-2SI-F-2020 x 996L-BE-RV-2SI/377TKC 03SS 304L		LHR	US32D	VO
1	LFIC Core	32N2201			26	ME
1	Rim Cylinder	20-057 50-231 ICX			630	SC
1	Mortise Cylinder	20-061 50-231 ICX			626	SC
1	Closer	4040XP SCUSH			AL	LC
	Note: PUSH SIDE MOUNTED					
1	Protection Plate	8400 24" x 34" 8402 (UL) B-CS TK-TX			US32D	IV
1	Door Seal	488S-BK 17'				ZE
1	Threshold	566A 36"				ZE

Note: NOTE:

MEETS ICC 500-2020 AND FEMA 320/361 WHEN USED WITH STEELCRAFT PALADIN DOOR ASSEMBLY. ICC500-2020
-2SI "UNLOCKED": OUTSIDE LEVER IS ACTIVE WHEN -2SI IS SET TO "UNLOCKED" STATE. INGRESS BY OUTSIDE LEVER.
-2SI "LOCKED": OUTSIDE LEVER IS RIGID WHEN -2SI IS SET TO "LOCKED" STATE. THUMBTURN IS RIGID. INGRESS BY
FREE EGRESS BY THE PUSH PAD.
IN A STORM EVENT, A USER CAN SEE THE LOCK'S STATUS VIA THE INDICATOR TO QUICKLY DETERMINE IF THE DOOR

Heading #I1P2 (Set #I1P2)

1	Single Door #**10.S1.26**	S1	CORR. 10.S1.15 to MICROKITCHEN STORAGE 10.S1.26			LH
	Opening Description:	3' 0" x 7' 0" x 1 3/4" x HMD Type A x HMF Type A1				
3	Hinges	5BB1 4 1/2 x 4 1/2			652	IV
1	Mortise Passage Set	L9010 03N		LH	630	SC
1	Wall Stop	WS406/407CCV			US32D	IV
1	Door Seal	488S-BK 17'				ZE

Heading #I1P4 (Set #I1P4)

1	Single Door #**10.S1.11**	S1	CORR. 10.S1.15 to HARD COZY 10.S1.11			RH
1	Single Door #**10.S1.12**	S1	CORR. 10.S1.15 to HARD COZY 10.S1.12			RH
1	Single Door #**10.S1.21**	S1	OPEN OFFICE 10.S1.23 to SMALL CONFERENCE 10.S1.21			LH
1	Single Door #**10.S1.22**	S1	OPEN OFFICE 10.S1.23 to MEDIUM CONFERENCE 10.S1.22			LH
	Opening Description:	3' 0" x 7' 0" x 1 3/4" x WD Type E-WD Type A1-ALF				
12	Hinges	5BB1 4 1/2 x 4 1/2			652	IV
2	Mortise Passage Set	L9010 03N		RH	630	SC
2	Mortise Passage Set	L9010 03N		LH	630	SC
4	Floor Stop	FS410			US26D	IV
4	Door Seal	488S-BK 17'				ZE

Heading #I1SFXL2 (Set #I1SFXL2)

1	Single Door #**10.S1.02B**	S1	ENTRY VEST. 10.S1.01 from ENTRY LOBBY 10.S1.01		90°	RHR
	Opening Description:	3' 0" x 7' 9 1/2" Type AL-GL Type ALSF				
1	Continuous Hinge	026XY 95" CUSTOM CUT		LH	628	IV
	Properties: Custom Length=92.5					
1	Exit Device	9875L x 996L-M 03		RHR	US32D	VO
1	LFIC Core	32N2201			26	ME
1	Mortise Cylinder	20-061 50-231 ICX			626	SC
1	Closer	4040XP RWPA ST-			AL	LC
	Note: CLOSER MOUNTED PULL SIDE					
	Properties: Template #=1630					
1	Adapter Plate	4040XP-18PA			AL	LC
1	Overhead Stop	104S			US32D	GL
1	Door Bottom	254A 36"				ZE

Note: PROVIDE A MINIMUM OF 7" TOP RAIL AT STOREFRONT DOOR TO MOUNT CLOSER

PERIMETER SEALS BY FRAME MANUFACTURER

Heading #I1T3 (Set #I1T3)

1	Single Door #**10.S1.09**	S1	CORR. 10.S1.05 to MENS RESTROOM 10.S1.09			LH
1	Single Door #**10.S1.10**	S1	CORR. 10.S1.05 to WOMENS RESTROOM 10.S1.10			RH
	Opening Description:	3' 0" x 7' 0" x 1 3/4" x WD Type A-WD Type A1-ALF				
6	Hinges	5BB1 4 1/2 x 4 1/2			652	IV
2	Push Plate	8200 4 x 16			US32D	IV
2	Pull Plate	8302-0 4 x 16			US32D	IV
2	Closer	4040XP RWPA			AL	LC
	Note: PULL SIDE MOUNTED					
2	Protection Plate	8400 24" x 34" B-CS TK-TX			US32D	IV
2	Wall Stop	WS406/407CCV			US32D	IV
2	Door Seal	488S-BK 17'				ZE

Heading #I2FWSM2 (Set #I2FWSM2)

1	Pair Doors #**10.S1.05A**	S1	CORR. 10.S1.15 to CORR. 10.S1.05		RHA

Opening Description: 2 - 3' 2" x 7' 0" x 1 3/4" x HMD Type D-ICC x HMF Type A2 x 90 MIN

Note: SURFACE BOLTS ARE REQUIRED BY STEELCRAFT TO MAINTAIN ICC 500 RATING.

6	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP		652	IV
2	Surface Bolt	SB360 12"		US2C	IV
1	Multi-Point Mortise Lockset	LM9350T 03N 50-231 IS-LOC	RH	626	SC
1	LFIC Core	32N2201		26	ME
2	Magnetic Holder	SEM7830		AL	LC
2	Closer Note: PULL SIDE MOUNTED	4040XP RWPA		AL	LC
2	Protection Plate	8400 12" x 36" B-CS TK-TX		US32D	IV
1	Door Seal	488S-BK 21'			ZE
1	Weatherstrip	139A 96"			ZE
1	Threshold	566A 38"			ZE

Note: NOTE:

IN A STORM EVENT, A USER CAN SEE THE LOCK'S STATUS VIA THE INDICATOR TO QUICKLY DETERMINE IF THE DOOR NEEDS TO BE LOCKED.

DOOR(S) NORMALLY UNLOCKED AND HELD OPEN BY WALL MAGNETS. DOOR(S) WILL SELF CLOSE AND LATCH UPON

PROVIDE EXTENSION PIECES AS NEEDED TO ALLOW ARMATURE AND MAG HOLDER TO CONNECT PROPERLY.

Heading #I2XL1 (Set #I2XL1)

1	Pair Doors #**10.S1.15B**	S1	CORR. 10.S1.15 from CORR. 10.N2.12		RHRA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type D x HMF Type A1

8	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP		652	IV
1	Flush Bolt	FB51T 36"		US32D	IV
1	Exit Device	9875L-BE x 996L-BE-M 03SS 99GBK-M	RHR	US32D	VO
1	Coordinator	3780		US28	AB
2	Closer Note: PUSH SIDE MOUNTED	4040XP SCUSH		AL	LC
2	Protection Plate	8400 24" x 34" B-CS TK-TX		US32D	IV
1	Door Seal	488S-BK 25'			ZE

Heading #SE1SFXL1 (Set #SE1SFXL1)

1	Single Door #**10.S1.01**	S1	EXTERIOR from ENTRY VEST. 10.S1.01			LHR
	Opening Description:	3' 0" x 7' 9 1/2" Type AL-GL Type ALSF				
1	Continuous Hinge	026XY 95" CUSTOM CUT		RH	628	IV
	Properties: Custom Length=92.5					
1	Exit Device	LD RX 9875L x M996L-BE-M 03SS CON FSE		LHR	US32D	VO
1	LFIC Core	32N2201			26	ME
1	Rim Cylinder	20-057 50-231 ICX			630	SC
1	Closer	4040XP SCUSH			AL	LC
	Note: PUSH SIDE MOUNTED					
1	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS				MISC
1	Electric Power Transfer	EPT 10 CON			SP28	VO
1	Power Supply Extension	CON-6W				SC
1	Wire Harness	CON-192P				SC
1	Length of Rain Drip	142AA 40"				ZE
1	Door Sweep	8197AA 36"				ZE
1	Threshold	625A 36" 223-MSLA-10				ZE

Note: LOCAL ALARTM BY DIV 28
PERIMETER SEALS BY FRAME MANUFACTURER

NOTE:

1. COORDINATE FRAME WITH DOOR POSITION SWITCH FOR IN-FRAME MOUNTING AT HEAD
2. PROVIDE A 7" MINIMUM TOP RAIL AT STOREFRONT DOOR FOR CLOSER MOUNTING.

OPERATION:

DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
FREE EGRESS ALWAYS PERMITTED.
INSIDE LEVER/TOUCHBAR HAS RX (REQUEST TO EXIT) SWITCH TO SIGNAL AUTHORIZED EGRESS.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SI1E2 (Set #SI1E2)

1	Single Door #**10.E2.05**	E2	CORR. 10.E2.03 to FIRE RISER 10.E2.05		90°	LH
1	Single Door #**10.N1.07**	N1	CORR. 10.N1.12 to FIRE RISER 10.N1.07		90°	LH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type A x HMF Type A1

4	Hinges	5BB1 HW 4 1/2 x 4 1/2		652	IV
2	Hinge	5BB1 HW TW8 CON 4 1/2" x 4 1/2"		652	IV
2	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON RX	LH	630	SC
2	LFIC Core	32N2201		26	ME
2	Closer	4040XP RWPA ST-		AL	LC
	Note: CLOSER MOUNTED PULL SIDE				
	Properties: Template #=1630				
2	Adapter Plate	4040XP-18TJ		AL	LC
2	Overhead Stop	104S		US32D	GL
2	Protection Plate	8400 24" x 34" B-CS TK-TX		US32D	IV
2	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
2	Power Supply Extension	CON-6W			SC
2	Wire Harness	CON-38P			SC
2	Door Seal	488S-BK 17'			ZE

Note: NOTE:

1. COORDINATE FRAME WITH DOOR POSITION SWITCH FOR IN-FRAME MOUNTING AT HEAD

OPERATION:

DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
FREE EGRESS ALWAYS PERMITTED.
INSIDE LEVER/TOUCHBAR HAS RX (REQUEST TO EXIT) SWITCH TO SIGNAL AUTHORIZED EGRESS.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SI1E3 (Set #SI1E3)

1	Single Door #**10.S1.07**	S1	CORR. 10.S1.05 to BMS WORKSTATION 10.S1.07			LH
	Opening Description:	3' 0" x 7' 0" x 1 3/4" x WD Type E-WD Type A1-ALF				
2	Hinges	5BB1 4 1/2 x 4 1/2			652	IV
1	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8			652	IV
1	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON		LH	630	SC
1	LFIC Core	32N2201			26	ME
1	Closer	4040XP RWPA			AL	LC
	Note: PULL SIDE MOUNTED					
1	Protection Plate	8400 24" x 34" B-CS TK-TX			US32D	IV
1	Wall Stop	WS406/407CCV			US32D	IV
1	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS				MISC
1	Power Supply Extension	CON-6W				SC
1	Wire Harness	CON-38P				SC
1	Door Seal	488S-BK 17'				ZE

Note:

OPERATION:

DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
FREE EGRESS ALWAYS PERMITTED.
INSIDE LEVER/TOUCHBAR HAS RX (REQUEST TO EXIT) SWITCH TO SIGNAL AUTHORIZED EGRESS.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SI1E3.1 (Set #SI1E3)

1	Single Door #**10.E2.16**	E2	CORR. 10.E2.03 to JANITOR MOP CLOSET 10.E2.16			LH
1	Single Door #**10.S1.16**	S1	CORR. 10.S1.15 to WET JANITOR CLOSET 10.S1.16			RH
1	Single Door #**10.S1.17**	S1	CORR. 10.S1.15 to DRY JANITOR 10.S1.17			LH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type A x HMF Type A1

6	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
3	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
2	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON RX	LH	630	SC
1	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON RX	RH	630	SC
3	LFIC Core	32N2201		26	ME
3	Closer Note: PULL SIDE MOUNTED	4040XP RWPA		AL	LC
3	Protection Plate	8400 24" x 34" B-CS TK-TX		US32D	IV
3	Wall Stop	WS406/407CCV		US32D	IV
3	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
3	Power Supply Extension	CON-6W			SC
3	Wire Harness	CON-38P			SC
3	Door Seal	488S-BK 17'			ZE

Note:

OPERATION:

DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
FREE EGRESS ALWAYS PERMITTED.
INSIDE LEVER/TOUCHBAR HAS RX (REQUEST TO EXIT) SWITCH TO SIGNAL AUTHORIZED EGRESS.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SI1GE2 (Set #SI1GE2)

1	Single Door #**10.N2.11**	N2	CORR. 10.N2.12 to FIRE RISER 10.N2.11		90°	LH
1	Single Door #**10.N3.07**	N3	CORR. 10.N3.11 to FIRE RISER 10.N3.07		90°	RH
1	Single Door #**10.N4.14**	N4	CORR. 10.N4.15 to FIRE RISER 10.N4.14		90°	LH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type A x HMF Type A1

6	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
3	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
2	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON RX	LH	630	SC
1	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON RX	RH	630	SC
3	LFIC Core	32N2201		26	ME
3	Closer Note: CLOSER MOUNTED PULL SIDE Properties: Template #=1630	4040XP RWPA ST-		AL	LC
3	Adapter Plate	4040XP-18TJ		AL	LC
3	Overhead Stop	104S		US32D	GL
3	Protection Plate	8400 24" x 34" B-CS TK-TX		US32D	IV
3	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
3	Power Supply Extension	CON-6W			SC
3	Wire Harness	CON-38P			SC
3	Weatherstrip	328AA 1 x 36" 2 x 84"			ZE
3	Auto Door Bottom	355AA 36"			ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
FREE EGRESS ALWAYS PERMITTED.
INSIDE LEVER/TOUCHBAR HAS RX (REQUEST TO EXIT) SWITCH TO SIGNAL AUTHORIZED EGRESS.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SI1GE3 (Set #SI1GE3)

1	Single Door #**10.N3.08**	N3	CORR. 10.N3.11 to HUMIDIFER ROOM 10.N3.08	LH
1	Single Door #**10.N4.12**	N4	CORR. 10.N4.15 to JANITOR MOP CLOSET 10.N4.12	LH
1	Single Door #**10.S2.02**	S2	SHIPPING & RECEIVING 10.S2.01 to SHIPPING & RECEIVING OFFICE 10.S2.02	LH
1	Single Door #**10.S2.11**	S2	CORR. 10.S2.08 to SSB MECHANICAL ROOM 10.S2.11	LH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type A x HMF Type A1 (10.N3.08, 10.N4.12, 10.S2.11)
3' 0" x 7' 0" x 1 3/4" x HMD Type C x HMF Type A1 (10.S2.02)

8	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
4	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
4	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON RX	LH	630	SC
4	LFIC Core	32N2201		26	ME
4	Closer Note: PULL SIDE MOUNTED	4040XP RWPA		AL	LC
4	Protection Plate	8400 24" x 34" B-CS TK-TX		US32D	IV
4	Wall Stop	WS406/407CCV		US32D	IV
4	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
4	Power Supply Extension	CON-6W			SC
4	Wire Harness	CON-38P			SC
4	Weatherstrip	328AA 1 x 36" 2 x 84"			ZE
4	Auto Door Bottom	355AA 36"			ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
FREE EGRESS ALWAYS PERMITTED.
INSIDE LEVER/TOUCHBAR HAS RX (REQUEST TO EXIT) SWITCH TO SIGNAL AUTHORIZED EGRESS.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SI1GE3.1 (Set #SI1GE3)

1	Single Door #**10.S1.08**	S1	CORR. 10.S1.05 to LACTATION ROOM 10.S1.08			RH
1	Single Door #**10.S1.13**	S1	CORR. 10.S1.15 to FIRE ALARM EQUIPMENT ROOM 10.S1.13			LH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x WD Type A-WD Type A1-ALF (10.S1.08)
3' 0" x 7' 0" x 1 3/4" x WD Type E-WD Type A1-ALF (10.S1.13)

4	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
2	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
1	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON RX	LH	630	SC
1	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON RX	RH	630	SC
2	LFIC Core	32N2201		26	ME
2	Closer Note: PULL SIDE MOUNTED	4040XP RWPA		AL	LC
2	Protection Plate	8400 10" x 34" B-CS TK-TX		US32D	IV
2	Wall Stop	WS406/407CCV		US32D	IV
2	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
2	Power Supply Extension	CON-6W			SC
2	Wire Harness	CON-38P			SC
2	Weatherstrip	328AA 1 x 36" 2 x 84"			ZE
2	Auto Door Bottom	355AA 36"			ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
FREE EGRESS ALWAYS PERMITTED.
INSIDE LEVER/TOUCHBAR HAS RX (REQUEST TO EXIT) SWITCH TO SIGNAL AUTHORIZED EGRESS.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SI1GE3.2 (Set #SI1GE3)

1	Single Door #**10.S1.06**	S1	CORR. 10.S1.05 to PPE & EMERGENCY SUPPLY 10.S1.06			LH
	Opening Description:	3' 0" x 7' 0" x 1 3/4" x HMD Type A x HMF Type A1				
2	Hinges	5BB1 4 1/2 x 4 1/2			652	IV
1	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8			652	IV
1	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON RX		LH	630	SC
1	LFIC Core	32N2201			26	ME
1	Closer Note: PULL SIDE MOUNTED	4040XP RWPA			AL	LC
1	Protection Plate	8400 24" x 34" B-CS TK-TX			US32D	IV
1	Wall Stop	WS406/407CCV			US32D	IV
1	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS				MISC
1	Power Supply Extension	CON-6W				SC
1	Wire Harness	CON-38P				SC
1	Weatherstrip	328AA 1 x 36" 2 x 84"				ZE
1	Auto Door Bottom	355AA 36"				ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
FREE EGRESS ALWAYS PERMITTED.
INSIDE LEVER/TOUCHBAR HAS RX (REQUEST TO EXIT) SWITCH TO SIGNAL AUTHORIZED EGRESS.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SI2GE2 (Set #SI2GE2)

1	Pair Doors #**10.S1.20**	S1	CORR. 10.S1.15 to MAINTENANCE ROOM 10.S1.20	90°	RHA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type D x HMF Type A1

1	Hinge	5BB1 HW TW8 CON 4 1/2" x 4 1/2"		652	IV
7	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP		652	IV
1	Flush Bolt	FB51T 36"		US32D	IV
1	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON RX	RH	630	SC
1	LFIC Core	32N2201		26	ME
1	Coordinator	3780		US28	AB
2	Closer	4040XP RWPA ST-		AL	LC
	Note: CLOSER MOUNTED PULL SIDE				
	Properties: Template #=1630				
2	Adapter Plate	4040XP-18TJ		AL	LC
2	Overhead Stop	104S		US32D	GL
2	Protection Plate	8400 24" x 34" B-CS TK-TX		US32D	IV
2	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
1	Power Supply Extension	CON-6W			SC
1	Wire Harness	CON-38P			SC
1	Weatherstrip	328AA 1 x 72" 2 x 108"			ZE
2	Auto Door Bottom	355AA 36"			ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
FREE EGRESS ALWAYS PERMITTED.
INSIDE LEVER/TOUCHBAR HAS RX (REQUEST TO EXIT) SWITCH TO SIGNAL AUTHORIZED EGRESS.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SSE1XL1 (Set #SSE1XL1)

1	Single Door #**10.E1.03**	E1	EXTERIOR from CORR. 10.E1.03	RHR
1	Single Door #**10.E1.04**	E1	EXTERIOR from SPOKE PARTS 10.E1.04	LHR
1	Single Door #**10.E2.06A**	E2	EXTERIOR from CORR. 10.E2.06	LHR
1	Single Door #**10.E2.06B**	E2	EXTERIOR from CORR. 10.E2.06	RHR
1	Single Door #**10.N4.15A**	N4	EXTERIOR from CORR. 10.N4.15	LHR
1	Single Door #**10.S1.15A**	S1	EXTERIOR from CORR. 10.S1.15	LHR
1	Single Door #**10.S2.08**	S2	EXTERIOR from CORR. 10.S2.08	RHR
1	Single Door #**10.S2.09B**	S2	EXTERIOR from SSB ELECTRICAL ROOM 10.S2.09	RHR

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type A x HMF Type A3

24	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP		630	IV
4	Exit Device	LD 9875L x M996L-M CON FSE	RHR	US32D	VO
4	Exit Device	LD 9875L x M996L-M CON FSE	LHR	US32D	VO
8	LFIC Core	32N2201		26	ME
8	Mortise Cylinder	20-061 50-231 ICX		626	SC
8	Closer Note: PUSH SIDE MOUNTED	4040XP SCUSH		AL	LC
8	Lock Guard	LG10		US32D	IV
8	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
8	Electric Power Transfer	EPT 10 CON		SP28	VO
8	Power Supply Extension	CON-6W			SC
8	Wire Harness	CON-38P			SC
8	Length of Rain Drip	142AA 40"			ZE
16	Weatherstrip Note: @ HINGE & LOCK JAMB	328AA 84"			ZE
8	Door Seal Note: @ FRAME HEAD (SHORTEST LENGTH AVAILABLE IS 8')	488S-BK 8'			ZE
8	Door Sweep	111AA 36"			ZE
8	Threshold	625A 36" 223-MSLA-10			ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY
INSIDE CARD READER WILL SHUNT AUDIBLE ALARM UPON EXIT
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE)
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS

Heading #SSE1XL1.1 (Set #SSE1XL1)

1	Single Door #**10.E1.06**	E1	EXTERIOR from CORR. 10.E1.03	LHR
1	Single Door #**10.E1.08**	E1	EXTERIOR from CORR. 10.E1.08	LHR
1	Single Door #**10.E2.03**	E2	EXTERIOR from CORR. 10.E2.03	LHR
1	Single Door #**10.E2.07**	E2	EXTERIOR from CORR. 10.E2.07	RHR
1	Single Door #**10.N2.12**	N2	EXTERIOR from CORR. 10.N2.12	RHR
1	Single Door #**10.N3.11**	N3	EXTERIOR from CORR. 10.N3.11	RHR

Opening Description: 4' 0" x 9' 0" x 1 3/4" x HMD Type A x HMF Type A3

24	Hinges	5BB1 HW 5 x 4 1/2 NRP		630	IV
3	Exit Device	LD 9875L x M996L-M 48" CON FSE	LHR	US32D	VO
3	Exit Device	LD 9875L x M996L-M 48" CON FSE	RHR	US32D	VO
6	LFIC Core	32N2201		26	ME
6	Mortise Cylinder	20-061 50-231 ICX		626	SC
6	Closer	4040XP SCUSH		AL	LC
	Note: PUSH SIDE MOUNTED				
6	Lock Guard	LG10		US32D	IV
6	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
6	Electric Power Transfer	EPT 10 CON		SP28	VO
6	Power Supply Extension	CON-6W			SC
6	Length of Rain Drip	142AA 52"			ZE
12	Weatherstrip	328AA 108"			ZE
	Note: @ FRAME HINGE & LOCK JAMBS				
6	Door Seal	488S-BK 8'			ZE
	Note: @ FRAME HEAD (SHORTEST LENGTH AVAILABLE IS 8')				
6	Door Sweep	111AA 48"			ZE
6	Threshold	625A 48" 223-MSLA-10			ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY
INSIDE CARD READER WILL SHUNT AUDIBLE ALARM UPON EXIT
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE)
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS

Heading #SSE1XL1.2 (Set #SSE1XL1)

1	Single Door #**10.N4.15C**	N4	EXTERIOR from CORR. 10.N4.15			RHR
	Opening Description:	3' 8" x 9' 0" x 1 3/4" x HMD Type A x HMF Type A3				
4	Hinges	5BB1 HW 5 x 4 1/2 NRP			630	IV
1	Exit Device	LD 9875L x M996L-M 48" CON FSE		RHR	US32D	VO
1	LFIC Core	32N2201			26	ME
1	Mortise Cylinder	20-061 50-231 ICX			626	SC
1	Closer	4040XP SCUSH			AL	LC
	Note: PUSH SIDE MOUNTED					
1	Lock Guard	LG10			US32D	IV
1	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS				MISC
1	Electric Power Transfer	EPT 10 CON			SP28	VO
1	Power Supply Extension	CON-6W				SC
2	Weatherstrip	328AA 108"				ZE
	Note: @ FRAME HINGE & LOCK JAMBS					
1	Door Seal	488S-BK 8'				ZE
	Note: @ FRAME HEAD (SHORTEST LENGTH AVAILABLE IS 8')					
1	Length of Rain Drip	142AA 48"				ZE
1	Door Sweep	111AA 44"				ZE
1	Threshold	625A 44" 223-MSLA-10				ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY
INSIDE CARD READER WILL SHUNT AUDIBLE ALARM UPON EXIT
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE)
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS

Heading #SSE2XL1 (Set #SSE2XL1)

1	Pair Doors #**10.S2.01B**	S2	EXTERIOR from SHIPPING & RECEIVING 10.S2.01			RHRA
	Opening Description:	2 - 3' 0" x 7' 0" x 1 3/4" x HMD Type B x HMF Type A3				
5	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP			630	IV
1	Hinge	5BB1 HW TW8 CON 4 1/2" x 4 1/2"			630	IV
1	Flush Bolt Set	FB51P			US32D	IV
1	Exit Device	LD 9875L x M996L-M CON FSE		RHR	US32D	VO
1	LFIC Core	32N2201			26	ME
1	Mortise Cylinder	20-061 50-231 ICX			626	SC
1	Coordinator	3780			US28	AB
2	Closer	4040XP SCUSH			AL	LC
	Note: PUSH SIDE MOUNTED					
2	Protection Plate	8400 24" x 34" B-CS TK-TX			US32D	IV
2	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS				MISC
1	Power Supply Extension	CON-6W				SC
1	Wire Harness	CON-38P				SC
1	Length of Rain Drip	142AA 76"				ZE
2	Weatherstrip	328AA 84"				ZE
	Note: @ HINGE & LOCK JAMB					
1	Door Seal	488S-BK 8'				ZE
	Note: @ FRAME HEAD (SHORTEST LENGTH AVAILABLE IS 8')					
2	Door Sweep	111AA 36"				ZE
1	Threshold	1674A 72" 223-MSLA-10				ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY
INSIDE CARD READER WILL SHUNT AUDIBLE ALARM UPON EXIT
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE)
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS

Heading #SSI1FGXL1 (Set #SSI1FGXL1)

1	Single Door #**10.E2.08**	E2	CORR. 10.E2.17 from LIGHTING INVERTER ROOM 10.E2.08	RHR
1	Single Door #**10.E2.10**	E2	CORR. 10.E2.17 from LIGHTING INVERTER ROOM 10.E2.10	RHR
1	Single Door #**10.E2.13**	E2	CORR. 10.E2.17 from LIGHTING INVERTER ROOM 10.E2.13	RHR
1	Single Door #**10.E2.14**	E2	CORR. 10.E2.17 from LIGHTING INVERTER ROOM 10.E2.14	RHR
1	Single Door #**10.S2.10**	S2	CORR. 10.S2.08 from LIGHTING INVERTER ROOM 10.S2.10	LHR

Opening Description: 4' 0" x 9' 0" x 1 3/4" x HMD Type A x HMF Type A1 x 90 MIN

5	Hinge	5BB1 HW TW8 CON 5" x 4 1/2"		652	IV
15	Hinges	5BB1 HW 5 x 4 1/2 NRP		652	IV
4	Exit Device	9875L-F x M996L-M 48" CON FSE	RHR	US32D	VO
1	Exit Device	9875L-F x M996L-M 48" CON FSE	LHR	US32D	VO
5	LFIC Core	32N2201		26	ME
5	Mortise Cylinder	20-061 50-231 ICX		626	SC
5	Closer Note: PUSH SIDE MOUNTED	4040XP SCUSH		AL	LC
5	Protection Plate	8400 24" x 46" 8402 (UL) B-CS TK-TX		US32D	IV
5	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
5	Power Supply Extension	CON-6W			SC
5	Wire Harness	CON-50P			SC
5	Door Seal	488S-BK 25'			ZE
5	Auto Door Bottom	355AA 48"			ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY
INSIDE CARD READER WILL SHUNT AUDIBLE ALARM UPON EXIT
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE)
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS

Heading #SSI1FGXL1A (Set #SSI1FGXL1)

1	Single Door #**10.E2.09**	E2	CORR. 10.E2.17 from NS UPS GALLERY 10.E2.09	RHR
1	Single Door #**10.E2.11**	E2	CORR. 10.E2.17 from NS UPS GALLERY 10.E2.11	RHR
1	Single Door #**10.N1.08**	N1	CORR. 10.N1.12 from GS.MDF ELECTRICAL 10.N1.08	LHR
1	Single Door #**10.N2.10**	N2	CORR. 10.N2.12 from GS.MDF ELECTRICAL 10.N2.10	LHR

Opening Description: 4' 0" x 9' 0" x 1 3/4" x HMD Type A x HMF Type A1 x 45 MIN

4	Hinge	5BB1 HW TW8 CON 5" x 4 1/2"		652	IV
12	Hinges	5BB1 HW 5 x 4 1/2 NRP		652	IV
2	Exit Device	9875L-F x M996L-M 48" CON FSE	RHR	US32D	VO
2	Exit Device	9875L-F x M996L-M 48" CON FSE	LHR	US32D	VO
4	LFIC Core	32N2201		26	ME
4	Mortise Cylinder	20-061 50-231 ICX		626	SC
4	Closer Note: PUSH SIDE MOUNTED	4040XP SCUSH		AL	LC
4	Protection Plate	8400 24" x 46" 8402 (UL) B-CS TK-TX		US32D	IV
4	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
4	Power Supply Extension	CON-6W			SC
4	Wire Harness	CON-50P			SC
4	Door Seal	488S-BK 25'			ZE
4	Auto Door Bottom	355AA 48"			ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY
INSIDE CARD READER WILL SHUNT AUDIBLE ALARM UPON EXIT
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE)
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS

Heading #SSI1GE1 (Set #SSI1GE1)

1	Single Door #**10.S2.04C**	S2	SHIPPING & RECEIVING 10.S2.01 from TECHNICAL FLUID WORK ROOM 10.S2.04			LHR
1	Single Door #**10.S2.04D**	S2	CORR. 10.N1.12 from TECHNICAL FLUID WORK ROOM 10.S2.04			RHR
	Opening Description:	3' 0" x 7' 0" x 1 3/4" x HMD Type A x HMF Type A1				
2	Hinge	5BB1 HW TW8 CON 4 1/2" x 4 1/2"			652	IV
4	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP			652	IV
1	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON		RHR	630	SC
1	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON		LHR	630	SC
2	LFIC Core	32N2201			26	ME
2	Closer	4040XP SCUSH			AL	LC
	Note: PUSH SIDE MOUNTED					
2	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS				MISC
2	Power Supply Extension	CON-6W				SC
2	Wire Harness	CON-38P				SC
4	Weatherstrip	328AA 84"				ZE
	Note: @ HINGE & LOCK JAMB					
2	Door Seal	488S-BK 8'				ZE
	Note: @ FRAME HEAD (SHORTEST LENGTH AVAILABLE IS 8')					
2	Auto Door Bottom	355AA 36"				ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
FREE EGRESS ALWAYS PERMITTED.
INSIDE LEVER/TOUCHBAR HAS RX (REQUEST TO EXIT) SWITCH TO SIGNAL AUTHORIZED EGRESS.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SSI1GE2 (Set #SSI1GE2)

1	Single Door #**10.S2.05B**	S2	CORR. 10.S2.12 to HIGH VALUE STORAGE 10.S2.05		90°	RH
1	Single Door #**10.S2.06B**	S2	CORR. 10.S2.12 to SITE OPS & ENS STORAGE 10.S2.06		90°	LH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type C x HMF Type A1

6	Hinges	5BB1 HW 4 1/2 x 4 1/2		652	IV
2	Hinge	5BB1 HW TW8 CON 4 1/2" x 4 1/2"		652	IV
1	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON	LH	630	SC
1	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON	RH	630	SC
2	LFIC Core	32N2201		26	ME
2	Closer	4040XP RWPA ST-		AL	LC
	Note: CLOSER MOUNTED PULL SIDE				
	Properties: Template #=1630				
2	Adapter Plate	4040XP-18TJ		AL	LC
2	Overhead Stop	104S		US32D	GL
2	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
2	Power Supply Extension	CON-6W			SC
2	Wire Harness	CON-38P			SC
4	Weatherstrip	328AA 84"			ZE
	Note: @ HINGE & LOCK JAMB				
2	Door Seal	488S-BK 8'			ZE
	Note: @ FRAME HEAD (SHORTEST LENGTH AVAILABLE IS 8')				
2	Auto Door Bottom	355AA 36"			ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
FREE EGRESS ALWAYS PERMITTED.
INSIDE LEVER/TOUCHBAR HAS RX (REQUEST TO EXIT) SWITCH TO SIGNAL AUTHORIZED EGRESS.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SSI1GE3 (Set #SSI1GE3)

1	Single Door #**10.S1.14**	S1	CORR. 10.S1.15 to SCR WORKSPACE 10.S1.14			LH
	Opening Description:	3' 0" x 7' 0" x 1 3/4" x HMD Type A x HMF Type A1				
2	Hinges	5BB1 HW 4 1/2 x 4 1/2			652	IV
1	Hinge	5BB1 HW TW8 CON 4 1/2" x 4 1/2"			652	IV
1	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON RX		LH	630	SC
1	LFIC Core	32N2201			26	ME
1	Closer	4040XP RWPA			AL	LC
	Note: PULL SIDE MOUNTED					
1	Wall Stop	WS406/407CCV			US32D	IV
1	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS				MISC
1	Power Supply Extension	CON-6W				SC
1	Wire Harness	CON-38P				SC
2	Weatherstrip	328AA 96"				ZE
	Note: @ FRAME HEAD AND JAMBS					
1	Door Seal	488S-BK 8'				ZE
	Note: @ FRAME HEAD (SHORTEST LENGTH AVAILABLE IS 8')					
1	Auto Door Bottom	355AA 36"				ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
FREE EGRESS ALWAYS PERMITTED.
INSIDE LEVER/TOUCHBAR HAS RX (REQUEST TO EXIT) SWITCH TO SIGNAL AUTHORIZED EGRESS.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SSI1GE3.1 (Set #SSI1GE3)

1	Single Door #**10.N1.09**	N1	CORR. 10.N1.12 to CARRIER MDF 10.N1.09	RH
1	Single Door #**10.N1.10**	N1	CORR. 10.N1.12 to GS ENTRY FIBER ROOM 10.N1.10	LH
1	Single Door #**10.N2.08**	N2	CORR. 10.N2.12 to GS ENTRY FIBER ROOM 10.N2.08	RH
1	Single Door #**10.N2.09**	N2	CORR. 10.N2.12 to CARRIER MDF 10.N2.09	LH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type A x HMF Type A1

8	Hinges	5BB1 HW 4 1/2 x 4 1/2		652	IV
4	Hinge	5BB1 HW TW8 CON 4 1/2" x 4 1/2"		652	IV
2	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON	LH	630	SC
2	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON	RH	630	SC
4	LFIC Core	32N2201		26	ME
4	Closer	4040XP RWPA		AL	LC
	Note: PULL SIDE MOUNTED				
4	Wall Stop	WS406/407CCV		US32D	IV
4	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
4	Power Supply Extension	CON-6W			SC
4	Wire Harness	CON-38P			SC
8	Weatherstrip	328AA 84"			ZE
	Note: @ HINGE & LOCK JAMB				
4	Door Seal	488S-BK 8'			ZE
	Note: @ FRAME HEAD (SHORTEST LENGTH AVAILABLE IS 8')				
4	Auto Door Bottom	355AA 36"			ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
FREE EGRESS ALWAYS PERMITTED.
INSIDE LEVER/TOUCHBAR HAS RX (REQUEST TO EXIT) SWITCH TO SIGNAL AUTHORIZED EGRESS.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SSI1GWE2 (Set #SSI1GWE2)

1	Single Door #**10.N1.03**	N1	CORR. 10.N1.12 to GS.MDF MECHANICAL 10.N1.03		90°	RH
1	Single Door #**10.N2.06**	N2	CORR. 10.N2.12 to GS.MDF MECHANICAL 10.N2.06		90°	RH

Opening Description: 3' 6" x 7' 0" x Type C1 x HMF Type A1

4	Hinges	5BB1 HW 5 x 4 1/2		652	IV
2	Hinge	5BB1 HW TW8 CON 5" x 4 1/2"		652	IV
2	Continuous Hinge Note: FOR WICKET DOOR Properties: Custom Length=13"	112XY 83" CUSTOM CUT	RH	628	IV
2	Mortise Passage Set Note: FOR WICKET DOOR	L9010 03N	RH	630	SC
2	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON	RH	630	SC
2	LFIC Core	32N2201		26	ME
2	Closer Note: CLOSER MOUNTED PULL SIDE Properties: Template #=1630	4040XP RWPA ST-		AL	LC
2	Adapter Plate	4040XP-18TJ		AL	LC
2	Overhead Stop	105S		US32D	GL
2	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
2	Wire Harness	CON-44P			SC
2	Power Supply Extension	CON-6W			SC
2	Weatherstrip	328AA 1 x 42" 2 x 84"			ZE
2	Auto Door Bottom	355AA 42"			ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
FREE EGRESS ALWAYS PERMITTED.
INSIDE LEVER/TOUCHBAR HAS RX (REQUEST TO EXIT) SWITCH TO SIGNAL AUTHORIZED EGRESS.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SSI1GXL1 (Set #SSI1GXL1)

1	Single Door #**10.S1.04**	S1	SECURITY DESK 10.S1.04 from CORR. 10.S1.15			LHR

Opening Description: 3' 0" x 7' 0" x 1 3/4" x WD Type E-WD Type A1-ALF

1	Hinge	5BB1 HW TW8 CON 4 1/2" x 4 1/2"		652	IV
2	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP		652	IV
1	Exit Device	LD 9875L x M996L-M CON FSE	LHR	US32D	VO
1	LFIC Core	32N2201		26	ME
1	Mortise Cylinder	20-061 50-231 ICX		626	SC
1	Closer Note: PUSH SIDE MOUNTED	4040XP SCUSH		AL	LC
1	Protection Plate	8400 10" x 34" B-CS TK-TX		US32D	IV
1	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
1	Power Supply Extension	CON-6W			SC
1	Wire Harness	CON-38P			SC
1	Door Seal	488S-BK 17'			ZE
1	Auto Door Bottom	355AA 36"			ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY
INSIDE CARD READER WILL SHUNT AUDIBLE ALARM UPON EXIT
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE)
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS

Heading #SSI1GXL1.1 (Set #SSI1GXL1)

1	Single Door #**10.S1.02A**	S1	ENTRY LOBBY 10.S1.01 from OPEN OFFICE 10.S1.23		LHR

Opening Description: 3' 0" x 8' 0" Type AL-GL Type ALSF

Note: VERIFY BOTTOM RAIL HEIGHT ON DOOR FOR KICKPLATE COORDINATION

1	Hinge	5BB1 HW TW8 CON 4 1/2" x 4 1/2"		652	IV
3	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP		652	IV
1	Exit Device	LD 9875L x M996L-M CON FSE	LHR	US32D	VO
1	LFIC Core	32N2201		26	ME
1	Mortise Cylinder	20-061 50-231 ICX		626	SC
1	Closer	4040XP SCUSH		AL	LC
	Note: PUSH SIDE MOUNTED				
1	Adapter Plate	4040XP-18PA		AL	LC
1	Protection Plate	8400 10" x 34" B-CS TK-TX		US32D	IV
1	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
1	Power Supply Extension	CON-6W			SC
1	Wire Harness	CON-38P			SC
1	Door Seal	488S-BK 20'			ZE
1	Auto Door Bottom	355AA 36"			ZE

Note: OPERATION:
DOOR IS NORMALLY CLOSED AND LOCKED
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY
INSIDE CARD READER WILL SHUNT AUDIBLE ALARM UPON EXIT
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE)
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS

Heading #SSI2FGE1 (Set #SSI2FGE1)

1	Pair Doors #**10.N1.16**	N1	CORR. 10.E2.03 from NS MECHANICAL GALLERY 10.N1.13		RHRA
1	Pair Doors #**10.N4.05**	N4	CORR. 10.E2.07 from FACILITY WATER ENTRY 10.N4.05		RHRA
1	Pair Doors #**10.N4.09**	N4	CORR. 10.N4.15 from FACILITY WATER ENTRY 10.N4.09		RHRA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type B x HMF Type A1 x 45 MIN

3	Hinge	5BB1 HW TW8 CON 4 1/2" x 4 1/2"		652	IV
21	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP		652	IV
3	Flush Bolt Kit	FB52		US32D	IV
	Note: TOP BOLT ONLY W/FIRE PIN				
3	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON	RHR	630	SC
3	LFIC Core	32N2201		26	ME
3	Coordinator	3780		US28	AB
6	Closer	4040XP SCUSH		AL	LC
	Note: PUSH SIDE MOUNTED				
6	Protection Plate	8400 24" x 34" 8402 (UL) B-CS TK-TX		US32D	IV
6	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
3	Power Supply Extension	CON-6W			SC
3	Wire Harness	CON-38P			SC
3	Door Seal	488S-BK 25'			ZE
6	Weatherstrip	328AA 108"			ZE
	Note: @ FRAME HINGE & LOCK JAMBS				
6	Auto Door Bottom	355AA 36"			ZE

Note: OPERATION:

DOOR IS NORMALLY CLOSED AND LOCKED
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY
INSIDE CARD READER WILL SHUNT AUDIBLE ALARM UPON EXIT
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE)
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS

Heading #SSI2FGE1.1 (Set #SSI2FGE1)

1	Pair Doors #**10.N1.06**	N1	CORR. 10.N1.12 from FACILITY WATER ENTRY 10.N1.06			RHRA
	Opening Description:	2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type B x HMF Type A1 x 90 MIN				
1	Hinge	5BB1 HW TW8 CON 4 1/2" x 4 1/2"			652	IV
7	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP			652	IV
1	Flush Bolt Kit	FB52			US32D	IV
	Note: TOP BOLT ONLY W/FIRE PIN					
1	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON		RHR	630	SC
1	LFIC Core	32N2201			26	ME
1	Coordinator	3780			US28	AB
2	Closer	4040XP SCUSH			AL	LC
	Note: PUSH SIDE MOUNTED					
2	Protection Plate	8400 24" x 34" 8402 (UL) B-CS TK-TX			US32D	IV
2	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS				MISC
1	Power Supply Extension	CON-6W				SC
1	Wire Harness	CON-38P				SC
1	Door Seal	488S-BK 25'				ZE
2	Weatherstrip	328AA 108"				ZE
	Note: @ FRAME HINGE & LOCK JAMBS					
2	Auto Door Bottom	355AA 36"				ZE

Note: OPERATION:

DOOR IS NORMALLY CLOSED AND LOCKED
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY
INSIDE CARD READER WILL SHUNT AUDIBLE ALARM UPON EXIT
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE)
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS

Heading #SSI2FGOXL (Set #SSI2FGOXL)

1	Pair Doors #**10.N1.01B**	N1	CORR. 10.N1.12 from NETWORK SUITE 1 10.N1.01			LHRA
1	Pair Doors #**10.N2.01C**	N2	CORR. 10.N2.12 from NETWORK SUITE 2 10.N2.02			RHRA
	Opening Description:	3' 0", 1' 6" x 8' 0" x 1 3/4" x HMD Type H x HMF Type A1 x 90 MIN				
2	Continuous Hinge	705 95"			630	IV
1	Continuous Hinge	705 95" EPT		LH	630	IV
1	Continuous Hinge	705 95" EPT		RH	630	IV
2	Flush Bolt Kit	FB52			US32D	IV
	Note: TOP BOLT ONLY W/FIRE PIN					
1	Exit Device	QEL 9475L-F x 940L 03 24VDC CON		LH	US26D	VO
1	Exit Device	QEL 9475L-F x 940L 03 24VDC CON		RH	US26D	VO
2	LFIC Core	32N2201			26	ME
2	Mortise Cylinder	20-061 50-231 ICX			626	SC
2	Coordinator	3780			US28	AB
2	SW200I single	SW200I SINGLE				MISC
2	Safety Flat Scan	10LZRFLATSCAN-SWW				MISC
2	Closer	4040XP SCUSH ST-			AL	LC
	Note: MOUNT CLOSER ON PUSH SIDE OF OPENING					
	Properties: Template #=2590					
2	Protection Plate	8400 24" x 34" 8402 (UL) B-CS TK-TX			US32D	IV
2	Protection Plate	8400 24" x 16" 8402 (UL) B-CS TK-TX			US32D	IV
4	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS				MISC
2	Electric Power Transfer	EPT 10 CON			SP28	VO
2	Power Supply Extension	CON-6W				SC
2	Wire Harness	CON-26P				SC
2	Power Supply	PS902 900-4RL FA				LO
2	Door Seal	488S-BK 21'				ZE
2	Auto Door Bottom	355AA 36"				ZE
2	Auto Door Bottom	355AA 18"				ZE

Note: OPERATION:

DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
INSIDE CARD READER WILL SHUNT SECURITY ALARM UPON EXIT.
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE).
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

LASER SAFETY SENSOR PACKAGE TO INTEGRATE WITH THE ROBOTIC TUGS AND KEEP THE DOORS OPEN AS THE TUGS

SAFETY SENSOR WILL PREVENT DOOR FROM OPENING IF THERE IS A PERSON OR OBJECT IN THE WAY, AND PREVENT

ONLY THE ACTIVE DOOR LEAF IS AUTOMATIC.

Heading #SSI2FGOXL1 (Set #SSI2FGOXL)

1	Pair Doors #**10.N1.01A**	N1	CORR. 10.E1.06 from NETWORK SUITE 1 10.N1.01			RHRA
1	Pair Doors #**10.N2.01D**	N2	CORR. 10.E2.03 from NETWORK SUITE 2 10.N2.02			LHRA
1	Pair Doors #**10.N3.01C**	N3	CORR. 10.E2.07 from NETWORK SUITE 3 10.N3.01			RHRA
1	Pair Doors #**10.N3.01D**	N3	CORR. 10.N3.11 from NETWORK SUITE 3 10.N3.01			LHRA
1	Pair Doors #**10.N4.01A**	N4	CORR. 10.N4.15 from NETWORK SUITE 4 10.N4.01			RHRA
1	Pair Doors #**10.N4.01B**	N4	CORR. 10.E1.08 from NETWORK SUITE 4 10.N4.01			LHRA
	Opening Description:	3' 0", 1' 6" x 8' 0" x 1 3/4" x HMD Type H x HMF Type A1 x 45 MIN				
6	Continuous Hinge	705 95"			630	IV
3	Continuous Hinge	705 95" EPT		LH	630	IV
3	Continuous Hinge	705 95" EPT		RH	630	IV
6	Flush Bolt Kit	FB52			US32D	IV
	Note: TOP BOLT ONLY W/FIRE PIN					
3	Exit Device	QEL 9475L-F x 940L 03 24VDC CON		LH	US26D	VO
3	Exit Device	QEL 9475L-F x 940L 03 24VDC CON		RH	US26D	VO
6	LFIC Core	32N2201			26	ME
6	Mortise Cylinder	20-061 50-231 ICX			626	SC
6	Coordinator	3780			US28	AB
6	SW200I single	SW200I SINGLE				MISC
6	Safety Flat Scan	10LZRFLATSCAN-SWW				MISC
6	Closer	4040XP SCUSH ST-			AL	LC
	Note: MOUNT CLOSER ON PUSH SIDE OF OPENING					
	Properties: Template #=2590					
6	Protection Plate	8400 24" x 34" 8402 (UL) B-CS TK-TX			US32D	IV
6	Protection Plate	8400 24" x 16" 8402 (UL) B-CS TK-TX			US32D	IV
12	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS				MISC
6	Electric Power Transfer	EPT 10 CON			SP28	VO
6	Power Supply Extension	CON-6W				SC
6	Wire Harness	CON-26P				SC
6	Power Supply	PS902 900-4RL FA				LO
6	Door Seal	488S-BK 20'				ZE
6	Auto Door Bottom	355AA 36"				ZE
6	Auto Door Bottom	355AA 18"				ZE

Heading #SSI2FGOXL1 (Set #SSI2FGOXL)

Note: OPERATION:

DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
INSIDE CARD READER WILL SHUNT SECURITY ALARM UPON EXIT.
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE).
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

LASER SAFETY SENSOR PACKAGE TO INTEGRATE WITH THE ROBOTIC TUGS AND KEEP THE DOORS OPEN AS THE TUGS

SAFETY SENSOR WILL PREVENT DOOR FROM OPENING IF THERE IS A PERSON OR OBJECT IN THE WAY, AND PREVENT

ONLY THE ACTIVE DOOR LEAF IS AUTOMATIC.

Heading #SSI2FGOXM (Set #SSI2FGOXM)

1	Pair Doors #**10.N1.01D**	N1	CORR. 10.E1.06 from NETWORK SUITE 1 10.N1.01			LHRA
1	Pair Doors #**10.N2.01A**	N2	CORR. 10.E2.03 from NETWORK SUITE 2 10.N2.02			RHRA
1	Pair Doors #**10.N3.01A**	N3	CORR. 10.N3.11 from NETWORK SUITE 3 10.N3.01			RHRA
1	Pair Doors #**10.N3.01B**	N3	CORR. 10.E2.07 from NETWORK SUITE 3 10.N3.01			LHRA
1	Pair Doors #**10.N4.01C**	N4	CORR. 10.E1.08 from NETWORK SUITE 4 10.N4.01			RHRA
1	Pair Doors #**10.N4.01D**	N4	CORR. 10.N4.15 from NETWORK SUITE 4 10.N4.01			LHRA
	Opening Description:	2 - 4' 0" x 9' 0" x 1 3/4" x HMD Type D x HMF Type A1 x 45 MIN				
6	Continuous Hinge	705 120" Custom Cut EPT		LH	630	IV
	Properties: Enter Length=107, EPT- Model/Location=TBD					
6	Continuous Hinge	705 120" Custom Cut EPT		RH	630	IV
	Properties: Enter Length=107, EPT- Model/Location=TBD					
3	Exit Device	QEL 9447L-F x 940L 03 48" CON ER-ADJ9.8-94 LBRAFL		RHR	US26D	VO
3	Exit Device	QEL 9447L-F x 940L 03 48" CON ER-ADJ9.8-94 LBRAFL		LHR	US26D	VO
6	Exit Device	QEL 9447EO-F 48" CON ER-ADJ9.8-94 LBRAFL			US26D	VO
6	LFIC Core	32N2201			26	ME
6	Mortise Cylinder	20-061 50-231 ICX			626	SC
6	Auto Operator	SW200I PAIR				MISC
12	Safety Flat Scan	10LZRFLATSCAN-SWW				MISC
12	Protection Plate	8400 24" x 46" 8402 (UL) B-CS TK-TX			US32D	IV
12	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS				MISC
12	Electric Power Transfer	EPT 10 CON			SP28	VO
12	Power Supply Extension	CON-6W				SC
12	Wire Harness	CON-50P				SC
6	Door Seal	488S-BK 18'				ZE
	Note: Applied to Jambs					
6	Door Seal	488S-BK 8'				ZE
	Note: @ FRAME HEAD (SHORTEST LENGTH AVAILABLE IS 8')					
6	Weatherstrip	328AA 108"				ZE
	Note: @ FRAME HINGE & LOCK JAMBS					
12	Auto Door Bottom	355AA 48"				ZE
6	Wire Harness	CON-26P				SC
6	Power Supply	PS902 900-4RL FA				LO

Heading #SSI2FGOXM (Set #SSI2FGOXM)

Note: NOTE:

1. COORDINATE FRAME WOTH DOOR POSITION SWITCH FOR IN-FRAME MOUNTING AT HEAD

OPERATION:

DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
INSIDE CARD READER WILL SHUNT SECURITY ALARM UPON EXIT.
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE).
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

LASER SAFETY SENSOR PACKAGE TO INTEGRATE WITH THE ROBOTIC TUGS AND KEEP THE DOORS OPEN AS THE TUGS

SAFETY SENSOR WILL PREVENT DOOR FROM OPENING IF THERE IS A PERSON OR OBJECT IN THE WAY, AND PREVENT

Heading #SSI2FGOXM1 (Set #SSI2FGOXM)

1	Pair Doors #**10.N1.01C**	N1	CORR. 10.N1.12 from NETWORK SUITE 1 10.N1.01		RHRA
1	Pair Doors #**10.N2.01B**	N2	CORR. 10.N2.12 from NETWORK SUITE 2 10.N2.02		LHRA
	Opening Description:	2 - 4' 0" x 9' 0" x 1 3/4" x HMD Type D x HMF Type A1 x 90 MIN			
2	Continuous Hinge	705 120" Custom Cut EPT	LH	630	IV
	Properties: Enter Length=107, EPT- Model/Location=TBD				
2	Continuous Hinge	705 120" Custom Cut EPT	RH	630	IV
	Properties: Enter Length=107, EPT- Model/Location=TBD				
1	Exit Device	QEL 9447L-F x 940L 03 48" CON ER-ADJ9.8-94 LBRAFL	RHR	US26D	VO
1	Exit Device	QEL 9447L-F x 940L 03 48" CON ER-ADJ9.8-94 LBRAFL	LHR	US26D	VO
2	Exit Device	QEL 9447EO-F 48" CON ER-ADJ9.8-94 LBRAFL		US26D	VO
2	LFIC Core	32N2201		26	ME
2	Mortise Cylinder	20-061 50-231 ICX		626	SC
2	Auto Operator	SW200I PAIR			MISC
4	Safety Flat Scan	10LZRFLATSCAN-SWW			MISC
4	Protection Plate	8400 24" x 46" 8402 (UL) B-CS TK-TX		US32D	IV
4	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
4	Electric Power Transfer	EPT 10 CON		SP28	VO
4	Power Supply Extension	CON-6W			SC
2	Wire Harness	CON-26P			SC
2	Door Seal	488S-BK 18'			ZE
	Note: Applied to Jambs				
2	Weatherstrip	328AA 108"			ZE
	Note: @ FRAME HINGE & LOCK JAMBS				
2	Door Seal	488S-BK 8'			ZE
	Note: @ FRAME HEAD (SHORTEST LENGTH AVAILABLE IS 8')				
4	Auto Door Bottom	355AA 48"			ZE
2	Power Supply	PS902 900-4RL FA			LO

Heading #SSI2FGOXM1 (Set #SSI2FGOXM)

Note: NOTE:

1. COORDINATE FRAME WOTH DOOR POSITION SWITCH FOR IN-FRAME MOUNTING AT HEAD

OPERATION:

DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
INSIDE CARD READER WILL SHUNT SECURITY ALARM UPON EXIT.
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE).
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

LASER SAFETY SENSOR PACKAGE TO INTEGRATE WITH THE ROBOTIC TUGS AND KEEP THE DOORS OPEN AS THE TUGS

SAFETY SENSOR WILL PREVENT DOOR FROM OPENING IF THERE IS A PERSON OR OBJECT IN THE WAY, AND PREVENT

Heading #SSI2GE1 (Set #SSI2GE1)

1	Pair Doors #**10.E1.05**	E1	CORR. 10.E1.03 from SPOKE TECH ROOM 10.E1.05		RHRA
1	Pair Doors #**10.S2.01F**	S2	SHIPPING & RECEIVING 10.S2.01 from CORR. 10.S2.12		RHRA
1	Pair Doors #**10.S2.07B**	S2	CORR. 10.S2.08 from INFRASTRUCTURE & FACS OPS STORAGE 10.S2.07		LHRA
1	Pair Doors #**10.S2.07C**	S2	CORR. 10.S2.08 from INFRASTRUCTURE & FACS OPS STORAGE 10.S2.07		RHRA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type D x HMF Type A1

4	Hinge	5BB1 HW TW8 CON 4 1/2" x 4 1/2"		652	IV
28	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP		652	IV
4	Flush Bolt Note: TOP BOLT ONLY	FB51T 36"		US32D	IV
3	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON	RHR	630	SC
1	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON	LHR	630	SC
4	LFIC Core	32N2201		26	ME
4	Coordinator	3780		US28	AB
8	Closer Note: PUSH SIDE MOUNTED	4040XP SCUSH		AL	LC
8	Protection Plate	8400 24" x 34" B-CS TK-TX		US32D	IV
8	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
4	Power Supply Extension	CON-6W			SC
4	Wire Harness	CON-38P			SC
4	Door Seal	488S-BK 25'			ZE
8	Weatherstrip	139A 108"			ZE
8	Auto Door Bottom	355AA 36"			ZE

Note: NOTE:

1. COORDINATE FRAME WOTH DOOR POSITION SWITCH FOR IN-FRAME MOUNTING AT HEAD

OPERATION:

DOOR IS NORMALLY CLOSED AND LOCKED
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
INSIDE CARD READER WILL SHUNT SECURITY ALARM UPON EXIT.
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE).
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SSI2GE1.1 (Set #SSI2GE1)

1	Pair Doors #**10.S2.01A**	S2	SHIPPING & RECEIVING 10.S2.01 to CORR. 10.S1.15	RHA
1	Pair Doors #**10.S2.07A**	S2	CORR. 10.S2.12 to INFRASTRUCTURE & FACS OPS STORAGE 10.S2.07	RHA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type D x HMF Type A1

Note:
VERIFY CLOSER - MODEL SPECIFIED IS MOUNTED ON THE PUSH SIDE OF THE DOOR

2	Hinge	5BB1 HW TW8 CON 4 1/2" x 4 1/2"		652	IV
14	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP		652	IV
2	Flush Bolt Note: TOP BOLT ONLY	FB51T 36"		US32D	IV
2	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON	RH	630	SC
2	LFIC Core	32N2201		26	ME
2	Coordinator	3780		US28	AB
4	Closer Note: PUSH SIDE MOUNTED	4040XP SCUSH		AL	LC
4	Protection Plate	8400 24" x 34" B-CS TK-TX		US32D	IV
4	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
2	Power Supply Extension	CON-6W			SC
2	Wire Harness	CON-38P			SC
2	Door Seal	488S-BK 25'			ZE
4	Weatherstrip	139A 108"			ZE
4	Auto Door Bottom	355AA 36"			ZE

Note: NOTE:

1. COORDINATE FRAME WOTH DOOR POSITION SWITCH FOR IN-FRAME MOUNTING AT HEAD

OPERATION:

DOOR IS NORMALLY CLOSED AND LOCKED
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
INSIDE CARD READER WILL SHUNT SECURITY ALARM UPON EXIT.
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE).
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SSI2GE2 (Set #SSI2GE2)

1	Pair Doors #**10.S2.05A**	S2	CORR. 10.S2.12 to HIGH VALUE STORAGE 10.S2.05	90°	RHA
1	Pair Doors #**10.S2.06A**	S2	CORR. 10.S2.12 to SITE OPS & ENS STORAGE 10.S2.06	90°	RHA

Opening Description: 2 - 4' 0" x 9' 0" x 1 3/4" x HMD Type D x HMF Type A1

14	Hinges	5BB1 HW 5 x 4 1/2		652	IV
2	Hinge	5BB1 HW TW8 CON 5" x 4 1/2"		652	IV
2	Flush Bolt	FB51T 36"		US32D	IV
	Note: TOP BOLT ONLY				
2	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON	RH	630	SC
2	LFIC Core	32N2201		26	ME
2	Coordinator	3780		US28	AB
4	Closer	4040XP RWPA ST-		AL	LC
	Note: CLOSER MOUNTED PULL SIDE				
	Properties: Template #=1630				
4	Adapter Plate	4040XP-18TJ		AL	LC
4	Overhead Stop	106S		US32D	GL
4	Protection Plate	8400 24" x 46" B-CS TK-TX		US32D	IV
4	DOOR POSITION SWITCH	DPS BY OTHERS			MISC
2	Power Supply Extension	CON-6W			SC
2	Wire Harness	CON-50P			SC
2	Door Seal	488S-BK 18'			ZE
4	Weatherstrip	328AA 108"			ZE
	Note: @ FRAME HINGE & LOCK JAMBS				
2	Door Seal	488S-BK 8'			ZE
	Note: @ FRAME HEAD (SHORTEST LENGTH AVAILABLE IS 8')				
4	Auto Door Bottom	355AA 48"			ZE

Note: NOTE:

1. COORDINATE FRAME WOTH DOOR POSITION SWITCH FOR IN-FRAME MOUNTING AT HEAD

OPERATION:

DOOR IS NORMALLY CLOSED AND LOCKED
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
INSIDE CARD READER WILL SHUNT SECURITY ALARM UPON EXIT.
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE).
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SSI2GE2.1 (Set #SSI2GE2)

1	Pair Doors #**10.S1.18**	S1	CORR. 10.S1.15 to ERAD 10.S1.18	90°	RHA
1	Pair Doors #**10.S1.19**	S1	CORR. 10.S1.15 to NETWORK INFRSTRUCTURE WORKRM 10.S1.19	90°	RHA
1	Pair Doors #**10.S2.03**	S2	SHIPPING & RECEIVING 10.S2.01 to SHIPPING & RECEIVING STORAGE 10.S2.03	90°	RHA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type D x HMF Type A1

21	Hinges	5BB1 HW 4 1/2 x 4 1/2		652	IV
3	Hinge	5BB1 HW TW8 CON 4 1/2" x 4 1/2"		652	IV
3	Flush Bolt	FB51T 36"		US32D	IV
	Note: TOP BOLT ONLY				
3	Electrified Mortise Lockset	L9092 EU T 03N 50-231 CON	RH	630	SC
3	LFIC Core	32N2201		26	ME
3	Coordinator	3780		US28	AB
6	Closer	4040XP RWPA ST-		AL	LC
	Note: CLOSER MOUNTED PULL SIDE				
	Properties: Template #=1630				
6	Adapter Plate	4040XP-18TJ		AL	LC
6	Overhead Stop	104S		US32D	GL
6	Protection Plate	8400 24" x 34" B-CS TK-TX		US32D	IV
6	DOOR POSITION SWITCH	DPS BY OTHERS			MISC
3	Power Supply Extension	CON-6W			SC
3	Wire Harness	CON-38P			SC
3	Door Seal	488S-BK 25'			ZE
6	Weatherstrip	328AA 108"			ZE
	Note: @ FRAME HINGE & LOCK JAMBS				
6	Auto Door Bottom	355AA 36"			ZE

Note: NOTE:

1. COORDINATE FRAME WOTH DOOR POSITION SWITCH FOR IN-FRAME MOUNTING AT HEAD

OPERATION:

DOOR IS NORMALLY CLOSED AND LOCKED
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
INSIDE CARD READER WILL SHUNT SECURITY ALARM UPON EXIT.
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE).
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Heading #SSI2GOXL (Set #SSI2GOXL)

1	Pair Doors #**10.E1.01A**	E1	CORR. 10.E1.08 from ENTRY FIBER 1 10.E1.01			RHRA
1	Pair Doors #**10.E1.01B**	E1	CORR. 10.E1.06 from ENTRY FIBER 1 10.E1.01			LHRA
1	Pair Doors #**10.E2.01C**	E2	CORR. 10.E2.03 from ENTRY FIBER 2 10.E2.01			RHRA
1	Pair Doors #**10.E2.01D**	E2	CORR. 10.E2.07 from ENTRY FIBER 2 10.E2.01			LHRA
	Opening Description:	3' 0", 1' 6" x 8' 0" x 1 3/4" x HMD Type H x HMF Type A1				
4	Continuous Hinge	705 95"			630	IV
2	Continuous Hinge	705 95" EPT		LH	630	IV
2	Continuous Hinge	705 95" EPT		RH	630	IV
4	Flush Bolt	FB51T 24"			US32D	IV
2	Exit Device	QEL 9475L x 940L 03 24VDC CON		LH	US26D	VO
2	Exit Device	QEL 9475L x 940L 03 24VDC CON		RH	US26D	VO
4	LFIC Core	32N2201			26	ME
4	Mortise Cylinder	20-061 50-231 ICX			626	SC
4	Besam Auto Operator - Sgl.	SW200I - SGL			689	MISC
4	Coordinator	3780			US28	AB
4	Safety Flat Scan	10LZRFLATSCAN-SWW				MISC
4	Closer	4040XP SCUSH ST-			AL	LC
	Note: MOUNT CLOSER ON PUSH SIDE OF OPENING					
	Properties: Template #=2590					
4	Protection Plate	8400 24" x 16" B-CS TK-TX			US32D	IV
4	Protection Plate	8400 24" x 34" B-CS TK-TX			US32D	IV
8	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS				MISC
4	Electric Power Transfer	EPT 10 CON			SP28	VO
4	Power Supply Extension	CON-6W				SC
4	Wire Harness	CON-26P				SC
4	Door Seal	488S-BK 21'				ZE
4	Auto Door Bottom	355AA 36"				ZE
4	Auto Door Bottom	355AA 18"				ZE
4	Power Supply	PS902 900-4RL FA				LO

Heading #SSI2GOXL (Set #SSI2GOXL)

Note: NOTE:

1. COORDINATE FRAME WOTH DOOR POSITION SWITCH FOR IN-FRAME MOUNTING AT HEAD

OPERATION:

DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
INSIDE CARD READER WILL SHUNT SECURITY ALARM UPON EXIT.
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE).
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

LASER SAFETY SENSOR PACKAGE TO INTEGRATE WITH THE ROBOTIC TUGS AND KEEP THE DOORS OPEN AS THE TUGS

SAFETY SENSOR WILL PREVENT DOOR FROM OPENING IF THERE IS A PERSON OR OBJECT IN THE WAY, AND PREVENT

Heading #SSI2GOXM (Set #SSI2GOXM)

1	Pair Doors #**10.E1.01C**	E1	CORR. 10.E1.06 from ENTRY FIBER 1 10.E1.01	RHRA
1	Pair Doors #**10.E1.01D**	E1	CORR. 10.E1.08 from ENTRY FIBER 1 10.E1.01	RHRA
1	Pair Doors #**10.E2.01A**	E2	CORR. 10.E2.07 from ENTRY FIBER 2 10.E2.01	RHRA
1	Pair Doors #**10.E2.01B**	E2	CORR. 10.E2.03 from ENTRY FIBER 2 10.E2.01	RHRA
1	Pair Doors #**10.S2.01G**	S2	CORR. 10.N2.12 from SHIPPING & RECEIVING 10.S2.01	RHRA
1	Pair Doors #**10.S2.01H**	S2	CORR. 10.N1.12 from SHIPPING & RECEIVING 10.S2.01	RHRA

Opening Description: 2 - 4' 0" x 9' 0" x 1 3/4" x HMD Type D x HMF Type A1

Note: OPENINGS 10.S2.01H, 10.S2.01G:DIRECTION OF SWING MAY CONFLICT WITH SECURE SIDE CARD READER LOCATION

6	Continuous Hinge Properties: Enter Length=107, EPT- Model/Location=TBD	705 120" Custom Cut EPT	LH	630	IV
6	Continuous Hinge Properties: Enter Length=107, EPT- Model/Location=TBD	705 120" Custom Cut EPT	RH	630	IV
6	Exit Device	QEL 9447EO 48" CON ER-ADJ9.8-94 LBR		US26D	VO
6	Exit Device	QEL 9447L x 940L 03 48" CON ER-ADJ9.8-94 LBR	RHR	US26D	VO
6	LFIC Core	32N2201		26	ME
6	Mortise Cylinder	20-061 50-231 ICX		626	SC
6	Besam Auto Operator	SW200I - DBL	LH	689	MISC
12	Safety Flat Scan	10LZRFLATSCAN-SWW			MISC
12	Protection Plate	8400 24" x 46" B-CS TK-TX		US32D	IV
12	DOOR POSITION SWITCH(By Others)	DPS BY OTHERS			MISC
12	Electric Power Transfer	EPT 10 CON		SP28	VO
12	Power Supply Extension	CON-6W			SC
6	Door Seal Note: Applied to Jambs	488S-BK 18'			ZE
6	Door Seal Note: @ FRAME HEAD (SHORTEST LENGTH AVAILABLE IS 8')	488S-BK 8'			ZE
12	Auto Door Bottom	355AA 48"			ZE
6	Wire Harness	CON-26P			SC
6	Power Supply	PS902 900-4RL FA			LO

Heading #SSI2GOXM (Set #SSI2GOXM)

Note: NOTE:

1. COORDINATE FRAME WOTH DOOR POSITION SWITCH FOR IN-FRAME MOUNTING AT HEAD

OPERATION:

DOOR IS NORMALLY CLOSED AND LOCKED.
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
INSIDE CARD READER WILL SHUNT SECURITY ALARM UPON EXIT.
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE).
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

LASER SAFETY SENSOR PACKAGE TO INTEGRATE WITH THE ROBOTIC TUGS AND KEEP THE DOORS OPEN AS THE TUGS

SAFETY SENSOR WILL PREVENT DOOR FROM OPENING IF THERE IS A PERSON OR OBJECT IN THE WAY, AND PREVENT

Heading #SSI2GXM (Set #SSI2GXM)

1	Pair Doors #**10.S2.09A**	S2	CORR. 10.S2.08 from SSB ELECTRICAL ROOM 10.S2.09		LHRA
	Opening Description:	2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type B x HMF Type A1			
2	Hinge	5BB1 HW TW8 CON 4 1/2" x 4 1/2"		652	IV
6	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP		652	IV
1	Exit Device	LD 9847L x M996L-BE-M 03 CON ER-ADJ9.8-94 FSE LBR	LHR	US32D	VO
1	Exit Device	LD RX 9847EO ER-ADJ9.8-94 LBR		US32D	VO
1	LFIC Core	32N2201		26	ME
1	Rim Cylinder	20-057 50-231 ICX		630	SC
2	Closer	4040XP SCUSH		AL	LC
	Note: PUSH SIDE MOUNTED				
2	Protection Plate	8400 24" x 34" B-CS TK-TX		US32D	IV
2	DOOR POSITION SWITCH	DPS BY OTHERS			MISC
2	Power Supply Extension	CON-6W			SC
2	Wire Harness	CON-38P			SC
1	Power Supply	PS902 900-4RL FA			LO
1	Door Seal	488S-BK 25'			ZE
2	Weatherstrip	139A 108"			ZE
2	Auto Door Bottom	355AA 36"			ZE

Note: NOTE:

1. COORDINATE FRAME WOTH DOOR POSITION SWITCH FOR IN-FRAME MOUNTING AT HEAD

OPERATION:

DOOR IS NORMALLY CLOSED AND LOCKED
OUTSIDE CARD READER WILL UNLOCK DOOR FOR ENTRY.
INSIDE CARD READER WILL SHUNT SECURITY ALARM UPON EXIT.
OUTSIDE OF DOOR REMAINS LOCKED IN A POWER FAILURE (FAIL SECURE).
FREE EGRESS ALWAYS PERMITTED, ALARM WILL SOUND IF INSIDE CARD READER IS BYPASSED.
COORDINATE WITH ACCESS CONTROL DRAWINGS AND SPECIFICATIONS.

Legend

Description	Quantity	Unit
Count Measurement	46	Count