Himmel's Architectural Door & Hardware, LLC - NA
12021 Volunteer Blvd., Mt. Juliet, TN 37122
Tel: 615-622-5777

MCA1-2- META Data Center
303872

SCHEDULE OF
FINISHED HARDWARE

DATE	April 12, 2024
ARCHITECT	
CONTRACTOR	DPR Construction - PA
DETAILED BY	Jonathan Trumps

Opening List

DCB1

Opening	Hdw Set	Hdw Heading	Opening Label	Door Type	Frame Type
1.01.A.01A	I1AO-2B	I1AO-2B		HM-N1	HM-F1
1.01.A.01B	I2AO-2B	I2AO-2B		HM-N2	HM-F1
1.01.A.01C	I2AO-2A	I2AO-2A	90Min	HM-N2	HM-F1
1.01.A.01D	I1AO-2A	I1AO-2A	90Min	HM-N1	HM-F1
1.01.A.02A	I2S-7A	I2S-7A	45Min	HM-N2	HM-F1
1.01.A.02B	I2S-7A	I2S-7A:1	90Min	HM-N2	HM-F1
1.01.A.03A	I2S-1E	I2S-1E:WA		HM-N2	HM-F1
1.01.A.03B	I2S-1E	I2S-1E:1WI	90Min	HM-N2	HM-F1
1.01.A.06A	I2S-1E	I2S-1E		HM-N2	HM-F1
1.01.A.06B	I2S-1E	I2S-1E:1	90Min	HM-N2	HM-F1
1.01.A.07	I2S-5C	I2S-5C:1		HM-N1	HM-F1
1.01.A.08	I1S-2D	I1S-2D		HM-F	HM-F1
1.01.A.09	I1S-2D	I1S-2D		HM-F	HM-F1
1.01.A.10	I1S-5B	I1S-5B		HM-F	HM-F1
1.01.A.11	I1S-5C	I1S-5C:2		HM-N1	HM-F1
1.01.A.13	I1S-5C	I1S-5C:2		HM-N1	HM-F1
1.01.A.12	E1S-3A	E1S-3A		HM-F	HM-F1
1.01.A.15	I2NS-2A	I2NS-2A:1	90Min	HM-N2	HM-F1
1.01.B.01A	I2AO-2B	I2AO-2B		HM-N2	HM-F1
1.01.B.01B	I1AO-2B	I1AO-2B		HM-N1	HM-F1
1.01.B.01C	I1AO-2A	I1AO-2A	90Min	HM-N1	HM-F1
1.01.B.01D	I2AO-2A	I2AO-2A	90Min	HM-N2	HM-F1
1.01.B.02A	I2S-7A	I2S-7A	45Min	HM-N2	HM-F1
1.01.B.02B	I2S-7A	I2S-7A:1	90Min	HM-N2	HM-F1
1.01.B.03A	I2S-1E	I2S-1E:WI		HM-N2	HM-F1
1.01.B.03B	I2S-1E	I2S-1E:1WA	90Min	HM-N2	HM-F1
1.01.B.06A	I2S-1E	I2S-1E		HM-N2	HM-F1
1.01.B.06B	I2S-1E	I2S-1E:1	90Min	HM-N2	HM-F1
1.01.B.07	I1S-5C	I1S-5C:2		HM-N1	HM-F1
1.01.B.08	I1S-2D	I1S-2D:3		HM-F	HM-F1
1.01.B.09	I1S-2D	I1S-2D		HM-F	HM-F1
1.01.B.10	I1S-5C	I1S-5C:1		HM-F	HM-F1
1.01.B.11	I1S-5C	I1S-5C:2		HM-N1	HM-F1
1.01.B.12	E1S-3A	E1S-3A		HM-F	HM-F1
1.01.B.13	I1S-5C	I1S-5C:2		HM-N1	HM-F1
1.01.B.14	I1NS-2A	I1NS-2A		HM-F	HM-F1
1.01.B.16	I1S-5C	I1S-5C:2		HM-N1	HM-F1
1.01.C.01A	I1AO-2B	I1AO-2B		HM-N1	HM-F1
1.01.C.01B	I2AO-2B	I2AO-2B		HM-N2	HM-F1
1.01.C.01C	I2AO-2B	I2AO-2B		HM-N2	HM-F1
1.01.C.01D	I1AO-2B	I1AO-2B		HM-N1	HM-F1
1.01.C.02A	I2S-7A	I2S-7A	45Min	HM-N2	HM-F1
1.01.C.02B	I2S-7A	I2S-7A	45Min	HM-N2	HM-F1
1.01.C.03A	I2S-1E	I2S-1E:WA		HM-N2	HM-F1

Opening	Hdw Set	Hdw Heading	Opening Label	Door Type	Frame Type
1.01.C.03B	I2S-1E	I2S-1E:WI		HM-N2	HM-F1
1.01.C.06A	I2S-1E	I2S-1E		HM-N2	HM-F1
1.01.C.06B	I2S-1E	I2S-1E		HM-N2	HM-F1
1.01.C.07	I2S-4B	I2S-4B:3	90Min	HM-F	HM-F1
1.01.C.08	I2S-4B	I2S-4B:3	90Min	HM-F	HM-F1
1.01.C.09	I2S-5A	I2S-5A:1		HM-N2	HM-F1
1.01.C.10	I1S-5C	I1S-5C:2		HM-N1	HM-F1
1.01.C.11	I1S-5B	I1S-5B		HM-F	HM-F1
1.01.C.12	I1S-2D	I1S-2D		HM-F	HM-F1
1.01.C.13	I1S-5D	I1S-5D	90Min	HM-F	HM-F1
1.01.C.14	I1S-5C	I1S-5C:2		HM-N1	HM-F1
1.01.C.15	E1S-3A	E1S-3A		HM-F	HM-F1
1.01.C.16	E1S-3A	E1S-3A		HM-F	HM-F1
1.01.C.17	E1NS-1A	E1NS-1A		HM-F	HM-F1
1.01.D.01A	I2AO-2B	I2AO-2B		HM-N2	HM-F1
1.01.D.01B	I1AO-2B	I1AO-2B		HM-N1	HM-F1
1.01.D.01C	I1AO-2B	I1AO-2B		HM-N1	HM-F1
1.01.D.01D	I2AO-2B	I2AO-2B		HM-N2	HM-F1
1.01.D.02A	I2S-7A	I2S-7A	45Min	HM-N2	HM-F1
1.01.D.02B	I2S-7A	I2S-7A	45Min	HM-N2	HM-F1
1.01.D.03A	I2S-1E	I2S-1E:WI		HM-N2	HM-F1
1.01.D.03B	I2S-1E	I2S-1E:WA		HM-N2	HM-F1
1.01.D.06A	I2S-1E	I2S-1E		HM-N2	HM-F1
1.01.D.06B	I2S-1E	I2S-1E		HM-N2	HM-F1
1.01.D.07	I1S-5D	I1S-5D	90Min	HM-F	HM-F1
1.01.D.08	I2S-4B	I2S-4B:3	90Min	HM-F	HM-F1
1.01.D.09	I2S-4B	I2S-4B:3	90Min	HM-F	HM-F1
1.01.D.10	I1S-5B	I1S-5B		HM-F	HM-F1
1.01.D.11	I1S-5C	I1S-5C:2		HM-N1	HM-F1
1.01.D.12	I1S-2D	I1S-2D		HM-F	HM-F1
1.01.D.13	I1NS-2A	I1NS-2A		HM-F	HM-F1
1.01.D.14	I1S-5B	I1S-5B		HM-F	HM-F1
1.01.D.15	I1S-5C	I1S-5C:2		HM-N1	HM-F1
1.01.D.16	I1S-2C	I1S-2C		HM-F	HM-F1
1.01.D.17	E1S-3A	E1S-3A		HM-F	HM-F1
1.01.D.18	E1NS-1A	E1NS-1A		HM-F	HM-F1
1.01.E.02	I2S-4B	I2S-4B:5		HM-F	HM-F1
1.01.E.03	I1S-5C	I1S-5C:1		HM-N1	HM-F1
1.01.E.04	I2S-1C	I2S-1C		HM-F	HM-F1
1.01.E.05	IS1-7C	IS1-7C:1	90Min	HM-F	HM-F1
1.01.E.06	I1S-5D	I1S-5D:1	90Min	HM-F	HM-F1
1.01.E.07	I1S-2D	I1S-2D:1		WD-F	HM-F1
1.01.E.08	I1NS-3D	I1NS-3D		WD-FG	HM-F1
1.01.E.09	I1NS-3D	I1NS-3D		WD-FG	HM-F1
1.01.E.10	I1NS-3D	I1NS-3D:1		WD-FG	HM-F1
1.01.E.11	I2NS-1B	I2NS-1B:1		WD-FG	HM-F1
1.01.E.12	I1NS-3D	I1NS-3D		WD-FG	HM-F1
1.01.E.13	I1NS-3D	I1NS-3D		WD-FG	HM-F1
1.01.E.15	I1NS-3D	I1NS-3D		WD-FG	HM-F1

Opening	Hdw Set	Hdw Heading	Opening Label	Door Type	Frame Type
1.01.E.16	I1NS-3D	I1NS-3D		WD-FG	HM-F1
1.01.E.17	I2S-5B	I2S-5B:1		HM-F	HM-F1
1.01.E.18	I2S-5B	I2S-5B:1		HM-F	HM-F1
1.01.E.19A	I1S-6C	I1S-6C		HM-F	HM-F1
1.01.E.19B	I2S-5C	I2S-5C:3		HM-F	HM-F1
1.01.E.19C	I1S-6C	I1S-6C		HM-F	HM-F1
1.01.E.20	I2S-1C	I2S-1C:1	45Min	HM-F	HM-F1
1.01.E.21	I1S-2D	I1S-2D:1		WD-F	HM-F1
1.01.E.22	I1NS-9A	I1NS-9A		WD-F	HM-F1
1.01.E.23	I1S-2B	I1S-2B		HM-F	HM-F1
1.01.E.24	I1NS-2A	I1NS-2A		WD-F	HM-F1
1.01.E.25A	I1NS-6C	I1NS-6C:1	90Min	HM-F-361	HM-F1-361
1.01.E.25B	I1NS-6C	I1NS-6C:1	90Min	HM-F-361	HM-F1-361
1.01.E.26	I1S-5B	I1S-5B		HM-F	HM-F1
1.01.E.29	I1NS-6A	I1NS-6A		HM-F	HM-F1
1.01.E.30	I2AO-1A	I2AO-1A		HM-N2	HM-F1
1.01.F.02	I2S-4B	I2S-4B:5		HM-F	HM-F1
1.01.F.03	I1S-5B	I1S-5B		HM-N1	HM-F1
1.01.F.04	I2S-1C	I2S-1C		HM-F	HM-F1
1.01.F.05A	I2S-5A	I2S-5A:2		HM-N2	HM-F1
1.01.F.05B	I2S-4B	I2S-4B:1WI		HM-N2	HM-F1
1.01.F.05C	E2S-1A	E2S-1A		HM-F	HM-F1
1.01.F.05D	I1S-1A	I1S-1A		OH	OH
1.01.F.05E	I1S-1A	I1S-1A		OH	OH
1.01.F.05F	I1S-1A	I1S-1A		OH	OH
1.01.F.05G	I2AO-2B	I2AO-2B		HM-N2	HM-F1
1.01.F.06	I2S-2D	I2S-2D		HM-N2	HM-F1
1.01.F.07	I2S-1C	I2S-1C:1	45Min	HM-F	HM-F1
1.01.F.08	I1S-2F	I1S-2F		WD-F	HM-F1
1.01.F.09	I1NS-9A	I1NS-9A		WD-F	HM-F1
1.01.F.10	I1S-4A.AL1	I1S-4A.AL1		AL	AL
1.01.F.11A	E1S-1A.AL	E1S-1A.AL		AL	AL
1.01.F.11B	I1NS-7B.AL	I1NS-7B.AL		AL	AL
1.01.F.13	I1S-2D	I1S-2D:1		WD-F	HM-F1
1.01.F.14	I2S-5A	I2S-5A:1		HM-F	HM-F1
1.01.F.15	I2S-2A	I2S-2A		HM-F	HM-F1
1.01.F.16	I1S-2D	I1S-2D		HM-F	HM-F1
1.01.F.17	I2S-5A	I2S-5A:1		HM-F	HM-F1
1.01.F.18	I1S-3B	I1S-3B		HM-F	HM-F1
1.01.F.19	I1NS-2A	I1NS-2A		HM-F	HM-F1
1.01.F.20A	E1S-1A	E1S-1A		HM-F	HM-F1
1.01.F.20B	I1S-7C	I1S-7C		HM-F	HM-F1
1.01.F.21	I1S-2D	I1S-2D		HM-N1	HM-F1
1.01.N.01A	I1AO-2B	I1AO-2B		HM-N1	HM-F1
1.01.N.01B	I2AO-2B	I2AO-2B		HM-N2	HM-F1
1.01.N.01C	I2AO-2B	I2AO-2B		HM-N2	HM-F1
1.01.N.05A	I2S-7A	I2S-7A:1	90Min	HM-N2	HM-F1
1.01.N.05B	E1S-3A	E1S-3A		HM-F	HM-F1
1.01.N.05C	I1NS-3B	I1NS-3B	90Min	HM-N1	HM-F1

Opening	Hdw Set	Hdw Heading	Opening Label	Door Type	Frame Type
1.01.N.06A	I2S-1E	I2S-1E:WA		HM-N2	HM-F1
1.01.N.06B	I1NS-3F	I1NS-3F		HM-F	HM-F1
1.01.N.07A	I2S-1E	I2S-1E		HM-N2	HM-F1
1.01.N.07B	I1NS-3C	I1NS-3C		HM-F	HM-F1
1.01.N.21	I1S-5B	I1S-5B		HM-F	HM-F1
1.01.N.22	I1NS-2A	I1NS-2A		HM-F	HM-F1
1.01.N.23	I2S-4B	I2S-4B:3	90Min	HM-F	HM-F1
1.01.N.20	E1NS-1A	E1NS-1A		HM-F	HM-F1
1.01.N.26	E1S-3A	E1S-3A		HM-F	HM-F1
1.01.N.02A	I2AO-2B	I2AO-2B		HM-N2	HM-F1
1.01.N.02B	I1AO-2B	I1AO-2B		HM-N1	HM-F1
1.01.N.02C	I2AO-2B	I2AO-2B		HM-N2	HM-F1
1.01.N.08A	I2S-7A	I2S-7A:1	90Min	HM-N2	HM-F1
1.01.N.08B	E1S-3A	E1S-3A		HM-F	HM-F1
1.01.N.08C	I1NS-3B	I1NS-3B	90Min	HM-N1	HM-F1
1.01.N.09A	I2S-1E	I2S-1E:WI		HM-N2	HM-F1
1.01.N.09B	I1NS-3F	I1NS-3F		HM-F	HM-F1
1.01.N.10A	I2S-1E	I2S-1E		HM-N2	HM-F1
1.01.N.10B	I1NS-3C	I1NS-3C		HM-F	HM-F1
1.01.N.28	I2S-4B	I2S-4B:3	90Min	HM-F	HM-F1
1.01.N.29	I1NS-2A	I1NS-2A		HM-F	HM-F1
1.01.N.30	I1S-2F	I1S-2F:1		HM-F	HM-F1
1.01.N.31	I1S-5B	I1S-5B		HM-F	HM-F1
1.01.N.03A	I1AO-2B	I1AO-2B		HM-N1	HM-F1
1.01.N.03B	I2AO-2B	I2AO-2B		HM-N2	HM-F1
1.01.N.11A	E1S-3A	E1S-3A		HM-F	HM-F1
1.01.N.11B	I2S-7A	I2S-7A:1	90Min	HM-N2	HM-F1
1.01.N.12	I2S-1E	I2S-1E:WA		HM-N2	HM-F1
1.01.N.13	I2S-1E	I2S-1E		HM-N2	HM-F1
1.01.N.34	I2S-4B	I2S-4B:3	90Min	HM-F	HM-F1
1.01.N.33	I2S-4B	I2S-4B:3	90Min	HM-F	HM-F1
1.01.N.32	I2S-5A	I2S-5A		HM-F	HM-F1
1.01.N.04A	I2AO-2B	I2AO-2B		HM-N2	HM-F1
1.01.N.04B	I1AO-2B	I1AO-2B		HM-N1	HM-F1
1.01.N.14A	I2S-7A	I2S-7A:1	90Min	HM-N2	HM-F1
1.01.N.14B	E1S-3A	E1S-3A		HM-F	HM-F1
1.01.N.15	I2S-1E	I2S-1E:WI		HM-N2	HM-F1
1.01.N.16	I2S-1E	I2S-1E		HM-N2	HM-F1
1.01.N.19	I2S-5A	I2S-5A		HM-F	HM-F1
1.01.N.18	I2S-4B	I2S-4B:3	90Min	HM-F	HM-F1
1.01.N.17	I2S-4B	I2S-4B:3	90Min	HM-F	HM-F1

DCB2

Opening	Hdw Set	Hdw Heading	Opening Label	Door Type	Frame Type
2.01.A.01A	I1AO-2B	I1AO-2B		HM-N1	HM-F1
2.01.A.01B	I2AO-2B	I2AO-2B		HM-N2	HM-F1
2.01.A.01C	I2AO-2A	I2AO-2A	90Min	HM-N2	HM-F1
2.01.A.01D	I1AO-2A	I1AO-2A	90Min	HM-N1	HM-F1

Opening	Hdw Set	Hdw Heading	Opening Label	Door Type	Frame Type
2.01.A.02A	I2S-7A	I2S-7A	45Min	HM-N2	HM-F1
2.01.A.02B	I2S-7A	I2S-7A:1	90Min	HM-N2	HM-F1
2.01.A.03A	I2S-1E	I2S-1E:WA		HM-N2	HM-F1
2.01.A.03B	I2S-1E	I2S-1E:1WI	90Min	HM-N2	HM-F1
2.01.A.06A	I2S-1E	I2S-1E		HM-N2	HM-F1
2.01.A.06B	I2S-1E	I2S-1E:1	90Min	HM-N2	HM-F1
2.01.A.07	I2S-5C	I2S-5C		HM-N1	HM-F1
2.01.A.08	I1S-2D	I1S-2D		HM-F	HM-F1
2.01.A.09	I1S-5B	I1S-5B		HM-F	HM-F1
2.01.A.10	I1S-5C	I1S-5C:1		HM-N1	HM-F1
2.01.A.11	I1S-5C	I1S-5C:1		HM-N1	HM-F1
2.01.A.13A	E1S-3A	E1S-3A		HM-F	HM-F1
2.01.A.13B	E1S-3A	E1S-3A		HM-F	HM-F1
2.01.A.14	I2NS-2A	I2NS-2A	90Min	HM-N2	HM-F1
2.01.B.01A	I2AO-2B	I2AO-2B		HM-N2	HM-F1
2.01.B.01B	I1AO-2B	I1AO-2B		HM-N1	HM-F1
2.01.B.01C	I1AO-2A	I1AO-2A	90Min	HM-N1	HM-F1
2.01.B.01D	I2AO-2A	I2AO-2A	90Min	HM-N2	HM-F1
2.01.B.02A	I2S-7A	I2S-7A	45Min	HM-N2	HM-F1
2.01.B.02B	I2S-7A	I2S-7A:1	90Min	HM-N2	HM-F1
2.01.B.03A	I2S-1E	I2S-1E:WI		HM-N2	HM-F1
2.01.B.03B	I2S-1E	I2S-1E:1WA	90Min	HM-N2	HM-F1
2.01.B.06A	I2S-1E	I2S-1E		HM-N2	HM-F1
2.01.B.06B	I2S-1E	I2S-1E:1	90Min	HM-N2	HM-F1
2.01.B.07	I1S-5C	I1S-5C		HM-N1	HM-F1
2.01.B.08	I1S-5C	I1S-5C:1		HM-F	HM-F1
2.01.B.09	I1S-2D	I1S-2D		HM-F	HM-F1
2.01.B.10	I1S-5C	I1S-5C:1		HM-N1	HM-F1
2.01.B.11	I1S-5C	I1S-5C:1		HM-N1	HM-F1
2.01.B.13	I1NS-2A	I1NS-2A		HM-F	HM-F1
2.01.B.14	I1S-5C	I1S-5C:1		HM-N1	HM-F1
2.01.C.01A	I1AO-2B	I1AO-2B		HM-N1	HM-F1
2.01.C.01B	I2AO-2B	I2AO-2B		HM-N2	HM-F1
2.01.C.01C	I2AO-2B	I2AO-2B		HM-N2	HM-F1
2.01.C.01D	I1AO-2B	I1AO-2B		HM-N1	HM-F1
2.01.C.02A	I2S-7A	I2S-7A	45Min	HM-N2	HM-F1
2.01.C.02B	I2S-7A	I2S-7A	45Min	HM-N2	HM-F1
2.01.C.03A	I2S-1E	I2S-1E:WA		HM-N2	HM-F1
2.01.C.03B	I2S-1E	I2S-1E:WI		HM-N2	HM-F1
2.01.C.06A	I2S-1E	I2S-1E		HM-N2	HM-F1
2.01.C.06B	I2S-1E	I2S-1E		HM-N2	HM-F1
2.01.C.07	I2S-4B	I2S-4B:4	90Min	HM-F	HM-F1
2.01.C.08	I2S-4B	I2S-4B:4	90Min	HM-F	HM-F1
2.01.C.09	I2S-5A	I2S-5A:1		HM-N2	HM-F1
2.01.C.10	I1S-5C	I1S-5C:1		HM-N1	HM-F1
2.01.C.11	I1S-5B	I1S-5B		HM-F	HM-F1
2.01.C.12	I1S-2D	I1S-2D		HM-F	HM-F1
2.01.C.13	I1S-5D	I1S-5D	90Min	HM-F	HM-F1
2.01.C.14	I1S-5C	I1S-5C:1		HM-N1	HM-F1

Opening	Hdw Set	Hdw Heading	Opening Label	Door Type	Frame Type
2.01.C.15A	E1S-3A	E1S-3A		HM-F	HM-F1
2.01.C.15B	E1S-3A	E1S-3A		HM-F	HM-F1
2.01.C.17A	E1NS-1A	E1NS-1A		HM-F	HM-F1
2.01.C.17B	E1S-3A	E1S-3A		HM-F	HM-F1
2.01.C.17C	E1NS-1A	E1NS-1A		HM-F	HM-F1
2.01.D.01A	I2AO-2B	I2AO-2B		HM-N2	HM-F1
2.01.D.01B	I1AO-2B	I1AO-2B		HM-N1	HM-F1
2.01.D.01C	I1AO-2B	I1AO-2B		HM-N1	HM-F1
2.01.D.01D	I2AO-2B	I2AO-2B		HM-N2	HM-F1
2.01.D.02A	I2S-7A	I2S-7A	45Min	HM-N2	HM-F1
2.01.D.02B	I2S-7A	I2S-7A	45Min	HM-N2	HM-F1
2.01.D.03A	I2S-1E	I2S-1E:WI		HM-N2	HM-F1
2.01.D.03B	I2S-1E	I2S-1E:WA		HM-N2	HM-F1
2.01.D.06A	I2S-1E	I2S-1E		HM-N2	HM-F1
2.01.D.06B	I2S-1E	I2S-1E		HM-N2	HM-F1
2.01.D.07	I1S-5D	I1S-5D	90Min	HM-F	HM-F1
2.01.D.08	I2S-4B	I2S-4B:3	90Min	HM-F	HM-F1
2.01.D.09	I2S-4B	I2S-4B:3	90Min	HM-F	HM-F1
2.01.D.10	I1S-5B	I1S-5B:1		HM-F	HM-F1
2.01.D.11	I1S-5C	I1S-5C:1		HM-N1	HM-F1
2.01.D.12	I1S-2D	I1S-2D		HM-F	HM-F1
2.01.D.13	I1NS-2A	I1NS-2A		HM-F	HM-F1
2.01.D.14	I1S-5B	I1S-5B		HM-F	HM-F1
2.01.D.15	I1S-5C	I1S-5C:1		HM-N1	HM-F1
2.01.D.16	I1S-2C	I1S-2C		HM-F	HM-F1
2.01.E.01	I2S-4B	I2S-4B:3	90Min	HM-F	HM-F1
2.01.E.02	I2S-4B	I2S-4B		HM-N2	HM-F1
2.01.E.03	I2S-4B	I2S-4B		HM-N2	HM-F1
2.01.E.04	IS1-7C	IS1-7C	45Min	HM-N1	HM-F1
2.01.E.05	I2S-4B	I2S-4B:2	45Min	HM-F	HM-F1
2.01.E.06	I2S-1C	I2S-1C		HM-F	HM-F1
2.01.E.07	I1S-5D	I1S-5D:1	90Min	HM-F	HM-F1
2.01.E.08	I1S-2D	I1S-2D:1		WD-F	HM-F1
2.01.E.09	I1NS-3D	I1NS-3D		WD-FG	HM-F1
2.01.E.10	I1NS-3D	I1NS-3D		WD-FG	HM-F1
2.01.E.11	I1NS-3D	I1NS-3D:1		WD-FG	HM-F1
2.01.E.13	I1NS-3D	I1NS-3D		WD-FG	HM-F1
2.01.E.14	I1NS-3D	I1NS-3D		WD-FG	HM-F1
2.01.E.16	I1NS-3D	I1NS-3D		WD-FG	HM-F1
2.01.E.17	I1NS-3D	I1NS-3D		WD-FG	HM-F1
2.01.E.18A	I1S-6C	I1S-6C		HM-F	HM-F1
2.01.E.18B	I2S-5C	I2S-5C:2		HM-F	HM-F1
2.01.E.18C	I1S-6C	I1S-6C		HM-F	HM-F1
2.01.E.19	I2S-5B	I2S-5B		HM-F	HM-F1
2.01.E.20	I2S-5B	I2S-5B		HM-F	HM-F1
2.01.E.21	I1S-2D	I1S-2D:1		WD-F	HM-F1
2.01.E.22	I1NS-9A	I1NS-9A		WD-F	HM-F1
2.01.E.23A	I1NS-6C	I1NS-6C:1	90Min	HM-F-361	HM-F1-361
2.01.E.23B	I1NS-6C	I1NS-6C:1	90Min	HM-F-361	HM-F1-361

Opening	Hdw Set	Hdw Heading	Opening Label	Door Type	Frame Type
2.01.E.24	I1NS-2A	I1NS-2A		WD-F	HM-F1
2.01.E.25	I1S-2B	I1S-2B		HM-F	HM-F1
2.01.E.26	I1S-5B	I1S-5B		HM-F	HM-F1
2.01.E.32	I2NS-1B	I2NS-1B		WD-FG	HM-F1
2.01.E.33A	I1NS-6A	I1NS-6A		HM-F	HM-F1
2.01.E.33B	I2AO-1A	I2AO-1A		HM-N2	HM-F1
2.01.F.01	I2S-4B	I2S-4B:3	90Min	HM-F	HM-F1
2.01.F.02	I2S-4B	I2S-4B:3	90Min	HM-F	HM-F1
2.01.F.03	I2S-4B	I2S-4B		HM-N2	HM-F1
2.01.F.04	I2S-4B	I2S-4B		HM-N2	HM-F1
2.01.F.05	I2S-1C	I2S-1C		HM-F	HM-F1
2.01.F.06A	I2S-4B	I2S-4B:1		HM-N2	HM-F1
2.01.F.06B	I2S-4B	I2S-4B:1WA		HM-N2	HM-F1
2.01.F.06C	E2S-1A	E2S-1A		HM-F	HM-F1
2.01.F.06D	I1S-1A	I1S-1A		OH	OH
2.01.F.06E	I1S-1A	I1S-1A		OH	OH
2.01.F.06F	I1S-1A	I1S-1A		OH	OH
2.01.F.06G	I2S-4B	I2S-4B:1W		HM-N2	HM-F1
2.01.F.06H	I2AO-2B	I2AO-2B		HM-N2	HM-F1
2.01.F.07	I2S-2D	I2S-2D		HM-N2	HM-F1
2.01.F.08	I1S-2F	I1S-2F		WD-F	HM-F1
2.01.F.09	I1NS-9A	I1NS-9A		WD-F	HM-F1
2.01.F.10	I1S-4A.AL2	I1S-4A.AL2		AL	AL
2.01.F.11A	E1S-1A.AL	E1S-1A.AL		AL	AL
2.01.F.11B	I1NS-7B.AL	I1NS-7B.AL		AL	AL
2.01.F.13	I1S-2D	I1S-2D:1		WD-F	HM-F1
2.01.F.14	I2S-5A	I2S-5A:1		HM-F	HM-F1
2.01.F.15	I2S-2A	I2S-2A		HM-F	HM-F1
2.01.F.16	I1S-2D	I1S-2D:1		WD-F	HM-F1
2.01.F.17	I2S-5A	I2S-5A:1		HM-F	HM-F1
2.01.F.18	I1S-3B	I1S-3B		HM-F	HM-F1
2.01.F.19	I1NS-2A	I1NS-2A		WD-F	HM-F1
2.01.F.20A	E1S-1A	E1S-1A		HM-F	HM-F1
2.01.F.20B	I1S-7C	I1S-7C		HM-F	HM-F1
2.01.F.21	I1S-2D	I1S-2D		HM-N1	HM-F1

Manufacturer List

Code	Name
AB	ABH Manufacturing Inc.
GL	Glynn Johnson
IV	Ives
LC	LCN Closers
LO	Schlage Electronics
ME	Medeco
MISC	Miscellaneous Items
SC	Schlage
VO	Von Duprin
ZE	Zero

Finish List

Code	Description
26	Satin Chrome
626	Satin Chromium Plated
628	Satin Aluminum, Clear Anodized
630	Satin Stainless Steel
652	Satin Chromium Plated
AL	Aluminum (BHMA 689)
SP28	Lacquer Sprayed Aluminum
US26D	Chromium Plated, Dull
US28	Aluminum - Clear Anodized
US32D	Stainless Steel, Dull

Option List

Code	Description
03	03 LEVER DESIGN
06	06 LEVER DESIGN-FURNISHED STANDARD
36"	36" ROD LENGTH (Automatic Bolts)
4040-18TJ	Drop Plate
425-SNB (QTY-2)	SEX BOLTS (2)
425-SNB (QTY-6)	SEX BOLTS (6)
48"	4 FOOT CROSSBAR
48"	4'0" BAR
8402 (UL)	UL Approved Kickplate
900-4RL	4 Relay Boards with Time Delays
900-FA	Plug-in Fire Alarm Relay (PS902)
B-CS	4 BEVELED EDGES -COUNTERSUNK HOLES (STD)
CON	Molex Connector
CON	Molex Connectors
CON	Molex Electrical Connector

Code	Description
CON	Molex Electrical Connector (EPT 10)
CUSTOM CUT	Custom Cut to Length Charge (XY)
CYLDEL	DELAYED ACTION
EPT	Electric Power Transfer Prep
ER-ADJ9.8-94	ADJ. EXT. ROD 8'0" to 9'8" DOOR
FSE	FAIL SECURE
Header Length	Header - 33" to 48"
Header Length	Header - 65" to 98" (9560)
HL/D	End Dress Plates
ICX	ICX FSIC CONST. CORE (NEW JOBS) 5 Pin
L283-722	Vacant/Occupied Indicator(Outside of Dr)
L583-363	DISABILITY T/TURN (Replaces XL11-800)
LBR	LESS BOTTOM ROD
LBRAFL	LESS BOTTOM ROD with Fire Latch Kit
LD	LESS DOGGING
NRP	NRP (other than 4-1/2 x 4-1/2 sizes)
NRP	NRP (Steel&SS HNG - 4 1/2 x 4 1/2 only)
QEL	Quiet Electric Latch Retraction
QEL	Quiet Electric Latch Retraction (94/95)
RX	REQUEST TO EXIT
RX	REQUEST TO EXIT (RX)
SRI	SPECIAL RUST INHIBITOR
TBWMS	TB & WMS Package
TW8	Elec.Thru-Wire,(Steel) 8 Wire
TYPE F MTG.	TYPE F MOUNTING
WS	Windstorm Option
Z49	Door Bottom End cap System w/o Pullout

Hardware Schedule

Heading #I1NS-2A (Set #I1NS-2A)

1	Single Door #**1.01.B.14**	CORR. 1.01.D.17 to ALL GENDER RR. 1.01.B.15	RH
1	Single Door #**1.01.D.13**	CORR. to ALL GENDER RR. 1.01.D.13	RH
1	Single Door #**1.01.E.24**	CORR. 1.01.E.25 to TLT. RM. 1.01.E.24	LH
1	Single Door #**1.01.F.19**	SECURE PACKAGE DROP VEST. 1.01.F.20 to ALL GENDER RR. 1.01.F.19	RH
1	Single Door #**1.01.N.22**	CORR. to ALL GENDER RR. 1.01.NS1.06	RH
1	Single Door #**1.01.N.29**	CORR. to ALL GENDER RR. 1.01.N.29	RH
1	Single Door #**2.01.B.13**	CORR. 2.01.D.17 to ALL GENDER RR. 2.01.B.13	RH
1	Single Door #**2.01.D.13**	CORR. to ALL GENDER RR. 2.01.D.13	RH
1	Single Door #**2.01.E.24**	CORR. 2.01.E.23 to TLT. RM. 2.01.E.24	RH
1	Single Door #**2.01.F.19**	SECURE PACKAGE DROP VEST. 2.01.F.19 to ALL GENDER RR. 2.01.F.19	LH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1 (1.01.B.14, 1.01.D.13, 1.01.F.19, 1.01.N.22, 1.01.N.29, 2.01.B.13, 2.01.D.13)
3' 0" x 7' 0" x 1 3/4" x WD Type WD-F x HMF Type HM-F1 (1.01.E.24, 2.01.E.24, 2.01.F.19)

Note: HARDWARE GROUP 341E

30	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
8	Mortise Privacy Set	L9040 03N L283-722 L583-363	RH	626	SC
	Note: INDICATOR ON OUTSIDE OF DOOR				
2	Mortise Privacy Set	L9040 03N L283-722 L583-363	LH	626	SC
	Note: INDICATOR ON OUTSIDE OF DOOR				
10	Closer	4040XP RWPA TBWMS		AL	LC
10	Protection Plate	8400 10" X 34" B-CS		US32D	IV
10	Wall Stop	WS406/407CCV		US32D	IV
10	Weatherstrip	8303AA 1 x 36" 2 x 84"			ZE

Heading #I1NS-3B (Set #I1NS-3B)

1	Single Door #**1.01.N.05C**	ELECTRICAL RM. NS1 1.01.N.05 to ELECTRICAL RM. NS4 1.01.N.14	LH
1	Single Door #**1.01.N.08C**	ELECTRICAL RM. N2 1.01.N.08 to ELECTRICAL RM. N3 1.01.N.11	RH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1 x 90Min

Note: HARDWARE GROUP 401CG2

6	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
1	Mortise Passage Set	L9010 03N	LH	626	SC
1	Mortise Passage Set	L9010 03N	RH	626	SC
2	Closer	4040XP SCUSH TBWMS		AL	LC
2	Protection Plate	8400 10" X 34" B-CS		US32D	IV
2	Weatherstrip	475AA 1 x 36" 2 x 84"			ZE
2	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
2	Auto Door Bottom	355AA 36"			ZE

Heading #I1NS-3C (Set #I1NS-3C)

1	Single Door #**1.01.N.07B**	FCA GALLERY N1.2 1.01.N.07 to FCA GALLERY N4.2 1.01.N.16	LH
1	Single Door #**1.01.N.10B**	FCA GALLERY N2.2 1.01.N.10 to FCA GALLERY N3.2 1.01.N.13	RH

Opening Description: 3' 6" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP 401CG2W

6	Hinges	5BB1 HW 5 x 4 1/2		652	IV
1	Mortise Passage Set	L9010 03N	LH	626	SC
1	Mortise Passage Set	L9010 03N	RH	626	SC
2	Closer	4040XP SCUSH TBWMS		AL	LC
2	Protection Plate	8400 10" X 40" B-CS		US32D	IV
2	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
2	Weatherstrip	475AA 1 x 42" 2 x 84"			ZE
2	Auto Door Bottom	355AA 42"			ZE

Heading #I1NS-3D (Set #I1NS-3D)

1	Single Door #**1.01.E.08**	CORR. 1.01.E.28 to SMALL CONFERENCE 1.01.E.08	LH
1	Single Door #**1.01.E.09**	CORR. 1.01.E.28 to SEATED HUDDLE 1.01.E.09	LH
1	Single Door #**1.01.E.12**	OPEN OFFICE 1.01.E.11 to DAY OFFICE 1.01.E.12	RH
1	Single Door #**1.01.E.13**	OPEN OFFICE 1.01.E.11 to DAY OFFICE 1.01.E.13	RH
1	Single Door #**1.01.E.15**	OPEN OFFICE 1.01.E.11 to HARD COZY 1.01.E.15	RH
1	Single Door #**1.01.E.16**	OPEN OFFICE 1.01.E.11 to HARD COZY 1.01.E.16	RH
1	Single Door #**2.01.E.09**	CORR. 2.01.E.28 to SMALL CONFERENCE 2.01.E.09	RH
1	Single Door #**2.01.E.10**	CORR. 2.01.E.28 to SEATED HUDDLE 2.01.E.10	RH
1	Single Door #**2.01.E.13**	OPEN OFFICE 2.01.E.12 to HARD COZY 2.01.E.13	LH
1	Single Door #**2.01.E.14**	OPEN OFFICE 2.01.E.12 to HARD COZY 2.01.E.14	LH
1	Single Door #**2.01.E.16**	OPEN OFFICE 2.01.E.12 to DAY OFFICE 2.01.E.16	LH
1	Single Door #**2.01.E.17**	OPEN OFFICE 2.01.E.12 to DAY OFFICE 2.01.E.17	LH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x WD Type WD-FG x HMF Type HM-F1

Note: HARDWARE GROUP 401G2

36	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
6	Mortise Passage Set	L9010 03N	LH	626	SC
6	Mortise Passage Set	L9010 03N	RH	626	SC
12	Closer	4040XP RWPA TBWMS		AL	LC
12	Protection Plate	8400 10" X 34" B-CS		US32D	IV
12	Wall Stop	WS406/407CCV		US32D	IV
12	Weatherstrip	475AA 1 x 36" 2 x 84"			ZE
12	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
12	Auto Door Bottom	360AA 36" Z49			ZE

Heading #I1NS-3D:1 (Set #I1NS-3D)

1	Single Door #**1.01.E.10**	OPEN OFFICE 1.01.E.11 to LARGE CONFERENCE 1.01.E.10	LH
1	Single Door #**2.01.E.11**	OPEN OFFICE 2.01.E.12 to LARGE CONFERENCE 2.01.E.11	RH

Opening Description: 3' 6" x 7' 0" x 1 3/4" x WD Type WD-FG x HMF Type HM-F1

Note: HARDWARE GROUP 401G2

6	Hinges	5BB1 5 x 4 1/2		652	IV
1	Mortise Passage Set	L9010 03N	LH	626	SC
1	Mortise Passage Set	L9010 03N	RH	626	SC
2	Closer	4040XP RWPA TBWMS		AL	LC
2	Protection Plate	8400 10" X 40" B-CS		US32D	IV
2	Wall Stop	WS406/407CCV		US32D	IV
2	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
2	Weatherstrip	475AA 1 x 42" 2 x 84"			ZE
2	Auto Door Bottom	360AA 42" Z49			ZE

Heading #I1NS-3F (Set #I1NS-3F)

1	Single Door #**1.01.N.06B**	FCA GALLERY N1.1 1.01.N.06 to FCA GALLERY N4.1 1.01.N.15	RH
1	Single Door #**1.01.N.09B**	FCA GALLERY N2.1 1.01.N.09 to FCA GALLERY N3.1 1.01.N.12	LH

Opening Description: 3' 6" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP 401G2W

6	Hinges	5BB1 HW 5 x 4 1/2		652	IV
1	Mortise Passage Set	L9010 03N	LH	626	SC
1	Mortise Passage Set	L9010 03N	RH	626	SC
2	Closer	4040XP RWPA TBWMS		AL	LC
2	Protection Plate	8400 10" X 40" B-CS		US32D	IV
2	Dome Stop	FS436		US26D	IV
2	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
2	Weatherstrip	475AA 1 x 42" 2 x 84"			ZE
2	Auto Door Bottom	355AA 42"			ZE

Note: SOMETHING ON THE FLOOR PLAN IS LOCATED BEHIND THE DOOR THAT WILL INTERFERE WITH THE WALL STOP. A FLOOR STOP HAS BEEN INCLUDED AT THESE LOCATIONS.

Heading #I2NS-1B (Set #I2NS-1B)

1	Pair Doors #**2.01.E.32**	CORR. 2.01.E.32 from OPEN OFFICE 2.01.E.12			RHRA
	Opening Description:	2 - 3' 0" x 7' 0" x 1 3/4" x WD Type WD-FG x HMF Type HM-F1			
	Note: HARDWARE GROUP 506EW				
6	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP		652	IV
1	Flush Bolt	FB41T		US32D	IV
1	Mortise Classroom Lockset	L9070T 03N	RHR	626	SC
1	LFIC Core	32N2201		26	ME
1	Coordinator	3780		US28	AB
2	Closer	4040XP RWPA 4040-18TJ TBWMS		AL	LC
	Note: Mount using Special Template ST-1630				
2	Overhead Stop	104S		US32D	GL
2	Protection Plate	8400 10" X 35" B-CS		US32D	IV
1	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
1	Weatherstrip	8303AA 1 x 72" 2 x 84"			ZE
2	Meeting Stile	328AA 84"			ZE

Heading #I2NS-1B:1 (Set #I2NS-1B)

1	Pair Doors #**1.01.E.11**	CORR. 1.01.E.31 from OPEN OFFICE 1.01.E.11			RHRA
	Opening Description:	2 - 4' 0" x 9' 0" x 1 3/4" x WD Type WD-FG x HMF Type HM-F1			
	Note: HARDWARE GROUP 506EW				
8	Hinges	5BB1 HW 5 x 4 1/2 NRP		652	IV
1	Flush Bolt	FB41T		US32D	IV
1	Mortise Classroom Lockset	L9070T 03N	RHR	626	SC
1	LFIC Core	32N2201		26	ME
1	Coordinator	3780		US28	AB
2	Closer	4040XP RWPA TBWMS		AL	LC
2	Protection Plate	8400 10" X 47" B-CS		US32D	IV
2	Wall Stop	WS406/407CCV		US32D	IV
1	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
1	Weatherstrip	8303AA 1 x 96" 2 x 108"			ZE
2	Meeting Stile	328AA 108"			ZE

Heading #I2NS-2A (Set #I2NS-2A)

1	Double Egress Door #**2.01.A.14**	CORR. 2.01.A.14 to/from CORR. 2.01.C.17		DELHR

Opening Description: 2 - 4' 0" x 7' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1 x 90Min

Note: HARDWARE GROUP 728DERWX

6	Hinges	5BB1 HW 5 x 4 1/2	652	IV
2	Exit Device	9447EO-F 48" LBRAFL	US26D	VO
2	Magnetic Holder	SEM7850	AL	LC
2	Closer	4040XPT DE STDTRK TBWMS	AL	LC
	Note: Mount Closer on Push Side of Door			
2	Protection Plate	8400 10" X 47" B-CS	US32D	IV
1	Door Seal	488S-BK 8'		ZE
	Note: APPLY TO DOOR HEAD ONLY			
1	Astragal	44STST 84"		ZE
1	Weatherstrip	8303AA 1 x 96" 2 x 84"		ZE

Note: -PROVIDE 120VAC AND FIRE ALARM CONNECTIONS FOR WALL MAGNETIC HOLD OPENS.
-WIRE THE MAGNETIC HOLD OPENS TO THE FIRE ALARM SYSTEM.
-THE MAGNETIC HOLD OPENS ARE TO RELEASE UPON ACTIVATION OF THE FIRE ALARMS SYSTEM.

Heading #I2NS-2A:1 (Set #I2NS-2A)

1	Double Egress Door #**1.01.A.15**	CORR. 1.01.C.15 to/from CORR. 1.01.A.91		DELHR

Opening Description: 2 - 4' 0" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1 x 90Min

Note: HARDWARE GROUP 728DERWX

8	Hinges	5BB1 HW 5 x 4 1/2	652	IV
2	Exit Device	9947EO-F 48" ER-ADJ9.8-94	US26D	VO
2	Magnetic Holder	SEM7850	AL	LC
2	Closer	4040XPT DE STDTRK TBWMS	AL	LC
	Note: Mount Closer on Push Side of Door			
2	Protection Plate	8400 10" X 47" B-CS	US32D	IV
1	Door Seal	488S-BK 8'		ZE
	Note: APPLY TO DOOR HEAD ONLY			
1	Weatherstrip	8303AA 1 x 96" 2 x 108"		ZE
1	Astragal	44STST 108"		ZE

Note: -PROVIDE 120VAC AND FIRE ALARM CONNECTIONS FOR WALL MAGNETIC HOLD OPENS.
-WIRE THE MAGNETIC HOLD OPENS TO THE FIRE ALARM SYSTEM.
-THE MAGNETIC HOLD OPENS ARE TO RELEASE UPON ACTIVATION OF THE FIRE ALARMS SYSTEM.

Heading #I1NS-6A (Set #I1NS-6A)

1	Single Door #**1.01.E.29**	CORR. 1.01.E.28 from CORR. 1.01.E.29	LHR
1	Single Door #**2.01.E.33A**	CORR. 2.01.E.28 from CORR. 2.01.E.29	RHR

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP 801

6	Hinges	5BB1 HW 4 1/2 x 4 1/2	652	IV
2	Push Plate	8200 4 x 16	US32D	IV
2	Pull Plate	8303-0 4 x 16 TYPE F MTG.	US32D	IV
2	Closer	4040XP SCUSH TBWMS	AL	LC
2	Protection Plate	8400 10" X 34" B-CS	US32D	IV
2	Door Seal	488S-BK 17'		ZE

Note: This Reference number is shown in 2 hardware groups. It is shown in 731CEMC and 801. We are providing it in Hardware Group 801.

Heading #I1NS-7B.AL (Set #I1NS-7B.AL)

1	Single Door #**1.01.F.11B**	ENTRY VEST. 1.01.F.11 from SECONDARY ENTRY LOBBY 1.01.F.10	RHR
1	Single Door #**2.01.F.11B**	ENTRY VEST. 2.01.F.11 from SECONDARY ENTRY LOBBY 2.01.F.10	LHR

Opening Description: 3' 6" x 7' 0" Type AL Type AL

Note: HARDWARE GROUP 801AVZ

Note: ALL HARDWARE BY ALUMINUM STOREFRONT SUPPLIER

Heading #I1NS-9A (Set #I1NS-9A)

1	Single Door #**1.01.E.22**	CORR. 1.01.E.30 to WOMEN'S RR. 1.01.E.22	LH
1	Single Door #**1.01.F.09**	CORR. 1.01.E.30 to MEN'S RESTROOM 1.01.F.09	RH
1	Single Door #**2.01.E.22**	CORR. 2.01.E.30 to MEN'S RR. 2.01.E.22	RH
1	Single Door #**2.01.F.09**	CORR. 2.01.E.30 to WOMEN'S RR. 2.01.F.09	LH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x WD Type WD-F x HMF Type HM-F1

Note: HARDWARE GROUP 887Y

12	Hinges	5BB1 HW 4 1/2 x 4 1/2		652	IV
4	Push Plate	8200 4 x 16		US32D	IV
4	Pull Plate	8303-0 4 x 16 TYPE F MTG.		US32D	IV
2	Closer	4011 REGARM CYLDEL SRI TBWMS	LH	AL	LC
2	Closer	4011 REGARM CYLDEL SRI TBWMS	RH	AL	LC
4	Protection Plate	8400 10" X 34" B-CS		US32D	IV
4	Wall Stop	WS406/407CCV		US32D	IV
4	Door Seal	488S-BK 17'			ZE

Heading #I2AO-1A (Set #I2AO-1A)

1	Pair Doors #**1.01.E.30**	CORR. 1.01.E.30 from CORR. 1.01.E.29			RHRA
1	Pair Doors #**2.01.E.33B**	CORR. 2.01.E.30 from CORR. 2.01.E.29			RHRA

Opening Description: 2 - 4' 0" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1

Note: HARDWARE GROUP A730ERXZ

2	Continuous Hinge	112XY 119" CUSTOM CUT EPT	LH	628	IV
	Properties: Custom Length=107", EPT-Model/Location= VD EPT 10, Loc: 61 1/2" CL from Top				
2	Continuous Hinge	112XY 119" CUSTOM CUT EPT	RH	628	IV
	Properties: Custom Length=107", EPT-Model/Location= VD EPT 10, Loc: 61 1/2" CL from Top				
2	Exit Device	QEL 9447EO 48" ER-ADJ9.8-94 LBR		US26D	VO
	Note: ORDER WITH CON OPTION				
2	Exit Device	QEL 9447L-BE x 940L-BE 03 48" CON ER-ADJ9.8-94 LBR	RHR	US26D	VO
2	Automatic Operator	9563 REGARM2 HDR2 Header Length HL/D		AL	LC
	Properties: Header Length=72				
4	Protection Plate	8400 10" X 47" B-CS		US32D	IV
2	Wall Stop	WS406/407CCV		US32D	IV
4	Electric Power Transfer	EPT 10 CON		SP28	VO
2	Actuator	ACTUATOR BY OTHERS			MISC
4	Power Supply Extension	CON-6W			SC
2	Power Supply	PS902 900-4RL 900-FA			LO
4	Wire Harness	CON-6P			SC
2	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
2	Weatherstrip	8303AA 1 x 96" 2 x 108"			ZE
4	Meeting Stile	328AA 108"			ZE

Note: -INGRESS BY THE LEVER OR KEY OVERRIDE.
-FREE EGRESS BY THE ACTUATOR OR PUSH PADS.
-THE ELECTRIFIED LATCH BOLTS WILL BE SEQUENCED WITH THE AUTOMATIC OPENER AND RETRACT PRIOR TO THE AUTOMATIC OPENER ACTIVATING.
-WIRE THE ELECTRIFIED LATCH BOLTS TO THE FIRE ALARM SYSTEM.
-THE ELECTRIFIED LATCH BOLTS ARE TO REMAIN IN THE EXTENDED POSITION UPON ACTIVATION OF THE FIRE ALARM SYSTEM, UNLESS MANUALLY RETRACTED BY THE PUSH PADS OR BY THE LEVERS.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.
-OMIT POWER SUPPLY WHERE PROVIDED BY SECURITY

Heading #I2AO-2A (Set #I2AO-2A)

1	Pair Doors #**1.01.A.01C**	CORR. 1.01.C.15 from DATA HALL A 1.01.A.01			RHRA
1	Pair Doors #**1.01.B.01D**	CORR. 1.01.D.17 from DATA HALL B 1.01.B.01			RHRA
1	Pair Doors #**2.01.A.01C**	CORR. 2.01.C.18 from DATA HALL A 2.01.A.01			RHRA
1	Pair Doors #**2.01.B.01D**	CORR. 2.01.D.17 from DATA HALL B 2.01.B.01			RHRA

Opening Description: 2 - 4' 0" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1 x 90Min

Note: HARDWARE GROUP ACY710GQRXZ

4	Continuous Hinge	112XY 119" CUSTOM CUT EPT	LH	628	IV
	Properties: Custom Length=107", EPT-Model/Location= VD EPT 10, Loc: 61 1/2" CL from Top				
4	Continuous Hinge	112XY 119" CUSTOM CUT EPT	RH	628	IV
	Properties: Custom Length=107", EPT-Model/Location= VD EPT 10, Loc: 61 1/2" CL from Top				
4	Exit Device	QEL 9447EO-F 48" ER-ADJ9.8-94 LBRAFL		US26D	VO
	Note: ORDER WITH CON OPTION				
4	Exit Device	QEL 9447L-F x 940L 03 48" CON ER-ADJ9.8-94 LBRAFL	RHR	US26D	VO
4	LFIC Core	32N2201		26	ME
4	Mort. HSG w/ Const Core	30-008 ICX		626	SC
4	Automatic Operator	9563 REGARM2 HDR2 Header Length HL/D		AL	LC
	Note: 90 DEG MAXIMUM OPENING				
	Properties: Header Length=96"				
8	Protection Plate	8400 34" x 47" 8402 (UL) B-CS		US32D	IV
8	Wall Stop	WS406/407CCV		US32D	IV
8	Electric Power Transfer	EPT 10 CON		SP28	VO
8	Actuator	ACTUATOR BY OTHERS			MISC
8	Power Supply Extension	CON-6W			SC
4	Power Supply	PS902 900-4RL 900-FA			LO
8	Header Mount Safety Sensor	8310-877			LC
	Note: Includes 8310-846 Wire Harness				
8	Wire Harness	CON-6P			SC
8	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
4	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
4	Weatherstrip	8303AA 1 x 96" 2 x 108"			ZE
8	Meeting Stile	328AA 108"			ZE
8	Auto Door Bottom	365AA 48"			ZE

Heading #I2AO-2A (Set #I2AO-2A)

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY THE ACTUATOR OR THE PUSH PADS.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-SAFETY SENSORS FOR ROBOTS. **Quantity subject to RFI answer**
-THE ELECTRIFIED LATCH BOLTS WILL BE SEQUENCED WITH THE AUTOMATIC OPENER AND RETRACT PRIOR TO THE AUTOMATIC OPENER ACTIVATING.
-WIRE THE ELECTRIFIED LATCH BOLTS TO THE FIRE ALARM SYSTEM.
-THE ELECTRIFIED LATCH BOLTS ARE TO REMAIN IN THE EXTENDED POSITION UPON ACTIVATION OF THE FIRE ALARM SYSTEM, UNLESS MANUALLY RETRACTED BY THE PUSH PADS OR BY KEY OVERRIDE.
-PROVIDE MORTISED DOOR BOTTOM OR DOOR SWEEP TO MEET ADA AS REQUIRED.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.
-OMIT POWER SUPPLY WHERE PROVIDED BY SECURITY.

Heading #I2AO-2B (Set #I2AO-2B)

1	Pair Doors #**1.01.A.01B**	CORR.1.01.A.12 from DATA HALL A 1.01.A.01	RHRA
1	Pair Doors #**1.01.B.01A**	CORR. 1.01B.12 from DATA HALL B 1.01.B.01	RHRA
1	Pair Doors #**1.01.C.01B**	CORR. 1.01.C.15 from DATA HALL C 1.01.C.01	RHRA
1	Pair Doors #**1.01.C.01C**	CORR. 1.01.C.17 from DATA HALL C 1.01.C.01	RHRA
1	Pair Doors #**1.01.D.01A**	CORR. from DATA HALL D 1.01.D.01	RHRA
1	Pair Doors #**1.01.D.01D**	CORR. from DATA HALL D 1.01.D.01	RHRA
1	Pair Doors #**1.01.F.05G**	CORR. 1.01.E.30 from SHIPPING & RECEIVING 1.01.F.05	RHRA
1	Pair Doors #**1.01.N.01B**	ALCOVE FOR EQUIP 1.01.N.24 from NETWORK SUITE 1 1.01.N.01	RHRA
1	Pair Doors #**1.01.N.01C**	NETWORK SUITE 4 1.01.N.04 from NETWORK SUITE 1 1.01.N.01	RHRA
1	Pair Doors #**1.01.N.02A**	ALCOVE FOR EQUIP 1.01.N.27 from NETWORK SUITE 2 1.01.N2.01	RHRA
1	Pair Doors #**1.01.N.02C**	NETWORK SUITE 3 1.01.N.03 from NETWORK SUITE 2 1.01.N.02	RHRA
1	Pair Doors #**1.01.N.03B**	CORR. 1.01B.12 from NETWORK SUITE 3 1.01.N.03	RHRA
1	Pair Doors #**1.01.N.04A**	CORR.1.01.A.12 from NETWORK SUITE 4 1.01.N.04	RHRA
1	Pair Doors #**2.01.A.01B**	CORR. 2.01.A.15 from DATA HALL A 2.01.A.01	RHRA
1	Pair Doors #**2.01.B.01A**	CORR. 2.01.B.15 from DATA HALL B 2.01.B.01	RHRA
1	Pair Doors #**2.01.C.01B**	CORR. 2.01.C.18 from DATA HALL C 2.01.C.01	RHRA
1	Pair Doors #**2.01.C.01C**	CORR. 2.01.C.17 from DATA HALL C 2.01.C.01	RHRA
1	Pair Doors #**2.01.D.01A**	CORR. 2.01.D.17 from DATA HALL D 2.01.D.01	RHRA
1	Pair Doors #**2.01.D.01D**	CORR. from DATA HALL D 2.01.D.01	RHRA
1	Pair Doors #**2.01.F.06H**	CORR. 2.01.E.30 from SHIPPING & RECEIVING 2.01.F.06	RHRA

Opening Description: 2 - 4' 0" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1

Note: HARDWARE GROUP ACY710GQXZ

Heading #I2AO-2B (Set #I2AO-2B)

20	Continuous Hinge	112XY 119" CUSTOM CUT EPT	LH	628	IV
	Properties: Custom Length=107", EPT-Model/Location= VD EPT 10, Loc: 61 1/2" CL from Top				
20	Continuous Hinge	112XY 119" CUSTOM CUT EPT	RH	628	IV
	Properties: Custom Length=107", EPT-Model/Location= VD EPT 10, Loc: 61 1/2" CL from Top				
20	Exit Device	QEL 9447EO 48" ER-ADJ9.8-94 LBR		US26D	VO
	Note: ORDER WITH CON OPTION				
20	Exit Device	QEL 9447L x 940L 03 48" CON ER-ADJ9.8-94 LBR	RHR	US26D	VO
20	LFIC Core	32N2201		26	ME
20	Mort. HSG w/ Const Core	30-008 ICX		626	SC
20	Automatic Operator	9563 REGARM2 HDR2 Header Length HL/D		AL	LC
	Note: 90 DEG MAXIMUM OPENING				
	Properties: Header Length=96"				
40	Protection Plate	8400 34" x 47" B-CS		US32D	IV
40	Wall Stop	WS406/407CCV		US32D	IV
40	Electric Power Transfer	EPT 10 CON		SP28	VO
20	Actuator	ACTUATOR BY OTHERS			MISC
40	Power Supply Extension	CON-6W			SC
40	Header Mount Safety Sensor	8310-877			LC
	Note: Includes 8310-846 Wire Harness				
40	Wire Harness	CON-6P			SC
20	Power Supply	PS902 900-4RL			LO
40	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
20	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
20	Weatherstrip	8303AA 1 x 96" 2 x 108"			ZE
40	Meeting Stile	328AA 108"			ZE
40	Auto Door Bottom	365AA 48"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY THE ACTUATOR OR THE PUSH PADS.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-SAFETY SENSORS FOR ROBOTS.
-THE ELECTRIFIED LATCH BOLTS WILL BE SEQUENCED WITH THE AUTOMATIC OPENER AND RETRACT PRIOR TO THE AUTOMATIC OPENER ACTIVATING.
-PROVIDE MORTISED DOOR BOTTOM OR DOOR SWEEP TO MEET ADA AS REQUIRED.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.
-OMIT POWER SUPPLY WHERE PROVIDED BY SECURITY.
-AUTO OPERATOR TO ACT AS STOP WHERE WALL STOP IS NOT APPLICABLE.

Heading #I1AO-2A (Set #I1AO-2A)

1	Single Door #**1.01.A.01D**	CORR. 1.01.C.15 from DATA HALL A 1.01.A.01	RHR
1	Single Door #**1.01.B.01C**	CORR. 1.01.D.17 from DATA HALL B 1.01.B.01	LHR
1	Single Door #**2.01.A.01D**	CORR. 2.01.C.18 from DATA HALL A 2.01.A.01	RHR
1	Single Door #**2.01.B.01C**	CORR. 2.01.D.17 from DATA HALL B 2.01.B.01	LHR

Opening Description: 3' 6" x 7' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1 x 90Min

Note: HARDWARE GROUP ACY711GMQRXZ

2	Exit Device	QEL 9475NL-F x 940L 03 CON	RHR	US26D	VO
2	Exit Device	QEL 9475NL-F x 940L 03 CON	LHR	US26D	VO
2	Continuous Hinge	112XY 83" EPT	LH	628	IV
	Properties: EPT-Model/Location=VD EPT 10 Loc: 37 1/2" CL from Top				
2	Continuous Hinge	112XY 83" EPT	RH	628	IV
	Properties: EPT-Model/Location=VD EPT 10 Loc: 37 1/2" CL from Top				
4	LFIC Core	32N2201		26	ME
4	Mort. HSG w/ Const Core	30-008 ICX		626	SC
2	Automatic Operator	9531 HDR Header Length	LH	AL	LC
	Properties: Header Length=42				
2	Automatic Operator	9531 HDR Header Length	RH	AL	LC
	Properties: Header Length=42				
4	Protection Plate	8400 34" x 40" 8402 (UL) B-CS		US32D	IV
4	Wall Stop	WS406/407CCV		US32D	IV
4	Electric Power Transfer	EPT 10 CON		SP28	VO
4	Actuator	ACTUATOR BY OTHERS			MISC
4	Power Supply Extension	CON-6W			SC
4	Power Supply	PS902 900-4RL 900-FA			LO
4	Header Mount Safety Sensor	8310-877			LC
	Note: Includes 8310-846 Wire Harness				
4	Wire Harness	CON-6P			SC
4	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
4	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
4	Weatherstrip	8303AA 1 x 42" 2 x 84"			ZE
4	Auto Door Bottom	355AA 42"			ZE

Heading #I1AO-2A (Set #I1AO-2A)

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY THE ACTUATOR OR THE PUSH PAD.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-SAFETY SENSOR FOR ROBOTS.
-THE ELECTRIFIED LATCH BOLTS WILL BE SEQUENCED WITH THE AUTOMATIC OPENER AND RETRACT PRIOR TO THE AUTOMATIC OPENER ACTIVATING.
-WIRE THE ELECTRIFIED LATCH BOLTS TO THE FIRE ALARM SYSTEM.
-THE ELECTRIFIED LATCH BOLTS ARE TO REMAIN IN THE EXTENDED POSITION UPON ACTIVATION OF THE FIRE ALARM SYSTEM, UNLESS MANUALLY RETRACTED BY THE PUSH PADS OR BY KEY OVERRIDE.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.
-OMIT POWER SUPPLY WHERE PROVIDED BY SECURITY.
-AUTO OPERATOR TO ACT AS STOP WHERE WALL STOP IS NOT APPLICABLE.

Heading #I1AO-2B (Set #I1AO-2B)

1	Single Door #**1.01.A.01A**	CORR.1.01.A.12 from DATA HALL A 1.01.A.01	LHR
1	Single Door #**1.01.B.01B**	CORR. 1.01B.12 from DATA HALL B 1.01.B.01	RHR
1	Single Door #**1.01.C.01A**	CORR. 1.01.C.15 from DATA HALL C 1.01.C.01	LHR
1	Single Door #**1.01.C.01D**	CORR. 1.01.C.17 from DATA HALL C 1.01.C.01	RHR
1	Single Door #**1.01.D.01B**	CORR. from DATA HALL D 1.01.D.01	RHR
1	Single Door #**1.01.D.01C**	CORR. from DATA HALL D 1.01.D.01	LHR
1	Single Door #**1.01.N.01A**	CORR. from NETWORK SUITE 1 1.01.N.01	LHR
1	Single Door #**1.01.N.02B**	CORR. from NETWORK SUITE 2 1.01.N2.01	RHR
1	Single Door #**1.01.N.03A**	CORR. 1.01B.12 from NETWORK SUITE 3 1.01.N.03	LHR
1	Single Door #**1.01.N.04B**	CORR.1.01.A.12 from NETWORK SUITE 4 1.01.N.04	RHR
1	Single Door #**2.01.A.01A**	CORR. 2.01.A.15 from DATA HALL A 2.01.A.01	LHR
1	Single Door #**2.01.B.01B**	CORR. 2.01.B.15 from DATA HALL B 2.01.B.01	RHR
1	Single Door #**2.01.C.01A**	CORR. 2.01.C.18 from DATA HALL C 2.01.C.01	LHR
1	Single Door #**2.01.C.01D**	CORR. 2.01.C.17 from DATA HALL C 2.01.C.01	RHR
1	Single Door #**2.01.D.01B**	CORR. 2.01.D.17 from DATA HALL D 2.01.D.01	RHR
1	Single Door #**2.01.D.01C**	CORR. from DATA HALL D 2.01.D.01	LHR

Opening Description: 3' 6" x 7' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1

Note: HARDWARE GROUP ACY711GMQXZ

8	Exit Device	QEL 9475NL x 940L 03 CON	LHR	US26D	VO
8	Exit Device	QEL 9475NL x 940L 03 CON	RHR	US26D	VO
8	Continuous Hinge	112XY 83" EPT	LH	628	IV
	Properties: EPT-Model/Location=VD EPT 10 Loc: 37 1/2" CL from Top				
8	Continuous Hinge	112XY 83" EPT	RH	628	IV
	Properties: EPT-Model/Location=VD EPT 10 Loc: 37 1/2" CL from Top				
16	LFIC Core	32N2201		26	ME
16	Mort. HSG w/ Const Core	30-008 ICX		626	SC
8	Automatic Operator	9531 HDR Header Length	LH	AL	LC
	Properties: Header Length=42				
8	Automatic Operator	9531 HDR Header Length	RH	AL	LC
	Properties: Header Length=42				
16	Protection Plate	8400 34" X 40" B-CS		US32D	IV
16	Wall Stop	WS406/407CCV		US32D	IV
16	Electric Power Transfer	EPT 10 CON		SP28	VO

Heading #I1AO-2B (Set #I1AO-2B)

16	Actuator	ACTUATOR BY OTHERS	MISC
16	Power Supply Extension	CON-6W	SC
16	Header Mount Safety Sensor	8310-877	LC
	Note: Includes 8310-846 Wire Harness		
16	Wire Harness	CON-6P	SC
16	Power Supply	PS902 900-4RL	LO
16	Door Position Switch by Others	DOOR POSITION SWITCH	MISC
16	Door Seal	488S-BK 8'	ZE
	Note: APPLY TO DOOR HEAD ONLY		
16	Weatherstrip	8303AA 1 x 42" 2 x 84"	ZE
16	Auto Door Bottom	355AA 42"	ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY THE ACTUATOR OR THE PUSH PAD.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-SAFETY SENSOR FOR ROBOTS.
-THE ELECTRIFIED LATCH BOLT WILL BE SEQUENCED WITH THE AUTOMATIC OPENER AND RETRACT PRIOR TO THE AUTOMATIC OPENER ACTIVATING.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.
-OMIT POWER SUPPLY WHERE PROVIDED BY SECURITY.
-AUTO OPERATOR TO ACT AS STOP WHERE WALL STOP IS NOT APPLICABLE.

Heading #I1S-1A (Set #I1S-1A)

1	Other Door #**1.01.F.05D**	EXT. to SHIPPING & RECEIVING 1.01.F.05
1	Other Door #**1.01.F.05E**	EXT. to SHIPPING & RECEIVING 1.01.F.05
1	Other Door #**1.01.F.05F**	EXT. to SHIPPING & RECEIVING 1.01.F.05
1	Other Door #**2.01.F.06D**	EXT. to SHIPPING & RECEIVING 2.01.F.06
1	Other Door #**2.01.F.06E**	EXT. to SHIPPING & RECEIVING 2.01.F.06
1	Other Door #**2.01.F.06F**	EXT. to SHIPPING & RECEIVING 2.01.F.06

Opening Description: 8' 0" x 10' 0" Type OH Type OH

Note: HARDWARE GROUP C001

6	LFIC Core	32N2201	26	ME
6	Mort. HSG w/ Const Core	30-008 ICX	626	SC

Note: BALANCE OF HDW BY OVERHEAD DOOR SUPPLIER.

Heading #I2S-1C (Set #I2S-1C)

1	Pair Doors #**1.01.E.04**	CORR. from MECH. RM. 1.01.E.04	RHRA
1	Pair Doors #**1.01.F.04**	CORR. from FLEX SPACE 1.01.F.04	RHRA
1	Pair Doors #**2.01.E.06**	CORR. 2.01.E.28 from AHU 2.01.E.06	RHRA
1	Pair Doors #**2.01.F.05**	CORR. to MECH. RM. 2.01.F.05	RHA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP C200CE

28	Hinges	5BB1 4 1/2 x 4 1/2 NRP		652	IV
4	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
4	Flush Bolt	FB31T 36"		US32D	IV
3	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
4	LFIC Core	32N2201		26	ME
4	Coordinator	3780		US28	AB
8	Closer	4040XP SCUSH TBWMS		AL	LC
8	Protection Plate	8400 10" X 35" B-CS		US32D	IV
4	Wire Harness	CON-38P			SC
8	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
4	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
4	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
8	Meeting Stile	328AA 108"			ZE
4	Weatherstrip	8303AA 1 x 72" 2 x 108"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-1C:1 (Set #I2S-1C)

1	Pair Doors #**1.01.E.20**	CORR. 1.01.E.30 from MECH. 1.01.E.20	RHRA
1	Pair Doors #**1.01.F.07**	CORR. 1.01.E.30 from MECH. RM. 1.01.F.07	RHRA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1 x 45Min

Note: HARDWARE GROUP C200CE

14	Hinges	5BB1 4 1/2 x 4 1/2 NRP		652	IV
2	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
2	Flush Bolt Kit	FB32 36"		US32D	IV
2	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
2	LFIC Core	32N2201		26	ME
2	Coordinator	3780		US28	AB
4	Closer	4040XP SCUSH TBWMS		AL	LC
4	Protection Plate	8400 10" X 35" B-CS		US32D	IV
2	Wire Harness	CON-38P			SC
4	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
2	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
4	Meeting Stile	328AA 108"			ZE
2	Weatherstrip	8303AA 1 x 72" 2 x 108"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-1E (Set #I2S-1E)

1	Pair Doors #**1.01.A.06A**	CORR.1.01.A.12 from FCA GALLERY A2 1.01.A.06	RHRA
1	Pair Doors #**1.01.B.06A**	CORR. 1.01B.12 from FCA GALLERY B2 1.01.B.06	RHRA
1	Pair Doors #**1.01.C.06A**	CORR. 1.01.C.15 from FCA GALLERY C2 1.01.C.06	RHRA
1	Pair Doors #**1.01.C.06B**	CORR. 1.01.C.17 from FCA GALLERY C2 1.01.C.06	RHRA
1	Pair Doors #**1.01.D.06A**	CORR. from FCA GALLERY D2 1.01.D.06	RHRA
1	Pair Doors #**1.01.D.06B**	CORR. from FCA GALLERY D2 1.01.D.06	RHRA
1	Pair Doors #**1.01.N.07A**	ALCOVE FOR EQUIP 1.01.N.24 from FCA GALLERY N1.2 1.01.N.07	RHRA
1	Pair Doors #**1.01.N.10A**	ALCOVE FOR EQUIP 1.01.N.27 from FCA GALLERY N2.2 1.01.N.10	RHRA
1	Pair Doors #**1.01.N.13**	CORR. 1.01B.12 from FCA GALLERY N3.2 1.01.N.13	RHRA
1	Pair Doors #**1.01.N.16**	CORR.1.01.A.12 from FCA GALLERY N4.2 1.01.N.16	RHRA
1	Pair Doors #**2.01.A.06A**	CORR. 2.01.A.15 from FCA GALLERY A2 2.01.A.06	RHRA
1	Pair Doors #**2.01.B.06A**	CORR. 2.01.B.15 from FCA GALLERY B2 2.01.B.06	RHRA
1	Pair Doors #**2.01.C.06A**	CORR. 2.01.C.18 from FCA GALLERY C2 2.01.C.06	RHRA
1	Pair Doors #**2.01.C.06B**	CORR. 2.01.C.17 from FCA GALLERY C2 2.01.C.06	RHRA
1	Pair Doors #**2.01.D.06A**	CORR. 2.01.D.17 from FCA GALLERY D2 2.01.D.06	RHRA
1	Pair Doors #**2.01.D.06B**	CORR. from FCA GALLERY D2 2.01.D.06	RHRA

Opening Description: 2 - 3' 6" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1

Note: HARDWARE GROUP C200CGW

112	Hinges	5BB1 HW 5 x 4 1/2 NRP		652	IV
16	Hinges	5BB1 HW 5 x 4 1/2 CON TW8		652	IV
16	Flush Bolt	FB31T 36"		US32D	IV
16	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
16	LFIC Core	32N2201		26	ME
16	Coordinator	3780		US28	AB
32	Closer	4040XP SCUSH TBWMS		AL	LC
32	Protection Plate	8400 10" X 41" B-CS		US32D	IV
16	Wire Harness	CON-44P			SC
32	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
16	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
16	Door Seal	488S-BK 8'			ZE

Heading #I2S-1E (Set #I2S-1E)

Note: APPLY TO DOOR HEAD ONLY

32	Meeting Stile	328AA 108"	ZE
16	Weatherstrip	8303AA 1 x 84" 2 x 108"	ZE
32	Auto Door Bottom	355AA 42"	ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-1E:WI (Set #I2S-1E)

1	Pair Doors #**1.01.B.03A**	CORR. 1.01B.12 from FCA GALLERY B1 1.01.B.03	RHRA
1	Pair Doors #**1.01.C.03B**	CORR. 1.01.C.17 from FCA GALLERY C1 1.01.C.03	RHRA
1	Pair Doors #**1.01.D.03A**	CORR. from FCA GALLERY D1 1.01.D.03	RHRA
1	Pair Doors #**1.01.N.09A**	CORR. from FCA GALLERY N2.1 1.01.N.09	RHRA
1	Pair Doors #**1.01.N.15**	CORR. from FCA GALLERY N4.1 1.01.N.15	RHRA
1	Pair Doors #**2.01.B.03A**	CORR. 2.01.B.15 from FCA GALLERY B1 2.01.B.03	RHRA
1	Pair Doors #**2.01.C.03B**	CORR. 2.01.C.17 from FCA GALLERY C1 2.01.C.03	RHRA
1	Pair Doors #**2.01.D.03A**	CORR. 2.01.D.17 from FCA GALLERY D1 2.01.D.03	RHRA

Opening Description: 2 - 3' 6" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1

Note: HARDWARE GROUP C200CGW

56	Hinges	5BB1 HW 5 x 4 1/2 NRP		652	IV
8	Hinges	5BB1 HW 5 x 4 1/2 CON TW8		652	IV
8	Flush Bolt	FB31T 36"		US32D	IV
8	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
8	LFIC Core	32N2201		26	ME
8	Coordinator	3780		US28	AB
8	Closer	4040XP RWPA TBWMS		AL	LC
8	Closer	4040XP SCUSH TBWMS		AL	LC
16	Protection Plate	8400 10" X 41" B-CS		US32D	IV
8	Wall Stop	WS406/407CCV		US32D	IV
8	Wire Harness	CON-44P			SC
16	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
8	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
8	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
16	Meeting Stile	328AA 108"			ZE
8	Weatherstrip	8303AA 1 x 84" 2 x 108"			ZE
16	Auto Door Bottom	355AA 42"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-1E:WA (Set #I2S-1E)

1	Pair Doors #**1.01.A.03A**	CORR.1.01.A.12 from FCA GALLERY A1 1.01A.03	RHRA
1	Pair Doors #**1.01.C.03A**	CORR. 1.01.C.15 from FCA GALLERY C1 1.01.C.03	RHRA
1	Pair Doors #**1.01.D.03B**	CORR. from FCA GALLERY D1 1.01.D.03	RHRA
1	Pair Doors #**1.01.N.06A**	CORR. from FCA GALLERY N1.1 1.01.N.06	RHRA
1	Pair Doors #**1.01.N.12**	CORR. 1.01B.12 from FCA GALLERY N3.1 1.01.N.12	RHRA
1	Pair Doors #**2.01.A.03A**	CORR. 2.01.A.15 from FCA GALLERY A1 2.01.A.03	RHRA
1	Pair Doors #**2.01.C.03A**	CORR. 2.01.C.18 from ELECTRICAL RM. C 2.01.C.02	RHRA
1	Pair Doors #**2.01.D.03B**	CORR. from FCA GALLERY D1 2.01.D.03	RHRA

Opening Description: 2 - 3' 6" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1

Note: HARDWARE GROUP C200CGW

56	Hinges	5BB1 HW 5 x 4 1/2 NRP		652	IV
8	Hinges	5BB1 HW 5 x 4 1/2 CON TW8		652	IV
8	Flush Bolt	FB31T 36"		US32D	IV
8	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
8	LFIC Core	32N2201		26	ME
8	Coordinator	3780		US28	AB
8	Closer	4040XP RWPA TBWMS		AL	LC
8	Closer	4040XP SCUSH TBWMS		AL	LC
16	Protection Plate	8400 10" X 41" B-CS		US32D	IV
8	Wall Stop	WS406/407CCV		US32D	IV
8	Wire Harness	CON-44P			SC
16	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
8	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
8	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
16	Meeting Stile	328AA 108"			ZE
8	Weatherstrip	8303AA 1 x 84" 2 x 108"			ZE
16	Auto Door Bottom	355AA 42"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-1E:1 (Set #I2S-1E)

1	Pair Doors #**1.01.A.06B**	CORR. 1.01.C.15 from FCA GALLERY A2 1.01.A.06	RHRA
1	Pair Doors #**1.01.B.06B**	CORR. 1.01.D.17 from FCA GALLERY B2 1.01.B.06	RHRA
1	Pair Doors #**2.01.A.06B**	CORR. 2.01.C.18 from FCA GALLERY A2 2.01.A.06	RHRA
1	Pair Doors #**2.01.B.06B**	CORR. 2.01.D.17 from FCA GALLERY B2 2.01.B.06	RHRA

Opening Description: 2 - 3' 6" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1 x 90Min

Note: HARDWARE GROUP C200CGW

28	Hinges	5BB1 HW 5 x 4 1/2 NRP		652	IV
4	Hinges	5BB1 HW 5 x 4 1/2 CON TW8		652	IV
4	Flush Bolt Kit	FB32 36"		US32D	IV
4	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
4	LFIC Core	32N2201		26	ME
4	Coordinator	3780		US28	AB
8	Closer	4040XP SCUSH TBWMS		AL	LC
8	Protection Plate	8400 10" X 41" B-CS		US32D	IV
4	Wire Harness	CON-44P			SC
8	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
4	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
4	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
8	Meeting Stile	328AA 108"			ZE
4	Weatherstrip	8303AA 1 x 84" 2 x 108"			ZE
8	Auto Door Bottom	355AA 42"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-1E:1WI (Set #I2S-1E)

1	Pair Doors #**1.01.A.03B**	CORR. 1.01.C.15 from FCA GALLERY A1 1.01A.03	RHRA
1	Pair Doors #**2.01.A.03B**	CORR. 2.01.C.18 from FCA GALLERY A1 2.01.A.03	RHRA

Opening Description: 2 - 3' 6" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1 x 90Min

Note: HARDWARE GROUP C200CGW

14	Hinges	5BB1 HW 5 x 4 1/2 NRP		652	IV
2	Hinges	5BB1 HW 5 x 4 1/2 CON TW8		652	IV
2	Flush Bolt Kit	FB32 36"		US32D	IV
2	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
2	LFIC Core	32N2201		26	ME
2	Coordinator	3780		US28	AB
2	Closer	4040XP RWPA TBWMS		AL	LC
2	Closer	4040XP SCUSH TBWMS		AL	LC
4	Protection Plate	8400 10" X 41" B-CS		US32D	IV
2	Wall Stop	WS406/407CCV		US32D	IV
2	Wire Harness	CON-44P			SC
4	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
2	Door Seal	488S-BK 8'			ZE
4	Meeting Stile	328AA 108"			ZE
2	Weatherstrip	8303AA 1 x 84" 2 x 108"			ZE
4	Auto Door Bottom	355AA 42"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-1E:1WA (Set #I2S-1E)

1	Pair Doors #**1.01.B.03B**	CORR. 1.01.D.17 from FCA GALLERY B1 1.01.B.03	RHRA
1	Pair Doors #**2.01.B.03B**	CORR. 2.01.D.17 from FCA GALLERY B1 2.01.B.03	RHRA

Opening Description: 2 - 3' 6" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1 x 90Min

Note: HARDWARE GROUP C200CGW

14	Hinges	5BB1 HW 5 x 4 1/2 NRP		652	IV
2	Hinges	5BB1 HW 5 x 4 1/2 CON TW8		652	IV
2	Flush Bolt Kit	FB32 36"		US32D	IV
2	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
2	LFIC Core	32N2201		26	ME
2	Coordinator	3780		US28	AB
2	Closer	4040XP RWPA TBWMS		AL	LC
2	Closer	4040XP SCUSH TBWMS		AL	LC
4	Protection Plate	8400 10" X 41" B-CS		US32D	IV
2	Wall Stop	WS406/407CCV		US32D	IV
2	Wire Harness	CON-44P			SC
4	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
2	Door Seal	488S-BK 8'			ZE
4	Meeting Stile	328AA 108"			ZE
2	Weatherstrip	8303AA 1 x 84" 2 x 108"			ZE
4	Auto Door Bottom	355AA 42"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-2B (Set #I1S-2B)

1	Single Door #**1.01.E.23**	CORR. 1.01.E.25 to EMERGENCY SUPPLY 1.01.E.23	RH
1	Single Door #**2.01.E.25**	CORR. 2.01.E.23 to EMERGENCY SUPPLY 2.01.E.25	LH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP C201E

2	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
4	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	LH	626	SC
2	LFIC Core	32N2201		26	ME
2	Closer	4040XP RWPA TBWMS		AL	LC
2	Protection Plate	8400 10" X 34" B-CS		US32D	IV
2	Wall Stop	WS406/407CCV		US32D	IV
2	Wire Harness	CON-38P			SC
2	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
2	Weatherstrip	8303AA 1 x 36" 2 x 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-2C (Set #I1S-2C)

1	Single Door #**1.01.D.16**	CORR. to MECH. RM. 1.01.D.16	RH
1	Single Door #**2.01.D.16**	CORR. to MECH. RM. 2.01.D.16	RH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP C201EW

4	Hinges	5BB1 HW 4 1/2 x 4 1/2		652	IV
2	Hinge	5BB1 HW TW8 CON 4 1/2" x 4 1/2"		652	IV
2	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
2	LFIC Core	32N2201		26	ME
2	Closer	4040XP RWPA TBWMS		AL	LC
2	Protection Plate	8400 10" X 34" B-CS		US32D	IV
2	Wall Stop	WS406/407CCV		US32D	IV
2	Wire Harness	CON-38P			SC
2	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
2	Weatherstrip	8303AA 1 x 36" 2 x 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-2D (Set #I1S-2D)

1	Single Door #**1.01.A.08**	CORR.1.01.A.12 to SPRINKLER RISER RM. 1.01.A.08	RH
1	Single Door #**1.01.A.09**	CORR.1.01.A.12 to FLEX SPACE 1.01.A.09	LH
1	Single Door #**1.01.B.09**	CORR. 1.01B.12 to SPRINKLER RISER RM. 1.01.B.09	RH
1	Single Door #**1.01.C.12**	CORR. 1.01.C.17 to SPRINKLER RISER RM. 1.01.C.12	RH
1	Single Door #**1.01.D.12**	CORR. to SPRINKLER RISER RM. 1.01.D.12	RH
1	Single Door #**1.01.F.16**	CORR. 1.01.F.22 to TESTING LAB 1.01.F.16	LH
1	Single Door #**1.01.F.21**	SHIPPING & RECEIVING 1.01.F.05 to SHIPPING & RECEIVING OFFICE 1.01.F.21	LH
1	Single Door #**2.01.A.08**	CORR. 2.01.A.15 to SPRINKLER RISER RM. 2.01.A.08	RH
1	Single Door #**2.01.B.09**	CORR. 2.01.B.15 to SPRINKLER RISER RM. 2.01B.09	RH
1	Single Door #**2.01.C.12**	CORR. 2.01.C.17 to SPRINKLER RISER RM. 2.01.C.12	RH
1	Single Door #**2.01.D.12**	CORR. to SPRINKLER RISER RM. 2.01.D.12	RH
1	Single Door #**2.01.F.21**	SHIPPING & RECEIVING 2.01.F.06 to SHIPPING & RECEIVING OFFICE 2.01.F.21	RH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1 (1.01.A.08, 1.01.A.09, 1.01.B.09, 1.01.C.12, 1.01.D.12, 1.01.F.16, 2.01.A.08, 2.01.B.09, 2.01.C.12, 2.01.D.12)
3' 0" x 7' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1 (1.01.F.21, 2.01.F.21)

Note: HARDWARE GROUP C201G

12	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
24	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
9	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
3	Electrified Mortise Lockset	L9092 EU T 03N CON RX	LH	626	SC
12	LFIC Core	32N2201		26	ME
12	Closer	4040XP RWPA TBWMS		AL	LC
12	Protection Plate	8400 10" X 34" B-CS		US32D	IV
12	Wall Stop	WS406/407CCV		US32D	IV
12	Wire Harness	CON-38P			SC
12	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
12	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC

Heading #I1S-2D (Set #I1S-2D)

12	Weatherstrip	8303AA 1 x 36" 2 x 84"	ZE
12	Auto Door Bottom	355AA 36"	ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-2D:1 (Set #I1S-2D)

1	Single Door #**1.01.E.07**	CORR. 1.01.E.28 to MOTHER'S RM. 1.01.E.07	RH
1	Single Door #**1.01.E.21**	CORR. 1.01.E.30 to DRY JAN. 1.01.E.21	LH
1	Single Door #**1.01.F.13**	CORR. 1.01.F.22 to SECURITY TECH RM. 1.01.F.13	LH
1	Single Door #**2.01.E.08**	CORR. 2.01.E.28 to MOTHER'S RM. 2.01.E.08	LH
1	Single Door #**2.01.E.21**	CORR. 2.01.E.30 to DRY JAN. 2.01.E.21	RH
1	Single Door #**2.01.F.13**	CORR. 2.01.F.22 to SECURITY TECH RM. 2.01.F.13	RH
1	Single Door #**2.01.F.16**	CORR. 2.01.F.22 to TESTING LAB 2.01.F.16	RH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x WD Type WD-F x HMF Type HM-F1

Note: HARDWARE GROUP C201G

7	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
14	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
4	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
3	Electrified Mortise Lockset	L9092 EU T 03N CON RX	LH	626	SC
7	LFIC Core	32N2201		26	ME
7	Closer	4040XP RWPA TBWMS		AL	LC
7	Protection Plate	8400 10" X 34" B-CS		US32D	IV
7	Wall Stop	WS406/407CCV		US32D	IV
7	Wire Harness	CON-38P			SC
7	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
7	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
7	Weatherstrip	8303AA 1 x 36" 2 x 84"			ZE
7	Auto Door Bottom	360AA 36" Z49			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-2D:3 (Set #I1S-2D)

1	Single Door #**1.01.B.08**	CORR. 1.01B.12 to FLEX SPACE 1.01.B.08			RH

Opening Description: 3' 6" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP C201G

2	Hinges	5BB1 5 x 4 1/2		652	IV
1	Hinge	5BB1 TW8 CON 5" x 4 1/2"		652	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
1	LFIC Core	32N2201		26	ME
1	Closer	4040XP RWPA TBWMS		AL	LC
1	Protection Plate	8400 10" X 40" B-CS		US32D	IV
1	Wall Stop	WS406/407CCV		US32D	IV
1	Wire Harness	CON-44P			SC
1	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
1	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
1	Weatherstrip	8303AA 1 x 42" 2 x 84"			ZE
1	Auto Door Bottom	355AA 42"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-2F (Set #I1S-2F)

1	Single Door #**1.01.F.08**	CORR. 1.01.E.30 to WET JANITOR 1.01.F.08			RH
1	Single Door #**2.01.F.08**	CORR. 2.01.E.30 to WET JANITOR 2.01.F.08			LH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x WD Type WD-F x HMF Type HM-F1

Note: HARDWARE GROUP C201GP

2	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
4	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	LH	626	SC
2	LFIC Core	32N2201		26	ME
2	Closer	4040XP RWPA TBWMS		AL	LC
2	Protection Plate	8400 34" X 34" B-CS		US32D	IV
2	Wall Stop	WS406/407CCV		US32D	IV
2	Wire Harness	CON-38P			SC
2	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
2	Weatherstrip	8303AA 1 x 36" 2 x 84"			ZE
2	Auto Door Bottom	360AA 36" Z49			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-2F:1 (Set #I1S-2F)

1	Single Door #**1.01.N.30**	CORR. to JAN. MOP CLOSET 1.01.N.30		LH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP C201GP

1	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
2	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	LH	626	SC
1	LFIC Core	32N2201		26	ME
1	Closer	4040XP RWPA TBWMS		AL	LC
1	Protection Plate	8400 34" X 34" B-CS		US32D	IV
1	Wall Stop	WS406/407CCV		US32D	IV
1	Wire Harness	CON-38P			SC
1	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
1	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
1	Weatherstrip	8303AA 1 x 36" 2 x 84"			ZE
1	Auto Door Bottom	355AA 36"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-2A (Set #I2S-2A)

1	Pair Doors #**1.01.F.15**	CORR. 1.01.F.22 to FACILITY MAINTENANCE 1.01.F.15	RHA
1	Pair Doors #**2.01.F.15**	CORR. 2.01.F.22 to FACILITY MAINTENANCE 2.01.F.15	RHA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP C206E

2	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
14	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
2	Flush Bolt	FB31T 36"		US32D	IV
2	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
2	LFIC Core	32N2201		26	ME
2	Coordinator	3780		US28	AB
4	Closer	4040XP RWPA 4040-18TJ TBWMS		AL	LC
	Note: Mount using Special Template ST-1630				
4	Overhead Stop	104S		US32D	GL
4	Protection Plate	8400 10" X 35" B-CS		US32D	IV
2	Wire Harness	CON-38P			SC
4	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
2	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
4	Meeting Stile	328AA 108"			ZE
2	Weatherstrip	8303AA 1 x 72" 2 x 108"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-2D (Set #I2S-2D)

1	Pair Doors #**1.01.F.06**	SHIPPING & RECEIVING 1.01.F.05 to SHIPPING & RECIEVING STOR. 1.01.F.06			RHA
1	Pair Doors #**2.01.F.07**	SHIPPING & RECEIVING 2.01.F.06 to SHIPPING & RECEIVING STOR. 2.01.F.07			RHA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1

Note: HARDWARE GROUP C206EP

2	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
14	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
2	Flush Bolt	FB31T 36"		US32D	IV
2	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
2	LFIC Core	32N2201		26	ME
2	Coordinator	3780		US28	AB
4	Closer	4040XP RWPA 4040-18TJ TBWMS		AL	LC
	Note: Mount using Special Template ST-1630				
4	Overhead Stop	104S		US32D	GL
4	Protection Plate	8400 34" X 35" B-CS		US32D	IV
2	Wire Harness	CON-38P			SC
4	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
2	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
4	Meeting Stile	328AA 108"			ZE
2	Weatherstrip	8303AA 1 x 72" 2 x 108"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-3B (Set #I1S-3B)

1	Single Door #**1.01.F.18**	CORR. 1.01.F.22 from FIRE RISER RM. 1.01.F.18			LHR
1	Single Door #**2.01.F.18**	CORR. 2.01.F.22 from FIRE RISER RM. 2.01.F.18			RHR

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP C207GP

4	Hinges	5BB1 4 1/2 x 4 1/2 NRP		652	IV
2	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	LHR	626	SC
2	LFIC Core	32N2201		26	ME
2	Closer	4040XP RWPA 4040-18TJ TBWMS		AL	LC
	Note: Mount using Special Template ST-1630				
2	Overhead Stop	104S		US32D	GL
2	Protection Plate	8400 34" X 34" B-CS		US32D	IV
2	Wire Harness	CON-38P			SC
2	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
2	Weatherstrip	8303AA 1 x 36" 2 x 84"			ZE
2	Auto Door Bottom	355AA 36"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY LEVER.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-4A.AL1 (Set #I1S-4A.AL1)

1	Single Door #**1.01.F.10**	CORR. 1.01.E.30 to SECONDARY SECURITY OFFICE 1.02.F.12			RH

Opening Description: 3' 1" x 7' 1/2" Type AL Type AL

Note: HARDWARE GROUP C711ACZ

1	LFIC Core	32N2201		26	ME
1	Rim Hsg w/Const Core	20-057 ICX		626	SC

Note: BALANCE OF HARDWARE BY STOREFRONT SUPPLIER

Heading #I1S-4A.AL2 (Set #I1S-4A.AL2)

1	Single Door #**2.01.F.10**	CORR. 2.01.E.30 to SECONDARY SECURITY OFFICE 2.01.F.12			LH

Opening Description: 2' 11 1/4" x 7' 0" Type AL Type AL

Note: HARDWARE GROUP C711ACZ

1	LFIC Core	32N2201		26	ME
1	Rim Hsg w/Const Core	20-057 ICX		626	SC

Note: BALANCE OF HARDWARE BY STOREFRONT SUPPLIER

Heading #E1S-1A (Set #E1S-1A)

1	Single Door #**1.01.F.20A**	EXT. from SECURE PACKAGE DROP VEST. 1.01.F.20	RHR
1	Single Door #**2.01.F.20A**	EXT. from SECURE PACKAGE DROP VEST. 2.01.F.19	LHR

Opening Description: 3' 6" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP C715AZ

1	Continuous Hinge Properties: EPT-Model/Location=40	112XY 83" EPT	RH	628	IV
1	Continuous Hinge Properties: EPT-Model/Location=40	112XY 83" EPT	LH	628	IV
2	Exit Device	QEL RX 98NL-OP x 110MD-NL 425-SNB (QTY-6) 48" CON		US26D	VO
2	LFIC Core	32N2201		26	ME
2	Rim Hsg w/Const Core	20-057 ICX		626	SC
2	Door Pull	8190HD-0		US32D	IV
2	Closer	4040XP SCUSH TBWMS		AL	LC
2	Electric Power Transfer	EPT 10 CON		SP28	VO
2	Power Supply Extension	CON-6W			SC
2	Wire Harness	CON-6P			SC
2	Power Supply	PS902			LO
2	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Door Sweep	8197AA 42"			ZE
2	Weatherstrip	475AA 1 x 42" 2 x 84"			ZE
2	Threshold	625A 42"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-FREE EGRESS BY THE PUSH PAD.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.
-OMIT POWER SUPPLY WHERE PROVIDED BY SECURITY.

Heading #E1S-1A.AL (Set #E1S-1A.AL)

1	Single Door #**1.01.F.11A**	EXT. from ENTRY VEST. 1.01.F.11	RHR
1	Single Door #**2.01.F.11A**	EXT. from ENTRY VEST. 2.01.F.11	LHR

Opening Description: 3' 6" x 7' 0" Type AL Type AL

Note: HARDWARE GROUP C715AZ

2	LFIC Core	32N2201	26	ME
2	Rim Hsg w/Const Core	20-057 ICX	626	SC

Note: BALANCE OF HARDWARE BY STOREFRONT SUPPLIER

Heading #I2S-4B (Set #I2S-4B)

1	Pair Doors #**2.01.E.02**	CORR. 2.01.B.15 to ENTRANCE FACILITY 3 2.01.E.02	RHA
1	Pair Doors #**2.01.E.03**	CORR. 2.01.B.15 to ENTRANCE FACILITY 4 2.01.E.03	RHA
1	Pair Doors #**2.01.F.03**	CORR. to ENTRANCE FACILITY 2 2.01.F.03	RHA
1	Pair Doors #**2.01.F.04**	CORR. to ENTRANCE FACILITY 1 2.01.F.04	RHA

Opening Description: 2 - 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1

Note: HARDWARE GROUP CY200CE

4	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
20	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
4	Flush Bolt	FB31T		US32D	IV
4	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
4	LFIC Core	32N2201		26	ME
4	Coordinator	3780		US28	AB
8	Closer	4040XP SCUSH TBWMS		AL	LC
8	Protection Plate	8400 10" X 35" B-CS		US32D	IV
4	Wire Harness	CON-38P			SC
8	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
4	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
4	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
4	Weatherstrip	8303AA 1 x 72" 2 x 84"			ZE
8	Meeting Stile	328AA 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-4B:1 (Set #I2S-4B)

1	Pair Doors #**2.01.F.06A**	CORR. 2.01.F.22 from SHIPPING & RECEIVING 2.01.F.06			RHRA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1

Note: HARDWARE GROUP CY200CE

7	Hinges	5BB1 4 1/2 x 4 1/2 NRP		652	IV
1	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
1	Flush Bolt	FB31T 36"		US32D	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
1	LFIC Core	32N2201		26	ME
1	Coordinator	3780		US28	AB
2	Closer	4040XP SCUSH TBWMS		AL	LC
2	Protection Plate	8400 10" X 35" B-CS		US32D	IV
1	Wire Harness	CON-38P			SC
2	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
1	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
1	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
2	Meeting Stile	328AA 108"			ZE
1	Weatherstrip	8303AA 1 x 72" 2 x 108"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-4B:1WI (Set #I2S-4B)

1	Pair Doors #**1.01.F.05B**	CORR. 1.01.F.22 from SHIPPING & RECEIVING 1.01.F.05			RHRA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1

Note: HARDWARE GROUP CY200CE

7	Hinges	5BB1 4 1/2 x 4 1/2 NRP		652	IV
1	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
1	Flush Bolt	FB31T 36"		US32D	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
1	LFIC Core	32N2201		26	ME
1	Coordinator	3780		US28	AB
1	Closer	4040XP RWPA TBWMS		AL	LC
1	Closer	4040XP SCUSH TBWMS		AL	LC
2	Protection Plate	8400 10" X 35" B-CS		US32D	IV
1	Wall Stop	WS406/407CCV		US32D	IV
1	Wire Harness	CON-38P			SC
2	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
1	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
1	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
2	Meeting Stile	328AA 108"			ZE
1	Weatherstrip	8303AA 1 x 72" 2 x 108"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-4B:1WA (Set #I2S-4B)

1	Pair Doors #**2.01.F.06B**	CORR. 2.01.F.22 from SHIPPING & RECEIVING 2.01.F.06			RHRA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1

Note: HARDWARE GROUP CY200CE

7	Hinges	5BB1 4 1/2 x 4 1/2 NRP		652	IV
1	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
1	Flush Bolt	FB31T 36"		US32D	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
1	LFIC Core	32N2201		26	ME
1	Coordinator	3780		US28	AB
1	Closer	4040XP RWPA TBWMS		AL	LC
1	Closer	4040XP SCUSH TBWMS		AL	LC
2	Protection Plate	8400 10" X 35" B-CS		US32D	IV
1	Wall Stop	WS406/407CCV		US32D	IV
1	Wire Harness	CON-38P			SC
2	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
1	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
1	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
2	Meeting Stile	328AA 108"			ZE
1	Weatherstrip	8303AA 1 x 72" 2 x 108"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-4B:1W (Set #I2S-4B)

1	Pair Doors #**2.01.F.06G**	CORR. from SHIPPING & RECEIVING 2.01.F.06			RHRA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1

Note: HARDWARE GROUP CY200CE

7	Hinges	5BB1 4 1/2 x 4 1/2 NRP		652	IV
1	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
1	Flush Bolt	FB31T 36"		US32D	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
1	LFIC Core	32N2201		26	ME
1	Coordinator	3780		US28	AB
2	Closer	4040XP RWPA TBWMS		AL	LC
2	Protection Plate	8400 10" X 35" B-CS		US32D	IV
2	Wall Stop	WS406/407CCV		US32D	IV
1	Wire Harness	CON-38P			SC
2	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
1	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
1	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
2	Meeting Stile	328AA 108"			ZE
1	Weatherstrip	8303AA 1 x 72" 2 x 108"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-4B:2 (Set #I2S-4B)

1	Pair Doors #**2.01.E.05**	CORR. 2.01.B.15 from UPS 2.01.E.05			RHRA

Opening Description: 2 - 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1 x 45Min

Note: HARDWARE GROUP CY200CE

5	Hinges	5BB1 4 1/2 x 4 1/2 NRP		652	IV
1	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
1	Flush Bolt Kit	FB32		US32D	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
1	LFIC Core	32N2201		26	ME
1	Coordinator	3780		US28	AB
2	Closer	4040XP SCUSH TBWMS		AL	LC
2	Protection Plate	8400 10" X 35" B-CS		US32D	IV
1	Wire Harness	CON-38P			SC
2	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
1	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
1	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
1	Weatherstrip	8303AA 1 x 72" 2 x 84"			ZE
2	Meeting Stile	328AA 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-4B:3 (Set #I2S-4B)

1	Pair Doors #**1.01.C.07**	CORR. 1.01.C.15 from UPS 1.01.C.07	RHRA
1	Pair Doors #**1.01.C.08**	CORR. 1.01.C.15 from UPS 1.01.C.08	RHRA
1	Pair Doors #**1.01.D.08**	CORR. from UPS 1.01.D.08	RHRA
1	Pair Doors #**1.01.D.09**	CORR. from UPS 1.01.D.09	RHRA
1	Pair Doors #**1.01.N.23**	CORR. from UPS 1.01.N.23	RHRA
1	Pair Doors #**1.01.N.28**	CORR. from UPS 1.01.N.28	RHRA
1	Pair Doors #**1.01.N.34**	CORR. 1.01B.12 from UPS 1.01.N.34	RHRA
1	Pair Doors #**1.01.N.33**	CORR. 1.01B.12 from UPS 1.01.N.33	RHRA
1	Pair Doors #**1.01.N.18**	CORR.1.01.A.12 from UPS 1.01.N.18	RHRA
1	Pair Doors #**1.01.N.17**	CORR.1.01.A.12 from UPS 1.01.N.17	RHRA
1	Pair Doors #**2.01.D.08**	CORR. 2.01.D.17 from UPS 2.01.D.08	RHRA
1	Pair Doors #**2.01.D.09**	CORR. 2.01.D.17 from UPS 2.01.D.09	RHRA
1	Pair Doors #**2.01.E.01**	CORR. 2.01.B.15 from UPS 2.01.E.01	RHRA
1	Pair Doors #**2.01.F.01**	CORR. from UPS 2.01.F.01	RHRA
1	Pair Doors #**2.01.F.02**	CORR. from UPS 2.01.F.02	RHRA

Opening Description: 2 - 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1 x 90Min

Note: HARDWARE GROUP CY200CE

75	Hinges	5BB1 4 1/2 x 4 1/2 NRP		652	IV
15	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
15	Flush Bolt Kit	FB32		US32D	IV
15	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
15	LFIC Core	32N2201		26	ME
15	Coordinator	3780		US28	AB
30	Closer	4040XP SCUSH TBWMS		AL	LC
30	Protection Plate	8400 10" X 35" B-CS		US32D	IV
15	Wire Harness	CON-38P			SC
30	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
15	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
15	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
15	Weatherstrip	8303AA 1 x 72" 2 x 84"			ZE
30	Meeting Stile	328AA 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-4B:4 (Set #I2S-4B)

1	Pair Doors #**2.01.C.07**	CORR. 2.01.C.18 from UPS 2.01.C.07	RHRA
1	Pair Doors #**2.01.C.08**	CORR. 2.01.C.18 from UPS 2.01.C.08	RHRA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1 x 90Min

Note: HARDWARE GROUP CY200CE

14	Hinges	5BB1 4 1/2 x 4 1/2 NRP		652	IV
2	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
2	Flush Bolt Kit	FB32 36"		US32D	IV
2	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
2	LFIC Core	32N2201		26	ME
2	Coordinator	3780		US28	AB
4	Closer	4040XP SCUSH TBWMS		AL	LC
4	Protection Plate	8400 10" X 35" B-CS		US32D	IV
2	Wire Harness	CON-38P			SC
4	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
2	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
4	Meeting Stile	328AA 108"			ZE
2	Weatherstrip	8303AA 1 x 72" 2 x 108"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-4B:5 (Set #I2S-4B)

1	Pair Doors #**1.01.E.02**	CORR. from ENTRANCE FACILITY 1 1.01.E.02			RHRA
1	Pair Doors #**1.01.F.02**	CORR. from ENTRANCE FACILITY 2 1.01.F.02			RHRA

Opening Description: 2 - 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP CY200CE

10	Hinges	5BB1 4 1/2 x 4 1/2 NRP		652	IV
2	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
2	Flush Bolt	FB31T		US32D	IV
2	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
2	LFIC Core	32N2201		26	ME
2	Coordinator	3780		US28	AB
4	Closer	4040XP SCUSH TBWMS		AL	LC
4	Protection Plate	8400 10" X 35" B-CS		US32D	IV
2	Wire Harness	CON-38P			SC
4	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
2	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
2	Weatherstrip	8303AA 1 x 72" 2 x 84"			ZE
4	Meeting Stile	328AA 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-5B (Set #I1S-5B)

1	Single Door #**1.01.A.10**	CORR.1.01.A.12 to CONTROL PANEL 1.01.A.10	LH
1	Single Door #**1.01.C.11**	CORR. 1.01.C.17 to CONTROL PANEL 1.01.C.11	RH
1	Single Door #**1.01.D.10**	CORR. to CONTROL PANEL 1.01.D.10	RH
1	Single Door #**1.01.D.14**	CORR. to CONTROL PANEL 1.01.D.14	LH
1	Single Door #**1.01.E.26**	CORR. 1.01.E.25 to CMCC 1.01.E.26	RH
1	Single Door #**1.01.F.03**	CORR. to CARRIER MDF 2 1.01.F.03	RH
1	Single Door #**1.01.N.21**	CORR. to CONTROL PANEL 1.01.N.21	RH
1	Single Door #**1.01.N.31**	CORR. to CONTROL PANEL 1.01.N.31	LH
1	Single Door #**2.01.A.09**	CORR. 2.01.A.15 to CONTROL PANEL 2.01.A.09	LH
1	Single Door #**2.01.C.11**	CORR. 2.01.C.17 to CONTROL PANEL 2.01.C.11	RH
1	Single Door #**2.01.D.14**	CORR. to CONTROL PANEL 2.01.D.14	LH
1	Single Door #**2.01.E.26**	CORR. 2.01.E.23 to SECONDARY CMCC 2.01.E.26	LH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1 (1.01.A.10, 1.01.C.11, 1.01.D.10, 1.01.D.14, 1.01.E.26, 1.01.N.21, 1.01.N.31, 2.01.A.09, 2.01.C.11, 2.01.D.14, 2.01.E.26)
3' 0" x 7' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1 (1.01.F.03)

Note: HARDWARE GROUP CY201E

12	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
24	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
6	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
6	Electrified Mortise Lockset	L9092 EU T 03N CON RX	LH	626	SC
12	LFIC Core	32N2201		26	ME
12	Closer	4040XP RWPA TBWMS		AL	LC
12	Protection Plate	8400 10" X 34" B-CS		US32D	IV
12	Wall Stop	WS406/407CCV		US32D	IV
12	Wire Harness	CON-38P			SC
12	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
12	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
12	Weatherstrip	8303AA 1 x 36" 2 x 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CARD READER BYPASSES ALARM ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-5B:1 (Set #I1S-5B)

1	Single Door #**2.01.D.10**	CORR. 2.01.D.17 to CONTROL PANEL 2.01.D.10			RH

Opening Description: 3' 6" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP CY201E

2	Hinges	5BB1 5 x 4 1/2		652	IV
1	Hinge	5BB1 TW8 CON 5" x 4 1/2"		652	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
1	LFIC Core	32N2201		26	ME
1	Closer	4040XP RWPA TBWMS		AL	LC
1	Protection Plate	8400 10" X 40" B-CS		US32D	IV
1	Wall Stop	WS406/407CCV		US32D	IV
1	Wire Harness	CON-44P			SC
1	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
1	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
1	Weatherstrip	8303AA 1 x 42" 2 x 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CARD READER BYPASSES ALARM ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-5C (Set #I1S-5C)

1	Single Door #**2.01.B.07**	CORR. 2.01.B.15 to GS.IDF 2B1 2.01.B.07			RH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1

Note: HARDWARE GROUP CY201EW

2	Hinges	5BB1 HW 4 1/2 x 4 1/2		652	IV
1	Hinge	5BB1 HW TW8 CON 4 1/2" x 4 1/2"		652	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
1	LFIC Core	32N2201		26	ME
1	Closer	4040XP RWPA TBWMS		AL	LC
1	Protection Plate	8400 10" X 34" B-CS		US32D	IV
1	Wall Stop	WS406/407CCV		US32D	IV
1	Wire Harness	CON-38P			SC
1	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
1	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
1	Weatherstrip	8303AA 1 x 36" 2 x 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CARD READER BYPASSES ALARM ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-5C:1 (Set #I1S-5C)

1	Single Door #**1.01.B.10**	CORR. 1.01B.12 to CONTROL PANEL 1.01.B.10	LH
1	Single Door #**1.01.E.03**	CORR. to CARRIER MDF 1 1.01.E.03	RH
1	Single Door #**2.01.A.10**	CORR. 2.01.A.15 to GS.IDF 2A2 2.01.A.10	LH
1	Single Door #**2.01.A.11**	CORR. 2.01.C.18 to GS.IDF. 2A3 2.01.A.11	LH
1	Single Door #**2.01.B.08**	CORR. 2.01.B.15 to CONTROL PANEL 2.01.B.08	RH
1	Single Door #**2.01.B.10**	CORR. 2.01.B.15 to GS.IDF 2B22.01.B.10	LH
1	Single Door #**2.01.B.11**	CORR. 2.01.D.17 to GS.IDF 2B3 2.01.B.11	LH
1	Single Door #**2.01.B.14**	CORR. 2.01.D.17 to GS.IDF 2B4 2.01.B.14	RH
1	Single Door #**2.01.C.10**	CORR. 2.01.C.17 to GS.IDF 2C1 2.01.C.10	LH
1	Single Door #**2.01.C.14**	CORR. 2.01.C.17 to GS.IDF 2C2 2.01.C.14	RH
1	Single Door #**2.01.D.11**	CORR. to GS.IDF 2D1 2.01.D.11	LH
1	Single Door #**2.01.D.15**	CORR. to GS.IDF 2D2 2.01.D.15	RH

Opening Description: 3' 6" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1 (1.01.B.10, 2.01.B.08)
3' 6" x 7' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1 (1.01.E.03, 2.01.A.10, 2.01.A.11, 2.01.B.10, 2.01.B.11, 2.01.B.14, 2.01.C.10, 2.01.C.14, 2.01.D.11, 2.01.D.15)

Note: HARDWARE GROUP CY201EW

12	Hinges	5BB1 HW 5 x 4 1/2 CON TW8		652	IV
24	Hinges	5BB1 HW 5 x 4 1/2		652	IV
5	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
7	Electrified Mortise Lockset	L9092 EU T 03N CON RX	LH	626	SC
12	LFIC Core	32N2201		26	ME
12	Closer	4040XP RWPA TBWMS		AL	LC
12	Protection Plate	8400 10" X 40" B-CS		US32D	IV
12	Wall Stop	WS406/407CCV		US32D	IV
12	Wire Harness	CON-44P			SC
12	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
12	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
12	Weatherstrip	8303AA 1 x 42" 2 x 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CARD READER BYPASSES ALARM ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-5C:2 (Set #I1S-5C)

1	Single Door #**1.01.A.11**	CORR.1.01.A.12 to GS.IDF 1A2 1.01.A.11	LH
1	Single Door #**1.01.A.13**	CORR.1.01.A.12 to GS.IDF 1A3 1.01.A.13	LH
1	Single Door #**1.01.B.07**	CORR. 1.01B.12 to GS.IDF 1B1 1.01.B.07	RH
1	Single Door #**1.01.B.11**	CORR. 1.01B.12 to GS.IDF. 1B2 1.01.B.11	LH
1	Single Door #**1.01.B.13**	CORR. 1.01.D.17 to GS.IDF 1B3 1.01.B.13	LH
1	Single Door #**1.01.B.16**	CORR. 1.01.D.17 to GS.IDF 1B4 1.01.B.16	RH
1	Single Door #**1.01.C.10**	CORR. 1.01.C.17 to GS.IDF 1C1 1.01.C.10	LH
1	Single Door #**1.01.C.14**	CORR. 1.01.C.17 to GS.IDF 1C2 1.01.C.14	RH
1	Single Door #**1.01.D.11**	CORR. to GS.IDF 1D1	LH
1	Single Door #**1.01.D.15**	CORR. to GS.IDF 1D2 1.01.D.15	RH

Opening Description: 3' 6" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1

Note: HARDWARE GROUP CY201EW

10	Hinges	5BB1 HW 5 x 4 1/2 CON TW8		652	IV
30	Hinges	5BB1 HW 5 x 4 1/2		652	IV
4	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
6	Electrified Mortise Lockset	L9092 EU T 03N CON RX	LH	626	SC
10	LFIC Core	32N2201		26	ME
10	Closer	4040XP RWPA TBWMS		AL	LC
10	Protection Plate	8400 10" X 40" B-CS		US32D	IV
10	Wall Stop	WS406/407CCV		US32D	IV
10	Wire Harness	CON-44P			SC
10	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
10	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
10	Weatherstrip	8303AA 1 x 42" 2 x 108"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CARD READER BYPASSES ALARM ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-5D (Set #I1S-5D)

1	Single Door #**1.01.C.13**	CORR. 1.01.C.17 from LIGHTING INVERTER RM. 1.01.C.13	RHR
1	Single Door #**1.01.D.07**	CORR. from LIGHTING INVERTER RM. 1.01.D.07	LHR
1	Single Door #**2.01.C.13**	CORR. 2.01.C.17 from LIGHTING INVERTER RM. 2.01.C.13	RHR
1	Single Door #**2.01.D.07**	CORR. 2.01.D.17 from LIGHTING INVERTER RM. 2.01.D.07	LHR

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1 x 90Min

Note: HARDWARE GROUP CY201G

8	Hinges	5BB1 4 1/2 x 4 1/2 NRP		652	IV
4	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
2	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
2	Electrified Mortise Lockset	L9092 EU T 03N CON RX	LHR	626	SC
4	LFIC Core	32N2201		26	ME
4	Closer	4040XP RWPA TBWMS		AL	LC
4	Protection Plate	8400 10" X 34" B-CS		US32D	IV
4	Wall Stop	WS406/407CCV		US32D	IV
4	Wire Harness	CON-38P			SC
4	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
4	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
4	Weatherstrip	8303AA 1 x 36" 2 x 84"			ZE
4	Auto Door Bottom	355AA 36"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-5D:1 (Set #I1S-5D)

1	Single Door #**1.01.E.06**	CORR. 1.01.E.28 to LIGHTING INVERTER RM. 1.01.E.06	LH
1	Single Door #**2.01.E.07**	CORR. 2.01.E.28 to LIGHTING INVERTER RM. 2.01.E.07	RH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1 x 90Min

Note: HARDWARE GROUP CY201G

2	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
4	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	LH	626	SC
2	LFIC Core	32N2201		26	ME
2	Closer	4040XP RWPA TBWMS		AL	LC
2	Protection Plate	8400 10" X 34" B-CS		US32D	IV
2	Wall Stop	WS406/407CCV		US32D	IV
2	Wire Harness	CON-38P			SC
2	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
2	Weatherstrip	8303AA 1 x 36" 2 x 84"			ZE
2	Auto Door Bottom	355AA 36"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-5A (Set #I2S-5A)

1	Pair Doors #**1.01.N.32**	CORR. 1.01B.12 to ENTRANCE FACILITY 3 1.01.N.32			RHA
1	Pair Doors #**1.01.N.19**	CORR.1.01.A.12 to ENTRANCE FACILITY 4 1.01.N.19			RHA

Opening Description: 2 - 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP CY206E

2	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
10	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
2	Flush Bolt	FB31T		US32D	IV
2	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
2	LFIC Core	32N2201		26	ME
2	Coordinator	3780		US28	AB
4	Closer	4040XP RWPA 4040-18TJ TBWMS		AL	LC
	Note: Mount using Special Template ST-1630				
4	Overhead Stop	104S		US32D	GL
4	Protection Plate	8400 10" X 35" B-CS		US32D	IV
2	Wire Harness	CON-38P			SC
4	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
2	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
2	Weatherstrip	8303AA 1 x 72" 2 x 84"			ZE
4	Meeting Stile	328AA 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-5A:1 (Set #I2S-5A)

1	Pair Doors #**1.01.C.09**	CORR. 1.01.C.15 to SPOKE TECH RM. 1.01.C.09	RHA
1	Pair Doors #**1.01.F.14**	CORR. 1.01.F.22 to GDCC VENDOR WORK RM. 1.01.F.14	RHA
1	Pair Doors #**1.01.F.17**	CORR. 1.01.F.22 to ERAD 1.01.F.17	RHA
1	Pair Doors #**2.01.C.09**	CORR. 2.01.C.18 to SPOKE TECH RM. 2.01.C.09	RHA
1	Pair Doors #**2.01.F.14**	CORR. 2.01.F.22 to GDCC VENDOR WORK RM. 2.01.F.14	RHA
1	Pair Doors #**2.01.F.17**	CORR. 2.01.F.22 to ERAD 2.01.F.17	RHA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1 (1.01.F.14, 1.01.F.17, 2.01.F.14, 2.01.F.17)
2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1 (1.01.C.09, 2.01.C.09)

Note: HARDWARE GROUP CY206E

6	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
42	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
6	Flush Bolt	FB31T 36"		US32D	IV
6	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
6	LFIC Core	32N2201		26	ME
6	Coordinator	3780		US28	AB
12	Closer	4040XP RWPA 4040-18TJ TBWMS		AL	LC
	Note: Mount using Special Template ST-1630				
12	Overhead Stop	104S		US32D	GL
12	Protection Plate	8400 10" X 35" B-CS		US32D	IV
6	Wire Harness	CON-38P			SC
12	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
6	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
6	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
12	Meeting Stile	328AA 108"			ZE
6	Weatherstrip	8303AA 1 x 72" 2 x 108"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-5A:2 (Set #I2S-5A)

1	Pair Doors #**1.01.F.05A**	CORR. 1.01.F.22 from SHIPPING & RECEIVING 1.01.F.05			RHRA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1

Note: HARDWARE GROUP CY206E

7	Hinges	5BB1 4 1/2 x 4 1/2 NRP		652	IV
1	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
1	Flush Bolt	FB31T 36"		US32D	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RHR	626	SC
1	LFIC Core	32N2201		26	ME
1	Coordinator	3780		US28	AB
2	Closer	4040XP RWPA 4040-18TJ TBWMS		AL	LC
	Note: Mount using Special Template ST-1630				
2	Overhead Stop	104S		US32D	GL
2	Protection Plate	8400 10" X 35" B-CS		US32D	IV
1	Wire Harness	CON-38P			SC
2	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
1	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
1	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
2	Meeting Stile	328AA 108"			ZE
1	Weatherstrip	8303AA 1 x 72" 2 x 108"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-5C (Set #I2S-5C)

1	Single Door #**2.01.A.07**	CORR. 2.01.A.15 to GS.IDF 2A1 2.01.A.07			RH

Opening Description: 3' 6" x 7' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1

Note: HARDWARE GROUP CY206EPW

1	Hinges	5BB1 HW 5 x 4 1/2 CON TW8		652	IV
2	Hinges	5BB1 HW 5 x 4 1/2		652	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
1	LFIC Core	32N2201		26	ME
1	Closer	4040XP RWPA TBWMS		AL	LC
1	Protection Plate	8400 34" X 40" B-CS		US32D	IV
1	Wall Stop	WS406/407CCV		US32D	IV
1	Wire Harness	CON-44P			SC
1	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
1	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
1	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
1	Weatherstrip	8303AA 1 x 42" 2 x 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-5C:1 (Set #I2S-5C)

1	Single Door #**1.01.A.07**	CORR.1.01.A.12 to GS.IDF 1A1 1.01.A.07			RH

Opening Description: 3' 6" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1

Note: HARDWARE GROUP CY206EPW

1	Hinges	5BB1 HW 5 x 4 1/2 CON TW8		652	IV
3	Hinges	5BB1 HW 5 x 4 1/2		652	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
1	LFIC Core	32N2201		26	ME
1	Closer	4040XP RWPA TBWMS		AL	LC
1	Protection Plate	8400 34" X 40" B-CS		US32D	IV
1	Wall Stop	WS406/407CCV		US32D	IV
1	Wire Harness	CON-44P			SC
1	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
1	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
1	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
1	Weatherstrip	8303AA 1 x 42" 2 x 108"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-5C:2 (Set #I2S-5C)

1	Pair Doors #**2.01.E.18B**	CORR. 2.01.E.29 to GDCC RUN OPS & FAC OPS STOR. 2.01.E.18			RHA

Opening Description: 2 - 4' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP CY206EPW

1	Hinges	5BB1 HW 5 x 4 1/2 CON TW8		652	IV
5	Hinges	5BB1 HW 5 x 4 1/2		652	IV
1	Flush Bolt	FB31T		US32D	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
1	LFIC Core	32N2201		26	ME
1	Coordinator	3780		US28	AB
2	Closer	4040XP RWPA 4040-18TJ TBWMS		AL	LC
	Note: Mount using Special Template ST-1630				
2	Overhead Stop	106S		US32D	GL
2	Protection Plate	8400 34" x 47" B-CS		US32D	IV
1	Wire Harness	CON-50P			SC
2	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
1	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
1	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
1	Weatherstrip	8303AA 1 x 96" 2 x 84"			ZE
2	Meeting Stile	328AA 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-5C:3 (Set #I2S-5C)

1	Pair Doors #**1.01.E.19B**	CORR. 1.01.E.29 to GDCC RUN OPS & FAC OPS STOR. 1.01.E.19			RHA

Opening Description: 2 - 4' 0" x 9' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP CY206EPW

1	Hinges	5BB1 HW 5 x 4 1/2 CON TW8		652	IV
7	Hinges	5BB1 HW 5 x 4 1/2		652	IV
1	Flush Bolt	FB31T 36"		US32D	IV
1	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
1	LFIC Core	32N2201		26	ME
1	Coordinator	3780		US28	AB
2	Closer	4040XP RWPA 4040-18TJ TBWMS		AL	LC
	Note: Mount using Special Template ST-1630				
2	Overhead Stop	106S		US32D	GL
2	Protection Plate	8400 34" x 47" B-CS		US32D	IV
1	Wire Harness	CON-50P			SC
2	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
1	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
1	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
1	Weatherstrip	8303AA 1 x 96" 2 x 108"			ZE
2	Meeting Stile	328AA 108"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-5B (Set #I2S-5B)

1	Pair Doors #**2.01.E.19**	CORR. 2.01.E.29 to SITE OPS SPARES & ENS ASSETS 2.01.E.19			RHA
1	Pair Doors #**2.01.E.20**	CORR. 2.01.E.29 to HIGH VALUE 2.01.E.20			RHA

Opening Description: 2 - 4' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP CY206EW

2	Hinges	5BB1 HW 5 x 4 1/2 CON TW8		652	IV
10	Hinges	5BB1 HW 5 x 4 1/2		652	IV
2	Flush Bolt	FB31T		US32D	IV
2	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
2	LFIC Core	32N2201		26	ME
2	Coordinator	3780		US28	AB
4	Closer	4040XP RWPA 4040-18TJ TBWMS		AL	LC
	Note: Mount using Special Template ST-1630				
4	Overhead Stop	106S		US32D	GL
4	Protection Plate	8400 10" X 47" B-CS		US32D	IV
2	Wire Harness	CON-50P			SC
4	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
2	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
2	Weatherstrip	8303AA 1 x 96" 2 x 84"			ZE
4	Meeting Stile	328AA 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-5B:1 (Set #I2S-5B)

1	Pair Doors #**1.01.E.17**	CORR. 1.01.E.29 to SITE OPS SPARES & ENS ASSETS 1.01.E.17			RHA
1	Pair Doors #**1.01.E.18**	CORR. 1.01.E.29 to HIGH VALUE 1.01.E.18			RHA

Opening Description: 2 - 4' 0" x 9' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP CY206EW

2	Hinges	5BB1 HW 5 x 4 1/2 CON TW8		652	IV
14	Hinges	5BB1 HW 5 x 4 1/2		652	IV
2	Flush Bolt	FB31T 36"		US32D	IV
2	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
2	LFIC Core	32N2201		26	ME
2	Coordinator	3780		US28	AB
4	Closer	4040XP RWPA 4040-18TJ TBWMS		AL	LC
	Note: Mount using Special Template ST-1630				
4	Overhead Stop	106S		US32D	GL
4	Protection Plate	8400 10" X 47" B-CS		US32D	IV
2	Wire Harness	CON-50P			SC
4	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
2	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
2	Weatherstrip	8303AA 1 x 96" 2 x 108"			ZE
4	Meeting Stile	328AA 108"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-6C (Set #I1S-6C)

1	Single Door #**1.01.E.19A**	CORR. 1.01.E.29 to GDCC RUN OPS & FAC OPS STOR. 1.01.E.19	RH
1	Single Door #**1.01.E.19C**	CORR. 1.01.E.29 to GDCC RUN OPS & FAC OPS STOR. 1.01.E.19	LH
1	Single Door #**2.01.E.18A**	CORR. 2.01.E.29 to GDCC RUN OPS & FAC OPS STOR. 2.01.E.18	LH
1	Single Door #**2.01.E.18C**	CORR. 2.01.E.29 to GDCC RUN OPS & FAC OPS STOR. 2.01.E.18	RH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP CY207EP

4	Hinges	5BB1 4 1/2 x 4 1/2 CON TW8		652	IV
12	Hinges	5BB1 4 1/2 x 4 1/2		652	IV
2	Electrified Mortise Lockset	L9092 EU T 03N CON RX	RH	626	SC
2	Electrified Mortise Lockset	L9092 EU T 03N CON RX	LH	626	SC
4	LFIC Core	32N2201		26	ME
4	Closer	4040XP RWPA 4040-18TJ TBWMS		AL	LC
	Note: Mount using Special Template ST-1630				
4	Overhead Stop	104S		US32D	GL
4	Protection Plate	8400 34" X 34" B-CS		US32D	IV
4	Wire Harness	CON-38P			SC
4	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
4	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
4	Weatherstrip	8303AA 1 x 36" 2 x 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND LEVER.
-FREE EGRESS AT ALL TIMES.
-INSIDE CARD READER BYPASSES ALARM ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-7A (Set #I2S-7A)

1	Pair Doors #**1.01.A.02A**	CORR.1.01.A.12 from ELECTRICAL RM. A 1.01.A.02	RHRA
1	Pair Doors #**1.01.B.02A**	CORR. 1.01B.12 from ELECTRICAL RM. B 1.01.B.02	RHRA
1	Pair Doors #**1.01.C.02A**	CORR. 1.01.C.15 from ELECTRICAL RM. C 1.01.C.02	RHRA
1	Pair Doors #**1.01.C.02B**	CORR. 1.01.C.17 from ELECTRICAL RM. C 1.01.C.02	RHRA
1	Pair Doors #**1.01.D.02A**	CORR. from ELECTRICAL RM. D 1.01.D.02	RHRA
1	Pair Doors #**1.01.D.02B**	CORR. from ELECTRICAL RM. D 1.01.D.02	RHRA
1	Pair Doors #**2.01.A.02A**	CORR. 2.01.A.15 from ELECTRICAL RM. A 2.01.A.02	RHRA
1	Pair Doors #**2.01.B.02A**	CORR. 2.01.B.15 from ELECTRICAL RM. B 2.01.B.02	RHRA
1	Pair Doors #**2.01.C.02A**	CORR. 2.01.C.18 from ELECTRICAL RM. C 2.01.C.02	RHRA
1	Pair Doors #**2.01.C.02B**	CORR. 2.01.C.17 from ELECTRICAL RM. 2.01.C.02	RHRA
1	Pair Doors #**2.01.D.02A**	CORR. 2.01.D.17 from ELECTRICAL RM. D 2.01.D.02	RHRA
1	Pair Doors #**2.01.D.02B**	CORR. from ELECTRICAL RM. D 2.01.D.02	RHRA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1 x 45Min

Note: HARDWARE GROUP CY710CEMR

96	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP		652	IV
12	Flush Bolt Kit	FB32 36"		US32D	IV
12	Exit Device	9875L-F x M996L-M 03 425-SNB (QTY-2) CON FSE	RHR	US26D	VO
12	LFIC Core	32N2201		26	ME
12	Mort. HSG w/ Const Core	30-008 ICX		626	SC
12	Coordinator	3780		US28	AB
24	Closer	4040XP SCUSH TBWMS		AL	LC
24	Protection Plate	8400 10" X 35" B-CS		US32D	IV
12	Electric Power Transfer	EPT 10 CON		SP28	VO
12	Wire Harness	CON-38P			SC
24	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
12	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
12	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
24	Meeting Stile	328AA 108"			ZE
12	Weatherstrip	8303AA 1 x 72" 2 x 108"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-FREE EGRESS AT ALL TIMES.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I2S-7A:1 (Set #I2S-7A)

1	Pair Doors #**1.01.A.02B**	CORR. 1.01.C.15 from ELECTRICAL RM. A 1.01.A.02	RHRA
1	Pair Doors #**1.01.B.02B**	CORR. 1.01.D.17 from ELECTRICAL RM. B 1.01.B.02	RHRA
1	Pair Doors #**1.01.N.05A**	CORR. from ELECTRICAL RM. NS1 1.01.N.05	RHRA
1	Pair Doors #**1.01.N.08A**	CORR. from ELECTRICAL RM. N3 1.01.N.11	RHRA
1	Pair Doors #**1.01.N.11B**	CORR. 1.01B.12 from ELECTRICAL RM. N3 1.01.N.11	RHRA
1	Pair Doors #**1.01.N.14A**	CORR. from ELECTRICAL RM. NS4 1.01.N.14	RHRA
1	Pair Doors #**2.01.A.02B**	CORR. 2.01.C.18 from ELECTRICAL RM. A 2.01.A.02	RHRA
1	Pair Doors #**2.01.B.02B**	CORR. 2.01.D.17 from ELECTRICAL RM.B 2.01.B.02	RHRA

Opening Description: 2 - 3' 0" x 9' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1 x 90Min

Note: HARDWARE GROUP CY710CEMR

64	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP		652	IV
8	Flush Bolt Kit	FB32 36"		US32D	IV
8	Exit Device	9875L-F x M996L-M 03 425-SNB (QTY-2) CON FSE	RHR	US26D	VO
8	LFIC Core	32N2201		26	ME
8	Mort. HSG w/ Const Core	30-008 ICX		626	SC
8	Coordinator	3780		US28	AB
16	Closer	4040XP SCUSH TBWMS		AL	LC
16	Protection Plate	8400 10" X 35" B-CS		US32D	IV
8	Electric Power Transfer	EPT 10 CON		SP28	VO
8	Wire Harness	CON-38P			SC
16	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
8	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
8	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
16	Meeting Stile	328AA 108"			ZE
8	Weatherstrip	8303AA 1 x 72" 2 x 108"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-FREE EGRESS AT ALL TIMES.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #I1S-7C (Set #I1S-7C)

1	Single Door #**1.01.F.20B**	CORR. 1.01.F.22 to SECURE PACKAGE DROP VEST. 1.01.F.20	RHR
1	Single Door #**2.01.F.20B**	SECURE PACKAGE DROP VEST. 2.01.F.19 from CORR. 2.01.F.22	LHR

Opening Description: 3' 6" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP CY711ACZ

1	Continuous Hinge	112XY 83" EPT	LH	628	IV
	Properties: EPT-Model/Location=VD EPT 10 Loc: 37 1/2" CL from Top				
1	Continuous Hinge	112XY 83" EPT	RH	628	IV
	Properties: EPT-Model/Location=VD EPT 10 Loc: 37 1/2" CL from Top				
2	Exit Device	QEL 98NL-OP x 110MD-NL 425-SNB (QTY-6) 48" CON		US26D	VO
2	LFIC Core	32N2201		26	ME
2	Rim Hsg w/Const Core	20-057 ICX		626	SC
2	Door Pull	8190HD-0		US32D	IV
2	Closer	4040XP RWPA TBWMS		AL	LC
2	Wall Stop	WS406/407CCV		US32D	IV
2	Electric Power Transfer	EPT 10 CON		SP28	VO
2	Wire Harness	CON-6P			SC
2	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
2	Weatherstrip	8303AA 1 x 42" 2 x 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND PUSH PAD.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #IS1-7C (Set #IS1-7C)

1	Single Door #**2.01.E.04**	CORR. 2.01.B.15 from ELECTRICAL RM. 2.01.E.04			LHR

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-N x HMF Type HM-F1 x 45Min

Note: HARDWARE GROUP CY711CEMW

3	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP		652	IV
1	Exit Device	9875L-F x M996L-M 03 425-SNB (QTY-2) CON FSE	LHR	US26D	VO
1	LFIC Core	32N2201		26	ME
1	Mort. HSG w/ Const Core	30-008 ICX		626	SC
1	Closer	4040XP SCUSH TBWMS		AL	LC
1	Protection Plate	8400 10" X 34" B-CS		US32D	IV
1	Electric Power Transfer	EPT 10 CON		SP28	VO
1	Wire Harness	CON-38P			SC
1	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
1	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
1	Weatherstrip	8303AA 1 x 36" 2 x 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-FREE EGRESS AT ALL TIMES.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.
-OMIT POWER SUPPLY WHERE PROVIDED BY SECURITY.

Heading #IS1-7C:1 (Set #IS1-7C)

1	Single Door #**1.01.E.05**	CORR. 1.01.E.28 to ELECTRICAL RM. 1.01.E.05			RHR

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1 x 90Min

Note: HARDWARE GROUP CY711CEMW

3	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP		652	IV
1	Exit Device	9875L-F x M996L-M 03 425-SNB (QTY-2) CON FSE	RHR	US26D	VO
1	LFIC Core	32N2201		26	ME
1	Mort. HSG w/ Const Core	30-008 ICX		626	SC
1	Closer	4040XP SCUSH TBWMS		AL	LC
1	Protection Plate	8400 10" X 34" B-CS		US32D	IV
1	Electric Power Transfer	EPT 10 CON		SP28	VO
1	Wire Harness	CON-38P			SC
1	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
1	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
1	Weatherstrip	8303AA 1 x 36" 2 x 84"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-FREE EGRESS AT ALL TIMES.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #E2S-1A (Set #E2S-1A)

1	Pair Doors #**1.01.F.05C**	EXT. from SHIPPING & RECEIVING 1.01.F.05	RHRA
1	Pair Doors #**2.01.F.06C**	EXT. from SHIPPING & RECEIVING 2.01.F.06	RHRA

Opening Description: 2 - 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP CY714M

12	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP		630	IV
2	Flush Bolt Set	FB31P		US32D	IV
2	Strike	DP2		US26D	IV
2	Exit Device	QEL 9875NL x 990NL-M 03 425-SNB (QTY-2) CON	RHR	US26D	VO
2	LFIC Core	32N2201		26	ME
2	Mort. HSG w/ Const Core	30-008 ICX		626	SC
2	Coordinator	3780		US28	AB
4	Closer	4040XP SCUSH TBWMS		AL	LC
4	Protection Plate	8400 10" X 35" B-CS		US32D	IV
2	Electric Power Transfer	EPT 10 CON		SP28	VO
2	Power Supply Extension	CON-6W			SC
2	Wire Harness	CON-6P			SC
4	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
2	Power Supply By Others	POWER SUPPLY BY OTHERS			MISC
2	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
4	Door Sweep	8197AA 36"			ZE
2	Weatherstrip	475AA 1 x 72" 2 x 84"			ZE
2	Threshold	625A 72"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-EGRESS BY THE CREDENTIAL READER AND PUSH PAD.
-FREE EGRESS AT ALL TIMES.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #E1S-3A (Set #E1S-3A)

1	Single Door #**1.01.A.12**	EXT. from CORR.1.01.A.12	LHR
1	Single Door #**1.01.B.12**	EXT. from CORR. 1.01.B.12	RHR
1	Single Door #**1.01.C.15**	EXT. from CORR. 1.01.C.15	LHR
1	Single Door #**1.01.C.16**	EXT. from CORR. 1.01.C.17	LHR
1	Single Door #**1.01.D.17**	EXT. from CORR. 1.01.D.17	RHR
1	Single Door #**1.01.N.05B**	EXT. from ELECTRICAL RM. NS1 1.01.N.05	RHR
1	Single Door #**1.01.N.26**	EXT. from CORR.	LHR
1	Single Door #**1.01.N.08B**	EXT. from ELECTRICAL RM. N3 1.01.N.11	LHR
1	Single Door #**1.01.N.11A**	EXT. from ELECTRICAL RM. N3 1.01.N.11	RHR
1	Single Door #**1.01.N.14B**	EXT. from ELECTRICAL RM. NS4 1.01.N.14	LHR
1	Single Door #**2.01.A.13A**	EXT. from CORR. 2.01.A.15	LHR
1	Single Door #**2.01.A.13B**	EXT. from CORR. 2.01.B.15	RHR
1	Single Door #**2.01.C.15A**	EXT. from CORR. 2.01.C.17	LHR
1	Single Door #**2.01.C.15B**	EXT. from CORR. 2.01.D.17	RHR
1	Single Door #**2.01.C.17B**	EXT. from CORR. 2.01.C.17	LHR

Opening Description: 3' 8" x 9' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP CY715MW

60	Hinges	5BB1 HW 5 x 4 1/2 NRP		630	IV
6	Exit Device	QEL 9875NL x 990NL-M 03 425-SNB (QTY-2) 48" CON	RHR	US26D	VO
9	Exit Device	QEL 9875NL x 990NL-M 03 425-SNB (QTY-2) 48" CON	LHR	US26D	VO
15	LFIC Core	32N2201		26	ME
15	Mort. HSG w/ Const Core	30-008 ICX		626	SC
15	Closer	4040XP SCUSH TBWMS		AL	LC
15	Protection Plate	8400 10" X 42" B-CS		US32D	IV
15	Electric Power Transfer	EPT 10 CON		SP28	VO
15	Power Supply Extension	CON-6W			SC
15	Lock Guard	LG1		US32D	IV
15	Wire Harness	CON-6P			SC
15	Power Supply	PS902			LO
15	Door Position Switch by Others	DOOR POSITION SWITCH			MISC
15	Door Seal	488S-BK 8'			ZE
	Note: APPLY TO DOOR HEAD ONLY				
15	Length of Rain Drip	142AA 48"			ZE
15	Door Sweep	8197AA 44"			ZE
15	Weatherstrip	475AA 1 x 44" 2 x 108"			ZE
15	Threshold	625A 44"			ZE

Note: -INGRESS BY THE CREDENTIAL READER OR KEY OVERRIDE.
-INSIDE CREDENTIAL READER FOR ALARM BYPASS ONLY.
-FREE EGRESS AT ALL TIMES.
-COORDINATE POWER SUPPLY WITH SECURITY CONTRACTOR PRIOR TO SUBMITTALS.

Heading #E1NS-1A (Set #E1NS-1A)

1	Single Door #**1.01.C.17**	EXT. from CORR. 1.01.C.17	RHR
1	Single Door #**1.01.D.18**	EXT. from CORR.	LHR
1	Single Door #**1.01.N.20**	EXT. from CORR.	RHR
1	Single Door #**2.01.C.17A**	EXT. from CORR.	LHR
1	Single Door #**2.01.C.17C**	EXT. from CORR. 2.01.C.17	RHR

Opening Description: 3' 8" x 9' 0" x 1 3/4" x HMD Type HM-F x HMF Type HM-F1

Note: HARDWARE GROUP D725MW

20	Hinges	5BB1 HW 5 x 4 1/2 NRP	630	IV
5	Exit Device	LD 9875EO 425-SNB (QTY-6) 48"	US26D	VO
5	Closer	4040XP SCUSH TBWMS	AL	LC
5	Protection Plate	8400 10" X 42" B-CS	US32D	IV
5	Lock Guard	LG1	US32D	IV
5	Door Position Switch by Others	DOOR POSITION SWITCH		MISC
5	Door Seal	488S-BK 8'		ZE
	Note: APPLY TO DOOR HEAD ONLY			
5	Length of Rain Drip	142AA 48"		ZE
5	Door Sweep	8197AA 44"		ZE
5	Weatherstrip	475AA 1 x 44" 2 x 108"		ZE
5	Threshold	625A 44"		ZE

Note: -EXIT ONLY. NO ENTRY.
-DOOR CONTACT FOR MONITORING.
-NO RX PROVIDED IN EXIT DEVICE.

Heading #I1NS-6C:1 (Set #I1NS-6C)

1	Single Door #**1.01.E.25A**	CORR. 1.01.E.31 from CORR. 1.01.E.25	LHR
1	Single Door #**1.01.E.25B**	OPEN OFFICE 1.01.E.11 from CORR. 1.01.E.25	LHR
1	Single Door #**2.01.E.23A**	CORR. 2.01.E.32 from CORR. 2.01.E.23	RHR
1	Single Door #**2.01.E.23B**	OPEN OFFICE 2.01.E.12 from CORR. 2.01.E.23	RHR

Opening Description: 3' 0" x 7' 0" x 1 3/4" x HMD Type HM-F-361 x HMF Type HM-F1-361 x 90Min

Note: HARDWARE GROUP T731CR

12	Hinges	5BB1 HW 4 1/2 x 4 1/2 NRP		652	IV
2	Exit Device	WS 9827L-BE-F x 996L-BE-R&V 06 425-SNB (QTY-2)	LHR	US26D	VO
2	Exit Device	WS 9827L-BE-F x 996L-BE-R&V 06 425-SNB (QTY-2)	RHR	US26D	VO
2	Latch Guard	WS-LGO-3	RHR	US32D	VO
2	Latch Guard	WS-LGO-3	LHR	US32D	VO
4	Closer	4040XP SCUSH TBWMS		AL	LC
4	Protection Plate	8400 10" X 34" B-CS		US32D	IV
4	Weatherstrip	8303AA 1 x 36" 2 x 84"			ZE

Note: -FOR USE WITH STEELCRAFT PALADIN DOOR ASSEMBLY.
-MEETS ICC 500-2014 AND FEMA 320/361.