CANNONDESIGN

Submittal Identification Sheet

email all submittals and RFI's to
DEN-CAC@cannondesign.com

To be completed by Contractor/CM

CAA Nashville Yards
PROJECT NAME

161 Rosa L Parks Blvd, Nashville TN 37203
ADDRESS

007156.02
NUMBER

Creative Artist Agency LLC
OWNER

CannonDesign
ARCHITECT/ENGINEER

DPR
SUBMITTED BY

081113-01-2
CONTRACTOR/CM SUBMITTAL NO.

DRAWING/DETAIL REFERENCE | SPECIFICATION SEC./PARAGRAPH

Himmels
MANUFACTURER/SUPPLIER | ITEM/PRODUCT ID

2/4/26
REQUIRED DATE | PRIORITY | CRITICAL

ITEM BEING SUBMITTED (check only one)

- ○ Shop Drawings
- ○ Certification/Qualifications
- ○ Coordination Drawing
- ○ Samples (copies)
- ○ Record Documents
- ○ Calculations
- ○ LEED Submittal
- ● Product Data
- ○ Schedules
- ○ Other
- ○ O&M Manuals

ITEM BEING SUBMITTED FOR (check only one)

- ○ Action
- ○ Information Only
- ○ Record

REMARKS OR DEVIATIONS

Contractor / CM Certification (Submittals not certified will be returned without review)

Joey Chandler | 1/23/26
REVIEWED BY | DATE

To be completed by CannonDesign

007156.02
CANNONDESIGN PROJECT NUMBER

081113-01.2
CANNONDESIGN SUBMITTAL NUMBER

1/23/26
RECEIVED DATE

- ○ **A. NO EXCEPTIONS TAKEN**
  No further review of submittal is required.
- ● **B. MAKE CORRECTIONS NOTED**
  Incorporate corrections in work- resubmission is not required.
- ○ **C. REVISE AND RESUBMIT**
  Revise as noted, and resubmit for review.
- ○ **D. REJECTED**
  Submittal is not in compliance with Contract Documents - provide new submittal.
- ○ **E. FOR RECORD/INFORMATION ONLY**
  Submittal was reviewed for Record/ Information purposes only.
- ○ **F. NOT REQUIRED FOR REVIEW**
  Submittal is not required by Contract Documents and has not been reviewed.

Review is for conformance with the design concept of this project and for general compliance with Contract Documents. Contractor is responsible for quantities, dimensions and compliance with Contract Documents and for information that pertains to fabrication processes, construction techniques and coordination of this work with all trades which will be affected thereby. This review is null and void if submittal deviates from Contract Documents and does not indicate or note deviations.

A/E COMMENTS ○ **See attached sheet(s) for additional comments**

Aaron Salva Digitally signed by Aaron Salva DN: C=US, E=asalva@cannondesign.com, O=CannonDesign, CN=Aaron Salva Date: 2026.01.29 13:57:44-05'00' | 1/29/26
REVIEWED BY | DATE

Himmel's Architectural Door & Hardware, LLC - NA
12021 Volunteer Blvd., Mt. Juliet, TN 37122
Tel: 615-622-5777

CAA Nashville Yards
304682

RESUBMITTAL FOR OPENINGS 09-15A, 10-03AB, 10-82A, 10-82B & 10-83A

DATE	December 2, 2025
ARCHITECT	CannonDesign
CONTRACTOR	DPR Construction PA
DETAILED BY	Jonathan Trumps
Note	To keep the project moving in a timely manner, we ask that submittals be returned approved within three (3) weeks from submitted date. Delays in receiving approvals may impact lead times, pricing and material need by dates.

Door Frame Submittal Legend

Manufacturer	
CD	Ceco Door Products
VI	VT Industries - EDI Catalog

Door Description		
VI	WD	Wood door

Door Series		
VI	5508	5508 Wood Veneer SCLC 5 Ply

Door Thickness		
VI	2 ¼	2 1/4" Door Thickness
	1 3/4	1 3/4" Door Thickness

Door Material		
VI	HDF	HDF Primed Surface Doors
	PLAM	Plastic Laminate

Door Edge		
VI	LM	Plastic Laminate
	X9	3MM HDF PAINTABLE EDGE

Door Core		
VI	SCLC	Bonded Structural Composite Lumber Core

Door Finish		
VI	LAM-WILL	7965-12 WALNUT HEIGHTS
	PRME_PRM	HDF PRIMED OPAQUE PRIMED EDGES ONLY

Frame Description		
CD	SGL	3 Piece Frame - Single
HMGE	SGL	Single 3 Sided Frame

Frame Series		
CD	SQ	Equal Frame Rabbet
HMGE	EZJAMB	EZ Jamb

Frame Gauge		
CD	16	16 Gauge
HMGE	18	18 Gauge

Frame Construction		
CD	SH T3	T3 Full Profile Weld
HMGE	KD	Knocked Down

Frame Material		
CD	CRS	Cold Rolled Steel
HMGE	CRS	Cold Rolled Steel

Frame Profile		
HMGE	ISD	Inswing Door Frame
	SRC	EzyJamb Sgl. Rabbet

Frame Anchors		
CD	A03_MSZ2-	MSZ2 Welded With Flr Anc to 7'2"

IT ROOM 10-12A to
IT BUILD ROOM
10-12B

CAA Nashville Yards
304682

CORR 10-90 to
MAILROOM 10-03A

Door Frame Submittal

OPENINGS UPDATED IN PR04

Opening								Door											Frame													
																	ELEV											ELEV				
OPEN NO.	LOCATION	QTY	OPEN SIZE	SGL/PR	HAND	LABEL	HEADING	MFG	ARCH TYPE	THICK	SERIES	MATL	CORE	FINISH	GAUGE	TYPE	CODE	PAGE	MFG	ARCH TYPE	MATL	SERIES	PROF	GAUGE	HEAD	JAMB/ THROAT	CODE	PAGE	ANCHOR	WELD	NOTES
10-03AB	CORR 10-90 to STOR 10-01	1	3070	S	LH		06	VI	WD-F-PN	1 3/4	5508	HDF	SCLC	PRME_PRM		F	F		CD	HM-00STP	CRS	SQ		16		600 500			A03_MSZ2-	Y	
10-12B	CORR 10-90 to STOR 10-01	1	3070	S	LH		04.PR4	VI	WD-F-PN	1 3/4	5508	HDF	SCLC	PRME_PRM		F	F		CD	HM-00STP	CRS	SQ		16		600 500			A03_MSZ2-	Y	
10-83A	OPEN OFFICE 10-13 from STOR 10-89	1	3070	S	RHR		26.1	VI	WD-F-PN	1 3/4	5508	HDF	SCLC	PRME_PRM		F	F		HMGE	CFB-OS	CRS	EZJAMB	SRC	18		4.875 4 7/8					

GAME LOUNGE
10-83 to CORR 10-90

CAA Nashville Yards
304682

Door Frame Submittal 10TH FLOOR SPEAKEASY REDESIGN

Opening								Door											Frame												
																	ELEV										ELEV				
OPEN NO.	LOCATION	QTY	OPEN SIZE	SGL/PR	HAND	LABEL	HEADING	MFG	ARCH TYPE	THICK	SERIES	MATL	CORE	FINISH	GAUGE	TYPE	CODE	PAGE	MFG	ARCH TYPE	MATL	SERIES	PROF	GAUGE	HEAD	JAMB/ THROAT	CODE	PAGE	ANCHOR	WELD	NOTES
10-82A.R1M	OPEN OFFICE 10-80 to 10TH FLOOR SPEAKEASY 10-82	1	30811	S	RH		12.R1	VI	WD-F	2 1/4	5508	HDF	SCLC	PRME_PRM		F	F		HMGE	CFB-IS	CRS	EZJAMB	ISD	18		4.875 4 7/8					
10-82B.R1M	GAME LOUNGE 10-83 to 10TH FLOOR SPEAKEASY 10-82	1	30811	S	LH		12.R1	VI	WD-F	2 1/4	5508	HDF	SCLC	PRME_PRM		F	F		HMGE	CFB-IS	CRS	EZJAMB	ISD	18		4.875 4 7/8					

CAA Nashville Yards
304682

Door Frame Submittal

REVISION OF OPENING AWAY FROM STC

Opening								Door											Frame												
																	ELEV										ELEV				
OPEN NO.	LOCATION	QTY	OPEN SIZE	SGL/PR	HAND	LABEL	HEADING	MFG	ARCH TYPE	THICK	SERIES	MATL	CORE	FINISH	GAUGE	TYPE	CODE	PAGE	MFG	ARCH TYPE	MATL	SERIES	PROF	GAUGE	HEAD	JAMB/ THROAT	CODE	PAGE	ANCHOR	WELD	NOTES
09-15AREV1	SOCIAL HUB 09-13 from 9TH FLOOR SPEAKEASY 09-15	1	6'0"10'0"	P	RHRA		21	VI	WD-F	1 3/4	808	HPLAM	SCLC	LAM-WIL		F	F-PR		HMGE	CFA-OS	CRS	EZJAMB	SRC	18		618 618					

Himmel's Architectural Door & Hardware, LLC - NA
12021 Volunteer Blvd., Mt. Juliet, TN 37122
Tel: 615-622-5777

CAA Nashville Yards
304682

RESUBMITTAL FOR OPENINGS 09-15A,
10-03AB, 10-82A, 10-82B & 10-83A

DATE	December 2, 2025
ARCHITECT	CannonDesign
CONTRACTOR	DPR Construction PA
DETAILED BY	Jonathan Trumps
Note	To keep the project moving in a timely manner, we ask that submittals be returned approved within three (3) weeks from submitted date. Delays in receiving approvals may impact lead times, pricing and material need by dates.

Hardware Schedule

IT ROOM to IT BUILD ROOM

Heading #04.PR4 (Set #04)

1 Single Door #**10-12B** CORR 10-90 to STOR 10-01 90° LH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x WD Type WD-F-PN x HMF Type HM-00STP

1	Continuous Hinge	A515 83-1/8" CUT TO CUSTOM LENGTH PT	LH	US32D	AB
	Properties: Cut to Length=S4 Finish, Specify Electrical Power Transfer Model & Location=37 1/2"'				
1	Electrified Mortise Lockset	L9092 EU H 01A 50-231 CON RX	LH	622	SC
1	Interchangeable Core Cylinder	80-037 50-002-VKC GMK		622	SC
1	Closer	4040XP REGARM 4040-18 TBSRT		622	LC
1	Overhead Holder	1013		S4	AB
1	Floor Stop	RM446		S4	AB
1	Card Reader(By Others)	CARD READER BY SECURITY VENDOR			MISC
1	Mag Door Contacts - By Others(By Others)	MAG DOOR CONTACTS - PROVIDED BY OTHERS			MISC
1	Power Transfer	PT1000EZ		S4	AB
1	Wire Harness	EZAL-192			AB
1	Wire Harness	EZAL-38-1			AB
3	Door Silencer	SR64		GRY	IV

Note: ENTRY BY CREDENTIAL, FREE EGRESS ALWAYS, INTERNAL RX SWITCH SHUNTS ALARM FOR AUTHORIZED EGRESS
WIRING, CONDUIT, ACCESS CONTROL EQUIPMENT & INTERFACE BY SECURITY CONTRACTOR

Heading #06 (Set #06)

CORR TO MAILROOM

1 Single Door #**10-03AB** CORR 10-90 to STOR 10-01 90° LH

Opening Description: 3' 0" x 7' 0" x 1 3/4" x WD Type WD-F-PN x HMF Type HM-00STP

1	Continuous Hinge	A515 83-1/8" CUT TO CUSTOM LENGTH PT	LH	US32D	AB
	Properties: Cut to Length=S4 Finish, Specify Electrical Power Transfer Model & Location=37 1/2"'				
1	Electrified Mortise Lockset	L9092 EU H 01A 50-231 CON ICX RX	LH	622	SC
1	Interchangeable Core Cylinder	80-037 50-002-VKC GMK		622	SC
1	Closer	4040XP REGARM TBSRT		622	LC
1	Overhead Holder	1013		S4	AB
1	Protection Plate	8400 34" x 35" B-CS		BLK	IV
1	Floor Stop	RM446		S4	AB
1	Card Reader(By Others)	CARD READER BY SECURITY VENDOR			MISC
1	Mag Door Contacts - By Others(By Others)	MAG DOOR CONTACTS - PROVIDED BY OTHERS			MISC
1	Power Transfer	PT1000EZ		S4	AB
1	Wire Harness	EZAL-32			AB
1	Wire Harness	EZAL-192			AB
3	Door Silencer	SR64		GRY	IV

Note: ENTRY BY CREDENTIAL, FREE EGRESS ALWAYS, INTERNAL RX SWITCH SHUNTS ALARM FOR AUTHORIZED EGRESS
WIRING, CONDUIT, ACCESS CONTROL EQUIPMENT & INTERFACE BY SECURITY CONTRACTOR

GAME LOUNGE TO CORR

Heading #26.1 (Set #26.1)

1	Single Door #**10-83A**	OPEN OFFICE 10-13 from STOR 10-89	105°	RHR

Opening Description: 3' 0" x 7' 0" x 1 3/4" x WD Type WD-F-PN x HMF Type CFB-OS

3	Ezy Jamb Rocyork	EZY JAMB ROCYORK RYST60 BLACK	BLACK	MISC
1	Back to Back Pull Set	ABH 5240 60" CTC/OVERALL BTB SET S4	S4	HIMM
1	Mortise Cylinder	80-131 50-002-VKC GMK GRN Core L583-255	622	SC
1	Interchangeable Core Cylinder	80-037 50-002-VKC GMK	622	SC
2	Card Reader(By Others)	CARD READER BY SECURITY VENDOR		MISC
1	Mag Door Contacts - By Others(By Others)	MAG DOOR CONTACTS - PROVIDED BY OTHERS		MISC
1	Dorma OH Concealed Closer	RTS88-90 BFI	695	MISC
1	C.R. Laurence Applied Stops	1NT308MBL	BLK	MISC
1	Power Supply	PS902 900-FA		LO
1	Key Switch	653-04 L2	SF-613	LO

Note: EGRESS TO CORRIDOR BY VALID CREDENTIAL WHICH RELEASES DELAYED EGRESS MAGNET FOR AUTHORIZED EGRESS
PRESSURE TO THE DOOR FROM EITHER SIDE FOR MORE THAN THE NUISANCE TIME PERIOR WILL PUT THE DELAYED EGRESS MAGNETIC INTO ALARMED RELEASE MODE WITH AN AUDIBLE SIGNAL AFTER 15 SECOND. ALARM NEEDS TO BE RESET AT THE DOOR BY KEYSWITCH.

FROM CHANGE ORDER 3 - OPTION 1 TO LET THESE DOORS HAVE CLOSERS

Hardware Schedule

Heading #12.R1 (Set #12.R1)

1	Single Door #**10-82A.R1M**	OPEN OFFICE 10-80 to 10TH FLOOR SPEAKEASY 10-82		RH
1	Single Door #**10-82B.R1M**	GAME LOUNGE 10-83 to 10TH FLOOR SPEAKEASY 10-82		LH

Opening Description: 3' 0" x 8' 11" x 2 1/4" x WD Type WD-F x HMF Type CFB-IS

8	Ezy Jamb Rocyork	EZY JAMB ROCYORK RYST120 BLACK	BLACK	MISC
2	ABH Pull	ABH 5240 12" CTC/OVERALL S4	S4	HIMM
	Note: ORDER WITH CONCEALED HD MOUNT			
2	Shear Lock	GF3000TRD DSM/MBS		LO
2	RocYork Closer by EZ	ROCYORK CONCEALED SLIDE ARM CLOSER	BK	MISC
2	Card Reader(By Others)	CARD READER BY SECURITY VENDOR		MISC
2	Motion Sensor(By Others)	MOTION SENSOR BY OTHERS		MISC
2	Push Button	621GR EX DA NS	SF-613	LO

Note: OPERATIONAL DESCRIPTION: DOOR ACCESS: PRESENT CREDENTIAL TO CARD READER TO RELEASE MAGNETIC LOCK.
DOOR EGRESS: MOTION SENSOR (REQUEST TO EXIT) TO RELEASE MAGNETIC LOCK.
EMERGENCY PUSH BUTTON (WITHIN 5 FOOT OF DOORS) TO OVERRIDE AND RELEASE MAGNETIC LOCK WHEN NEEDED. UPON POWER LOSS OR FIRE ALARM ACTIVATION DOOR SHAL UNLOCK (FAIL SAFE).

IF AUTO OPERATOR OPTION IS SELECTED, THIS SET WILL NOT BE PROVIDED.

Hardware Schedule

Heading #12.1.R1 (Set #12.1.R1)

1	Single Door #**10.82A.R1A**	OPEN OFFICE 10-80 to 10TH FLOOR SPEAKEASY 10-82	RH
1	Single Door #**10.82B.R1A**	GAME LOUNGE 10-83 to 10TH FLOOR SPEAKEASY 10-82	LH

Opening Description: 3' 0" x 8' 11" x 2 1/4" x WD Type HM-F x HMF Type CFB-IS (10.82A.R1A)
3' 0" x 8' 11" x 2 1/4" x WD Type WD-F x HMF Type CFB-IS (10.82B.R1A)

Note: EZ Jamb Inswing Frames are not compatible with Concealed overhead Auto Operators. Surface Mounted Auto Operator included instead.

PROVIDED AS BLACK IN FINISH. CONFIRM THIS WILL BE COMPATIBLE WITH WALL FINISH.

8	Ezy Jamb Rocyork	EZY JAMB ROCYORK RYST120 BLACK	BLACK	MISC
2	Mortise Cylinder	80-131 50-002-VKC GMK GRN Core L583-255	622	SC
2	Interchangeable Core Cylinder	80-037 50-002-VKC GMK	622	SC
2	ABH Pull	ABH 5240 12" CTC/OVERALL S4	S4	HIMM
2	Shear Lock	GF3000TRD DSM/MBS		LO
2	Operator	6311	BSP	NO
2	Card Reader(By Others)	CARD READER BY SECURITY VENDOR		MISC
2	Motion Sensor(By Others)	MOTION SENSOR BY OTHERS		MISC
2	Key Switch	653-04 L2	SF-613	LO
2	Push Button	621GR EX DA NS	SF-613	LO
2	Spindle Plate	2810-11B	710	LC
	Note: OPERATOR MOUNTING PLATE			
4	Touchless Actuator	10MS31		AUTO

Note: WIRING, CONDUIT, POWER ACCESS CONTROL SYSTEM AND FIRE ALARM REQUIREMENTS BY DIV 26/28.
WIRING, CONDUIT, POWER AND AUTO OPERATOR INTERFACE BY SUPPLIER.
OPERATIONAL DESCRIPTION: DOOR ACCESS: PRESENT CREDENTIAL TO CARD READER TO RELEASE MAGNETIC LOCK.
DOOR EGRESS: MOTION SENSOR (REQUEST TO EXIT) TO RELEASE MAGNETIC LOCK.
EMERGENCY PUSH BUTTON (WITHIN 5 FOOT OF DOORS) TO OVERRIDE AND RELEASE MAGNETIC LOCK WHEN NEEDED. UPON POWER LOSS OR FIRE ALARM ACTIVATION DOOR SHAL UNLOCK (FAIL SAFE).
INTERIOR ACTUATOR TO START OPENING CYCLE (UNLESS ADO IS POWERED OFF).
CARD READER WIRED IN SERIES THROUGH ACCESS CONTROL SYSTEM AUX RELAY THAT UPON PRESENTATION OF VALID CARD, CARD READER TO START OPENING CYCLE.

IF CLOSER OPTION IS SELECTED, THIS SET WILL NOT BE PROVIDED.

Hardware Schedule

Heading #21 (Set #21)

1	Pair Doors #**09-15AREV 1**	SOCIAL HUB 09-13 from 9TH FLOOR SPEAKEASY 09-15		90°	RHRA

Opening Description: 2 - 3' 0" x 10' 0" x 1 3/4" x WD Type WD-F x HMF Type CFA-OS

10	Ezy Jamb Rocyork(By Others)	EZY JAMB ROCYORK RYST120 BLACK		BLACK	MISC
1	Automatic Flush Bolt	1860S EXT-36		S4	AB
1	Electrified Mortise Lockset	L9092 EU H 01A 50-231 CON RX	RHR	622	SC
1	Interchangeable Core Cylinder	80-037 50-002-VKC GMK		622	SC
2	Closer	ITS 9625 HO INV		613	DM
2	Floor Stop	RM446		S4	AB
1	Card Reader(By Others)	CARD READER BY SECURITY VENDOR			MISC
2	Mag Door Contacts - By Others(By Others)	MAG DOOR CONTACTS - PROVIDED BY OTHERS			MISC
1	Electric Power Transfer	EPT 10 CON		622	VO
1	Wire Harness	CON-192P			SC
1	Wire Harness	CON-38P			SC
2	Auto Door Bottom	364AA 36" Z49			ZE
1	Threshold	655BK 72" 223-MSLA-10 V3			ZE

Note: ENTRY BY CREDENTIAL,FREE EGRESS ALWAYS,INTERNAL RX SWITCH SHUNTS ALARM FOR AUTHORIZED EGRESS
WIRING, CONDUIT, ACCESS CONTROL EQUIPMENT & INTERFACE BY SECURITY CONTRACTOR