Utilisation of individual gas-turbine and steam vintages

Several vintages run below 1% (e.g. the 2030 natural-gas OCGT vintage in every scenario, including REF-LC). * = vintage with a policy minimum.



Source: PyPSA-RSA gas-to-power study, saved solved networks (REF-LC 22 Oct 2026; POL runs 27 Oct 2026), commit db90bff. 1-node, LC-182h development results - not hourly-resolution findings.
Low capacity factors are NOT evidence of economic stranding: these units earn reserve-margin capacity value (duals not saved), and dispatch among identical pre-conversion OCGT units is near-degenerate (which unit runs is arbitrary). Fleet-level utilisation (Figure 4) is the robust measure. LC-182h CFs are indicative only.