

Datenpunktliste °CaleonBox Clima

Rooms: 12

Reading

Modbus-Register	Description	Unit	Additions
40000	Outdoor Temperature	*10 °C	
40001	Room Count	-	
40002	Season Mode	-	
40003	Room 1 Temperature	*10 °C	
40004	Room 1 Humidity	*10 %	
40005	Room 2 Temperature	*10 °C	
40006	Room 2 Humidity	*10 %	
40007	Room 3 Temperature	*10 °C	
40008	Room 3 Humidity	*10 %	
40009	Room 4 Temperature	*10 °C	
40010	Room 4 Humidity	*10 %	
40011	Room 5 Temperature	*10 °C	
40012	Room 5 Humidity	*10 %	
40013	Room 6 Temperature	*10 °C	
40014	Room 6 Humidity	*10 %	
40015	Room 7 Temperature	*10 °C	
40016	Room 7 Humidity	*10 %	
40017	Room 8 Temperature	*10 °C	
40018	Room 8 Humidity	*10 %	
40019	Room 9 Temperature	*10 °C	
40020	Room 9 Humidity	*10 %	
40021	Room 10 Temperature	*10 °C	
40022	Room 10 Humidity	*10 %	
40023	Room 11 Temperature	*10 °C	
40024	Room 11 Humidity	*10 %	
40025	Room 12 Temperature	*10 °C	
40026	Room 12 Humidity	*10 %	

Datenpunktliste °CaleonBox Clima

Rooms: 12

Writing

Modbus-Register	Description	Unit	Additions
41024	Room Flag	-	0xFFFF for all rooms 0x0001 for temperature 0x0002 for humidity
41025	Room Number	-	0xFFFF for all rooms 0x000<room number>
41026	Sensor	-	0x0000 for outdoor sensore
41027	Season Switch	-	first Byte: possible (0/1) second Byte: heating/cooling (0/1)
41028	Room 1 Tset	*10 °C	
41029	Room 1 Hysteresis	*10 °C	
41030	Room 2 Tset	*10 °C	
41031	Room 2 Hysteresis	*10 °C	
41032	Room 3 Tset	*10 °C	
41033	Room 3 Hysteresis	*10 °C	
41034	Room 4 Tset	*10 °C	
41035	Room 4 Hysteresis	*10 °C	
41036	Room 5 Tset	*10 °C	
41037	Room 5 Hysteresis	*10 °C	
41038	Room 6 Tset	*10 °C	
41039	Room 6 Hysteresis	*10 °C	
41040	Room 7 Tset	*10 °C	
41041	Room 7 Hysteresis	*10 °C	
41042	Room 8 Tset	*10 °C	
41043	Room 8 Hysteresis	*10 °C	
41044	Room 9 Tset	*10 °C	
41045	Room 9 Hysteresis	*10 °C	
41046	Room 10 Tset	*10 °C	
41047	Room 10 Hysteresis	*10 °C	
41048	Room 11 Tset	*10 °C	
41049	Room 11 Hysteresis	*10 °C	
41050	Room 12 Tset	*10 °C	
41051	Room 12 Hysteresis	*10 °C	