

SECTION 08 71 00

DOOR HARDWARE

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes: Door hardware for wood doors, steel doors, aluminum framed entrance doors, all glass entrance doors, and miscellaneous hardware items.
- B. Provide hardware not described herein but otherwise required for proper completion of the project, conforming to size, function, quality, and finish of other specified hardware.

1.2 REFERENCED STANDARDS

- A. American National Standards Institute (ANSI):
 - 1. ANSI A117.1 Accessible and Usable Buildings and Facilities
- B. Builders Hardware Manufacturers Association (BHMA):
 - 1. ANSI/BHMA A156.1 Butts and Hinges.
 - 2. ANSI/BHMA A156.2 Bored and Preassembled Locks and Latches.
 - 3. ANSI/BHMA A156.3 Exit Devices.
 - 4. ANSI/BHMA A156.4 Door Controls - Closers.
 - 5. ANSI/BHMA A156.5 Auxiliary Locks and Associated Products.
 - 6. ANSI/BHMA A156.6 Architectural Door Trim.
 - 7. ANSI/BHMA A156.7 Template Hinge Dimensions.
 - 8. ANSI/BHMA A156.8 Door Controls - Overhead Stops and Holders.
 - 9. ANSI/BHMA A156.10 Power Operated Pedestrian Doors.
 - 10. ANSI/BHMA A156.13 Mortise Locks and Latches.
 - 11. ANSI/BHMA A156.14 Sliding and Folding Door Hardware.
 - 12. ANSI/BHMA A156.15 Release Devices: Closer Holders, Electromagnetic and Electromechanical.
 - 13. ANSI/BHMA A156.16 Auxiliary Hardware.
 - 14. ANSI/BHMA A156.17 Self-Closing Hinges and Pivots.
 - 15. ANSI/BHMA A156.18 Materials & Finishes.
 - 16. ANSI/BHMA A156.19 Power Assist & Low Energy Power Operated Doors.
 - 17. ANSI/BHMA A156.21 Thresholds.
 - 18. ANSI/BHMA A156.22 Door Gasketing and Edge Seal Systems.
 - 19. ANSI/BHMA A156.23 Electromagnetic Locks.
 - 20. ANSI/BHMA A156.24 Delayed Egress Locks.
 - 21. ANSI/BHMA A156.25 Electrified Locking Devices.
 - 22. ANSI/BHMA A156.26 Continuous Hinges.
 - 23. ANSI/BHMA A156.27 Power and Manual Operated Revolving Pedestrian Doors.
 - 24. ANSI/BHMA A156.28 Recommended Practices for Mechanical Keying Systems.
 - 25. ANSI/BHMA A156.29 Exit Locks, Exit Locks with Exit Alarms, Exit Alarms, Alarms for Exit.
 - 26. ANSI/BHMA A156.30 High Security Cylinders.
 - 27. ANSI/BHMA A156.31 Electrified Strikes and Frame Mounted Activators.
 - 28. ANSI/BHMA A156.32 Integrated Door Opening Assemblies.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

29. ANSI/BHMA A156.34 Ligature Resistant Locks.
30. ANSI/BHMA A156.36 Auxiliary Locks.
31. ANSI/BHMA A156.37 Multipoint Locks.
32. ANSI/BHMA A156.38 Low Energy Power Operated Sliding and Folding Doors.
33. ANSI/BHMA A156.39 Residential Locksets and Latchsets.
34. ANSI/BHMA A156.40 Residential Deadbolts.
35. ANSI/BHMA A156.41 Door Hardware Single Motion to Egress.
36. ANSI/BHMA A156.115 Hardware Preparation in Steel Doors with Steel Frames.
37. ANSI/BHMA A156.115W Hardware Preparation in Wood Doors with Wood or Steel Frames.

- C. California Code of Regulations, Title 24:
 1. California Building Code (CBC)
 2. California Referenced Standards Code
- D. Door and Hardware Institute (DHI):
 1. ANSI/DHI A115.IG Installation Guide for Doors and Hardware
 2. DHI Keying Systems and Nomenclature
 3. DHI Sequence and Format for the Hardware Schedule
- E. Department of Justice (DOJ)
 1. ADA Standards for Accessible Design
- F. Local Building Codes
 1. French Cap, California
 2. San Joaquin County, California
- G. National Fire Protection Association (NFPA):
 1. NFPA 80 Fire Doors and Other Opening Protectives
 2. NFPA 101 Life Safety Code
 3. NFPA 252 Fire Tests of Door Assemblies
- H. New York State Office of Mental Health
 1. 2025 Patient Safety Standards, Materials and Systems Guidelines.
- I. Underwriters Laboratories Inc. (UL):
 1. UL 10C Positive Pressure Fire Tests Of Door Assemblies
 2. UL 305 Panic Hardware
 3. UL 437 Drill and Pick Resistant Key Cylinders
 4. UL 1034 Burglary-Resistant Electric Locking Mechanisms

1.3 SUBMITTALS

- A. Products other than those designated herein must be approved as substitutions prior to submittal of Door Hardware.
- B. Door Hardware Schedule: Vertical format conforming to DHI "Sequence and Format for the Hardware Schedule." Horizontal format schedules will be rejected without review. Format shall be 8-1/2 by 11 inch (A4) page size. Organize Schedule into headings, grouping doors to receive same hardware items, indicating quantity and complete designations of every item required for each door opening. The schedule shall include:

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

1. Cover sheet indicating name and location of Project; name of Architect; name of Contractor; name, address and phone of hardware supplier, name of hardware consultant preparing the schedule; date of submittal or revised submittal.
 2. A list of abbreviations used in schedule.
 3. An index of door openings, listed in numerical order, with hardware heading identification cross-referenced to Architect's set identification.
 4. Hardware headings shall be listed in numerical order corresponding, as closely as possible, with numerical order of Architect's set numbers.
 5. Each hardware heading shall have each door listed in numerical order according to door numbers in the Architect's door schedule, and denoting: location, configuration (single, pair, etc.), type (elevation, etc.), door and frame size(s), door and frame material(s), handing, fire rating, and key set identification.
 6. Type, complete model number, style, function, size, hand, and finish of each door hardware item.
 7. Manufacturer of each item.
 8. Fastenings and other pertinent information.
- C. Manufacturer's Technical Product Data / Catalog Cut Sheets: Clearly marked for each hardware item, including installation details, material descriptions, dimensions of individual components and profiles, and finishes. Format shall be 8-1/2 by 11 inch (A4) page size.
- D. Wiring Diagrams: No later than 14 days after receipt of reviewed hardware schedule submittal, submit detailed wiring diagrams for power, signaling, monitoring, and control of the access control system electrified hardware; identified by door number(s), and detailed specifically for each type and function of electrified door opening. Format shall be 8-1/2 by 11 inch (A4) page size. Include the following:
1. System Description of Operation. Include description of component functions including, but not limited to, the following situations: normal secured/unsecured state of door; authorized access; authorized egress; unauthorized access; unauthorized egress; fire alarm and loss of power conditions, and interfaces with other building control systems.
 2. Elevation single-line diagram, showing interface between electrified door hardware and fire alarm, power, access control, and security systems as applicable.
 3. Point-to-point wiring diagram for field-installed wiring.
- E. Keying Schedule: In accordance with Owner's final keying instructions for locks. Conform to DHI "Keying Systems and Nomenclature." Format shall be 8-1/2 by 11 inch (A4) page size.
- F. Operation and Maintenance Data: Provide complete operating and maintenance instructions listing routine maintenance procedures, possible breakdowns and repairs, and troubleshooting guides.
- G. Qualification Data: For firms and persons specified in "Quality Assurance" Article.
- H. Warranties: Special warranties specified in this Section.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

- I. Fire Door Assembly Inspection and Testing: Submit a written report of the results of functional testing and inspection for fire door assemblies, in compliance with current NFPA 80 requirements. Written report shall be provided to the Owner to be made available to the Authority Having Jurisdiction (AHJ). Report shall include the door number for each fire door assembly, door location, door and frame material, fire rating, and summary of deficiencies.

1.4 QUALITY ASSURANCE

- A. Obtain each type and variety of door hardware from a single manufacturer, unless otherwise indicated.
- B. Manufacturers, Hardware Supplier, and Installer shall have no less than five years experience in the provision of Door Hardware for projects similar in size, complexity and type to this Project.
- C. Hardware Schedule and Keying Schedule submittals shall be prepared by a Hardware Consultant holding the credentials of Architectural Hardware Consultant (AHC) issued by the Door and Hardware Institute. Hardware Consultant shall have no less than five years experience in the scheduling of Door Hardware for projects similar in size, complexity and type to this Project; and shall be available, at no additional cost, during the course of the Work to consult with Contractor, Architect, and Owner regarding door hardware and keying.

1.5 REGULATORY REQUIREMENTS

- A. Fire-Rated Door Assemblies: Provide door hardware for assemblies complying with all applicable regulations, listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction.
 1. At rated doors with panic exit devices, provide devices labeled as "Fire Exit Device."
- B. Comply with all applicable accessibility regulations as set forth in Americans with Disabilities Act (ADA) -- Accessibility Guidelines for Buildings and Facilities (ADAAG); ANSI A117.1; and California Building Code (CBC) Chapters 11A and 11B as applicable.
- C. Latching and locking doors that are hand-activated and that are in a path of travel shall be operable with a single effort by lever-type hardware, panic bars, push-pull activating bars, or other hardware designed to be easy to grasp with one hand, not requiring tight grasping, tight pinching or twisting of the wrist; from egress side shall not require the use of a key, tool, or special knowledge for operation.
 1. All hand-activated hardware shall be mounted between 34 inches (864 mm) and 44 inches (1118 mm) above finished floor.
- D. At sliding doors, when fully open, operating hardware shall be exposed and usable from both sides.
- E. Door closing devices shall comply with the following maximum opening-force requirements:
 1. Interior Hinged Doors: 5 lbf (22.2 N) applied perpendicular to door at latch.
 2. Exterior Hinged Doors: 5 lbf (22.2 N) applied perpendicular to door at latch.
 3. Sliding or Folding Doors: 5 lbf (22.2 N) applied parallel to door at latch.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

- 4. Fire Rated Doors: 5 lbf (22.2 N) applied perpendicular to door at latch. To insure latching, may be increased to the minimum force allowable by the appropriate administrative authority, not to exceed 15 lbf (67 N).
 - F. Where door closers are provided, adjust sweep speed so that from an open position of 70 degrees the door will take at least 3 seconds to move to a point 3 inches (76 mm) from the latch, measured to the leading edge of the door.
 - G. Thresholds shall be maximum 1/2 inch (13 mm) in height above floor and landing on both sides of openings. Bevel raised thresholds with a slope of not more than 1:12.
- 1.6 DELIVERY, STORAGE, AND HANDLING
- A. Each article of hardware shall be delivered individually packaged in the manufacturer's standard commercial carton or container, and shall be properly marked or labeled to be readily identifiable with the approved hardware schedule.
 - B. Manufacturer's printed installation instructions, fasteners, and special tools shall be included in each package.
 - C. Hardware shall be stored in a dry, secure locked area, complete with shelving for unpacking and sorting of the door hardware.
 - D. Deliver all master keys by restricted, receipted delivery directly from the manufacturer to the Owner.
- 1.7 COORDINATION
- A. Provide hardware templates to the parties involved for doors, frames, and other work specified to be factory prepared for door hardware. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing door hardware to comply with indicated requirements.
 - B. When required by door or frame fabricator, furnish physical samples of each mortised and recessed hardware item required.
 - C. Coordinate layout and installation of recessed pivots and closers with floor construction.
 - D. Electrical System Rough-in: Coordinate layout and installation of electrified door hardware with connections to power supplies, fire alarm system and detection devices, access control system, and security system as applicable.
 - E. Pre-Installation Conference: Arrange conference at job site to coordinate door, frame, hardware and electronic security hardware installation; to be attended by the Architect, Owner, Contractor and representative personnel of firms involved in the provision and installation of said items.
 - F. Keying Conference: Arrange conference with Owner, or designated representative, and Manufacturer's/ Hardware Supplier's Architectural Hardware Consultant to establish keying requirements. Incorporate keying conference decisions into Keying Schedule.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

1.8 WARRANTY

- A. In addition to, and not precluding, other warranty requirements in the Contract Documents, the following hardware items shall carry extended minimum warranties as indicated:
1. Hinges: Ten years from date of Substantial Completion.
 2. Locks: Five years from date of Substantial Completion.
 3. Exit Devices: Three years from date of Substantial Completion.
 4. Door Closers: Ten years from date of Substantial Completion.

1.9 MAINTENANCE

- A. Furnish a complete set of specialized tools and maintenance instructions as needed for Owner's continued adjustment, maintenance, and removal and replacement of door hardware.

PART 2 - PRODUCTS

2.1 ACCEPTABLE MANUFACTURERS

- A. Subject to compliance with requirements herein, provide products by one of the following manufacturers for each type of hardware:
1. Butt Hinges: Hager (HAG), Ives/Allegion (IVE), McKinney/ASSA ABLOY (MCK), PBB (PBB), Stanley/Dormakaba (STA), or approved equal.
 2. Continuous Pinned Hinges: Architectural Builders Hardware (ABH), Hager (HAG), Ives/Allegion (IVE), Markar/ASSA ABLOY (MAR), National Guard Products (NGP), Select (SEL), Stanley/Dormakaba (STA), or approved equal.
 3. Continuous Geared Hinges: Hager (HAG), Ives/Allegion (IVE), Legacy (LEG), National Guard Products (NGP), Pemko/ASSA ABLOY (PEM), Select (SEL), Stanley/Dormakaba (STA), or approved equal.
 4. Pivots: Architectural Builders Hardware (ABH), Dormakaba (DOR), Ives/Allegion (IVE), Rixson/ASSA ABLOY (RIX), or approved equal.
 5. Cylinders and Keying: As selected by Owner.
 6. Heavy-Duty Grade 1 Mortise Locksets and Latchsets: Accurate 9000/9100 Series (ACC), Best/Stanley 45H Series (BES), Corbin-Russwin/ASSA ABLOY ML2000 Series (COR), Sargent/ASSA ABLOY 8200 Series (SAR), Schlage/Allegion L9000 Series (SCH), Townsteel MS Series (TOW), Yale/ASSA ABLOY 8800 Series (YAL), or approved equal.
 7. Heavy-Duty Grade 1 Cylindrical Locksets and Latchsets: Best/Stanley 9K Series (BES), Corbin-Russwin/ASSA ABLOY CL3300/3500 Series (COR), Sargent/ASSA ABLOY 10 Series (SAR), Schlage/Allegion ND Series (SCH), Townsteel CE/CEC Series (TOW), Yale/ASSA ABLOY 5400LN Series (YAL), or approved equal.
 8. Push-Pull Locksets and Latchsets: Architectural Builders Hardware (ABH), Corbin-Russwin/ASSA ABLOY (COR), Glynn-Johnson/Allegion (GLY), Sargent/ASSA ABLOY (SAR), Townsteel (TOW), or approved equal.
 9. Heavy-Duty Grade 1 Mortise Ligature Resistant Locksets and Latchsets: Accurate (ACC), Sargent (SAR), Schlage (SCH), Stanley/Dormakaba (STA), Townsteel (TOW), or approved equal.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

10. Narrow Stile Locksets and Latchsets: Accurate (ACC), Adamsrite/ASSA ABLOY (ADR), Ilco/Dormakaba (ILC), or approved equal.
11. Exit Devices: Corbin-Russwin/ASSA ABLOY ED4000/5000 Series (COR), Precision/Stanley 2000 Series (PHI), Sargent/ASSA ABLOY (SAR), Townsteel (TOW), Von Duprin/Allegion 33/35/94/95/98/99 Series (VON), Yale/ASSA ABLOY 6000/7000 Series (YAL), or approved equal.
12. Integrated Door Opening Assemblies with Inset Hardware for Hollow Metal Doors: Rite Door-Adams Rite/ASSA ABLOY (ADR), Total Door (TOT), Syntegra (SYN), Von Duprin/Allegion InPact 94 Series, or approved equal.
13. Electric Strikes: Adams Rite/ASSA ABLOY (ADR), Folger Adam/ASSA ABLOY (FOL), Hanchett Entry Systems/ASSA ABLOY (HES), Rutherford Controls Intl. (RCI), Security Door Controls (SDC), Von Duprin/Allegion (VON), or approved equal.
14. Electromagnetic Lock Assemblies: DynaLock (DYN), Schlage/Allegion (SCH), Securitron/ASSA ABLOY (SEC), Security Door Controls (SDC), or approved equal.
15. Electrical Power Transfers: Adams Rite/ASSA ABLOY (ADR), Architectural Builders Hardware (ABH), Command Access (CAT), Inox (INO), Security Door Controls (SDC), Von Duprin/Allegion (VON), or approved equal.
16. Door Position Switches: George Risk Industries (GRI), G.E. Security (GES), Security Door Controls (SDC), Townsteel (TOW), or approved equal.
17. Power Supplies for Electrified Hardware: Architectural Control Systems (ACS), Command Access Technologies (CAT), Securitron/ASSA ABLOY (SEC), Security Door Controls (SDC), Townsteel (TOW), Von Duprin/Allegion (VON), or approved equal.
18. Flush Bolts and Door Coordinators: Architectural Builders Hardware (ABH), Door Controls International (DCI), Inox (INO), Ives/Allegion (IVE), Rockwood/ASSA ABLOY (ROC), Townsteel (TOW), Trimco (TRI) , or approved equal.
19. Narrow Stile Hardware for Aluminum/Glass Storefront Doors: Adamsrite/ASSA ABLOY (ADR), Ilco/Dormakaba (ILC), or approved equal.
20. Heavy-Duty Grade 1 Cast Iron Surface Door Closers: LCN/Allegion (LCN) 4040XP Series, Norton/ASSA ABLOY (NOR) 9500 Series, Sargent/ASSA ABLOY (SAR) 281 Series, Stanley/Dormakaba (STS) QDC100 Series, Townsteel (TOW), Yale/ASSA ABLOY (YAL) 5800 Series, or approved equal.
21. Overhead Holders and Stops: Architectural Builders Hardware (ABH), Glynn-Johnson/Allegion (GLY), Rixson/ASSA ABLOY (RIX), Rockwood/ASSA ABLOY (ROC), or approved equal.
22. Heavy-Duty Overhead Surface and Concealed Automatic / Low Energy Door Operators: Besam/ASSA ABLOY (BSM), Horton (HOR), LCN 2800/9500 Series (LCN), Record-USA (REC), Stanley/Dormakaba (STA), or approved equal.
23. Door Operator Accessories: BEA (BEA), Larco (LAR), LCN (LCN), Security Door Controls (SDC), Sedco (SED), Wikk (WIK), or approved equal.
24. Electromagnetic Holder / Releases: Architectural Builders Hardware (ABH), Inox (INO), LCN/Allegion (LCN), Rixson/ASSA ABLOY (RIX), or approved equal.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

25. Architectural Door Trim: Architectural Builders Hardware (ABH), Ives/Allegion (IVE), Markar/ASSA ABLOY (MAR), National Guard Products (NGP), Rockwood/ASSA ABLOY (ROC), Townsteel (TOW), Trimco (TRI), or approved equal.
26. Auxiliary Hardware: Ives/Allegion (IVE), Rockwood/ASSA ABLOY (ROC), Townsteel (TOW), Trimco (TRI), or approved equal.
27. Door Bottoms, Metal Thresholds, Weatherstripping and Gaskets: KN Crowder (KNC), Legacy (LEG), National Guard Products (NGP), Pemko/ASSA ABLOY (PEM), Reese (RSE), Zero/Allegion (ZER), or equal.
28. Key Storage System: Lund (LUN), MMF Industries (MMF), Telkee (TEL), or approved equal.
29. Security Fasteners: Bryce Fasteners/Penta-Plus, or approved equal.

2.2 MATERIALS AND FABRICATION

- A. Requirements for grade, materials, size, and other distinctive qualities of each type of door hardware are indicated herein. Furnish items in types, sizes or weight, in accordance with manufacturer's standards, appropriate for the conditions of installation and service, unless otherwise indicated.
- B. Products named or identified by make or model number, or other designation and described herein are base products. Base products establish the standards of type, in-service performance, physical properties, appearance, warranty, cost, and other characteristics required by the Project.

2.3 FASTENERS

- A. Provide concealed fasteners for hardware items on exterior doors which are exposed when door is closed.
- B. Combination machine screws and expansion shields shall be used for attaching hardware to concrete or masonry.
- C. Fasteners exposed to the weather in the finished work shall be of brass, bronze, or stainless steel.
- D. Through-Bolt attachments will not be allowed. Coordinate with door manufacturers to provide the proper reinforcement or blocking to prevent the use of through-bolts.
- E. All exposed fasteners in patient-accessible areas shall be "Penta Plus" hex-drive with center pin type from Bryce Fastener, or approved equivalent.

2.4 BUTT HINGES

- A. Butt hinges shall meet ANSI/BHMA A156.1 requirements.
- B. Hinge dimensions shall conform to ANSI/BHMA A156.7.
- C. Base Metal shall be steel plated for fire-rated doors; bronze or stainless steel for exterior outswinging doors; bronze or plated steel elsewhere as scheduled.
- D. Provide hinges with antifriction bearings for doors with closers.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

- E. Unless otherwise indicated for 1-3/4 inches (4 cm) thick doors, provide hinges in heights and gauges as follows:
 - 1. Doors to 36 inches (91 cm) wide: Standard Weight 4-1/2 inches (114 mm).
 - 2. Doors over 36 inches (91 cm) to 42 inches (107 cm) wide: Standard Weight 5 inches (127 mm).
 - 3. Doors over 42 inches (107 cm) to 48 inches (122 cm) wide: Heavy Weight 5 inches (127 mm).
 - 4. Doors over 48 inches (122 cm) wide: 6 inches (152 mm) or continuous hinge.
 - 5. Doors over 1-3/4 inches (4 cm) thick shall be per hinge manufacturers published listings or recommendations.
- F. Provide in minimum width sufficient to clear trim when door swings 180 degrees, whether or not shown on Drawings to swing 180 degrees.
- G. Number of hinges per leaf shall be as follows:
 - 1. Doors to 60 inches (152 cm) in height: 2 hinges.
 - 2. Doors over 60 to 90 inches (152 to 229 cm) in height: 3 hinges.
 - 3. Doors over 90 to 120 inches (229 to 305 cm) in height: 4 hinges.
 - 4. For doors over 120 inches (305 cm) in height: 4 hinges plus 1 hinge for every 30 inches (75 cm), or fraction thereof, door height greater than 120 inches (305 cm).
- H. Screws: Flat head wood screws not less than 1-1/2 inches (38 mm) long for hinges for wood doors; flat head machine screws elsewhere.
- I. Hinges for reverse bevel doors with locks shall have pins that are made non-removable when the door is in the closed position by means of a set screw in the hinge pin barrel.
- J. Electrified hinges:
 - 1. Coordinate number and size of wires for electrified hardware served.
 - 2. Provide junction box/ mortar shield for each electrified hinge.

2.6 CONTINUOUS PINNED HINGES

- A. Continuous hinges shall meet ANSI/BHMA A156.26 requirements.
- B. Type: Pin and barrel construction; 1/4 inch (6 mm) diameter stainless steel pin; split nylon or stainless steel bearings. Fabricated from 14 gauge cold-rolled steel or 304 stainless steel as indicated.
- C. Provide in minimum width sufficient to clear trim when door swings 180 degrees, whether or not shown on Drawings to swing 180 degrees.
- D. Hole pattern for fasteners shall be symmetrical and located to template dimensions.

2.7 CONTINUOUS GEARED HINGES

- A. Continuous hinges shall meet ANSI/BHMA A156.26 requirements.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

- B. Type: Heavy duty assembly of 3 interlocking aluminum extrusions. Door leaf and jamb leaf shall be continuously geared together the full hinge length; secured together with full length cover channel permitting 180 degree operation. Vertical door loads carried on integrated thrust bearings spaced no more than 3 inches (76 mm) apart.
- C. Hinges shall have non-removable cap at hinge top to prevent foreign material from becoming lodged in hinge gear mechanism.
- D. Unless otherwise noted, provide factory finished to match door and frame finish.
- E. Hole pattern for fasteners shall be symmetrical and located to template dimensions.

2.8 PIVOT HINGES

- A. Pivot hinges shall meet ANSI/BHMA A156.4 Grade 1 requirements.
- B. Pivots shall be constructed of steel, cast or forged bronze, or stainless steel as indicated by BHMA finish specified.
- C. Where offset pivots are used, provide intermediate pivots as follows:
 - 1. Doors over 60 to 90 inches (152 to 229 cm) in height provide one intermediate pivot.
 - 2. For doors over 90 inches (229 cm) in height provide one additional intermediate pivot for every 30 inches (75 cm), or fraction thereof.
- D. Electrified pivots:
 - 1. Coordinate number and size of wires for electrified hardware served.
 - 2. Provide junction box/ mortar shield for each electrified pivot.

2.9 CYLINDERS, KEYING AND KEY STORAGE

- A. Lock cylinders shall meet ANSI/BHMA A156.5 requirements.
- B. Keying system shall meet ANSI/BHMA A156.28 requirements.
- C. Cylinders shall be High-Security type, listed and labeled as complying with drill and pick-resistant testing requirements of UL 437.
- D. Keying shall be provided to integrate with existing system as directed.
- E. Cylinders shall be keyed according to approved Keying Schedule.
- F. Provide a temporary keying system for interim use during construction.
- G. Provide change keys in individual envelopes for each cylinder delivered. Envelopes shall be marked with respective door identification numbers.
- H. Key set symbol, and inscription "Do Not Duplicate" shall be stamped on all keys.
- I. Keys shall be supplied as follows:
 - 1. Locks: 3 change keys each lock.
 - 2. Master keyed sets: 2 keys each set.
 - 3. Grand master keys: 5 total.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

4. Great Grand master keys: 5 total.
 5. Interchangeable Core control keys: 2 total.
 6. Construction keys: 10 total.
 7. Blank keys: 100 total.
- J. Provide Key Storage / Control System conforming to ANSI/BHMA A156.5, including key-holding hooks, labels, two sets of key tags with self-locking key holders, key-gathering envelopes, and temporary and permanent markers. Contain system in metal cabinet with baked-enamel finish and key locking door.
1. Key tags and holders shall be inscribed with key-change number and key-control to conform with approved hardware schedule for identification.
 2. Key Storage System shall be large enough to accommodate 150 percent of the facility.
- K. Subject to compliance with requirements, provide emergency entrance key vault(s); Knox Company 3200 Series, or equal.
1. Finish Color - Black, Dark Bronze or Aluminum as selected by Architect.
 2. Where indicated provide security key override switches for electrically activated openings.
 3. Coordinate and provide keying and type per fire/ police department, and other jurisdictional agency requirements.
- 2.10 LOCKSETS AND LATCHSETS
- A. Mortise Locks and Latches shall meet ANSI/BHMA A156.13 Grade 1 requirements.
- B. Cylindrical Locks and Latches shall meet ANSI/BHMA A156.2 Series 4000 Grade 1 requirements.
- C. Interconnected Locks and Latches shall meet ANSI/BHMA A156.12 requirements.
- D. Auxiliary Locks shall meet ANSI/BHMA A156.5 requirements.
- E. Electrified Locks shall also meet ANSI/BHMA A156.25 requirements.
- F. Operating trim shall be lever type as selected by Architect, or approved equal.
- G. Lock functions which include thumb turn trim shall be provided with thumb turns compliant with accessibility code requirements.
- H. Lock Throw: Comply with requirements for length of latch bolts to comply with labeled fire door requirements.
- I. Lock backset shall be 2-3/4 inches (70 mm) unless otherwise indicated.
- J. Provide curved-lip strike with dust box for each latch or lock bolt, with lip extended to protect frame, finished to match door hardware set, unless otherwise indicated.
- K. Electromechanical locksets utilized at fire rated openings shall be listed and labeled by a testing agency acceptable to authorities having jurisdiction, and shall maintain door in positive latched position when power is off.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

2.11 SELF-CONTAINED ELECTRONIC GUEST ROOM LOCKS – Not Used

2.12 EXIT DEVICES

- A. Exit devices and exit device accessories shall meet ANSI/BHMA A156.3, Grade 1 requirements.
- B. Electromechanical exit devices shall also meet ANSI/BHMA A156.25 requirements.
- C. Panic Exit Devices: Listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for panic protection, based on testing according to UL 305.
- D. Fire Exit Devices: Complying with NFPA 80 that are listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for fire and panic protection, based on testing according to UL 305 and NFPA 252.
- E. Full compliance to UL 305 Standard for Safety: Panic Hardware
 - 1. Section 4.3: The ends of crossbar or push pad shall be curved, guarded, or otherwise designed to prevent catching of clothing of persons during exit.
- F. Outside Trim: Design, material and finish to match locksets, unless otherwise indicated.
- G. Adjustable strikes shall be provided for rim type and vertical rod devices.
- H. All fire-rated and non-rated concealed vertical rod (CVR) devices with bottom rods to receive floor strikes installed into floor or threshold.
- I. Fire Exit Removable Mullions: Where indicated, provide removable mullions for use with fire exit devices complying with NFPA 80 that are listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for fire and panic protection, based on testing according to UL 305 and NFPA 252. Mullions shall be used only with exit devices for which they have been tested.
- J. Electromechanical exit devices utilized at fire rated openings shall be listed and labeled by a testing agency acceptable to authorities having jurisdiction, and shall maintain door(s) in positive latched position when power is off.

2.13 ELECTRIC STRIKES

- A. Electric strikes shall meet ANSI/BHMA A156.31 Grade 1 requirements, and be listed and labeled under UL 1034 Burglary Resistant Electric Locking Equipment.
- B. Electric strikes for fire rated openings shall be listed and labeled for such use by a testing agency acceptable to authorities having jurisdiction. Fail Secure (fail locked) strikes shall be used at all fire rated openings.

2.14 ELECTROMAGNETIC LOCK ASSEMBLIES

- A. Electromagnetic lock assemblies shall meet ANSI/BHMA A156.23 Grade 1 requirements.

- B. Locks shall be field-selectable for 12 or 24 VDC operation, and provide 1,500 lbf (6672 N) minimum holding force for direct pull applications and 2,000 lbf (8896 N) holding force for shear type applications.
- C. Wiring connections shall be via on-board screw terminal connections. Lock shall have built-in circuit/ surge and voltage kickback suppression protection.
- D. Where indicated, locks shall be equipped with concealed sensors to monitor magnetic bond status and door position status.
- E. Locks used on fire rated doors shall be listed and labeled for such use by a testing agency acceptable to authorities having jurisdiction.

2.15 ELECTRICAL POWER TRANSFERS

- A. Electrical power transfers shall be capable of transferring sufficient electrical current to properly operate electrified hardware in door.
- B. Electrical power transfers used on fire rated doors shall be listed and labeled by a testing agency acceptable to authorities having jurisdiction.

2.16 DOOR POSITION SWITCHES

- A. Door position switches used on fire rated doors shall be listed and labeled by a testing agency acceptable to authorities having jurisdiction.

2.17 POWER SUPPLIES FOR ELECTRIFIED HARDWARE

- A. Power supplies shall be UL listed for applicable use; shall be housed in an approved enclosure; and provide both Class 1 and Class 2 outputs.
- B. Output shall be filtered and regulated. Relay, timer, and logic modules shall be provided as required for interface to related security components; and shall be assembled, connected, and fully contained within the power supply enclosure. A fire alarm emergency release input terminal shall be provided for connection to fire / life safety system at fire-rated openings.
- C. Power supplies shall provide sufficient power capacity for the worst-case condition that could occur in the operating environment without any loss or degradation of operation.

2.18 FLUSH BOLTS

- A. Automatic flush bolts shall meet ANSI/BHMA A156.3
- B. Manual flush bolts shall meet ANSI/BHMA A156.16 requirements.
 - 1. Bottom bolt shall have 12 inch (305 mm) long operating rod. Top bolt operating rod shall be determined by door height, assuring the operator is located less than 72 inches (183 cm) above the floor.
 - 2. Manual Flush Bolts are not to be utilized except where a pair of non-rated doors serving a room not normally occupied is needed for the movement of equipment.
- C. Provide dust proof strikes for bottom bolts. Dust proof strikes shall meet BHMA A156.16.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

2.19 DOOR COORDINATORS

- A. Door coordinators shall meet ANSI/BHMA A156.3 requirements.
- B. Door coordinators shall be flat bar type; stop mounted with all necessary filler bars and mounting brackets to accommodate required hardware.
- C. Provide carry bar at each pair of doors equipped with an overlapping astragal, except when automatic or self-latching bolts are used.

2.20 DOOR COORDINATOR / CLOSING SYSTEM – Not Used

2.21 SURFACE DOOR CLOSERS

- A. Door closing devices shall meet ANSI/BHMA A156.4, Grade 1 requirements.
- B. Surface closers shall be fully adjustable with sweep speed, latch speed and back check position valves.
- C. Provide closers size adjusted in accordance with ANSI/BHMA A156.4; sized as required to insure closing and latching of doors.
- D. Arm selection shall follow the requirements of the manufacturer's recommendations with brackets, drop plates and miscellaneous accessories provided as necessary.
- E. Provide closers with arms designed to permit openings of doors as far as job conditions will permit; unless otherwise indicated closers with arms restricting opening of door will not be acceptable.

2.22 OVERHEAD CONCEALED DOOR CLOSERS

- A. Overhead Concealed Door Closers shall meet ANSI/BHMA A156.4 requirements.
- B. Closers shall be fully adjustable with sweep speed, latch speed and back check position valves.
- C. Provide closers size adjusted in accordance with ANSI/BHMA A156.4; sized as required to insure closing and latching of doors.

2.23 FLOOR CLOSERS

- A. Floor Closers shall meet ANSI/BHMA A156.4, Grade 1 requirements.
- B. Closers shall be fully adjustable with sweep speed, latch speed and back check position valves.
- C. Floor closers shall have cement boxes.
- D. Pivots used on doors with floor closers shall be of the same manufacturer as the floor closers.
- E. Provide flush floor cover plates for floor closers unless thresholds are indicated. Match door hardware finish, unless otherwise indicated.

- F. Provide recessed floor plates to accommodate insert of floor finish material for floor closers, unless thresholds are indicated. Provide extended closer spindle to accommodate thickness of floor finish.

2.24 OVERHEAD HOLDERS AND STOPS

- A. Overhead holders and stops shall meet ANSI/BHMA A156.8 requirements.
- B. Overhead door holders and stops shall be adjustable from 90 to 110 degrees dead stop or hold open position, as applicable.
- C. Overhead door stops shall have shock absorbers providing 5 to 7 degrees compression before dead stop.
- D. Overhead stops shall not be provided with hold open function when used at fire rated doors.

2.25 AUTOMATIC AND LOW ENERGY DOOR OPERATORS

- A. Surface Applied Operator: The operator header shall be mounted to the surface of the door frame or wall. Connecting hardware shall be a double arm arrangement that can either push the door or pull the door open to suit the job condition. Provide parallel arm when operator mounting is on the pull side, and adjacent wall is within 4 inches (102 mm) of the door frame. Provide fire labeled unit for use at rated doors.
- B. Overhead Concealed Operator: The operator header shall be mounted directly over the door and serve as the door frame header. The operator output shaft shall connect to an arm that transmits power to the door via a slide block which moves in track that is recess mounted in the top of the door.
- C. In-Floor Operator Converter: Manufacturer's specialized unit to adapt specified automatic swing door operator to in-floor use. The converter shall be mounted beneath the door leaf and jamb area utilizing a standard pivot setback. Heavy-duty pivot shall incorporate 1200 pound rated, sealed thrust bearings in 1 inch (25 mm) steel bearing plate.
- D. Automatic Door Operators shall meet ANSI/BHMA A156.10 requirements.
 - 1. Provide guard rails and safety sensors to meet A156.10 requirements and all applicable codes.
 - 2. Power operation shall be activated by push plate switch, motion detector, or other actuators as indicated.
- E. Low Energy Door Operators shall meet ANSI/BHMA A156.19 requirements.
 - 1. Provide safety sensors and features to meet A156.19 requirements and all applicable codes.
 - 2. Door shall not open to back check faster than 3 seconds, and shall require no more than 15 lbf (67 N) applied 1 inch (25 mm) from latch edge to stop door movement.
 - 3. Door shall remain in fully open position for no less than 5 seconds.
 - 4. Door shall close from 90 degrees to 10 degrees no faster than 3 seconds, and 10 degrees to fully close no faster than 1-1/2 seconds.

- 5. Power operation shall be activated by push plate switch, or other actuators as indicated.
- F. For buildings or facilities serving 150 or more occupants, provide back-up power source capable of cycling door(s) a minimum of 100 cycles.
- G. Provide UL labeled operators at fire-rated openings. Provide power-disconnect interface to Fire Alarm; doors to be self closing and latching, in full compliance with Code requirements for "Fire Assembly, Self Closing" doors.
- H. Provide UL labeled operators at smoke barrier openings. Provide hold-open circuitry and power-disconnect interface to Fire Alarm; doors to be automatic closing and latching, in full compliance with Code requirements for "Fire Assembly, Automatic Closing" doors.

2.26 ELECTROMAGNETIC HOLDER / RELEASES

- A. Electromagnetic holders shall meet ANSI/BHMA A156.15 requirements.
- B. Size and configuration shall provide degree of swing and hold open position as indicated on the drawings.

2.27 ARCHITECTURAL DOOR TRIM

- A. Architectural door trim shall meet ANSI/BHMA A156.6 requirements.
- B. Door Protection Plates: Kick, mop, and armor plates shall be 0.050 inch (1.3 mm) thick brass, bronze, or stainless steel depending on finish indicated. Plates shall have beveled edges, and shall be provided with countersunk mounting holes and No. 6 oval head screw fasteners. Width of kick and armor plates shall be 2 inches (51 mm) less than door width for single doors and 1 inch (25 mm) less for pairs of doors. Width of mop plates shall be 1 inch (25 mm) less than door width. Unless otherwise indicated, height shall be 10 inches (254 mm) for kick and mop plates, and 34 inches (864 mm) for armor plates.
 - 1. At all fire-rated and non-rated doors, provide UL labeled protection plates in sizes, types, fasteners and materials only in accordance with door manufacturer's listings for respective ratings. UL label must be an embossed stamp into metal; no surface applied Mylar or any other material will be acceptable.
- C. Door Edging and Astragals: Fabricated from 18 gauge cold-rolled steel or 304 stainless steel as indicated; factory prepared for all mortise hardware; countersunk screw mounting.
 - 1. At fire rated doors, provide UL labeled edge protection in sizes, types, fasteners and materials only in accordance with door manufacturer's listings for respective ratings.
- D. Push and pull plates shall be 0.050 (1.3 mm) inch thick brass, bronze, or stainless steel depending on finish indicated. Plates shall have beveled edges, and shall be furnished with countersunk mounting holes and No. 6 oval head screw fasteners. Pull plates shall also be furnished with flat-head through bolts for pull grip.
- E. Push and pull bars and grip handles shall be brass, bronze, or stainless steel depending on BHMA finish indicated.

2.28 AUXILIARY HARDWARE

- A. Auxiliary hardware shall meet ANSI/BHMA A156.16 requirements.
- B. Door Stops: Stops shall be of heavy duty construction, provided in finish indicated. Wall bumpers shall have no visible fasteners. Floor stops shall be of height required by floor conditions. Unless otherwise indicated, provide stops at all doors as follows:
 - Medium and High Risk areas:
 - 1. At exterior and interior doors provide heavy duty wall bumper ABH 1841, or approved equal.
 - 2. Where it is not possible to place a wall stop, provide heavy duty floor stop Architectural Builders Hardware AB-446-RKW, Rockwood 446-RKW, Trimco 1209, or approved equal.
 - 3. Where it is not possible to properly place a wall or floor type stop, provide heavy duty concealed overhead type stop, or when door closer is indicated, provide stop function in closer mechanism.
 - Low Risk and all other areas:
 - 4. At exterior, outswinging doors provide heavy duty floor stop Rockwood, 481H, Trimco 1214H, or equal, unless stop function is indicated in door closer.
 - 5. At all other doors provide floor stop Rockwood 441CU, Trimco 1211, wall bumper Rockwood 409, Trimco 1270CV, or equal.
 - 6. Where it is not possible to properly place a floor or wall type stop, provide heavy duty concealed overhead type stop, or when door closer is indicated, provide heavy-duty dead stop function in closer.
- C. Silencers: Gray rubber, non-marring configured for metal or wood frames as scheduled. Provide 3 per single door and 2 per pair of doors. Silencers shall be tamper resistant once installed in door frame.

2.29 DOOR BOTTOMS

- A. Door bottoms shall be of aluminum or extruded bronze of the type and finish indicated and shall provide proper clearance and an effective seal with specified thresholds.
- B. Door bottom shall have a vinyl, neoprene, silicone rubber, polyurethane or brush seal as indicated.
- C. The door bottom shall exclude light when the door is in the closed position and shall inhibit the flow of air through the unit.

2.30 METAL THRESHOLDS

- A. Thresholds shall meet ANSI/BHMA A156.21 requirements.
- B. Thresholds shall be heavy-gauge aluminum or bronze of the configuration and finish indicated, and shall provide an effective seal with door bottom.
- C. Where required, thresholds shall be prepared to accommodate floor closers, pivots, and projecting bolts of latching hardware.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

- D. Thresholds at floor closers shall have mitered returns and removable access portion for floor closer maintenance.
- E. Provide thresholds at doors where indicated. Refer to Door Schedule and Drawing details for type and configuration required. Additionally, where combustible flooring passes under doors, provide fire door thresholds in accordance with applicable regulatory requirements.

2.31 METAL HOUSED TYPE WEATHERSTRIP

- A. Metal Housed Type Weatherstrip shall meet ANSI/BHMA A156.22 requirements.
- B. Metal Housed Type Weatherstrip shall be aluminum or bronze of the type and finish indicated, comprised of metal retainers with vinyl, neoprene, silicone rubber, polyurethane or brush inserts as indicated.

2.32 GASKETING

- A. Gasketing shall meet ANSI/BHMA A156.22 requirements.
- B. Shall be a compression type product for use with wood or steel doors; labeled for use on smoke-control and fire-rated doors where required.

2.33 FOLDING AND SLIDING DOOR HARDWARE – Not Used

2.34 FINISHES

- A. Provide hardware in finishes as indicated.
- B. Unless otherwise indicated, finishes shall conform to those identified in ANSI/BHMA A156.18. Comply with base material and finish requirements indicated by the following:
 - 1. BHMA 600: Primed for painting, steel base metal.
 - 2. BHMA 626: Satin chromium plated over nickel, brass or bronze base metal.
 - 3. BHMA 628: Satin aluminum, clear anodized, aluminum base metal.
 - 4. BHMA 630: Satin stainless steel, stainless-steel base metal.
 - 5. BHMA 652: Satin chromium plated over nickel, steel base metal.
 - 6. BHMA 689: Aluminum painted, any base material.
 - 7. BHMA 719: Mill finish aluminum, uncoated, aluminum base metal.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine doors and frames for compliance with requirements for installation tolerances, labeled fire door assembly construction, wall and floor construction, and other conditions affecting performance.
- B. Examine rough-in for electrical power systems to verify actual locations of wiring connections before electrified door hardware installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. Steel doors shall be factory prepared for hardware per ANSI/BHMA A156.115.
- B. Wood doors shall be factory prepared for hardware per ANSI/BHMA A156.115W.
- C. Installation shall be in accordance with DHI A115.IG.
- D. Hardware for fire door assemblies shall be installed conforming with NFPA 80, and all other applicable building codes and regulations.
- E. Hardware for smoke door assemblies shall be installed conforming with NFPA 105, and all other applicable building codes and regulations.
- F. Install each door hardware item according to manufacturer's printed instructions, utilizing templates and proper fasteners provided by manufacturer.
- G. Set units level, plumb, and true to line and location. Adjust and reinforce attachment substrates as necessary for proper installation and operation.
- H. Where cutting and fitting are required to install door hardware onto or into surfaces that are later to be painted or finished in another way, coordinate removal, storage, and reinstallation of surface protective trim units with finishing work specified in other Sections. Do not install surface-mounted items until finishes have been completed on substrates involved.

3.3 DOOR CLOSING DEVICES

- A. Surface closers on doors opening to or from halls and corridors shall be mounted on the room side of the door.
- B. Surface closers on doors opening into stairs or stair vestibules shall be mounted on the stair or stair vestibule side of the door.
- C. Surface closers on exterior doors shall be mounted on the interior side of building utilizing regular arm, or parallel arm mounting as required.
- D. Door closing devices with adjustable spring power shall be adjusted for proper door operation, and compliance with all applicable codes and regulations.
- E. Cutting of gasketing or weatherstripping to accommodate closer installation is not acceptable.
- F. Through-Bolt attachments will not be allowed. Coordinate with door manufacturers to provide the proper reinforcement or blocking to prevent the use of through-bolts.

3.4 PUSH-PULL PLATES

- A. Pull plate grip handles shall be through bolted through the door. When push plate is indicated on opposite door side, through bolts shall be countersunk with push plate mounted to conceal through bolts.

3.5 KEY CONTROL STORAGE SYSTEMS

- A. Key control storage system shall be installed where directed by the Architect.
- B. Place keys on markers and hooks in key control system cabinet, as determined by final keying schedule.

3.6 THRESHOLDS

- A. Thresholds shall be secured with a minimum of 3 fasteners per single door width and 6 fasteners per double door width with a maximum spacing of 12 inches (305 mm); with a minimum of 1 inch (25 mm) thread engagement into the floor or anchoring device used. Thresholds over 6 inches (152 mm) in width shall be secured with a double row of fasteners.
- B. Exterior thresholds shall be installed in a bed of sealant with combination expansion anchors and stainless steel machine screws, except that bronze or anodized bronze thresholds shall be installed with expansion anchors with brass screws.

3.7 ASTRAGALS

- A. Unless otherwise indicated install overlapping astragals as follows:
 - 1. At out-swing pairs of doors, mount astragal on active leaf.
 - 2. At in-swing pairs of doors, mount astragal on inactive leaf.

3.8 HARDWARE LOCATIONS

- A. Unless otherwise indicated install hardware as follows, unless shown otherwise on elevations or drawings:
 - 1. Bottom Hinge: 10 inches (254 mm) from door bottom to bottom of hinge.
 - 2. Top Hinge: 5 inches (127 mm) from door top to top of hinge.
 - 3. Center Hinge(s) or Pivot(s): Spaced equidistantly between top and bottom hinges/ pivots.
 - 4. Lockset / Latchset: 38 inches (965 mm) from finished floor to center of lever.
 - 5. Hospital Push-Pull Latchset/ Lockset: 42 inches (1067 mm) from finished floor to center of latch.
 - 6. Exit Device: 38 inches (965 mm) from finished floor to device centerline.
 - 7. Deadlock: Maximum height of 44 inches (1117 mm) from finished floor to center key cylinder / thumb turn.
 - 8. Push Plate/ Pull Plate: 42 inches (1067 mm) from finished floor to center of pull.
 - 9. Wall Bumper: Centered at point on wall where lever, or other operating trim, first makes contact with wall.
 - 10. Floor Stop: Adjacent to wall; not to exceed 4 inches (102 mm) from face of wall; located 3 inches (76 mm) from latch edge of door; in any case never more than 50 percent of door width from latch edge of door.

3.9 ADJUSTING

- A. Adjust and check each operating item of door hardware and each door to ensure proper operation or function of every unit. Replace units that cannot be adjusted to operate as intended.

- B. Engage a factory-authorized service representative to adjust door closing devices, compensating for final operation of heating and ventilating equipment, and to comply with referenced accessibility requirements.
- C. Follow-up Adjustment: Approximately 6 months after date of Substantial Completion, Installer shall perform the following:
 - 1. Examine and readjust each item of door hardware as necessary to ensure function of door hardware.
 - 2. Consult with and instruct Owner's personnel on recommended maintenance procedures.
 - 3. Replace door hardware items that have deteriorated or failed due to faulty design, materials, or installation of door hardware units.

3.10 FIELD INSPECTIONS

- A. Fire Door Assembly Inspection and Testing: Provide functional testing and inspection of fire door assemblies in accordance with current NFPA 80. Inspections shall be performed by individuals certified by Intertek as a Fire Door Assembly Inspector (FDAI), using reporting forms provided by the Door and Hardware Institute (DHI). Alternatively, inspections may be performed by individuals acceptable to the Architect, who have knowledge and understanding of the operating components of the applicable door type, and who have experience in preparing written reports of testing and inspection results.
 - 1. Schedule fire door assembly inspection within 90 days of Substantial Completion of the Project.
 - 2. Submit a signed, written final report as specified in Paragraph 1.03.K: Submittals.
 - 3. Contractor shall correct all deficiencies and schedule a reinspection of fire door assemblies which were noted as deficient on the inspection report.
 - 4. Inspector shall reinspect fire door assemblies after repairs are made.
 - 5. Additional reinspections which are required due to incomplete repairs will be performed by the inspector at the expense of the Contractor.

3.11 FIELD QUALITY CONTROL

- B. Independent Architectural Hardware Consultant:
 - 1. Engage a qualified independent Architectural Hardware Consultant to perform inspections and to prepare inspection reports.
 - 2. Independent Architectural Hardware Consultant shall inspect door hardware and prepare written report whether installed work complies with or deviates from requirements, whether door hardware is properly installed and adjusted, and prepare a specific list of any deficiencies, a copy of which shall be provided to Architect.
 - 3. Contractor shall correct all deficiencies noted in above report.
 - 4. Independent Architectural Hardware Consultant shall re-inspect door hardware and prepare a report certifying correction of deficiencies and compliance with requirements.

3.12 COMPLETION

- A. When complete all hardware shall be properly secured in place and all exposed surfaces shall be clean and free from scratches, paint, and other defects and damages.
- B. Contractor shall demonstrate that all keys properly operate the locks as identified in the approved Keying Schedule.

3.13 DOOR HARDWARE SETS

- A. The following is a general listing of hardware requirements. Provide hardware items required by established standards and practices to meet state and local codes, whether or not specifically indicated in the following sets.
- B. Silencers and gasketing, where listed in Hardware Sets, may be omitted at openings where door frames are provided with integral seals if integral seals satisfy all applicable Codes and Regulations.
- C. Refer to Door Schedule and/ or Drawings for door opening information, hardware set assignment, and related requirements.
- D. Door protection items -- mop plates, kick plates, armor plates, and edge guards -- are not indicated in Hardware Sets. Refer to Door Schedule and/ or Drawings for required locations.

-- Remainder of page intentionally left blank --

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

Note: Where possible, it is recommended to remove door closers on high-risk areas per NYS OMH standards.

HW 01 Interior Single Bedroom - Classroom Lock/Ligature Resistant - No Closer - Rescue Hdw**Each Opening to Receive: High Risk**

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge-Double Acting	A508	630	ABH
1 Ea.	Ligature Res. Mortise Lock-Classrm	MRX-A-05	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
1 Ea.	Emergency Rescue Stop	A509	630	ABH

HW 02 Interior Single - Office Lockset/Ligature Resistant - No Closer - Continuous Hinge**Each Opening to Receive: Medium Risk**

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC	630	ABH
1 Ea.	Ligature Res. Cyl. Lock-Office	CRX-A-81	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

HW 02A Interior Single - Office Lock/Ligature Resistant - Surface Closer/Track-Arm - Cont Hinge**Each Opening to Receive: Medium Risk**

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC	630	ABH
1 Ea.	Ligature Res. Cyl. Lock-Office	CRX-A-81	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer - Track Arm	4210T/4510T TRX mount on public side	689	LCN
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

HW 03 Interior Single - Storeroom Lock/Ligature Resistant - Surface Closer/Track-Arm - Cont Hng**Each Opening to Receive: Medium Risk**

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC	630	ABH
1 Ea.	Ligature Res. Cyl. Lock-Storerm	CRX-A-86	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer - Track Arm	4040XPT TROX	689	LCN
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 04 Interior Single - Storeroom Lockset/Ligature Resistant - Surface Closer - Continuous Hng**Each Opening to Receive: Medium Risk**

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC	630	ABH
1 Ea.	Ligature Res. Cyl. Lock-Storerm	CRX-A-86	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer	4210T/4510T TBTRX mount public side	689	LCN
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

HW 04A Interior Single - Storeroom Lockset/Ligature Resistant - Surface Closer - Continuous Hng**Each Opening to Receive: Medium Risk**

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC	630	ABH
1 Ea.	Ligature Res. Cyl. Lock-Storerm	CRX-A-86	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer	4040XPT BUMP Torx	689	LCN
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

HW 05 Interior Single - Storeroom Lockset - Surface Closer - Butt Hinges**Each Opening to Receive: N203 (Low Risk)**

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge-HT	CB51 HT	630	PBB
1 Ea.	Cyl. Lock-Storerm	CDC-86-S	626	TOW
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	OH Surface Closer	4040XP/4040XP EDA	689	LCN
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	5050	BLK	NGP

HW 05A Interior Single - Storeroom Lockset - No Closer - Butt Hinges**Each Opening to Receive: Low Risk**

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge-HT	CB51 HT	630	PBB
1 Ea.	Cyl. Lock-Storerm	CDC-86-S	626	TOW
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	5050	BLK	NGP

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 06 Interior Single - Card Reader - Elec Fail-Secure Lock - Surface Closer - Butt Hinges

Each Opening to Receive:		N112A		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge-HT	CB51 HT	630	PBB
1 Ea.	Hinge-Power Transfer	CB51EL HT	630	PBB
1 Ea.	Fail Secure Cyl. Lock	XCDC-86-S-RQE Fail Secure 24VDC	626	TOW
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	OH Surface Closer	4040XP/4040XP EDA	689	LCN
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	5050	BLK	NGP
1 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security. Free egress at all times. ~~Power Supply require 120VAC.~~

Note: Fail Secure - Upon loss of power lock becomes locked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains locked.

HW 06A Moved to Exterior Set HW E11**HW 07 Interior Single - Institutional Privacy/Occ Ind - Ligature Resistant - Self Closing Cont Hinge**

Each Opening to Receive:		High Risk - Patient RR		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Self Closing Continuous Hinge	A507SC HT	628	ABH
1 Ea.	Ligature Res Mort Lock-Ins.Privacy/ID	MRX-A-26-O	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Concealed Closer	2031 Torx	689	LCN
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

Note: NYS OMH Standards do not approve any door closers for High Risk areas. Closer removed.

HW 07A Interior Single - Storeroom Privacy w/ID&Override - Ligature Resistant - SRCL - Cont Hinge

Each Opening to Receive:		Medium Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC	630	ABH
1 Ea.	Lig Res Mortise Lock-Strm Priv w/ID	MRX-A-15-O (Storerm Prvy W/ID ORD)	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer	4210T/4510T TBTRX mount on public side	689	LCN
1 Ea.	OH Concealed Closer	2031 BUMP	689	LCN
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 07B Interior Single - Institutional Privacy/Occ Ind - Ligature Resistant - OHCC - Cont Hinge
Each Opening to Receive: Staff Toilet - High Risk

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Self Closing Continuous Hinge	A507SC HT	628	ABH
1 Ea.	Lig Res Mortise Lock-Strm Priv w/ID	MRX-A-15-O (Storerm Prvy W/ID ORD)	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Concealed Closer	2031 BUMP	689	LCN
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

Note: NYS OMH Standards do not approve any door closers for High Risk areas. Closer removed.

HW 08 Interior Single - Hotel Lockset - Surface Closer - Butt Hinges
Each Opening to Receive: Low Risk

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge-HT	CB51 HT	630	PBB
1 Ea.	Cyl. Lock-Hotel	CDC-93-S	626	TOW
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	OH Surface Closer	4040XP/4040XP EDA	689	LCN
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	5050	BLK	NGP

HW 09 Interior Single - Classroom Lockset/Ligature Resistant - No Closer - Continuous Hinge
Each Opening to Receive: Medium Risk

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC	630	ABH
1 Ea.	Ligature Res. Cyl. Lock-Classrm	CRX-A-84	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

HW 09A Interior Single - Classroom Lockset - No Closer - Butt Hinges
Each Opening to Receive: Low Risk

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge-HT	CB51 HT	630	PBB
1 Ea.	Cyl. Lock-Classrm	CDC-84-S	626	TOW
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	5050	BLK	NGP

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 09B Interior Single - Classroom Lockset/Ligature Resistant - No Closer - Continuous Hinge
Each Opening to Receive: High Risk

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC	630	ABH
1 Ea.	Ligature Res. Mortise Lock-Classrm	MRX-A-05	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

HW 10 Interior Single - Card Reader - Elec Fail Secure/Fail-Safe Lock/Lig Res - Surface Closer
Each Opening to Receive: Medium Risk

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC TW8	630	ABH
1 Ea.	Lig Res. Mortise Lock-Fail Safe/Secure	X-MRX-A-241/242C-RQE Fail Saf/Secure	630	TOW
2 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer	4210T/4510T TBTRX mount on public side	689	LCN
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
1 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security.
~~Power Supply require 120VAC.~~

Note: Fail Secure/Fail Safe as required per Security Drawings.

HW 10A Moved to Exterior Set HW E12

HW 10B Moved to Exterior Set HW E13

HW 10C Exterior doors only moved to Exterior Set HW E13; Door S100B is interior

HW 10C Interior Single - Push/Pull-Ligature Resistant - Automatic Operator
Each Opening to Receive: Medium Risk - Door S100B

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Ea.	Continuous Hinge	AC500 HT SEC	630	ABH
1 Set	Ligature Res. Push/Pull Set	MRX-A-72	630	TOW
1 Ea.	Overhead Surface Auto Operator	SW200i 115VAC	628	BSM
As Req.	Wave Sense Actuator	MS31 / MS41	---	BEA
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM

HW 11 Moved to Exterior Set HW E14

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

<u>HW 12</u> Interior Single - Passage Latchset/Ligature Resistant - OHC Closer - Cont Hng - Rescue				
Each Opening to Receive:		High Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge-Double Acting	A507	628	ABH
1 Ea.	Ligature Res. Mortise Lock-Classroom	MRX-A-05	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Double Acting OH Concealed Closer	KG35	630	KSG
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
1 Ea.	Emergency Rescue Stop	A509 L	630	ABH
1 Ea.	Cylinder (For Rescue Stop)	Per project	630	TBD
<u>HW 12A</u> Interior Single - Passage Latchset/Ligature Resistant - No Closer - Continuous Hinge				
Each Opening to Receive:		High Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC	630	ABH
1 Ea.	Ligature Res. Mortise Lock-Classroom	MRX-A-05	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
<u>HW 12B</u> Interior Single - Passage Latchset/Ligature Resistant - No Closer - Continuous Hinge				
Each Opening to Receive:		Medium Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC	630	ABH
1 Ea.	Ligature Res. Mortise Lock-Classrm	MRX-A-05	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
<u>HW 12C</u> Interior Single - Passage Latchset/Ligature Resistant - Surface Closer - Continuous Hinge				
Each Opening to Receive:		High Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Self-Closing Continuous Hinge	A507 HT SEC	630	ABH
1 Ea.	Ligature Res. Mortise Lock-Classrm	CRX-A-84	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer	4210T/4510T TBTRX-mnt-public side	689	LCN
1 Ea.	Wall Stop*	1841*	630	ABH
1 Ea.	Floor Stop**	AB-446-RKW**	BLK	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

Note: *Wall stop to be installed where adjacent wall exists per Specification 081700 Part 3.8.A.10.

Note: **At Client rooms only where no adjacent wall exists disregard Part 2.28.B.3 requiring an overhead stop and Part 3.8.A.10 to install floor stop close to hinge edge as not to create a tripping hazard.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 13 **Moved to Exterior Set HW E18**

HW 14 **Moved to Exterior Set HW E15**

HW 14A **Moved to Exterior Set HW E17**

HW 14B **NOT USED**

HW 14B **~~Exterior Single - Ligature Resistant Push/Pulls - Auto Operator- Continuous Hinge~~**

Each Opening to Receive:		Medium Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
2-Set	Continuous Hinge	AC500 HT SEC	630	ABH
2-Set	Ligature Res. Push/Pull Set	MRX-A-72	630	TOW
2-Ea.	Overhead Surface Auto Operator	SW200i 115VAC	628	BSM
As Req.	Wave Sense Actuator	MS31 / MS41	---	BEA
2-Ea.	Door Stop	Per Specification	---	---
1-Set	Gasketing	ANTI-LIG 5050	BLK	NGP
1-Ea.	Threshold	To Suit Sill Condition	719	PEM

HW 14B **Interior Pair - Ligature Resistant Push/Pulls - Automatic Operator- Continuous Hinge**

Each Opening to Receive:		Medium Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
2 Set	Continuous Hinge	AC500 HT SEC	630	ABH
2 Set	Ligature Res. Push/Pull Set	MRX-A-72	630	TOW
2 Ea.	Overhead Surface Auto Operator	SW200i 115VAC	628	BSM
As Req.	Wave Sense Actuator	MS31 / MS41	---	BEA
2 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 15	Not Used			
HW 15	Interior Single - Card Reader - Push/Pulls - Magnetic Locks - Auto Operator - Cont Hinge			
	Each Opening to Receive:	Medium Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Swing Clear Continuous Hinge	A511 HT SEC (Not NYS OMH approved)	630	ABH
1 Set	Ligature Res. Push/Pull Set	MRX-A-72	630	TOW
1 Ea.	Mag Lock	1511-V-D-B-A 24VDC	628	SDC
1 Ea.	Push to Lock/Unlock Button	CB402-AU (One Per Two Drs.)	---	SDC
1 Ea.	Emergency Release Button	CB402-B	---	SDC
1 Ea.	Overhead Surface Auto Operator	SW200i 115VAC	628	BSM
As Req.	Wave Sense Actuator	MS31 / MS41	---	BEA
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	REX Motion Sensor	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---
1 Ea.	Push to Exit Button	By Division 28	---	---

Note: ~~Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security.~~
~~Power Supply require 120VAC.~~

Note: ~~Fail Safe - Upon loss of power lock becomes unlocked. Secure side remains unlocked for egress.~~
~~Unsecure side remains unlocked.~~

HW 15	Interior Single - Ligature Restant Push/Pulls - Magnetic Lock - Automatic Operator			
HW 15A	Interior Single - Ligature Restant Push/Pulls - Magnetic Lock - Automatic Operator			
	Each Opening to Receive:	Medium Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Swing Clear Continuous Hinge	A511 HT SEC (Not NYS OMH approved)	630	ABH
1 Set	Ligature Res. Push/Pull Set	MRX-A-72	630	TOW
1 Ea.	Mag Lock	1511	628	SDC
1 Ea.	Push to Lock/Unlock Button	CB402-AU (One Per Two Drs.)	---	SDC
1 Ea.	Emergency Release Button	CB402-B	---	SDC
1 Ea.	Overhead Surface Auto Operator	SW200i 115VAC	628	BSM
As Req.	Wave Sense Actuator	MS31 / MS41	---	BEA
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM

Note: ~~Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security.~~
~~Power Supply - Automatic Operator requires 120VAC.~~

Note: ~~Fail Safe - Upon loss of power lock becomes unlocked. Secure side remains unlocked for egress.~~
~~Unsecure side remains unlocked.~~

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 16 **Moved to Exterior Set HW E19**

HW 17 **Moved to Exterior Set HW E20**

HW 18 **Interior Single - Card Reader - Elec Fail-Secure Lock - Self-Closing Hinges**
Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Low Risk</u> <u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Spring Hinge-HT	CP51 HT	630	PBB
1 Ea.	Hinge-Power Transfer	CB51EL HT	630	PBB
1 Ea.	Fail Secure Cyl. Lock	XCDC-86-S-RQE 24VDC	626	TOW
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	5050	BLK	NGP
1 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security. Free egress at all times. ~~Power Supply require 120VAC.~~

Note: Fail Secure - Upon loss of power lock becomes locked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains locked.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 19 Interior Double Egress - Card Readers - Exit Devices/Exit Only - Automatic Operators

Each Opening to Receive:		Medium Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
2 Set	Continuous Hinge	AC500 HT TW8 SEC	630	ABH
2 Set	CVR-LBR Device-EO/Rite Doors/REX	MLR-D3676/D8576-LBR-EO M2 SEC	630	ADR
1 Ea.	Fire Bolt	As Req @ Fire Door	630	ADR
1 Ea.	Exit Device Power Supply	PS-EXIT 120VDC	---	ADR
2 Ea.	Mag Lock/Delayed Egress	1511S-NC-K-V-D-B-A-VI SEC	628	SDC
2 Ea.	Overhead Surface Auto Operator	SW200i 115VAC SEC	628	BSM
1 Ea.	Wave Sense Actuator	MS31 / MS41 SEC	---	BEA
2 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	5050	BLK	NGP
2 Ea.	Card Reader	By Division 28	---	---
2 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Delayed Egress Controlled Opening - Free egress after 15 seconds. Power Supply and Automatic Operator require 120VAC and-connection to Fire Alarm.

Note: Controlled Opening - Card Readers both sides, Wiring, Controls, Power, and other components by Security. Power Supply require 120VAC.

Note: Fail Safe - Upon loss of power lock becomes unlocked. Secure side remains unlocked for egress. Unsecure side remains unlocked.

HW 20 Interior Automated Sliding Door

Each Opening to Receive:		N116B		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>

Note: Hardware by Slider Dr. MFG

HW 21 Exterior Automated Sliding Door - Card Reader

Each Opening to Receive:		N116A		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>

Note: Hardware by Slider Dr. MFG

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 22 Interior Single - Institutional Privacy Lock/Occupancy Indicator - OHC Closer - Rescue

Each Opening to Receive:		Medium Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge-Double Acting	A507	628	ABH
1 Ea.	Ligature Res. Cyl. Lock-Ins.Privacy/I.D.	MRX-A-26-O	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Double Acting OH Concealed Closer	KG35	630	KSG
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
1 Ea.	Emergency Rescue Stop	A509 L	630	ABH
1 Ea.	Cylinder (For Rescue Stop)	Per project	630	TBD

HW 23 Interior Single - Classroom Lockset - Surface Closer - Butt Hinges

Each Opening to Receive:		Low Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge-HT	CB51 HT	630	PBB
1 Ea.	Cyl. Lock-Classrm	CDC-84-S	626	TOW
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	OH Surface Closer	4040XP/4040XP EDA	689	LCN
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	5050	BLK	NGP

HW 24 Interior Single - Office Lockset - No Closer - Butt Hinges

Each Opening to Receive:		Low Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge-HT	CB51 HT	630	PBB
1 Ea.	Cyl. Lock-Office	CDC-81-S	626	TOW
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	5050	BLK	NGP

HW 24A Interior Single - Office Lockset - Surface Closer - Butt Hinges

Each Opening to Receive:		Low Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge-HT	CB51 HT	630	PBB
1 Ea.	Cyl. Lock-Office	CDC-81-S	626	TOW
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	OH Surface Closer	4040XP/4040XP EDA	689	LCN
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	5050	BLK	NGP

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 25 Interior Single - Passage Latchset - Surface Closer - Butt Hinges

Each Opening to Receive:		Low Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge-HT	CB51 HT	630	PBB
1 Ea.	Cyl. Lock-Passage	CDC-75-S	626	TOW
1 Ea.	OH Surface Closer	4040XP/4040XP EDA	689	LCN
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	5050	BLK	NGP

HW 25A Interior Single - Passage Latchset - No Closer - Butt Hinges

Each Opening to Receive:		Low Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge-HT	CB51 HT	630	PBB
1 Ea.	Cyl. Lock-Passage	CDC-75-S	626	TOW
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	5050	BLK	NGP

HW 26 Interior Single - Institutional Lockset/Ligature Resistant - No Closer - Continuous Hinge

Each Opening to Receive:		High Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC	630	ABH
1 Ea.	Ligature Res. Mortise Lock-Institution	MRX-A-30	630	TOW
2 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

HW 26A Interior Single - Institutional Lockset/Ligature Resistant - No Closer - Continuous Hinge

Each Opening to Receive:		High Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC	630	ABH
1 Ea.	Ligature Res. Cyl. Lock-Institution	CRX-A-87	630	TOW
2 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 27 Interior Single - Card Reader - Electrified Fail-Secure Lock/Ligature Resistant - No Closer
Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC TW8	630	ABH
1 Ea.	Ligature Res. Mortise Lock-Fail Secure	X-MRX-A-242C RQE	630	TOW
2 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
1 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security.
~~Power Supply require 120VAC.~~

Note: Fail Secure - Upon loss of power door remains latched and locked at both sides.

HW 28 Interior Single - Card Reader - Elec Fail-Secure Lock/Ligature Resistant - Self Closing Hinge
Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Self Closing Continuous Hinge	A507SC HT TW8 SEC	628	ABH
1 Ea.	Ligature Res. Mortise Lock-Fail Secure	X-MRX-A-242C RQE	630	TOW
2 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
1 Ea.	Power Supply	631RFUR-1 (One Per Two Drs.)	---	SDC
1 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC
1 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security.

Note: Communicating Bathroom - Wiring by Security. Simultaneously lock and unlock both doors.

Note: Fail Secure - Upon loss of power lock becomes locked at both sides

Note: NYS OMH Standards do not approve any door closers for High Risk areas. Closer removed.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 29 Interior Single - Classroom Lockset - Surface Closer - Butt Hinges

Each Opening to Receive:		Low Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge-HT	CB51 HT	630	PBB
1 Ea.	Cyl. Lock-Classrm	CDC-84-S	626	TOW
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	OH Surface Closer	4040XP/4040XP EDA	689	LCN
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	5050	BLK	NGP

HW 30 ~~Interior Single - Classroom Lockset - No Closer - Butt Hinges~~

HW 30 Interior Single - Card Reader - Elec Fail-Secure Lock - Self Closing Hinge

Each Opening to Receive:		Medium Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge-HT	CB51 HT	630	PBB
1 Ea.	Hinge-HT-Electrified	CB51ELHT	630	PBB
1 Ea.	Mortise Lock-Fail Secure @Both Sides	MSS-242C-S RQE	626	TOW
2 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer	4040XP/4040XP EDA	689	LCN
1 Ea.	OH Surface Closer	4210T/4510T TBTRX mnt public side	689	LCN
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	5050 or Silencers@Non-rated Dr.	BLK	NGP
2 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security.
Card in, card out. ~~Power Supply and Operator require 120VAC.~~

Note: Fail Secure - Upon loss of power door is latched and secured at both sides

HW 31A Interior Single - Privacy Lockset/Occupancy Indicator - Surface Closer

Each Opening to Receive:				
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge-HT	CB51 HT	630	PBB
1 Ea.	Cyl. Lock-Privacy w/ID	SLM-76-S	630	TOW
1 Ea.	OH Surface Closer	4040XP/4040XP EDA	689	LCN
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	5050	BLK	NGP

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 32 Not Used

HW 32 ~~Interior Single - Card Reader - Elec Fail-Secure Lock/Ligature Resistant - Surface Closer~~ ~~Each Opening to Receive:~~

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC TW8	630	ABH
1 Ea.	Mortise Lock-Fail Secure	X-MRX-A-242-RQE	630	TOW
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	OH Surface Closer	4210T/4510T TBTRX mount public side	689	LCN
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
1 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: ~~Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security. Free egress at all times. Power Supply require 120VAC.~~

Note: ~~Fail Secure - Upon loss of power lock becomes locked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains locked.~~

HW 33 Interior Single - Exit Device/Storeroom Lever - Surface Closer - Butt Hinges

HW 33 Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge-HT	CB51 HT	630	PBB
1 Ea.	Rim Device-LNL	EF1100 x ED309R-D	626	TOW
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	OH Surface Closer	4040XP/4040XP EDA	689	LCN
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	5050	BLK	NGP

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 34 Interior Single Dutch Door - Card Reader - Elec Fail-Secure Lock - No Closer

HW 34 Interior Single Operable Window - Card Reader - Elec Fail-Secure Lock - No Closer

Each Opening to Receive:		Low Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge-HT	CB51-HT	630	PBB
1 Ea.	Hinge-Power Transfer	CB51EL-HT	630	PBB
1 Ea.	Continuous Hinge	AC500 HT SEC TW8	630	ABH
1 Ea.	Dutch Door Bolt	054	626	IVE
1 Ea.	Fail Secure Cyl. Lock	XCDC-86-S-RQE-24VDC	626	TOW
1 Ea.	Ligature Res. Mortise Lock-FSecure	X-MRX-A-242ADB-RQE	630	TOW
1 Ea.	Cylinder	Per project	626	TBD
2 Ea.	Door Stop	Per Specification	---	---
1 Ea.	Dutch Door Astragal	By Door MFG	---	---
1 Set	Gasketing	5050	BLK	NGP
1 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security. Free egress at all times. ~~Power Supply require 120VAC.~~

Note: Fail Secure - Upon loss of power lock becomes locked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains locked.

HW 35 Interior Single - Card Reader - Elec Fail Secure/Fail-Safe Lock/Lig Res - Surf Closer

Each Opening to Receive:		Medium Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC TW8	630	ABH
1 Ea.	Ligature Res. Lock-Fail Safe/Secure	X-MRX-A-241/242C-RQE-Fail Saf/Sec	630	TOW
2 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer	4210T/4510T TBTRX mount public side	689	LCN
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
2 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: **Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security. Card in, card out.**

Note: Fail Secure/Safe (As Req) - Upon loss of power door is secured/unsecured at both sides.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 36 Interior Single - Storeroom Lockset/Ligature Resistant - No Closer**Each Opening to Receive:****High Risk**

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC	630	ABH
1 Ea.	Ligature Res. Mortise Lock-Storerm	MRX-A-07	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

HW 37 Interior Single - Lig Res BTB Pulls - Continuous Self-Closing Hinge**Each Opening to Receive:****Architect to verify risk level**

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Self Closing Continuous Hinge	A507SC HT SEC	628	ABH
1 Set	Ligature Res. BTB Push/Pull Set	MRX-A-F72	630	TOW
1 Ea.	Door Stop	1841	630	ABH
1 Ea.	Magnetic Roller Latch	9525MRL x Torx	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

HW 38 Interior Single - Classroom Lockset/Ligature Resistant - Surface Closer**Each Opening to Receive:****Medium Risk**

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC	630	ABH
1 Ea.	Ligature Res. Cyl. Lock-Classrm	CRX-A-84	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer-Hold Open @180°	4210T/4510T TBTRX mount public side	689	LCN
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

HW 39 Interior Single - Classroom Lockset/Ligature Resistant - Surface Closer**Each Opening to Receive:****Medium Risk**

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC	630	ABH
1 Ea.	Ligature Res. Cyl. Lock-Classrm	CRX-A-84	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer	4210T/4510T TBTRX mount public side	689	LCN
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 40 Interior Single - Card Reader - Elec Fail-Secure Lock/Ligature Resistant - Self Closing

Each Opening to Receive:		High Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Self Closing Continuous Hinge	A507SC HT TW8 SEC	628	ABH
1 Ea.	Ligature Res. Mortise Lock-Fail Secure	X-MRX-A-241 RQE	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
1 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security.
~~Power Supply require 120VAC.~~

Note: Fail Secure - Upon loss of power lock becomes locked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains locked.

Note: **NYS OMH Standards do not approve any door closers for High Risk areas. Closer removed.**

HW 41 Interior Single - Card Readers - Elec Fail-Secure Lock/Ligature Resistant - Self Closing

Each Opening to Receive:		High Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Self Closing Continuous Hinge	A507SC HT TW8 SEC	628	ABH
1 Ea.	Ligature Res. Mortise Lock-Fail Secure	X-MRX-A-242C RQE	630	TOW
2 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
2 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Readers both sides, Wiring, Controls, Power, and other components by Security. ~~Power Supply require 120VAC.~~

Note: Fail Secure - Card in card out. Upon loss of power door is secured at both sides

Note: **NYS OMH Standards do not approve any door closers for High Risk areas. Closer removed.**

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 42 Interior Single - Card Readers - Elec Fail-Secure Lock/Ligature Resistant - Self Closing				
Each Opening to Receive:		Medium Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT TW8 SEC	630	ABH
1 Ea.	Ligature Res. Mortise Lock-Fail Secure	X-MRX-A-241C RQE	630	TOW
2 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer	4210T/4510T TBTRX mount public side	689	LCN
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
2 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Readers both sides, Wiring, Controls, Power, and other components by Security. ~~Power Supply require 120VAC.~~

Note: Fail Secure - Card in card out. Upon loss of power door is secured at both sides

HW 43 Interior Single - Card Reader - Electrified Exit Device/Dummy Trim - Surface Closer				
Each Opening to Receive:		Medium Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT TW8 SEC	630	ABH
1 Set	ELR Mortise Device-EO/Rite Door	MLR-D8375/D3375-EO REX	630	ADR
1 Ea.	Exit Device Power Supply	PS-EXIT 120VDC	---	ADR
1 Ea.	Ligature Res. Dummy Trim	ED-MRX-A-41	630	TOW
1 Ea.	OH Surface Closer	4210T/4510T TBTRX mount public side	689	LCN
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
1 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security. Power Supply require 120VAC.

Note: Fail Secure - Upon loss of power lock becomes locked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains locked.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 44 Interior Single - Card Reader - Exit Device/Elec Fail-Secure Lever - Surface Closer

HW 44 Interior Single - Exit Device/Passage Lever - Surface Closer

Each Opening to Receive:		Low Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge-HT	CB51 HT	630	PBB
1 Ea.	Hinge-Power Transfer	CB51EL HT	630	PBB
1 Ea.	Rim Device W/Fail-Secure Passage Lvr	ED1100/EF1100 x 909ER2-S KES914R	626	TOW
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	OH Surface Closer	4040XP/4040XP EDA	689	LCN
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	5050	BLK	NGP
1 Ea.	Door Sweep	C627	628	NGP
1 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: ~~Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security. Free egress at all times. Power Supply require 120VAC.~~

Note: ~~Fail Secure - Upon loss of power lock becomes locked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains locked.~~

HW 45 Interior Single - Classroom Lockset - Surface Closer/Hold-Open

Each Opening to Receive:		Medium Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC	630	ABH
1 Ea.	Ligature Res. Cyl. Lock-Classrm Security	TRXL-80	630	TOW
2 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer-Hold Open @180°	4210T/4510T TBTRX mount public side	689	LCN
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 46 Interior Single - Card Readers - Inst Lock/Lig Rest - No Closer - Continuous Hinge

Each Opening to Receive:

High Risk

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC TW8	630	ABH
1 Ea.	Ligature Res. Mort Lock-Fail Secure	X-MRX-A-242C	630	TOW
2 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
2 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Reader In/Out, Wiring, Controls, Power, and other components by Security.

Note: Fail Secure - Upon loss of power door remains latched and locked at both sides.

HW 47 Interior Single Shower/Toliet Stall - Ligature Resistant Swinging Door System

Each Opening to Receive:

High Risk

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Ligature Rest Swinging Door System	Accurate LR-SW.xx.WGP	---	ACC
2 Ea.	Door Panels	Wood Grain Finish selected by Arch	---	ACC

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

ALUMINUM STOREFRONT DOORS

HW A01 Exterior Single Storefront - Push/Pull-Ligature Resistant - Surface Closer **Each Opening to Receive: Architect to verify risk level**

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	A110HD HT SEC	628	ABH
1 Set	Ligature Res. Push/Pull Set	MRX-A-72	630	TOW
1 Ea.	Overhead Surface Closer-Track Arm	4040XPT	689	LCN
1 Ea.	Door Stop	1841	630	ABH

Note: Alum/ Glass Doors - Perimeter, meeting stile and door bottom seals by door manufacturer.

HW A02 NOT USED

Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	A110HD HT SEC EA12	628	ABH
1 Ea.	Ligature Res. Mortise Lock Fail Secure	X-MRX-A-242RQE	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer Track Arm	4040XPT Torx	689	LCN
1 Ea.	Door Stop	1841	630	ABH

Note: ~~Controlled Opening Card Reader (Dinning RM Side), Wiring, Controls, Power, and other components by Security. Free egress at all times. Power Supply require 120VAC.~~

Note: ~~Fail Secure Upon loss of power strike becomes locked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains locked.~~

Note: ~~Alum/ Glass Doors Perimeter, meeting stile and door bottom seals by door manufacturer.~~

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW A03 Exterior Pair Storefront - Card Reader - Elec Exit Devices/Pulls - Surf Clrs/Stop-Arm
Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
2 Set	Electrified Continuous Hinge	A110HD EZ-12	628	ABH
1 Ea.	ELR CVR Device-EO	ED1300/EF1300-ELR-RX	630	TOW
1 Ea.	ELR CVR Device-NLOP	ED1300/EF1300-ELR-RX x Cyl. Only	630	TOW
1 Ea.	Power Supply	PS220B 120VAC	---	CAT
2 Ea.	Single Pull	Per Design	630	---
1 Ea.	Cylinder	Per project	626	TBD
2 Ea.	OH Surface Closer	4040XP SCUSH	689	LCN
1 Ea.	Bollard for card reader	SQ40 B-6SQ-RT-DB-SM-NP	710	WIK
2 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security. Power Supply require 120VAC.

Note: Fail Secure - Upon loss of power lock becomes locked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains locked.

Note: Alum/ Glass Doors - Perimeter, meeting stile and door bottom seals by door manufacturer.

HW A04 Exterior Single Storefront - Card Reader - Elec Exit Device/Pull - Surf Clrs/Stop-Arm
Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Ea.	Electrified Continuous Hinge	A110HD EZ-12	628	ABH
1 Ea.	ELR CVR Device-NLOP	ED1300/EF1300-ELR-RX x Cyl. Only	630	TOW
1 Ea.	Power Supply	PS220B 120VAC	---	CAT
1 Ea.	Single Pull	Per Design	630	---
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	OH Surface Closer	4040XP SCUSH	689	LCN
1 Ea.	Bollard for card reader	SQ40 B-6SQ-RT-DB-SM-NP	710	WIK
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security. Power Supply require 120VAC.

Note: Fail Secure - Upon loss of power lock becomes locked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains locked.

Note: Alum/ Glass Doors - Perimeter, meeting stile and door bottom seals by door manufacturer.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

EXTERIOR DOORS

HW E01 **NOT USED**

Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge	4C51-NRP	630	PBB
1 Ea.	Hinge-Power Transfer	4C51EL	630	PBB
1 Ea.	Rim Device-LNL-QEL	RX-ELR-ED1100/EF1100 x ED309R-D	630	TOW
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	OH Surface Closer-SCUSH	4040XP-SCUSH	689	LCN
1 Ea.	Overhead Rain Drip	16A (As Req)	628	NGP
1 Ea.	Door Sweep	C627	628	NGP
1 Set	Weatherstrip	700Nx700EN	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC

Note: ~~Controlled Opening—Card Reader, Wiring, Controls, Power, and other components by Security. Free egress at all times. Power Supply require 120VAC. Intercom where required.~~

Note: ~~Fail Secure—Upon loss of power lock becomes locked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains locked.~~

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW E01 Exterior Single 2xCR Delayed Egress Exit Device Fail Secure Trim Surface Closer-SCUSH
Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge	4C51 NRP	630	PBB
1 Ea.	Hinge-Power Transfer	4C51EL	630	PBB
1 Ea.	Delayed Egress Rim Device/Fail Secure	ED1100/EF110-DE x KES909ER2-S	630	TOW
1 Ea.	Power Supply	PS220B 120VAC	---	CAT
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	OH Surface Closer-SCUSH	4040XP SCUSH	689	LCN
1 Ea.	Overhead Rain Drip	16A (As Req)	628	NGP
1 Ea.	Door Sweep	C627	628	NGP
1 Set	Weatherstrip	700Nx700EN	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC
2 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Readers both sides, Wiring, Controls, Power, and other components by Security. Power Supply require 120VAC.

Note: Fail Secure - Upon loss of power lock becomes locked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains locked.

Note: Delayed Egress Controlled Opening - Free egress after 15 seconds. ~~Power Supply~~ requires ~~120VAC~~ and connection to Fire Alarm.

HW E02 Exterior Pair Storefront - Exit Devices/Exit Only - Surface Closers/Stop-Arm
Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge	4C51 NRP	630	PBB
1 Ea.	Removable Mullion	MUL	628	TOW
2 Ea.	Rim Device-EO	ED1100/EF1100-EO	630	TOW
1 Ea.	Cylinder for Mullion	Per project	626	TBD
2 Ea.	OH Surface Closer-SCUSH	4040XP SCUSH	689	LCN
1 Ea.	Overhead Rain Drip	16A (As Req)	628	NGP
1 Ea.	Mullion Seal	5100	BLK	NGP
2 Ea.	Door Sweep	C627	628	NGP
1 Set	Weatherstrip	700Nx700EN	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
2 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW E03 Moved to Gate Set HW G03

Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge	4C51 NRP	630	PBB
1 Ea.	Removable Mullion	MUL	628	TOW
1 Ea.	Rim Device EO	ED1100/EF1100-EO	630	TOW
1 Ea.	Rim Device LNL QEL	RX-ELR-ED1100/EF1100 x ED309R-D	630	TOW
2 Ea.	Cylinder	Per project	626	TBD
2 Ea.	OH Surface Closer-SCUSH	4040XP-SCUSH	689	LCN
1 Ea.	Overhead Rain Drip	16A (As Req)	628	NGP
1 Ea.	Mullion Seal	5100	BLK	NGP
2 Ea.	Door Sweep	C627	628	NGP
1 Set	Weatherstrip	700Nx700EN	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC

Note: ~~Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security. Free egress at all times. Power Supply require 120VAC.~~

Note: ~~Fail Secure - Upon loss of power lock becomes locked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains locked.~~

HW E04 Exterior Single - Institution Lockset/Ligature Resistant - Surface Closer

Each Opening to Receive:

High Risk

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT SEC	630	ABH
1 Ea.	Ligature Res. Mortise Lock-Institution	MRX-A-30	630	TOW
2 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer-Hold Open @180°	4210T/4510T TBTRX mount public side	689	LCN
1 Ea.	Door Stop	Per Specification	---	---
1 Ea.	Overhead Rain Drip	16A (As Req) SEC	628	NGP
2 Ea.	Door Sweep	C627 SEC	628	NGP
1 Set	Weatherstrip	700Nx700EN SEC	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC
1 Ea.	Door Position Switch	By Division 28	---	---

Note: **NYS OMH Standards do not approve any door closers for High Risk areas.**

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW E05 Exterior Pair - Exit Device/Storeroom Lever - Surface Closer/Stop-Arm Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge	4C51 NRP	630	PBB
1 Ea.	Removable Mullion	MUL	628	TOW
1 Ea.	Rim Device-EO	ED1100/EF1100-EO	630	TOW
1 Ea.	Rim Device-LNL	ED1100/EF1100 x ED309R-D	630	TOW
2 Ea.	Cylinder	Per project	626	TBD
2 Ea.	OH Surface Closer-SCUSH	4040XP SCUSH	689	LCN
1 Ea.	Overhead Rain Drip	16A (As Req)	628	NGP
1 Ea.	Mullion Seal	5100	BLK	NGP
2 Ea.	Door Sweep	C627	628	NGP
1 Set	Weatherstrip	700Nx700EN	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
2 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC
2 Ea.	Door Position Switch	By Division 28	---	---

HW E06 Not Used

HW E06 ~~Exterior Single - Exit Device/Passage Lever - Surface Closer/Stop-Arm~~ Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge	4C51 NRP	630	PBB
1 Ea.	Rim Device-Passage Trim	ED1100/EF1100 x ED314R-D	630	TOW
1 Ea.	OH Surface Closer-SCUSH	4040XP SCUSH	689	LCN
1 Ea.	Overhead Rain Drip	16A (As Req)	628	NGP
1 Ea.	Door Sweep	C627	628	NGP
1 Set	Weatherstrip	700Nx700EN	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW E07 Not Used

HW E07 ~~Exterior Single - Exit Device\Delayed Egress - Surface Closer/Stop Arm~~ Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge	4C51 NRP	630	PBB
1 Ea.	Hinge-Power Transfer	4C51EL	630	PBB
1 Ea.	Delayed Egress Rim Device-EO	ED1100/EF1100-DE-30Second	630	TOW
1 Ea.	OH Surface Closer-SCUSH	4040XP SCUSH	689	LCN
1 Ea.	Overhead Rain Drip	16A (As Req)	628	NGP
1 Ea.	Door Sweep	C627	628	NGP
1 Set	Weatherstrip	700Nx700EN	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC
1 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: ~~Delayed Egress Controlled Opening - Free egress after 30 seconds. Power Supply requires 120VAC and connection to Fire Alarm.~~

Note: **~~Request variance from Authority Having Jurisdiction (AHJ) to increase delayed egress cycle from 15 seconds to 30 seconds due to detention risk.~~**

HW E08 Exterior Single - Card Readers - Elec Fail-Secure Institutional Lock - Surface Closer

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT TW8 SEC	630	ABH
1 Ea.	Ligature Res. Mortise Lock-Fail Secure	X-MRX-A-241C RQE	630	TOW
2 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer	4210T/4510T TBTRX mount public side	689	LCN
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
2 Ea.	Door Sweep	C627 SEC	628	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC
2 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security. ~~Power Supply require 120VAC.~~

Note: Fail Secure - Card in card out. Upon loss of power door is secured at both sides

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW E09 Exterior Single - Delayed Egress Exit Device/Exit Only - Surface Closer
Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge	4C51 NRP	630	PBB
1 Ea.	Hinge-Power Transfer	4C51EL	630	PBB
1 Ea.	Delayed Egress Rim Device-EO	ED1100/EF1100-DE	630	TOW
1 Ea.	Power Supply	PS220B 120VAC	---	CAT
1 Ea.	OH Surface Closer-SCUSH	4040XP SCUSH	689	LCN
1 Ea.	Overhead Rain Drip	16A (As Req)	628	NGP
1 Ea.	Door Sweep	C627	628	NGP
1 Set	Weatherstrip	700Nx700EN	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Delayed Egress Controlled Opening - Free egress after 15 seconds. Power Supply requires 120VAC and connection to Fire Alarm.

HW E10 Exterior Pair - Storeroom Lockset - Surface Closer/Stop-Arm
Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge	4C51 NRP	630	PBB
1 Set	Auto Flush Bolts	1860P/1861P/1862P	630	ABH
1 Ea.	Dust Proof Strike	1870/1872	630	ABH
1 Ea.	Cyl. Lock -Storerm	CDC-86-S	626	SCH
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	Coordinator	3700 Series	600	ABH
2 Ea.	Mounting Bracket	3751/3752 (as required)	600	ABH
2 Ea.	OH Surface Closer-SCUSH	4040XP SCUSH	689	LCN
1 Ea.	Overlapping Astragal	355CS	628	PEM
2 Ea.	Door Sweep	C627	628	NGP
1 Set	Weatherstrip	700Nx700EN	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
2 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 06A	Exterior Single - Card Reader - Electrified Fail-Secure Lock - Surface Closer - Butt Hinges			
HW E11	Exterior Single - Card Reader - Electrified Fail-Secure Lock - Surface Closer - Butt Hinges			
	Each Opening to Receive:	Low Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
As Req	Hinge-HT	4C51 HT NRP	630	PBB
1 Ea.	Hinge-Power Transfer	4C51EL HT	630	PBB
1 Ea.	Fail Secure Cyl. Lock	XCDC-86-S-RQE 24VDC	626	TOW
1 Ea.	Cylinder	Per project	626	TBD
1 Ea.	OH Surface Closer	4040XP/4040XP EDA	689	LCN
1 Ea.	Door Stop	Per Specification	---	---
1 Ea.	Overhead Rain Drip	16A (As Req)	628	NGP
1 Ea.	Door Sweep	600A	628	NGP
1 Set	Weatherstrip	700Nx700EN	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC
1 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security. Free egress at all times. ~~Power Supply require 120VAC.~~

Note: Fail Secure - Upon loss of power lock becomes locked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains locked.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

~~HW 10A Interior Exterior Single - Card Reader - Elec Fail Secure Lock/Ligature Resistant - Surf Closer~~
~~HW E12 Not Used~~
~~HW E12 Exterior Single - Card Reader - Elec Fail Secure Lock/Ligature Resistant - Surface Closer~~
~~Each Opening to Receive: Medium Risk~~

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Ea.	Continuous Hinge	AC500 HT SEC TW8	630	ABH
1 Ea.	Ligature Res. Mortise Lock-Fail Secure	X-MRX-A-242-RQE	630	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer	4210T/4510T TBTRX mount public side	689	LCN
1 Ea.	Overhead Rain Drip	16A (As Req)	628	NGP
1 Ea.	Door Sweep	600A	628	NGP
1 Set	Weatherstrip	700Nx700EN	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC
1 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: ~~Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security. Free egress at all times. Power Supply require 120VAC.~~

Note: ~~Fail Secure - Upon loss of power lock becomes locked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains locked.~~

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 10B	Exterior Single - Card Reader - Storeroom Lock/Ligature Resistant - Surface Closer			
HW E13	Exterior Single - Card Reader - Inst Lock/Lig Res - Elec Strike - Automatic Operator			
	Each Opening to Receive:	Medium Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Ea.	Continuous Hinge	AC500 HT TW8 SEC	630	ABH
1 Ea.	Ligature Res. Mortise Lock-Storeroom	MRX-A-07	630	TOW
1 Ea.	Ligature Res. Mort Institutional Lock	MRX-A-30	630	TOW
2 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Elec. Strike	55 Series	630	SDC
1 Ea.	Overhead Surface Auto Operator	SW200i 115VAC	628	BSM
1 Ea.	Wave Sense Actuator	MS31 / MS41 SEC	---	BEA
1 Ea.	Overhead Rain Drip	16A (As Req)	628	NGP
1 Ea.	Door Sweep	600A SEC	628	NGP
1 Set	Weatherstrip	700Nx700EN SEC	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC
2 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	REX Motion Sensor	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security. **No** Free egress at all times. ~~Power Supply and Auto Operator requires 120VAC.~~

Note: Fail Secure - Upon loss of power door is latched and secured at both sides

Note: ~~Fail Secure - Upon loss of power lock becomes locked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains locked.~~

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

**HW 11 ~~Exterior Single - Card Reader - Elec Exit Devices/Ligature Resistant Lever - Surface Closers~~
~~Each Opening to Receive:~~**

**HW E14 Exterior Single - Card Reader - ELR Device/Lig Resistant Lever - Mag lock - Surf Clsr
Each Opening to Receive:**

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Ea.	Continuous Hinge	AC500 HT TW8 SEC	630	ABH
1 Ea.	ELR Mortise Device-EO	ELR-D3375/D8375-EO REX	630	ADR
1 Ea.	Ligature Res. Dummy Trim for Device	ED-MRXA-41	630	TOW
1 Ea.	Cylinder for Key Switch	Per project	626	TBD
1 Ea.	OH Surface Closer	4210T/4510T TBTRX mount public side	689	LCN
1 Ea.	Delayed Egress Mag Lock	1511S-NC-K-V-D-B-A-VI SEC	628	SDC
1 Ea.	Emergency Release Button	CB402-B SEC	---	SDC
1 Ea.	Alarm Kit w/Key Switch	101-1AK SEC	630	SDC
1 Ea.	Overhead Rain Drip	16A (As Req) SEC	628	NGP
1 Ea.	Door Sweep	C627 x SEC	628	NGP
1 Set	Weatherstrip	700Nx700EN x SEC	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC
2 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---

Note: Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security. Free egress at all times. Power Supply require 120VAC.

Note: Fail Secure - Upon loss of power lock becomes locked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains locked.

Note: Delayed Egress Controlled Opening - Free egress after 15 seconds. Power Supply requires 120VAC and connection to Fire Alarm.

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

~~HW 14 Exterior Single - Push/Pulls - Magnetic Lock - Automatic Operator~~

~~HW E15 Not Used~~

~~HW E15 Exterior Single - Card Readers - Push/Pulls - Magnetic Lock - Automatic Operator~~

Quantity	Description	Model Number	Finish	Manf
1 Ea.	Swing Clear Continuous Hinge	A511 HT SEC	630	ABH
1 Set	Ligature Res. Push/Pull Set	MRX-A-72	630	TOW
1 Ea.	Mag Lock	1511-V-D-B-A 24VDC	628	SDC
1 Ea.	Push to Lock/Unlock Button	CB402-AU (One Per Two Drs.)	---	SDC
1 Ea.	Emergency Release Button	CB402-B	---	SDC
1 Ea.	Overhead Concealed Auto Operator	SW200i 115VAC	628	BSM
As Req.	Wave Sense Actuator	MS31 / MS41	---	BEA
1 Ea.	Overhead Rain Drip	16A (As Req)	628	NGP
1 Ea.	Door Sweep	600A x SEC	628	NGP
1 Set	Weatherstrip	700Nx700EN x SEC	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC
1 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	REX Motion Sensor	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---
1 Ea.	Push to Exit Button	By Division 28	---	---

Note: ~~Controlled Opening - Card Reader, Wiring, Controls, Power, and other components by Security. Free egress at all times. Power Supply and Operator require 120VAC.~~

Note: ~~Fail Safe - Upon loss of power lock becomes unlocked. Secure side remains unlocked for egress. Unsecure side remains unlocked.~~

~~HW 10C Interior Single - Push/Pull-Ligature Resistant - Automatic Operator~~

~~HW E16 Interior Single - Push/Pull-Ligature Resistant - Automatic Operator~~

Quantity	Description	Model Number	Finish	Manf
1 Ea.	Continuous Hinge	AC500 HT SEC	630	ABH
1 Set	Ligature Res. Push/Pull Set	MRX-A-72	630	TOW
1 Ea.	Overhead Surface Auto Operator	SW200i 115VAC	628	BSM
As Req.	Wave Sense Actuator	MS31 / MS41	---	BEA
1 Ea.	Door Stop	Per Specification	---	---
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 14A **Not Used**

HW E17 **Not Used**

HW E17 **~~Exterior Single-Ligature Resistant Push/Pulls-Magnetic Lock-Automatic Operator~~**
~~Each Opening to Receive:~~ **~~Medium Risk~~**

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
2 Ea.	Continuous Hinge	AC500 HT SEC	630	ABH
2 Set	Ligature Res. Push/Pull Set	MRX-A-72	630	TOW
2 Ea.	Mag Lock	1511-V-D-B-A 24VDC	628	SDC
2 Ea.	Overhead Surface Auto Operator	SW200i Custom Hood 120VAC	630	BSM
As Req.	Wave Sense Actuator	MS31 / MS41	---	BEA
2 Ea.	Door Stop	Per Specification	---	---
1 Ea.	Overhead Rain Drip	16A (As Req)	628	NGP
1 Ea.	Door Sweep	600A	628	NGP
1 Set	Weatherstrip	700Nx700EN	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Motion Sensor	MD31	DB	SDC
1 Ea.	Push To Exti Button	By Security	---	---
2 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC
2 Ea.	Card Reader	By Division 28	---	---
2 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	REX Motion Sensor	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---
1 Ea.	Push to Exit Button	By Division 28	---	---

Note: ~~Controlled Opening-Card Reader, Wiring, Controls, Power, and other components by Security. Free egress at all times. Auto Door Operator and Power Supply require 120VAC.~~

Note: ~~Fail Safe-Upon loss of power door becomes unlocked. Door remains latched. Secure side remains unlocked for egress. Unsecure side remains unlocked.~~

HW 13 **Exterior Automated Sliding Gate**

HW E18 **Exterior Automated Sliding Gate**

N121A+B

Note: Hardware by Rollup Dr. MFG

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW 16 ~~Exterior Single-Classroom Lockset-Surface Closer~~

HW E19 Not Used

HW E19 ~~Exterior Single-Classroom Lockset-Surface Closer~~

~~Each Opening to Receive:~~

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Ea.	Continuous Hinge	AC500 HT	630	ABH
1 Ea.	Cyl. Lock-Classrm	CDC-84-S	626	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer	4040XP/4040XP-EDA	689	LCN
1 Ea.	Door Stop	Per Specification	---	---
1 Ea.	Overhead Rain Drip	16A (As Req)	628	NGP
1 Ea.	Door Sweep	600A	628	NGP
1 Set	Weatherstrip	700Nx700EN	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Push-To-Exti Button	By Security	---	---
1 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC
1 Ea.	Door Position Switch	By Division 28	---	---

HW 17 ~~Exterior Single-Storeroom Lockset-Surface Closer~~

HW E20 Not Used

HW E20 ~~Exterior Single-Storeroom Lockset-Surface Closer~~

~~Each Opening to Receive:~~

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Ea.	Continuous Hinge	AC500 HT	630	ABH
1 Ea.	Cyl. Lock-Storerm	CDC-86-S	626	TOW
1 Ea.	Cylinder	Per project	630	TBD
1 Ea.	OH Surface Closer	4040XP/4040XP-EDA	689	LCN
1 Ea.	Door Stop	Per Specification	---	---
1 Ea.	Overhead Rain Drip	16A (As Req)	628	NGP
1 Ea.	Door Sweep	600A	628	NGP
1 Set	Weatherstrip	700Nx700EN	719	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Push-To-Exti Button	By Security	---	---
1 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC
1 Ea.	Door Position Switch	By Division 28	---	---

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

<u>HW E21</u>				
Exterior Single - Card Readers - Elec Fail-Secure Institutional Lock - Automatic Operator				
Each Opening to Receive:		High Risk		
<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
1 Set	Continuous Hinge	AC500 HT TW8 SEC	630	ABH
1 Ea.	Ligature Res. Mort Lock-Fail Secure	X-MRX-A-241C	630	TOW
2 Ea.	Cylinder	Per project	630	TBD
1 Ea.	Overhead Surface Auto Operator	SW200i 120VAC	628	BSM
1 Ea.	Door Stop	1841	630	ABH
1 Set	Gasketing	ANTI-LIG 5050	BLK	NGP
2 Ea.	Door Sweep	C627 SEC	628	NGP
1 Ea.	Threshold	To Suit Sill Condition	719	PEM
1 Ea.	Door Position Switch	MC-4 (Or as Req)	---	SDC
2 Ea.	Card Reader	By Division 28	---	---
1 Ea.	Door Position Switch	By Division 28	---	---
1 Ea.	Lock Power Supply	By Division 28	---	---
Note:	Controlled Opening - Card Readers, Wiring, Controls, Power, and other components by Security. Automatic Operator requires 120VAC.			
Note:	Fail Secure - Card in card out. Upon loss of power door is secured at both sides. No free egress.			

NOT FOR CONSTRUCTION

SAN JOAQUIN COUNTY
BE-WELL BEHAVIORAL HEALTH CAMPUS

HMH / KMD ARCHITECTS
COUNTY PROJECT # - SJC-PDB-HCSA

HW G01 Exterior Pair Gates - Exit Devices/Storeroom Lever - Center Mullion - Gate Pivots/Closers
Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
2 Set	Spring Hinge/Closer	Mammoth-HD	TBD	LOC
1 Ea.	Center Mullion	By Gate Mfg.	TBD	---
1 Ea.	Exit Device-EO	40W-01CN	TBD	DET
1 Ea.	Exit Device-LNL	40W-09DN	TBD	DET
1 Ea.	Cylinder to Suit Device	Per Specification	---	---

Note: Gate - Balance of hardware by manufacturer.

HW G02 Exterior Pair Gates - Exit Device/Storeroom Lever - Cane Bolt - Gate Pivots/Closers
Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
2 Set	Spring Hinge/Closer	Mammoth-HD	TBD	LOC
1 Ea.	Exit Device-LNL	40W-09DN	TBD	DET
1 Ea.	Cylinder to Suit Device	Per Specification	---	---
1 Ea.	Cane Bolt	53-2528	TBD	STA
1 Ea.	Padlock for cane bolt	Per Specification	---	---

HW E03 Exterior Pair Gates - Exit Device/Storeroom Lever - Cane Bolt - Gate Pivots/Closers

HW G03 Exterior Pair Gates - Exit Device/Storeroom Lever - Cane Bolt - Gate Pivots/Closers
Each Opening to Receive:

<u>Quantity</u>	<u>Description</u>	<u>Model Number</u>	<u>Finish</u>	<u>Manf</u>
2 Set	Spring Hinge/Closer	Mammoth-HD	TBD	LOC
1 Ea.	Exit Device-LNL	40W-09DN	TBD	DET
1 Ea.	Cylinder to Suit Device	Per Specification	---	---
1 Ea.	Cane Bolt	53-2528	TBD	STA
1 Ea.	Padlock for cane bolt	Per Specification	---	---

Note: Gate - Balance of hardware by manufacturer.

END OF SECTION