

SECTION 087100 - DOOR HARDWARE

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes the following:
 - 1. Commercial door hardware.
 - 2. Cylinders for doors specified in other Sections.

1.2 SUBMITTALS

- A. Product Data: For each product indicated.
- B. Shop Drawings: Include details of electrified door hardware and wiring diagrams.
- C. Samples: For each exposed finish.
- D. Door Hardware Schedule: Organized into door hardware sets indicating type, style, function, size, label, hand, manufacturer, fasteners, location, and finish of each door hardware item. Include description of each electrified door hardware function, including sequence of operation.
- E. Keying Schedule: Detail Owner's final keying instructions for locks.
- F. Product certificates.

1.3 QUALITY ASSURANCE

- A. Supplier Qualifications: Person who is or employs a qualified DHI Architectural Hardware Consultant.
- B. Source Limitations: Obtain electrified door hardware from same manufacturer as mechanical door hardware, unless otherwise indicated. Manufacturers that are listed to perform electrical modifications, by a testing and inspecting agency acceptable to authorities having jurisdiction, are acceptable.

- C. Keying Conference: Conduct conference at Project site. Incorporate keying conference decisions into final keying schedule.
- D. Pre-Installation Conference: Conduct conference at Project site.
- E. Keys: Deliver keys to Owner by registered mail.
- F. Templates: Obtain and distribute templates for doors, frames, and other work specified to be factory prepared for installing door hardware.
- G. Standards: Comply with BHMA A156 series standards, Grade 1.
- H. Certified Products: Provide door hardware that is listed in BHMA directory of certified products.

1.4 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of door hardware that fails in materials or workmanship within warranty period from date of Substantial Completion.
 - 1. Warranty Period for Manual Closers: 10 years.
 - 2. Warranty Period for Exit Devices: 3 years.
 - 3. Warranty Period for Locks: 7 years.
 - 4. All other hardware one year.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Product: Subject to compliance with requirements, provide the product named for each door hardware item indicated in Door Hardware Sets.
- B. Basis-of-Design Product: Product named for each door hardware item indicated in Door Hardware Sets establishes the basis of design. Provide either the named product

or a comparable product by one of the manufacturers specified for each type of hardware item.

2.2 DOOR HARDWARE

- A. Scheduled Door Hardware: Provide door hardware according to Door Hardware Sets at the end of Part 3.

2.3 HINGES

- A. General: Except for hinges and pivots to be installed entirely (both leaves) into wood doors and frames, provide only template-produced units.
- B. Hinge Base Metal: Unless otherwise indicated, provide the following:
 - 1. Exterior Hinges: Stainless steel, with stainless-steel pin.
 - 2. Interior Hinges: Steel, with steel pin.
 - 3. Hinges for Fire-Rated Assemblies: Steel, with steel pin.
- C. Non-removable Pins: Provide set screw in hinge barrel that prevents removal of pin while door is closed; for out-swinging exterior doors.
- D. Screws: Phillips flat-head screws; screw heads finished to match surface of hinges.
- E. Metal Doors and Frames: Machine screws (drilled and tapped holes).

2.4 MECHANICAL LOCKS AND LATCHES

- A. Mortise Locks:
 - 1. Locks shall be ANSI A156.13, Grade 1 mortise locksets, Manufactured from heavy gauge steel, containing components of steel with a zinc dichromate plating for corrosion resistance.
 - 2. Locks to have a standard 2-3/4" backset with a full 3/4" throw stainless steel mechanical anti-friction latch bolt. Deadbolt shall be a full 1" throw, constructed of stainless steel.
 - 3. Lever trim shall be cast or forged in the design specified, with 2-1/8" diameter roses. Levers to be thru-bolted to assure proper alignment. Trim shall be applied by threaded bushing "no exposed screws".
- B. Cylindrical Locks:

1. Locks shall be ANSI A156.2, Series 4000 Grade 1 UL Listed for 3-hour doors. Manufactured from heavy gauge cold rolled steel mechanisms that are corrosion treated for normal conditions.
2. Locks to have standard 2-3/4" backset with a full 1/2" reversible dead latch. Thru-bolted mounting post for positive interlock to the door with concealed mounting screws.
3. Lever trim shall be pressure cast zinc to match finishes. The design specified, with 3-7/16" diameter roses. Trim shall be applied by "no exposed screws".

2.5 BOLTS

- A. Shall have forged bronze faceplate with extruded brass lever wrought brass guide and strike. Flush bolts for hollow metal doors shall be extension rod type door up to 7'6" in height shall have 12" steel or brass rods, manual flush bolts for doors over 7'6" in height shall be increased by 6" for each additional 6" of door height. Wood doors shall have corner-wrap type. Provide dust proof strikes for all bottom bolts.

2.6 EXIT DEVICES

- A. Panic Exit Devices: Listed and labeled for panic protection, based on testing according to UL 305.
- B. Fire Exit Devices: Complying with NFPA 80 that are listed and labeled for fire and panic protection, based on testing according to UL 305 and NFPA 252.
- C. All lever design shall match mortise or cylindrical lock lever designs.
- D. All devices to incorporate a security dead-latching feature. Provide roller strikes for all rim and surface mounted vertical rod devices, ASA strikes for mortise devices, and manufacturer's standard strikes for concealed vertical rod devices.
- E. Removable Mullions: BHMA A156.3.
 1. Fire-Exit Removable Mullions: Complying with NFPA 80 that are listed and labeled for fire and panic protection, based on testing according to UL 305 and NFPA 252. Mullions shall be used only with exit devices for which they have been tested.
- F. Carry-Open Bars: Provide carry-open bars for inactive leaves of pairs of doors, unless automatic or self-latching bolts are used.

2.7 CLOSERS

A. Surface-Mounted Closers:

1. Spring power shall be continuously adjustable over the full range of closer sizes, and allow for reduced opening force for the physically handicapped. Hydraulic regulation shall be by tamper-proof, non-critical valves. Closers shall have separate adjustment for latch speed, general speed, and back check.
2. All closers will not be seen on the public side or hallway side of the door. The appropriate drop plate or mounting plates will be used as conditions dictate.

2.8 PROTECTIVE TRIM UNITS

- A. Protective Trim Units: Sized 2" inches less than door width on push side and 1" inch less than door width on pull side, by height scheduled or indicated. Fasten with exposed machine or self-tapping screws.

2.9 STOPS AND HOLDERS

- A. Stops and Holders: Provide floor stops for doors, unless wall or other type stops are scheduled or indicated. Do not mount floor stops where they will impede traffic. Where floor or wall stops are not appropriate, provide overhead holders.
- B. Silencers for Door Frames: Neoprene or rubber; fabricated for drilled-in application to frame.

2.10 DOOR GASKETING AND THRESHOLDS

- A. Door Gasketing: Provide continuous weather-strip gasketing on exterior doors and provide smoke, light, or sound gasketing on interior doors where indicated or scheduled. Provide non-corrosive fasteners for exterior applications and elsewhere as indicated.

2.11 CYLINDERS, KEYING, AND STRIKES

- A. Cylinders: Tumbler type, constructed from brass or bronze, stainless steel, or nickel silver.
- B. Keying System: Factory-registered keying system; grand master key system.

2.12 FABRICATION

- A. Base Metals: Furnish metals of a quality equal to or greater than that of specified door hardware units and BHMA A156.18 for finishes. Do not furnish manufacturer's standard materials if different from specified standard.
- B. Fasteners: Phillips flat-head screws with finished heads to match surface of door hardware, unless otherwise indicated. Provide steel machine or wood screws or steel through bolts for fire-rated applications.
- C. Spacers or Sex Bolts: For through bolting of hollow metal doors.
- D. Fasteners for Wood Doors: Comply with requirements of DHI WDHS.2, "Recommended Fasteners for Wood Doors."
- E. Finishes: Comply with BHMA A156.18.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Examine doors and frames for compliance with requirements for installation tolerances, labeled fire door assembly construction, wall and floor construction, and other conditions affecting performance. Examine roughing-in for electrical power systems to verify actual locations of wiring connections before electrified door hardware installation.
- B. Steel Door and Frame Preparation: Comply with DHI A115 series. Drill and tap doors and frames for surface-applied hardware according to SDI 107.
- C. Wood Door Preparation: Comply with DHI A115-W series.
- D. Mounting Heights: Comply with the following requirements, unless otherwise indicated:
 - 1. Standard Steel Doors and Frames: DHI's "Recommended Locations for Architectural Hardware for Standard Steel Doors and Frames."
 - 2. Custom Steel Doors and Frames: DHI's "Recommended Locations for Builders' Hardware for Custom Steel Doors and Frames."
 - 3. Wood Doors: DHI WDHS.3, "Recommended Locations for Architectural Hardware for Wood Flush Doors."
- E. Adjust and reinforce attachment substrates as necessary for proper installation and operation. Drill and countersink units that are not factory prepared for anchorage fasteners. Space fasteners and anchors according to industry standards.
 - 1. Thresholds: Set thresholds for exterior and acoustical doors in full bed of sealant complying with requirements specified in Division 7 Section "Joint Sealants."
- F. Adjust door control devices to compensate for final operation of heating and ventilating equipment and to comply with accessibility requirements.

NEW BUILDINGS FOR VALOR ACRES -
BUILDING E

06/07/24
Bulletin #1 – 08/07/24
Bulletin #2 – 04/11/25
Bulletin #4 – 07/02/25

1. Door Closers: Adjust sweep period so that from an open position of 70 degrees, the door will take at least three seconds to move to a point 3 inches from the latch, measured to the leading edge of the door.

3.2 FIELD QUALITY CONTROL

- A. Inspections: Owner will engage a qualified independent Architectural Hardware Consultant to perform inspections and to prepare inspection reports.

3.3 DOOR HARDWARE SETS

Hardware Group No. 01: (Door U1 – Interior Unit Entry Swing Doors)
Each To Have:

Qty		Description	
3	EA	BB HINGE	BLK
1	EA	ENTRY SET (SCHLAGE LATITUDE LEVER STYLE)	BLK
1	EA	DEADBOLT W/ KEYFOB ACCESS	BLK
1	EA	OH STOP	BLK
1	EA	SURFACE CLOSER	BLK
1	SET	SEALS (SMOKE)	BLK
1	EA	DOOR VIEWER	BLK

Hardware Group No. 02: (Door U3 – Exterior Unit Entries & Balconies Swing Doors)
Each To Have:

Qty		Description	
3	EA	BB HINGE	BLK
1	EA	ENTRY SET (SCHLAGE LATITUDE LEVER STYLE)	BLK
1	EA	DEADBOLT W/ KEYFOB ACCESS (EXTERIOR DOOR ONLY)	BLK
1	EA	OH STOP	BLK
1	EA	SURFACE CLOSER	BLK
1	SET	SEALS (THERMAL)	BLK
1	EA	THRESHOLD	BLK
1	EA	DOOR VIEWER (ENTRY DOORS ONLY)	BLK

Hardware Group No. 03: (Doors U5 & U6 – Bathrooms/ Bedrooms Swing Doors)

NEW BUILDINGS FOR VALOR ACRES -
BUILDING E

06/07/24
Bulletin #1 – 08/07/24
Bulletin #2 – 04/11/25
Bulletin #4 – 07/02/25

Each To Have:

Qty		Description	
3	EA	PB HINGE	BLK
1	EA	PRIVACY SET (SCHLAGE LATITUDE LEVER STYLE)	BLK
1	EA	WALL STOP	BLK

Hardware Group No. 04: (Doors U7 & U9 – Closets/ Laundry Swing Doors)

Each To Have:

Qty		Description	
2	EA	BB HINGE	BLK
1	EA	PASSAGE SET (SCHLAGE LATITUDE LEVER STYLE)	BLK
1	EA	HINGE STOP	BLK

Hardware Group No. 05: (Doors U11 & U12 - Mechanical Closet Swing Doors)

Each To Have:

Qty		Description	
3	EA	PB HINGE	BLK
1	EA	PASSAGE SET (SCHLAGE LATITUDE LEVER STYLE)	BLK
1	EA	HINGE STOP	BLK

Hardware Group No. 06: (Door U2 – Balcony/Patio Swing Doors)

Each To Have:

Qty		Description	
3	EA	HINGE BY DR SUPPLIER	BLK
1	EA	ENTRY SET (SCHLAGE LATITUDE LEVER STYLE)	BLK
1	EA	SURFACE BOLTS	BLK
1	EA	WALL STOP	BLK
1	EA	DEADBOLT BY DR SUPPLIER	BLK

Hardware Group No. 07: (Doors U13, U14 & U16 – Single Barn doors)

Each To Have:

Qty		Description	
1	SET	BARN DR TRACK	BLK
2	EA	PULL (ACCESSIBLE WHERE REQUIRED)	BLK

Hardware Group No. 08: (Doors U15 & U16 – Double Barn Doors)

Each To Have:

NEW BUILDINGS FOR VALOR ACRES -
BUILDING E

06/07/24
Bulletin #1 – 08/07/24
Bulletin #2 – 04/11/25
Bulletin #4 – 07/02/25

Qty		Description	
2	SET	BARN DR TRACK	BLK
4	EA	PULL (ACCESSIBLE WHERE REQUIRED)	BLK

Hardware Group No. 09: (Doors 103A & ~~444A~~ **114**)
Each To Have:

Qty		Description	
1	SET	BARN DR TRACK	BLK
1	EA	ADA PULL	BLK
1	EA	DEADBOLT LOCK	BLK

Hardware Group No. 10: (Doors 104A, 105A & ~~426A~~ 124, 130A & 130B)
Each To Have:

Qty		Description	
4	EA	BB HINGE	BBLK
1	EA	STOREROOM LEVER LOCKSET	622
1	EA	CORE	622
1	EA	WALL STOP	BLK
1	SET	SEALS (FIRE) (DR 104A ONLY)	BLK

Hardware Group No. 11: (Doors 108A, 135 & 136)
Each To Have:

Qty		Description	
4	EA	BB HINGE (NRP)	BBLK
1	EA	STOREROOM LEVER LOCKSET	622
1	EA	CORE	622
1	EA	SURFACE CLOSER	693
1	SET	SEALS (THERMAL)	BLK
1	EA	THRESHOLD	AL

Hardware Group No. 12: (Doors ~~100A, 100B 123A, 127A, 200A, 200B, 300A, 300B, 400A, 400B,~~
~~500A, 500B & 600~~)

Each To Have:

Qty		Description	
8	EA	BB HINGE (NRP)	BBLK
1	EA	ELECT TRANSFER OR HINGE	BLK
1	EA	CONCEALED VERT ROD ELECT. EXIT DEVICE (DOGGING, NIGHT LATCH FUNCTION)	711

NEW BUILDINGS FOR VALOR ACRES -
BUILDING E

06/07/24
Bulletin #1 – 08/07/24
Bulletin #2 – 04/11/25
Bulletin #4 – 07/02/25

1	EA	CONCEALED VERT ROD ELECT. EXIT DEVICE (NIGHT LATCH FUNCTION)	711
2	EA	PULL	711
2	EA	CYLINDER	622
2	EA	CORE	622
1	EA	SURFACE CLOSER W/ OH STOP	693
1	EA	AUTO OPERATOR (DR 100B ONLY)	693
1	EA	ACTUATOR (WALL MOUNT) (DR 100B)	BLK
1	SET	SEALS (FIRE)	BLK
1	EA	ADA THRESHOLD	AL
1	EA	POWER SUPPLY	GRY
1	EA	CARD READER (BY OWNER'S SECURITY CONTRACTOR)	

CARD SWIPE ALLOWS AUTO OPERATOR TO FUNCTION

Hardware Group No. 13: (Door 400B 100A)
Each To Have:

Qty		Description	
8	EA	BB HINGE	BBLK
2	EA	CONCEALED VERT ROD ELECT. EXIT DEVICE (DOGGING, NIGHT LATCH DUMMY OR PASSAGE FUNCTION)	711
2	EA	PULL	711
2	EA	CYLINDER	622
2	EA	CORE	622
1	EA	SURFACE CLOSER W/ OH STOP	693
1	EA	AUTO OPERATOR	693
1	EA	ACTUATOR (WALL MOUNT)	BLK
1	SET	SEALS (SOUND)	AL
1	EA	ADA THRESHOLD	AL

Hardware Group No. 14: (Door 424A 128A)
Each To Have:

Qty		Description	
4	EA	BB HINGE	BBLK
1	EA	STOREROOM LEVER LOCKSET	622

NEW BUILDINGS FOR VALOR ACRES -
BUILDING E

06/07/24
Bulletin #1 – 08/07/24
Bulletin #2 – 04/11/25
Bulletin #4 – 07/02/25

1	EA	CORE	622
1	EA	SURFACE CLOSER W/ OH STOP	693
1	SET	SEALS (FIRE)	AL
1	EA	DOOR BOTTOM (FIRE)	AL

Hardware Group No. 15: (Doors 124B **116B**, 128B & 137)
Each To Have:

Qty		Description	
7	EA	BB HINGE (HW)	BBLK
1	EA	ELECT HINGE	BBLK
1	EA	ELECT STOREROOM LEVER LOCKSET	622
1	EA	CORE	622
1	SET	AUTO FLUSHBOLTS	BLK
1	EA	DUSTPROOF STRIKE	BLK
1	EA	SURFACE CLOSER	693
1	EA	OH STOP	BLK
1	SET	SEALS (THERMAL/ FIRE)	AL
1	EA	ASTRAGAL	AL
1	EA	DOOR BOTTOM (THERMAL/ FIRE)	AL
1	EA	POWER SUPPLY	
1	EA		

PREP DOOR FOR WIRE TO ELECTRIC LOCKSET

Hardware Group No. 16: (Door 107A & 107B)
Each To Have:

Qty		Description	
4	EA	BB HINGE	BBLK
1	EA	ELECT STRIKE	BLK
1	EA	ENTRY STOREROOM LEVER SET	622
1	EA	CORE	622
1	EA	SURFACE CLOSER	693
1	EA	WALL STOP	BLK
1	EA	POWER SUPPLY	GRY
1	EA	CARD READER (BY OWNER'S SECURITY CONTRACTOR)	

Hardware Group No. 17: (Doors 202, 302, 402, 502 & 602)
Each To Have:

Qty		Description	
4	EA	BB HINGE	BBLK
1	EA	PASSAGE LEVER SET	622

NEW BUILDINGS FOR VALOR ACRES -
BUILDING E

06/07/24
Bulletin #1 – 08/07/24
Bulletin #2 – 04/11/25
Bulletin #4 – 07/02/25

1	EA	SURFACE CLOSER	693
1	EA	WALL STOP	BLK
1	SET	SEALS (SMOKE)	AL

Hardware Group No. 18: (Door ST-1C)

Each To Have:

Qty		Description	
3	EA	BB HINGE (NRP)	BBLK
1	EA	ELECT HINGE	BBLK
1	EA	ELECT EXIT DEVICE W/ NIGHT LATCH FUNCTION & LEVER	711
1	EA	CYLINDER	622
1	EA	CORE	622
1	EA	SURFACE CLOSER W/ OH STOP	693
1	SET	SEALS (FIRE)	AL
1	EA	THRESHOLD	AL
1	EA	POWER SUPPLY	GRY
1	EA	CARD READER(BY OWNER'S SECURITY CONTRACTOR)	

Hardware Group No. 19: (Doors ST-1A, ST-1B & ST-2)

Each To Have:

Qty		Description	
3	EA	BB HINGE (NRP)	BBLK
1	EA	ELECT HINGE	BBLK
1	EA	ELECT EXIT DEVICE W/ NIGHT LATCH/ PASSAGE FUNCTION & LEVER	711
1	EA	CYLINDER	622
1	EA	CORE	622
1	EA	SURFACE CLOSER W/ OH STOP	693
1	SET	SEALS (FIRE)	AL
1	EA	DOOR BOTTOM	AL
1	EA	POWER SUPPLY	GRY
1	EA	CARD READER(BY OWNER'S SECURITY CONTRACTOR)	

Hardware Group No. 20: (Doors ST-3, ST-4, ST-5, ST-6, ST-7, ST-8, ST-9, ST-10, ST-11 & ST-12)

Each To Have:

Qty		Description	
4	EA	BB HINGE (NRP)	BBLK

NEW BUILDINGS FOR VALOR ACRES -
BUILDING E

06/07/24
Bulletin #1 – 08/07/24
Bulletin #2 – 04/11/25
Bulletin #4 – 07/02/25

1	EA	EXIT DEVICE W/ LATCHING/ PASSAGE FUNCTION & LEVER	711
1	EA	SURFACE CLOSER	693
1	EA	WALL STOP	BLK
1	SET	SEALS (FIRE)	AL
1	EA	DOOR BOTTOM	AL

Hardware Group No. 21A: (Doors 101A & 102A)
Each To Have:

Qty		Description	
4	EA	BB HINGE	BBLK
1	EA	ELECT STRIKE	BLK
1	EA	OFFICE STOREROOM LEVER LOCKSET	622
1	EA	CORE	622
1	EA	WALL STOP	BLK
1	EA	POWER SUPPLY	GRY
1	EA	CARD READER (BY OWNER'S SECURITY CONTRACTOR)	

Hardware Group No. 21B: (Doors 101A & 102A)
Each To Have:

Qty		Description	
1	EA	BB HINGE PIVOT (BY DR SUPPLIER)	BLK
1	EA	CONCEALED CLOSER WITH H.O. (BY DR SUPPLIER)	BLK
1	EA	SUPPLIED CENTER LOCK WITH DEADLATCH IN OFFICE FUNCTION	BLK
1	EA	CORE	622
1	EA	WALL STOP	BLK

REFER TO DIVISION 08 SECTION "ALL-GLASS ENTRANCES"

Hardware Group No. 22: (Doors 201, 203, 301, 303, 401, 403, 501, 503, 601 & 603)
Each To Have:

Qty		Description	
4	EA	BB HINGE	BBLK
1	EA	STOREROOM LEVER LOCKSET	622
1	EA	CORE	622
1	EA	SURFACE CLOSER W/ OH STOP	693
1	SET	SEALS (SMOKE)	AL

NEW BUILDINGS FOR VALOR ACRES -
BUILDING E

06/07/24
Bulletin #1 – 08/07/24
Bulletin #2 – 04/11/25
Bulletin #4 – 07/02/25

Hardware Group No. 23: (Door 109B)

Each To Have:

Qty		Description	
8	EA	BB HINGE (NRP)	BBLK
2	EA	CONCEALED VERT ROD ELECT. EXIT DEVICE (DOGGING, NIGHT LATCH FUNCTION) (PROVIDE HOLES IN EXIT DEVICE FOR DRAINAGE)	711
2	EA	PULL	711
2	EA	CYLINDER	622
2	EA	CORE	622
2	EA	SURFACE CLOSER W/ OH STOP	693
1	SET	SEALS (SOUND)	AL
1	EA	ADA THRESHOLD	AL

Hardware Group No. 24: (Doors ~~109A~~, ~~112B~~, ~~113B~~ & 117A)

Each To Have:

Qty		Description	
4	EA	BB HINGE (NRP)	BBLK
1	EA	EXIT DEVICE (DOGGING, NIGHT LATCH FUNCTION) (PROVIDE HOLES IN EXIT DEVICE FOR DRAINAGE)	711
1	EA	PULL	711
1	EA	CYLINDER	622
1	EA	CORE	622
1	EA	SURFACE CLOSER W/ OH STOP	693
1	SET	SEALS (THERMAL)	AL
1	EA	ADA THRESHOLD	AL

Hardware Group No. 25: (Doors ~~122A~~ **201, 203, 401, 403, 601 & 603**)

Each To Have:

Qty		Description	
4	EA	BB HINGE	BBLK
4	EA	ELECT STRIKE	BLK
1	EA	EXIT DEVICE (NL FUNCTION W/ LEVER	711
1	EA	CYLINDER	622
1	EA	CORE	622

NEW BUILDINGS FOR VALOR ACRES -
BUILDING E

06/07/24
Bulletin #1 – 08/07/24
Bulletin #2 – 04/11/25
Bulletin #4 – 07/02/25

1	EA	SURFACE CLOSER W/ OH STOP	693
4	EA	WALL STOP	BLK
4	EA	POWER SUPPLY	GRY
4	EA	CARD READER (BY OWNER'S SECURITY CONTRACTOR)	

Hardware Group No. 26: (Door 125A 122 & 129A)
Each To Have:

Qty		Description	
4	EA	BB HINGE (NRP)	BBLK
1	EA	ELECT STRIKE	BLK
1	EA	EXIT DEVICE W/ NIGHT LATCH/ PASSAGE FUNCTION & LEVER	711
2	EA	CYLINDER	622
2	EA	CORE	622
1	EA	SURFACE CLOSER	693
1	EA	WALL STOP	BLK
1	SET	SEALS (FIRE)	AL
1	EA	POWER SUPPLY	GRY
1	EA	CARD READER (BY OWNER'S SECURITY CONTRACTOR)	

Hardware Group No. 27: (Doors 122B & ~~125B~~ 129B, **200A, 200B, 300A, 300B, 400A, 400B, 500A, 500B & 600**)

Each To Have:

Qty		Description	
4	EA	BB HINGE (NRP)	BBLK
1	EA	ELECT HINGE	BBLK
1	EA	ELECT EXIT DEVICE W/ NIGHT LATCH/ PASSAGE FUNCTION & LEVER	711
1	EA	CYLINDER	622
1	EA	CORE	622
1	EA	SURFACE CLOSER	693
1	EA	WALL STOP	BLK
1	SET	SEALS (FIRE)	AL
1	EA	ADA THRESHOLD	AL
1	EA	POWER SUPPLY	GRY
1	EA	CARD READER (BY OWNER'S SECURITY CONTRACTOR)	

Hardware Group No. 28: (Doors 112, 113, 116A, & 125)

NEW BUILDINGS FOR VALOR ACRES -
BUILDING E

06/07/24
Bulletin #1 – 08/07/24
Bulletin #2 – 04/11/25
Bulletin #4 – 07/02/25

Each To Have:

Qty		Description	
4	EA	BB HINGE	BBLK
2	EA	B/B DUMMY LEVERS	BLK
1	EA	SURFACE CLOSER	693

Hardware Group No. 29: (Door 114)

Each To Have:

Qty		Description	
1	SET	DOOR SLIDE TRACK W/ STOP	BBLK
2	EA	B/B PULLS	BLK

Hardware Group No. 30: (Door 116C)

Each To Have:

Qty		Description	
1	EA	ALL HARDWARE BY DOOR SUPPLIER	BBLK

Hardware Group No. 31: (Doors 118, 119 & 120)

Each To Have:

Qty		Description	
3	EA	BB HINGE	BBLK
1	EA	PRIVACY LEVER SET W/ OCCUPANCY INDICATOR	BLK
1	EA	SURFACE CLOSER	693
1	EA	WALL STOP	BLK

Hardware Group No. 32: (Door 123)

Each To Have:

Qty		Description	
8	EA	BB HINGE	BBLK
1	EA	STOREROOM LEVER LOCKSET	622
1	EA	CORE	622
2	EA	SURFACE CLOSER W/ OH STOP	693
1	PR	MANUAL FLUSHBOLTS (INACTIVE DOOR)	BLK
1	EA	DUSTPROOF STRIKE	BLK

Hardware Group No. 33: (Doors 109A)

Each To Have:

Qty		Description	
4	EA	BB HINGE (NRP)	BBLK
1	EA	POWER TRANSFER	AL

NEW BUILDINGS FOR VALOR ACRES -
BUILDING E

06/07/24
Bulletin #1 – 08/07/24
Bulletin #2 – 04/11/25
Bulletin #4 – 07/02/25

1	EA	ELECTRIC STOREROOM LEVER LOCKSET W/ CARD ACCESS (FOR BOTH DIRECTIONS) TO OPEN DOOR	622
1	EA	PULL	711
1	EA	CYLINDER	622
1	EA	CORE	622
1	EA	SURFACE CLOSER W/ OH STOP	693
1	SET	SEALS (THERMAL)	AL
1	EA	ADA THRESHOLD	AL
1	EA	POWER SUPPLY	GRY
2	EA	CARD READER (BY OWNER'S SECURITY CONTRACTOR)	

THIS DOOR IS NOT AN EGRESS DOOR SO THAT IT LOCKS FROM BOTH SIDES AND A KEYFOB PRESENTED OPENS THE DOOR FROM EACH SIDE. PREP DOOR FOR WIRE TO ELECTRIC LOCKSET

Hardware Group No. 34: (Gate 138)

Each To Have:

Qty		Description	
4	EA	GATE SPRING HINGE	BBLK
2	EA	GATE HINGE	BBLK
2	EA	TRANSFER WIRE	---
2	EA	GATE MOUNTED ELECT EXIT DEVICE WITH MOUNTING PLATE & ADA PULLS	BLK
1	EA	CYLINDER	622
1	EA	CORE	622
2	EA	ELECT SHEAR LOCK MOUNTED IN GATE HEAD	BLK
1	EA	PUSH TO EXIT BUTTON	BLK
1	EA	POWER SUPPLY	GRY
1	EA	CARD READER (BY OWNER'S SECURITY CONTRACTOR)	

Hardware Group No. 35: (Gates 139 & 140)

Each To Have:

Qty		Description	
2	EA	GATE SPRING HINGE	BBLK
1	EA	TRANSFER WIRE	---

NEW BUILDINGS FOR VALOR ACRES -
BUILDING E

06/07/24
Bulletin #1 – 08/07/24
Bulletin #2 – 04/11/25
Bulletin #4 – 07/02/25

1	EA	GATE MOUNTED ELECT EXIT DEVICE WITH MOUNTING PLATE, LEVER AND STRIKE PLATE	BLK
1	EA	CYLINDER	622
1	EA	CORE	622
1	EA	POWER SUPPLY	GRY
1	EA	CARD READER (BY OWNER'S SECURITY CONTRACTOR)	

Hardware Group No. 36: (Gates U19)
Each To Have:

Qty		Description	
2	EA	GATE SPRING HINGE	BBLK
1	EA	TRANSFER WIRE	---
1	EA	GATE MOUNTED ELECT STOREROOM LEVER LOCKSET	BLK
1	EA	CORE	622
1	EA	POWER SUPPLY	GRY
1	EA	CARD READER (BY OWNER'S SECURITY CONTRACTOR)	

END OF SECTION 087100