COMcheck Software Version 4.1.5.5

Interior Lighting Compliance Certificate

Project Information

Energy Code: 2015 IECC
Project Title: FIFTH THIRD BANK WATSON
Project Type: New Construction

Construction Site:
2711 WATSON BOULEVARD
WARNER ROBBINS, GA 31093

Owner/Agent:

Designer/Contractor:

Additional Efficiency Package(s)

Credits: 1.0 Required 1.0 Proposed
Reduced Lighting Power, 1.0 credit

Allowed Interior Lighting Power

A Area Category	B Floor Area (ft2)	C Allowed Watts / ft2	D Allowed Watts (B X C)
1-Retail	2798	1.13	3173
		Total Allowed Watts =	3173

Proposed Interior Lighting Power

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixtures	D Fixture Watt.	E (C X D)
1-Retail				
LED 1: A/AE: Other:	1	29	15	435
LED 1 copy 1: B: Other:	1	40	3	120
LED 1 copy 1: C: Other:	1	9	52	468
LED 1 copy 2: F3: Other:	1	27	1	27
LED 1 copy 3: FEM: Other:	1	30	2	60
LED 1 copy 4: G: Other:	1	50	2	100
LED 1 copy 5: J/JE: Other:	1	19	8	152
LED 1 copy 6: PB: Other:	1	17	1	17
LED 1 copy 7: S: Other:	1	27	2	54
LED 1 copy 8: T: Other:	1	16	19	304
		Total Proposed Watts =		1737

Interior Lighting PASSES: Design 45% better than code

Interior Lighting Compliance Statement

Compliance Statement: The proposed interior lighting design represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed interior lighting systems have been designed to meet the 2015 IECC requirements in COMcheck Version 4.1.5.5 and to comply with any applicable mandatory requirements listed in the Inspection Checklist.

Travis Apperson — Digitally signed by Travis Apperson; DN: C=US, E=tapperson@praxis3designgroup.com, CN=Travis Apperson; Date: 2026.06.30 14:15:33-04'00' — 07/02/2026

Name - Title | Signature | Date

COMcheck Software Version 4.1.5.5

Exterior Lighting Compliance Certificate

Project Information

Energy Code: 2015 IECC
Project Title: FIFTH THIRD BANK WATSON
Project Type: New Construction
Exterior Lighting Zone: 4 (High activity metropolitan commercial district (LZ4))

Construction Site:
2711 WATSON BOULEVARD
WARNER ROBBINS, GA 31093

Owner/Agent:

Designer/Contractor:

Allowed Exterior Lighting Power

A Area/Surface Category	B Quantity	C Allowed Watts / Unit	D Tradable Wattage	E Allowed Watts (B X C)
Parking area	6873 ft2	0.13	Yes	893
Entry canopy	43 ft2	0.4	Yes	17
Entry canopy	237 ft2	0.4	Yes	95
Entry canopy	379 ft2	0.4	Yes	152
			Total Tradable Watts (a) =	1157
			Total Allowed Watts =	1157
			Total Allowed Supplemental Watts (b) =	1300

(a) Wattage tradeoffs are only allowed between tradable areas/surfaces.
(b) A supplemental allowance equal to 1300 watts may be applied toward compliance of both non-tradable and tradable areas/surfaces.

Proposed Exterior Lighting Power

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixtures	D Fixture Watt.	E (C X D)
Parking area (6873 ft2): Tradable Wattage				
LED 1: 1P4F: Other:	1	140	1	140
LED 1 copy 1: SP4DA: Other:	1	140	4	560
Entry canopy (43 ft2): Tradable Wattage				
LED 1 copy 2: G1/GEM: Other:	1	21	4	84
Entry canopy (237 ft2): Tradable Wattage				
LED 1 copy 6: G1/GEM: Other:	1	21	10	210
Entry canopy (379 ft2): Tradable Wattage				
LED 1 copy 7: G1/GEM: Other:	1	21	8	168
LED 1 copy 5: L: Other:	1	180	2	360
LED 1 copy 4: U1: Other:	1	9	2	18
LED 1 copy 3: U3: Other:	1	26	4	104
		Total Tradable Proposed Watts =		1644

Exterior Lighting PASSES: Design 33% better than code

Exterior Lighting Compliance Statement

Compliance Statement: The proposed exterior lighting design represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed exterior lighting systems have been designed to meet the 2015 IECC requirements in COMcheck Version 4.1.5.5 and to comply with any applicable mandatory requirements listed in the Inspection Checklist.

Travis Apperson — Digitally signed by Travis Apperson; DN: C=US, E=tapperson@praxis3designgroup.com, CN=Travis Apperson; Date: 2026.06.30 14:15:33-04'00' — 07/02/2026

Name - Title | Signature | Date

PRAXIS3
100 Peachtree St NW
Suite 1450
Atlanta, GA 30303
404-875-4500 tel
www.praxis3.com

GEORGIA REGISTERED No. 041468 PROFESSIONAL ENGINEER RAHN ONEAL WILLIAMS

Copyright (c) 2024 Praxis3, LLC

All reports, plans, specifications, computer files, field data, notes and other documents and instruments prepared by Praxis3 shall retain all common law, statutory and other reserved rights, including copyright thereto.

This drawing may not be reproduced in whole or in part without written permission of Praxis3. It is to be returned upon request. Scales as stated are valid on the original drawings.

Rev	Date	Comments
	07/02/2026	PERMIT SET

Client:
FIFTH THIRD BANK

Project Number: 26032
Project Name:
FIFTH THIRD BANK WATSON 1,900 SF

2711 WATSON BOULEVARD
WARNER ROBBINS, GA 31093

Key Plan:

Sheet Title:
COMCHECK

Sheet Number:
E-004

6/30/2026 2:31:58 PM