

1 E-160 ELECTRICAL FIRE ALARM PLAN
1/4" = 1'-0"

SHEET NOTES:

1. ALL FIRE ALARM DEVICES, INCLUDING SPEAKERS, VISUALS, SMOKE DETECTORS, ETC. SHALL BE CONNECTED TO THE BASE BUILDING BY A LANDLORD APPROVED, LICENSED FIRE ALARM CONTRACTOR WHO'S BUSINESS IS FIRE ALARM INSTALLATION AND/OR SERVICE.
2. ALL DEVICES ARE TO BE MOUNTED A MINIMUM OF 80" FROM BOTTOM OF STROBE TO FINISHED FLOOR. DEVICES ARE TO BE MOUNTED IN PROPER BOXES (NOT TO BE MOUNTED IN EXTENSION RINGS). JUNCTION BOXES ARE TO BE CLEARLY LABELED "F/A". FLEX CONDUIT WITH INTERNAL CONNECTORS ARE TO BE USED FROM DEVICE BOX TO HOME RUN JUNCTION BOX. IN FULL WALL PENETRATIONS, CONDUIT OR FLEX MUST BE KEPT AT 12" MINIMUM ABOVE THE CEILING.
3. STROBE AND HORN WIRING TO BE 14 AWG THIN STRANDED WIRED, RED/BLACK AND SPEAKER TO BE "BELDON 8760" WITH SHIELD, GRAY JACKET OR EQUIVALENT. FOUR CONDUCTOR OR CABLES ARE NOT TO BE USED ON FIRE ALARM DEVICES. SOLID WIRE IS NOT TO BE USED. SPLICING OF WIRE BETWEEN DEVICES IS PROHIBITED. ALL FIRE ALARM WIRING TO BE PUT IN MINIMUM 1/2" EMT CONDUIT, DEDICATED HANGERS OR STRAPPED, TO BE LOCATED AT THE HIGHEST POINT ABOVE THE CEILING. FIRE ALARM WIRE MUST NOT OCCUPY THE SAME WALL PENETRATION WITH DUCTWORK, PIPING, ELECTRICAL DEVICES OR CIRCUITS. ALL CONDUIT SHALL BE TERMINATED WITH INSULATION BUSHINGS.
4. PROVIDE AND INSTALL POWER SUPPLY FOR NEW STROBES - MATCH BUILDING STANDARD - WITH NECESSARY BATTERIES, BASED ON MAXIMUM OF 20 DEVICES PER POWER SUPPLY. POWER SUPPLY TO BE CONNECTED TO A DEDICATED CIRCUIT AND SUPERVISED FOR FAILURE.
5. WIRING METHOD TO MEET THE ABOVE BUILDING STANDARDS AND COMPLY WITH ARTICLE 760 OF NEC-70 CODE REQUIREMENTS.
6. ALL DEVICES SHALL BE 110 CANDELA UNLESS OTHERWISE NOTED. THE ENTIRE LENS OF VISUAL FIRE ALARM DEVICES SHALL BE MOUNTED AT LEAST 80" AFF.
7. COORDINATE FIRE ALARM SYSTEM SHUTDOWNS AND REPROGRAMMING WITH OWNER.
8. PROVIDE LETTER OF CERTIFICATION FOR NEW FIRE ALARM DEVICES.

PRAXIS3

100 Peachtree St NW
Suite 1450
Atlanta, GA 30303

404-875-4500 tel
www.praxis3.com

GEORGIA REGISTERED No. 041450 PROFESSIONAL ENGINEER RAHN ONEAL WILLIAMS

Copyright (c) 2024 Praxis3, LLC

All reports, plans, specifications, computer files, field data, notes and other documents and instruments prepared by Praxis3 shall retain all common law, statutory and other reserved rights, including copyright thereto.

This drawing may not be reproduced in whole or in part without written permission of Praxis3. It is to be returned upon request. Scales as stated are valid on the original drawings.

Rev	Date	Comments
	07/02/2026	PERMIT SET

Client:
FIFTH THIRD BANK

Project Number: 26032
Project Name:
FIFTH THIRD BANK WATSON 1,900 SF

2711 WATSON BOULEVARD
WARNER ROBBINS, GA 31093

Key Plan:

Sheet Title:
ELECTRICAL FIRE ALARM PLAN

Sheet Number:
E-160

6/30/2026 2:32:06 PM