



REQUIRED COMPACTION AND TESTING

1. OUTSIDE OF PAVED OR PROPOSED PAVED AREAS STANDARD PROCTOR, 90%, TESTING REQUIRED FIRST 3' ONLY.
2. UNDER PAVED OR PROPOSED PAVED AREAS STANDARD PROCTOR, 95%, TESTING REQUIRED EVERY 3' TO GRADE.
3. UNDER D.O.T. ROADWAYS OR PROPOSED D.O.T. ROADWAYS STANDARD PROCTOR, 98%, TESTING REQUIRED EVERY 3' TO GRADE.
4. ALL COMPACTION TESTING SHALL BE CONDUCTED BY AN APPROVED SOILS TESTING FIRM.


## SECTION - SANITARY SEWER BEDDING PVC PIPE

N.T.S.

PLOT SCALE: 1=12

| | | |
|---|---|---|
| SANITARY SEWER BEDDING - PVC PIPE | CITY OF WARNER ROBINS UTILITIES DISTRIBUTION STANDARD DETAIL WATER/SEWER/GAS/STORM | DATE: 08/30/01 FILE: SSBED2.DWG SHEET: S2 |

**DETAIL**




NOTE:

1. CONCRETE SHALL BE PLACED TO BOTTOM OF MANHOLE AND ENCASE DROP PIPING A MINIMUM OF 6" IN ALL DIRECTIONS.
2. EXTEND NEW PIPE A MAXIMUM OF 1" INTO EXISTING MANHOLE.
3. LOCATE DROP INVERT ABOVE EXISTING SHELF. GROUT SHELF TO 3:1 SLOPE.
4. DROP PIPE AND FITTINGS MAY BE DUCTILE IRON OR PVC


## SECTION - DROP TIE-IN TO EXIST. MANHOLE

SCALE: 1" = 2'-0"

PLOT SCALE: 1 = 24

| | | |
|---|---|---|
| DROP TIE-IN TO EXISTING MANHOLE | CITY OF WARNER ROBINS UTILITIES DISTRIBUTION STANDARD DETAIL WATER/SEWER/GAS/STORM | DATE: 8/30/01 FILE: SSDROPEX.DWG SHEET: S9 |

**DETAIL**




NOTES:

1. PROTECTIVE COATING SHALL BE STRIPPED PRIOR TO SPLICE. WRAP FINISHED SPLICE WITH ELECTRICAL TAPE.


## DETAIL - TRACER WIRE PLACEMENT - SEWER

N.T.S.

PLOT SCALE: 1=12

| | | |
|---|---|---|
| TRACER WIRE PLACEMENT | CITY OF WARNER ROBINS UTILITIES DISTRIBUTION STANDARD DETAIL WATER/SEWER/GAS/STORM | DATE: 11/01/01 FILE: SWIRE.DWG SHEET: S15 |

**DETAIL**




## DETAIL - CLEANOUT TO GRADE

SCALE: 1" = 1'-0"


PLOT SCALE 1=12


| | | |
|---|---|---|
| CLEANOUT TO GRADE | CITY OF WARNER ROBINS UTILITIES DISTRIBUTION STANDARD DETAIL WATER/SEWER/GAS/STORM | DATE: 8/30/01 FILE: SSCO.DWG SHEET: S17 |

**DETAIL**

## 1899CGD

APPROX. DRAIN AREA = 175.59 SQ IN
APPROX. WEIGHT = 32.00 LBS




SECTION A-A

DIMENSIONS ARE FOR REFERENCE ONLY
ACTUAL DIMENSIONS MAY VARY
DIMENSIONS ARE IN INCHES
QUALITY: MATERIALS SHALL CONFORM TO ASTM A536 GRADE 70-50-05
PAINT: CASTINGS ARE FURNISHED WITH A BLACK PAINT
LOCKING DEVICE AVAILABLE UPON REQUEST

THIS PRINT DISCLOSES SUBJECT MATTER IN WHICH NYLOPLAST HAS PROPRIETARY RIGHTS. THE RECEIPT OR POSSESSION OF THIS PRINT DOES NOT CONFER, TRANSFER, OR LICENSE THE USE OF THE DESIGN OR TECHNICAL INFORMATION SHOWN HEREIN. REPRODUCTION OF THIS PRINT OR ANY INFORMATION CONTAINED HEREIN, OR MANUFACTURE OF ANY ARTICLE HEREFROM, FOR THE DISCLOSURE TO OTHERS IS FORBIDDEN, EXCEPT BY SPECIFIC WRITTEN PERMISSION FROM NYLOPLAST.
©2013 NYLOPLAST

| | | | | | |
|---|---|---|---|---|---|
| DRAWN BY | EBC | MATERIAL | DUCTILE IRON | ADS Nyloplast | 3130 VERONA AVE BUFORD, GA 30518 PHN (770) 932-2443 FAX (770) 932-2490 www.nyloplast-us.com |
| DATE | 03-08-06 | | | | |
| REVISED BY | CCA | PROJECT NO./NAME | | TITLE | 18 IN DOME GRATE |
| DATE | 08-30-13 | | | | |
| DWG SIZE | A | SCALE 1:6 | SHEET 1 OF 1 | DWG NO. | 7001-110-215 REV E |

**DETAIL**

PREPARED IN THE OFFICE OF:
GASKINS +LECRAW
a PAPE-DAWSON company
© 2026 GASKINS + LECRAW
3475 CORPORATE WAY
SUITE A
DULUTH, GA 30096
PHONE - 678.546.8100
www.gaskinslecraw.com
PEF008127

REVISIONS:

| NO.# | DATE | DRAWN BY: | CHECKED BY: |
|---|---|---|---|
| 1 | | | |
| 1 | | | |
| 1 | | | |
| 1 | | | |
| 1 | | | |
| 1 | | | |

CLIENT
PRAXIS3
100 PEACHTREE STREET NW, SUITE 1450, ATLANTA, GEORGIA 30303

PROJECT
FIFTH THIRD BANK - WARNER ROBINS, GA
2711 WATSON BLVD
PARCEL ID: 0W0780-005000
WARNER ROBINS, HOUSTON COUNTY, GEORGIA

SEAL:

FOR INFORMATIONAL PURPOSES ONLY

CALL BEFORE YOU DIG

811 Know what's below. Call before you dig.

SCALE & NORTH ARROW:

DETAILS ARE **NOT** DRAWN TO SCALE

DESIGN INFO:

| | |
|---|---|
| DRAWN BY: | JOA |
| DESIGNED BY: | MAT |
| REVIEWED BY: | TKS |
| JOB #: | 75670007 |
| DATE: | JULY 9, 2026 |

CONSTRUCTION DETAILS - 3

**C-6.2**

Drawing name: C:\Users\cklentz\Gaskins+LeCraw Dropbox\Shared Folders\Engineering\75670007 - Praxis3 - Fifth Third - Warner Robins_GA\CADD\CONSTR\75670007 - 10 - DETAILS.dwg CONSTRUCTION DETAILS - 3 Jul 09, 2026 10:53am by: cklentz

This document, together with the concepts and designs presented herein, as an instrument of service, is intended only for the specific purpose and client for which it was prepared. Reuse of and improper reliance on this document without written authorization and adaptation by Gaskins + LeCraw, a Pape-Dawson Company shall be without liability to Gaskins + LeCraw, a Pape-Dawson Company, Copyright Gaskins + LeCraw, a Pape-Dawson Company, 2026