


NOTES:

1. TRENCH SHALL BE EXCAVATED TO THE DEPTH REQUIRED PROVIDING A UNIFORM AND CONTINUOUS BEARING AND SUPPORT FOR THE PIPE ON SOLID, UNDISTURBED GROUND AT EVERY POINT BETWEEN BELLS OR COUPLINGS.
2. WHEN POOR BEDDING SOIL IS ENCOUNTERED, REMOVE UNSUITABLE SOIL TO REQUIRED DEPTH AND BACKFILL WITH AN APPROVED AGGREGATE MATERIAL PRIOR TO LAYING PIPE. BACKFILL SHALL BE PLACED IN 6" LIFTS WITH EACH LAYER TAMPED TO 95% COMPACTION.


SECTION - WATER LINE BEDDING

N.T.S.

PLOT SCALE: 1=12

WATER LINE BEDDING	CITY OF WARNER ROBINS UTILITIES DISTRIBUTION STANDARD DETAIL — WATER/SEWER/GAS/STORM	DATE: 8/30/01 FILE: WBED.DWG SHEET: W1

DETAIL




DETAIL - THRUST BLOCK LOCATIONS

N.T.S.

PLOT SCALE: 1=12

TYPICAL LOCATIONS FOR THRUST BLOCKS	CITY OF WARNER ROBINS UTILITIES DISTRIBUTION STANDARD DETAIL — WATER/SEWER/GAS/STORM	DATE: 8/29/01 FILE: WTHRUSTLOC.DWG SHEET: W2

DETAIL



NOTES:

1. ALL FITTINGS SHALL BE PROPERLY BLOCKED OR TIE-RODDED AS REQUIRED TO INSURE SUFFICIENT ANCHORAGE OF THE PIPING.
2. PROVIDE SUFFICIENT BACKFILL AND COMPACTION OVER WATER LINE TO ASSURE PROTECTION OF THE PIPE.


PROFILE - WATER LINE CONFLICT

SCALE" 1" = 2'-0"


PLOT SCALE: 1=24

WATERLINE CONFLICT	CITY OF WARNER ROBINS UTILITIES DISTRIBUTION STANDARD DETAIL — WATER/SEWER/GAS/STORM	DATE: 8/30/01 FILE: WATCONF.DWG SHEET: W7

DETAIL



TYPE A - STANDARD MJ SLEEVE



TYPE B - CUTTING-IN MJ SLEEVE

NOTE:

1. EXISTING PIPE CUT OUT FOR FITTING MAY BE USED FOR SPOOL PIECE.


DETAIL - CUTTING-IN SLEEVE

N.T.S.

PLOT SCALE: 1=12

CUTTING-IN SLEEVE	CITY OF WARNER ROBINS UTILITIES DISTRIBUTION STANDARD DETAIL — WATER/SEWER/GAS/STORM	DATE: 11/01/01 FILE: WCUTIN.DWG SHEET: W8

DETAIL



NOTES:

1. TAPPING SLEEVE SHALL BE JCM MODEL #422 OR APPROVED EQUAL.
2. NO TAP SHALL BE MADE ON A PUBLIC MAIN WITHOUT PRIOR APPROVAL. A QUALIFIED REPRESENTATIVE SHALL BE ON-SITE FOR ALL TAPS.


DETAIL - TAPPING SLEEVE

N.T.S.

PLOT SCALE: 1=12

TAPPING SLEEVE SYSTEM	CITY OF WARNER ROBINS UTILITIES DISTRIBUTION STANDARD DETAIL — WATER/SEWER/GAS/STORM	DATE: 11/01/01 FILE: WTAP.DWG SHEET: W9

DETAIL




TYPICAL WATER VALVE SETTING

SCALE: 1"= 1'-0"

PLOT SCALE: 1=12

TYPICAL WATER VALVE SETTING	CITY OF WARNER ROBINS UTILITIES DISTRIBUTION STANDARD DETAIL — WATER/SEWER/GAS/STORM	DATE: 11/01/01 FILE: WVALVE.DWG SHEET: W11

DETAIL



NOTES:

1. PROTECTIVE COATING SHALL BE STRIPPED PRIOR TO SPLICE. WRAP FINISHED SPLICE WITH ELECTRICAL TAPE.


DETAIL - TRACER WIRE PLACEMENT - WATER

N.T.S.

PLOT SCALE: 1=12

TRACER WIRE PLACEMENT	CITY OF WARNER ROBINS UTILITIES DISTRIBUTION STANDARD DETAIL — WATER/SEWER/GAS/STORM	DATE: 11/01/01 FILE: WWIRE.DWG SHEET: W14

DETAIL



FOR 3/4" OR 1" METERS ONLY

NOTES:

1. GALVANIZED BUSHING WILL BE REQUIRED FOR 3/4" METER ON 1" CURB STOP.
2. ALL THREADS SHALL BE COATED WITH RECTOR SEAL NO. 5 OR APPROVED EQUAL.
3. METER BOX WITH READER DOOR SHALL BE DFW D1200-DIRB OR APPROVED EQUAL.
4. METER COUPLINGS SHALL BE OF ONE OF THE FOLLOWING:
   FORD P/N C38-23-2.5 (3/4"x 2-1/2" L) OR C38-44-2.625 (1"x2-5/8" L)
   MUELLER P/N H-10896 (3/4"x 2-1/2" L OR 1"x 2-5/8" L)
   A.Y. McDONALD P/N 4620 (3/4"x 2-1/2" L OR 1"x 2-5/8" L)

STANDARD WATER METER DETAIL

N.T.S.

PLOT SCALE: 1=12

WATER METER DETAIL	CITY OF WARNER ROBINS UTILITIES DISTRIBUTION STANDARD DETAIL — WATER/SEWER/GAS/STORM	DATE: 12/01/01 FILE: WMETER.DWG SHEET: W15

DETAIL

PREPARED IN THE OFFICE OF:
GASKINS +LECRAW
a PAPE-DAWSON company
© 2026 GASKINS + LECRAW
3475 CORPORATE WAY
SUITE A
DULUTH, GA 30096
PHONE - 678.546.8100
www.gaskinslecraw.com
PEF008127

REVISIONS:

NO. #	DATE	DRAWN BY:	CHECKED BY:
1			

CLIENT
PRAXIS3
100 PEACHTREE STREET NW, SUITE 1450, ATLANTA, GEORGIA 30303

PROJECT
FIFTH THIRD BANK - WARNER ROBINS, GA
2711 WATSON BLVD
PARCEL ID: 0W0780-005000
WARNER ROBINS, HOUSTON COUNTY, GEORGIA

SEAL:

FOR INFORMATIONAL PURPOSES ONLY

CALL BEFORE YOU DIG

811 Know what's below. Call before you dig.

SCALE & NORTH ARROW:

DETAILS ARE NOT DRAWN TO SCALE

DESIGN INFO:

DRAWN BY:	JOA
DESIGNED BY:	MAT
REVIEWED BY:	TKS
JOB #:	75670007
DATE:	JULY 9, 2026

CONSTRUCTION DETAILS - 4

C-6.3

Drawing name: C:\Users\cklentz\Gaskins+LeCraw Dropbox\Shared Folders\Engineering\75670007 - Praxis3 - Fifth Third - Warner Robins_GA\CADD\CONSTR\75670007 - 10 - DETAILS.dwg CONSTRUCTION DETAILS - 4 Jul 09, 2026 10:53am by: cklentz

This document, together with the concepts and designs presented herein, as an instrument of service, is intended only for the specific purpose and client for which it was prepared. Reuse of and improper reliance on this document without written authorization and adaptation by Gaskins + LeCraw, a Pape-Dawson Company shall be without liability to Gaskins + LeCraw, a Pape-Dawson Company, Copyright Gaskins + LeCraw, a Pape-Dawson Company, 2026