

Fire Safety Inspection Report

Inspection Date: 2024-06-07

Inspector Name: Jordan Lee

Building Name: Tech Park Tower

Address: 500 Tech Park Way, Silicon Valley, CA 95054

Number of Floors: 7

Fire Extinguishers

- **Locations:** Present on each floor near stairwells, elevator lobbies, and main corridors.
- **Pressure:** All units within operational range except 2nd Floor South (slightly below recommended pressure; scheduled for recharge).

Smoke Detectors

- **Functionality:** All detectors operational except one on 5th Floor West (battery low).
- **Last Test Date:** 2024-05-15

Sprinkler System

- **Pressure:** 120 psi (within recommended range).
- **Last Service:** 2024-04-20

Emergency Exits

- **Clearance:** All exits clear except 3rd Floor East (obstructed by storage boxes).
- **Lighting:** Exit signs illuminated and emergency lighting functional throughout.

Fire Doors

- **Functionality:** All fire doors close and latch properly; no obstructions.

Evacuation Plans

- **Visibility:** Posted at all elevator lobbies and main corridors; clearly visible and up to date.
-

Deficiencies Found

Deficiency	Location	Urgency Level	Notes
Blocked Exit	3rd Floor East	Immediate	Boxes obstructing path.
Faulty Detector	5th Floor West	High	Battery low.

Overall Fire Safety Rating: 6.7 out of 10

Next Scheduled Inspection: 2026-05-07