

Pri.	Timestamp	Object ID	Tag name	Description	State	Detailed State	Source ID	Signal number	Note	Alarm Advisory
Critical	2026-07-28 06:30:12	Bank05.Stream03.MeterA.CommunicationStatus	Bank05.Stream03.MeterA.CommunicationStatus	Communication status	Off	Failed	11	50		
Critical	2026-07-28 06:30:10	Bank08.Stream01.MeterA.CommunicationStatus	Bank08.Stream01.MeterA.CommunicationStatus	Communication status	Off	Failed	13	50		
Critical	2026-07-28 06:30:07	Bank10.Stream01.MeterA.CommunicationStatus	Bank10.Stream01.MeterA.CommunicationStatus	Communication status	Off	Failed	17	50		
Critical	2026-07-28 06:30:07	Bank13.Stream02.MeterA.CommunicationStatus	Bank13.Stream02.MeterA.CommunicationStatus	Communication status	Off	Failed	21	50		
Critical	2026-07-28 06:30:07	Bank05.Stream02.MeterA.CommunicationStatus	Bank05.Stream02.MeterA.CommunicationStatus	Communication status	Off	Failed	10	50		
Critical	2026-07-28 06:30:06	Bank03.Stream01.MeterA.CommunicationStatus	Bank03.Stream01.MeterA.CommunicationStatus	Communication status	Off	Failed	5	50		
Critical	2026-07-28 06:30:06	Bank08.Stream02.MeterA.CommunicationStatus	Bank08.Stream02.MeterA.CommunicationStatus	Communication status	Off	Failed	14	50		
Critical	2026-07-28 06:30:00	Bank15.Stream02.MeterA.CommunicationStatus	Bank15.Stream02.MeterA.CommunicationStatus	Communication status	Off	Failed	25	50		
General	2026-07-28 05:34:52	Bank08.Stream02.MeterA.LoFlowAlarm	Bank08.Stream02.MeterA.LoFlowAlarm	Low flow alarm	Off	On	14	1045		
Critical	2026-07-28 05:30:14	Bank03.Stream02.MeterA.CommunicationStatus	Bank03.Stream02.MeterA.CommunicationStatus	Communication status	Off	Failed	6	50		
Critical	2026-07-28 05:30:12	Bank13.Stream01.MeterA.CommunicationStatus	Bank13.Stream01.MeterA.CommunicationStatus	Communication status	Off	Failed	20	50		
General	2026-07-28 04:13:33	Bank19.Stream02.MeterA.Vx.DP.DevAB	Bank19.Stream02.MeterA.Vx.DP.DevAB	DP deviation	Off	Off	31	1225		
General	2026-07-28 03:30:30	Bank03.Stream02.MeterA.LoFlowAlarm	Bank03.Stream02.MeterA.LoFlowAlarm	Low flow alarm	On	On	6	1045		
General	2026-07-27 22:30:16	Bank15.Stream02.MeterA.LoFlowAlarm	Bank15.Stream02.MeterA.LoFlowAlarm	Low flow alarm	On	On	25	1045		
General	2026-07-27 15:27:15	Bank03.Stream02.MeterA.TrDevHi	Bank03.Stream02.MeterA.TrDevHi	Transmitter deviation high	Off	On	6	1047		
Critical	2026-07-27 14:41:59	ModbusMaster.client10081.Port1.ConnectionAlarm	ModbusMaster.client10081.Port1.ConnectionAlarm	Connection alarm	Off	Off	-1	-1		
General	2026-07-27 09:29:44	Bank13.Stream02.MeterA.PVT.MC.CalcAlarm	Bank13.Stream02.MeterA.PVT.MC.CalcAlarm	PVT calculation status	Off	Normal	-1	-1		
General	2026-07-27 01:09:50	Bank03.Stream01.MeterA.LoFlowAlarm	Bank03.Stream01.MeterA.LoFlowAlarm	Low flow alarm	On	On	5	1045		
General	2026-07-27 01:00:50	Bank03.Stream01.MeterA.Temp.DevAB	Bank03.Stream01.MeterA.Temp.DevAB	Temperature deviatation A-B	Off	Off	5	1292		
General	2026-07-26 21:00:36	Bank10.Stream01.MeterA.dPInlet.DevAB	Bank10.Stream01.MeterA.dPInlet.DevAB	Inlet DP deviation A-B	Off	Off	17	1293		
General	2026-07-26 20:59:36	Bank10.Stream01.MeterA.TrDevHi	Bank10.Stream01.MeterA.TrDevHi	Transmitter deviation high	Off	On	17	1047		
General	2026-07-26 20:51:26	Bank13.Stream01.MeterA.TrDevHi	Bank13.Stream01.MeterA.TrDevHi	Transmitter deviation high	Off	On	20	1047		
General	2026-07-26 20:38:59	Bank15.Stream02.MeterA.ElectrVoltLow	Bank15.Stream02.MeterA.ElectrVoltLow	Electronics voltage low	Off	On	25	1035		
General	2026-07-26 20:13:06	Bank10.Stream01.MeterA.LodPAlarm	Bank10.Stream01.MeterA.LodPAlarm	Low DP alarm	Off	On	17	1043		
General	2026-07-26 20:06:51	Bank10.Stream01.MeterA.LoFlowAlarm	Bank10.Stream01.MeterA.LoFlowAlarm	Low flow alarm	Off	On	17	1045		
General	2026-07-26 11:35:09	Bank05.Stream03.MeterA.LoFlowAlarm	Bank05.Stream03.MeterA.LoFlowAlarm	Low flow alarm	On	On	11	1045		
General	2026-07-26 11:14:27	Bank19.Stream01.MeterA.Vx.DP.DevAB	Bank19.Stream01.MeterA.Vx.DP.DevAB	DP deviation	Off	Off	30	1225		
General	2026-07-23 10:33:30	Bank13.Stream02.MeterA.LodPAlarm	Bank13.Stream02.MeterA.LodPAlarm	Low DP alarm	On	On	21	1043		
General	2026-07-23 10:30:15	Bank13.Stream02.MeterA.LoFlowAlarm	Bank13.Stream02.MeterA.LoFlowAlarm	Low flow alarm	On	On	21	1045		
General	2026-07-21 20:57:09	Bank03.Stream02.MeterA.PVT.CalcAlarm	Bank03.Stream02.MeterA.PVT.CalcAlarm	PVT calculation status	On	Failed	-1	-1		
General	2026-07-19 18:24:24	Bank08.Stream02.MeterA.PVT.MC.CalcAlarm	Bank08.Stream02.MeterA.PVT.MC.CalcAlarm	PVT calculation status	On	Failed	-1	-1		
General	2026-07-18 23:58:24	Bank13.Stream02.MeterA.dPInlet.DevAB	Bank13.Stream02.MeterA.dPInlet.DevAB	Inlet DP deviation A-B	On	High	21	1293		
General	2026-07-18 21:57:24	Bank13.Stream02.MeterA.TrDevHi	Bank13.Stream02.MeterA.TrDevHi	Transmitter deviation high	On	On	21	1047		
General	2026-07-14 10:44:47	Bank05.Stream02.MeterA.LoFlowAlarm	Bank05.Stream02.MeterA.LoFlowAlarm	Low flow alarm	On	On	10	1045		
General	2026-07-05 11:57:54	Bank08.Stream01.MeterA.LoFlowAlarm	Bank08.Stream01.MeterA.LoFlowAlarm	Low flow alarm	On	On	13	1045		
General	2026-07-05 11:56:09	Bank08.Stream01.MeterA.TrDevHi	Bank08.Stream01.MeterA.TrDevHi	Transmitter deviation high	On	On	13	1047		
General	2026-06-29 16:30:42	Bank03.Stream01.MeterA.dPInlet.DevAB	Bank03.Stream01.MeterA.dPInlet.DevAB	Inlet DP deviation A-B	On	High	5	1293		
General	2026-03-25 07:47:58	Bank13.Stream02.MeterA.PVT.UnstableFlowRate	Bank13.Stream02.MeterA.PVT.UnstableFlowRate	PVT unstable flow rate	On	On	-1	-1		
General	2026-03-01 00:02:27	Bank08.Stream02.MeterA.PVT.UnstableFlowRate	Bank08.Stream02.MeterA.PVT.UnstableFlowRate	PVT unstable flow rate	On	On	-1	-1		
Critical	2026-01-29 10:26:55	Bank05.Stream01.MeterA.CommunicationStatus	Bank05.Stream01.MeterA.CommunicationStatus	Communication status	On	Failed	9	50		
General	2026-01-29 10:25:57	Bank03.Stream01.MeterA.TrDevHi	Bank03.Stream01.MeterA.TrDevHi	Transmitter deviation high	On	On	5	1047		
Critical	2026-01-29 10:25:24	Bank21.Stream04.MeterA.CommunicationStatus	Bank21.Stream04.MeterA.CommunicationStatus	Communication status	On	Failed	38	50		
Critical	2026-01-29 10:25:18	Bank21.Stream03.MeterA.CommunicationStatus	Bank21.Stream03.MeterA.CommunicationStatus	Communication status	On	Failed	37	50		
Critical	2026-01-29 10:25:12	Bank21.Stream02.MeterA.CommunicationStatus	Bank21.Stream02.MeterA.CommunicationStatus	Communication status	On	Failed	36	50		
Critical	2026-01-29 10:25:12	Bank19.Stream04.MeterA.CommunicationStatus	Bank19.Stream04.MeterA.CommunicationStatus	Communication status	On	Failed	33	50		
Critical	2026-01-29 10:25:06	Bank19.Stream03.MeterA.CommunicationStatus	Bank19.Stream03.MeterA.CommunicationStatus	Communication status	On	Failed	32	50		
Critical	2026-01-29 10:25:05	Bank21.Stream01.MeterA.CommunicationStatus	Bank21.Stream01.MeterA.CommunicationStatus	Communication status	On	Failed	35	50		
Critical	2026-01-29 10:24:34	Bank15.Stream04.MeterA.CommunicationStatus	Bank15.Stream04.MeterA.CommunicationStatus	Communication status	On	Failed	27	50		
Critical	2026-01-29 10:24:28	Bank15.Stream03.MeterA.CommunicationStatus	Bank15.Stream03.MeterA.CommunicationStatus	Communication status	On	Failed	26	50		
Critical	2026-01-29 10:24:17	Bank15.Stream01.MeterA.CommunicationStatus	Bank15.Stream01.MeterA.CommunicationStatus	Communication status	On	Failed	24	50		
Critical	2026-01-29 10:23:42	Bank10.Stream03.MeterA.CommunicationStatus	Bank10.Stream03.MeterA.CommunicationStatus	Communication status	On	Failed	19	50		
Critical	2026-01-29 10:23:19	Bank10.Stream02.MeterA.CommunicationStatus	Bank10.Stream02.MeterA.CommunicationStatus	Communication status	On	Failed	18	50		
Critical	2026-01-29 10:22:37	Bank05.Stream04.MeterA.CommunicationStatus	Bank05.Stream04.MeterA.CommunicationStatus	Communication status	On	Failed	12	50		
General	2026-01-22 10:56:36	Bank03.Stream01.MeterA.PVT.MC.CalcAlarm	Bank03.Stream01.MeterA.PVT.MC.CalcAlarm	PVT calculation status	On	Failed	-1	-1		