

---

May 15,2023

From: Alex Granados

This report is a follow up to the safety inspection completed on May 15,2023. The purpose of the inspection was to identify potential safety hazards and/or OSHA violations. Attached is a list of observations and recommendations based on the conditions present at the time of my visit. Please review the report and verify that all potential hazards are corrected. If you have any questions or require additional information after reviewing this report, please don't hesitate to contact me.

Sincerely,

Alex Granados  
LF Jennings, Inc.  
Safety Department  
(703) 929-1626  
[alex.granados@lfjennings.net](mailto:alex.granados@lfjennings.net)



---

**May 15,2023**

**WESTWOOD SHOPPING CENTER**

Reported by: Alex Granados

On-site Supervisor: Chris Spinks

---

**observation**

None

The mid-rail needs to be re-installed



**observation**

None

Excavations need to be protected with fences, they were unprotected, 3 holes deep enough for a person to fall in, i asked Stanley and Alvaro to correct it and they did.



**observation**

None


These rails need to be re-installed, please make sure this gets done ASAP



**observation**

None

Need to install a hard barrier like fences and or guardrails, caution tape is not enough



## observation

### Concrete

Form pins need to be pulled out or install rebar caps



## observation

None

The operator was told to use water to minimized the silica dust, that is not an option anymore, water has to be used.





<b>observation</b>
None
<b>observation</b>
None
<b>observation</b>
None
<b>observation</b>
None
<b>observation</b>
Concrete
<b>observation</b>
None