
May 16,2023

From: Angel Cruz

This report is a follow up to the safety inspection completed on May 16,2023. The purpose of the inspection was to identify potential safety hazards and/or OSHA violations. Attached is a list of observations and recommendations based on the conditions present at the time of my visit. Please review the report and verify that all potential hazards are corrected. If you have any questions or require additional information after reviewing this report, please don't hesitate to contact me.

Sincerely,

Angel Cruz
LF Jennings, Inc.
Safety Department
(571) 389-4558
angel.cruz@lfjennings.net



May 16,2023

Heits Church

Reported by: Angel Cruz

On-site Supervisor: Joe Hansen

observation

We found a fire extinguisher with a bad date on it. Needs to be replace.

None



observation

Drywall guy working on the scissors lift with out the safety chain. Also he was not wearing safety glasses while working with the drill. He was told about it and corrected.

None



observation
We found a fire extinguisher with a bad date on it. Needs to be replace.
observation
Drywall guy working on the scissors lift with out the safety chain. Also he was not wearing safety glasses while working with the drill. He was told about it and corrected.