A Max Fordham Project

A description of the document that is important

MAX FORDHAM

LONDON OFFICE
T. +44 (0) 20 7267 5161

project	client	document description
A Max Fordham Project: Rotunda Refurbishment part 1 million	Max Fordham LLP Partnership	A description of a Max Fordham Project can split lines but no more than two

revision	status code	status description
C01	A4	Contractor design, procurement & coordination

project number	director	issue date	project - originator - volume - level - type - role - number
J4321	OH	02/01/2020	06667 - MXF - XX - XX - SH - M - 20003

Max Fordham LLP

maxfordham.com
Max Fordham LLP is a Limited Liability Partnership.

Registered in England and Wales
Number OC300026.

Registered office:
42–43 Gloucester Crescent
London NW1 7PE

Issue History

date	rev	status	description	issue notes
06 OCT 23	C01	S4	Suitable for Stage Approval	
28 JUL 23	1	S1	Suitable for Coordination	

Contributions

name	role
BM	Project Engineer

Notes

1.	this is a long important note about the schedule

Table of Contents

Plantroom

[TOC] Plantroom - SL_90_90

Mark	Uniclass System Code	Natural Ventilation	Mechanical Ventilation	Mechanical Ventilation Rate	Equipment List	Fire Compar-mentation	Description	Notes	Floor Loading	Clear Internal Length	Clear Internal Width	Clear Internal Height
SPC-1-1_M	Ss_60_40_37	No	Yes	4	LTHW pumping circuits and buffer vessels	TBC	Heating Plantroom		1000 *kg/m2*	4000 *mm*	4000 *mm*	2500 *mm*
SPC-1-2_M	Ss_60_40_17	No	Yes	4	CHW pumping circuits and buffer vessels	TBC	Cooling Plantroom		1000 *kg/m2*	4000 *mm*	4000 *mm*	2500 *mm*
SPC-1-3_M	Ss_65_40	No	Yes	4	Separate AHUs for residential and commercial ventilation systems	TBC	Ventilation Plantroom		1000 *kg/m2*	4000 *mm*	4000 *mm*	2500 *mm*
SPC-1-4_M	Ss_65_40	No	Yes	4		TBC	Borehole/ Ground Source Plantroom		1000 *kg/m2*	4000 *mm*	4000 *mm*	2500 *mm*
SPC-1-5_M	Ss_65_40	No	No		Separate AHUs for residential and commercial ventilation systems	TBC	External Ventilation Plant Deck	Surrounded by acoustic enclosure.	1000 *kg/m2*	4000 *mm*	4000 *mm*	2500 *mm*
SPC-2-1_E	Ss_70	No	Yes	4	Generator	TBC	Generator Plantroom		1000 *kg/m2*	4000 *mm*	4000 *mm*	2500 *mm*
SPC-2-2_E	Ss_70	No	Yes	4		TBC	DNO Substation		1000 *kg/m2*	4000 *mm*	4000 *mm*	2500 *mm*
SPC-2-3_E	Ss_70	No	Yes	4		TBC	Primary LV Switchroom		1000 *kg/m2*	4000 *mm*	4000 *mm*	2500 *mm*
SPC-2-4_E	Ss_70	No	Yes	4		TBC	Secondary LV Switchroom		1000 *kg/m2*	4000 *mm*	4000 *mm*	2500 *mm*
SPC-2-5_E	Ss_75_10	No	Yes	4		TBC	Main Comms/Server Room		1000 *kg/m2*	4000 *mm*	4000 *mm*	2500 *mm*
SPC-3-1_P	Ss_55_70_38_15	No	Yes	4		TBC	Cold Water Intake Room		1000 *kg/m2*	4000 *mm*	4000 *mm*	2500 *mm*
SPC-3-2_P	Ss_55_30_98_85	No	Yes	4		TBC	Sprinkler Plantroom		1000 *kg/m2*	4000 *mm*	4000 *mm*	2500 *mm*
SPC-3-3_P	Ss_55_70_38	No	Yes	4	Hot water storage cylinders, pumps	TBC	Domestic Hot Water Plantroom		1000 *kg/m2*	4000 *mm*	4000 *mm*	2500 *mm*
SPC-3-4_P	Ss_55_20_34	Yes	No		Gas meters	TBC	Gas Intake Metering Room		1000 *kg/m2*	4000 *mm*	4000 *mm*	2500 *mm*