MAX FORDHAM

In House App Testing

Document Description

Suitable for information

2020-01-02

06667-MXF-XX-XX-SH-M-20003

project			document description
A Max Fordham Project			**A description of the document that is important**
job number	project leader	issue date	
J4321	**OH**	**20/10/2023**	
status code	revision	status description	project - originator - volume - level - type - role - number
S2	**P01**	**Suitable for information**	**06667 - MXF - XX - XX - SH - M - 20003**

Max Fordham LLP

maxfordham.com
Max Fordham LLP is a Limited Liability Partnership.

Registered in England and Wales
Number OC300026.

Registered office:
42–43 Gloucester Crescent
London NW1 7PE

Issue History

date	rev	status	description	issue notes
06 OCT 23	C01	S4	Suitable for Stage Approval	
28 JUL 23	1	S1	Suitable for Coordination	

Contributions

name	role
BM	Project Engineer

Notes

1. this is a long important note about the schedule

Table of contents

DX-O-1 - Fan Coil Units

A fan coil unit



Another fan coil unit

Fan coil unit again!

Identity Data	
Abbreviation	DX-O
Type Reference	1
Uniclass Product Code	Pr_70_65_03_29
Uniclass Product Description	Fan coil units

Dimensional Data	
Overall Length	285.0 *mm*
Overall Width	765.0 *mm*
Overall Height	550.0 *mm*
Gross Weight	32.0 *kg*

Performance Data	
Cooling Output	3400.0 *W*

Application Data	
Notes	R32 refrigerant
Application	Single Split DX outdoor unit, serving DX-I-2

Electrical Data	
Voltage	230.0 *V*
Frequency	50.0 *Hz*