


A description of the document that is important



project

A Max Fordham Project

job number project leader issue date

J4321 OH 20/10/2023

status code revision status description

S2 P01 Suitable for information

document description

A description of the document that is important

project - originator - volume - level - type - role - number

06667 - MXF - XX - XX - SH - M - 20003

Issue History

Max Fordham LLP

maxfordham.com Max Fordham LLP is a Limited Liability Partnership.

Registered in England and Wales Number OC300026.

Registered office:
42–43 Gloucester Crescent
London NW1 7PE
This report is for the private and
confidential use of the clients for
whom the report is undertaken and
should not be reproduced in whole or
in part or relied upon by third parties
for any use whatsoever without the
express written authority of Max
Fordham LLP

© Max Fordham LLP

date	rev	status	description	issue notes
06 OCT 23	C01	S4	Suitable for Stage Approval	
28 JUL 23	1	S1	Suitable for Coordination	

Contributions

name	role
ВМ	Project Engineer

Notes

1. this is a long important note about the schedule


Table of Contents

Document Information	. 2
Issue History	. 2
Contributions	. 2
Notes	. 2
DX-O-1 - Fan Coil Units	. 4

DX-O-1 - Fan Coil Units

[TOC] Fan Coil Units - Pr_70_65_03_29







(a) Another fan coil unit



(a) Fan coil unit again!

Identity Data		
Abbreviation	DX-O	
Type Reference	1	
Uniclass Product Code	Pr_70_65_03_29	
Uniclass Product Description	Fan coil units	
Dimensional Data		
Overall Length	285.0 mm	
Overall Width	765.0 mm	
Overall Height	550.0 mm	
Gross Weight	32.0 kg	
Performance Data		
Cooling Output	3400.0 W	
Application Data		
Notes	R32 refrigerant	
Application	Single Split DX outdoor unit, serving DX-I-2	
Electrical Data		
Voltage	230.0 V	
Frequency	50.0 Hz	