# **A Max Fordham Project**

A description of the document that is important



project

A Max Fordham Project

job number project leade

J4321 OH

status code revision

S2 P01

project leader issue date

OH 20/10/2023

Suitable for information

document description

A description of the document that is important

project - originator - volume - level - type - role - number

06667 - MXF - XX - XX - SH - M - 20003

#### **Issue History**

#### Max Fordham LLP

maxfordham.com Max Fordham LLP is a Limited Liability Partnership.

Registered in England and Wales Number OC300026.

Registered office:
42–43 Gloucester Crescent
London NW1 7PE
This report is for the private and
confidential use of the clients for
whom the report is undertaken and
should not be reproduced in whole or
in part or relied upon by third parties
for any use whatsoever without the
express written authority of Max
Fordham LLP

© Max Fordham LLP

date	rev	status	description	issue notes
06 OCT 23	C01	S4	Suitable for Stage Approval	
28 JUL 23	1	S1	Suitable for Coordination	

#### **Contributions**

name	role	
BM	Project Engineer	

#### **Notes**

1. this is a long important note about the schedule



## **Table of Contents**

Document Information	. 2
Issue History	. 2
Contributions	. 2
Notes	. 2
DX-O-1 - Fan Coil Units	. 4



### **DX-O-1 - Fan Coil Units**

[TOC] Fan Coil Units - Pr\_70\_65\_03\_29

Identity Data			
Abbreviation	DX-O		
Type Reference	1		
Uniclass Product Code	Pr_70_65_03_29		
Uniclass Product Description	Fan coil units		
Dimensional Data			
Overall Length	285.0 mm		
Overall Width	765.0 mm		
Overall Height	550.0 mm		
Gross Weight	32.0 kg		
Performance Data			
Cooling Output	3400.0 W		
Application Data			
Notes	R32 refrigerant		
Application	Single Split DX outdoor unit, serving DX-I-2		
Electrical Data			
Voltage	230.0 V		
Frequency	50.0 Hz		