



Nombre o razon social del cliente: CORPORACION CULTURAL MUNICIPAL LOS ANGELES		RUT: 65.073.885-3				
Dirección		Comuna	Teléfono	Nombre persona de contacto de la empresa	Fecha de prestación de Servicio	Orden de Trabajo
LAUTARO 443		LOS ANGELES	56432218821	FELIPE ARRIAGADA	20-05-2025	1316747-30-AG25

Razón del mantenimiento: Según programa X				Por inspección		Acción Correctiva		Elementos de Protección Personal utilizados										Calzado de Seguridad	X	Casco	X	Antiparras	X	Audifonos/Tapones	X	Chaqueta reflectante	X	Bloqueador	X
N°	AGENTE / %	N° PRECINTO SEGURIDAD	Ubicación	N° Sello INCEN	N° Sello INCEN STE	N° Certificado	Exterior del Cilindro	Última PH	Estado PH	Fecha Vencimiento PH	Válvula	Manmetro o	Manguera	Cintillo y/o Soporte	Agente Extintor	Tubo Sifón	Sellos/Segu ro	Dispositi vo de Se guridad	Rotulación	Fecha Mantenimiento anterior	Recarga	Mantenion	Presión de Trabajo	Bono Kg					
1	PQS 75%	9757	CENTRO CULTURAL	S/I	S/I	4672099	OK	sept-15	OK	sept-27	OK	OK	OK	OK	OK	OK	OK	OK	OK	oct-23	OK	OK	150 PSI	6					
2	PQS 75%	9758	CENTRO CULTURAL	S/I	S/I	4672095	OK	sept-15	OK	sept-27	OK	OK	OK	OK	OK	OK	OK	OK	OK	oct-23	OK	OK	150 PSI	6					
3	PQS 75%	9759	CENTRO CULTURAL	S/I	S/I	4672097	OK	sept-15	OK	sept-27	OK	OK	OK	OK	OK	OK	OK	OK	OK	oct-23	OK	OK	150 PSI	6					
4	PQS 75%	9760	CENTRO CULTURAL	S/I	S/I	4672090	OK	sept-15	OK	sept-27	OK	OK	OK	OK	OK	OK	OK	OK	OK	oct-23	OK	OK	150 PSI	6					
5	PQS 75%	9761	CENTRO CULTURAL	S/I	S/I	5134340	OK	nov-16	OK	nov-28	OK	OK	OK	OK	OK	OK	OK	OK	OK	jun-20	OK	OK	150 PSI	6					
6	PQS 75%	9762	CENTRO CULTURAL	S/I	S/I	S/I	OK	sept-14	OK	sept-26	OK	OK	OK	OK	OK	OK	OK	OK	OK	oct-23	OK	OK	150 PSI	4					
7	PQS 75%	9763	CENTRO CULTURAL	S/I	S/I	4685129	OK	may-15	OK	may-27	OK	OK	OK	OK	OK	OK	OK	OK	OK	oct-23	OK	OK	150 PSI	10					
8	PQS 75%	9764	CENTRO CULTURAL	S/I	S/I	5134306	OK	nov-16	OK	nov-28	OK	OK	OK	OK	OK	OK	OK	OK	OK	oct-23	OK	OK	150 PSI	6					
9	PQS 90%	9765	CENTRO CULTURAL	S/I	S/I	4672102	OK	sept-15	OK	sept-27	OK	OK	OK	OK	OK	OK	OK	OK	OK	oct-23	OK	OK	150 PSI	6					
10	PQS 90%	9766	CENTRO CULTURAL	S/I	S/I	5134355	OK	nov-16	OK	nov-28	OK	OK	OK	OK	OK	OK	OK	OK	OK	oct-23	OK	OK	150 PSI	6					
11	CO2	9767	CENTRO CULTURAL	S/I	S/I	8843207	OK	mar-22	OK	mar-27	OK	OK	OK	OK	OK	OK	OK	OK	OK	oct-23	OK	OK	250 BAR	5					
12	CO2	9768	CENTRO CULTURAL	S/I	S/I	8843196	OK	mar-22	OK	mar-27	OK	OK	OK	OK	OK	OK	OK	OK	OK	oct-23	OK	OK	250 BAR	5					
13	CO2	9769	CENTRO CULTURAL	S/I	S/I	1102803	OK	nov-06	VENTOSA	nov-13	OK	OK	OK	OK	OK	OK	OK	OK	OK	oct-23	OK	OK	150 BAR	4					
14	CO2	9770	CENTRO CULTURAL	S/I	S/I	1102807	OK	nov-06	VENTOSA	nov-13	OK	OK	OK	OK	OK	OK	OK	OK	OK	oct-23	OK	OK	150 BAR	4					

Realizado por técnico: Rodolfo Recabarren Alarcón


EXTINTORES REAL E.I.R.L.
77.734.909-0

Representante Legal
EXTINTORES REAL E.I.R.L.

Cliente Recibe Conforme

