




CHAIR FOR ELECTRICAL ENERGY SYSTEMS
Chairman: Univ.-Prof. Dr.-Ing. Matthias Luther
Univ.-Prof. Dr.-Ing. Johann Jäger

Master Thesis M347
Modeling of Fast-Switching Transformers
for Voltage Stability Studies in Python

Author: Maximilian Markus Veit Köhler, B.Eng.
23176975

Supervisor: Ilya Burlakin, M.Sc.
Georg Kordowich, M.Sc.

Date of submission: May 2, 2025



Preface

This thesis marks the closing of another exiting chapter in my learning path so far. It hasn't been straight, and I like it that way. At first with the vision to become an engineer building cars, the beginning enthusiasm for informatics over a lot of practical experience at my first employer. Rescuing me in a energy storage topic for my bachelors thesis, gaining more interest, and the idea to pursue a masters course in energy systems. A lot of persons mentoring me, giving me impulses in every directions, I have to thank at least all of them! At FAU I was starting over at a completely different level of knowledge and abilities, but I was glad meeting a lot of fellow students helping me. I have to thank them all for studying with me, enjoying lunch in the mensa or just going out!

When looking into the electrical energy systems side first, I was overwhelmed. So I started with a student research paper, which was also the base for this thesis and everything that is currently ongoing and will happen in the future. At this point I have to be very grateful for my supervisors Ilya and Georg. Always being patient, triggering the right discussions for me, and don't mind explaining some more or less obvious things. Thank you for your supervision, it was a great time and I hope we can work on things in the future!

The past half year was quite demanding, but one of the steepest learning curves I ever had. Many thanks to the colleagues at Siemens FT, which help me gain a lot of momentum, and enjoying the way they work there! As well I have to thank Gregor Becker a lot for discussing with me so many times about ideas, ways to look at problems or even lending a pair of eyes in troubleshooting. Thank you as well for proofreading this thesis.

- Maximilian Köhler -

Abstract

In this thesis, a new control concept for transformer tap changers is investigated, which takes into account an increase in dynamic capabilities by shortening the switching times. This reduction is realized by a Fast Switching Module (FSM), which is based on power electronics and extending the classical On-Load Tap Changer (OLTC), resulting in a hybrid solution. A transformer model with variable transformation ratio and the associated control scheme for a tap changer are modeled in an existing Python package for electrical power grid simulation. The implemented extensions are evaluated and compared with results of the commercial grid simulation software DIgSILENT PowerFactory. In addition, tools for the evaluation of simulation scenarios are implemented. The toolset includes the calculation of P-V Curves and a Trajectory Violation Integral (TVI). The effects of the various controls on voltage stability are tested as part of an application study. In addition, improvements to the controls are derived and outlined. The implemented models are validated using commercial software. The results show a stabilization of the bus voltages through the application of the FSM. The study illustrates a feedback of the fast tap-changing to the power and speed fluctuations of a synchronous machine. In addition, a voltage band can be identified in which one of the controllers shows no reaction. As future outlook, the discussed control improvements can be realized. Further, an investigation a FSM applied to a phase shifting transformer seems useful.

Kurzfassung

In dieser Arbeit wird ein neuartiges Regelungskonzept für Stufenschalter für Leistungstransformatoren untersucht, welches eine Erhöhung der dynamischen Fähigkeiten durch eine Verkürzung der Schaltzeiten berücksichtigt. Diese Verkürzung wird durch ein Fast Switching Module (FSM) realisiert, das auf einem leistungselektronischen Komponenten basiert, den klassischen On-Load Tap Changer (OLTC) erweitert und damit zu einer hybriden Lösung macht. Ein Transformatormodell mit variablem Übersetzungsverhältnis und das zugehörige Regelungsschema für einen Stufenschalter werden in einem bestehenden Python Paket zur elektrischen Energienetzsimulation modelliert. Die implementierten Erweiterungen werden evaluiert und mit Ergebnissen der kommerziellen Netzsimulationssoftware DIgSILENT PowerFactory verglichen. Zusätzlich werden Werkzeuge für die Auswertung von Simulationsszenarien implementiert. Das Toolset beinhaltet die Berechnung von P-V Kurven und eines Trajectory Violation Integral (TVI). Im Rahmen einer Anwendungsstudie werden die Auswirkungen der verschiedenen Regelungen auf die Spannungsstabilität getestet. Zusätzlich werden Verbesserungen an den Regelungen abgeleitet und skizziert. Die implementierten Modelle werden mit Hilfe der kommerziellen Software validiert. Die Ergebnisse zeigen eine Stabilisierung der Busspannungen durch die Applikation des FSMs. Die Studie kann eine Rückkopplung der schnellen Stufenschaltung auf die Leistungs- und Drehzahlschwankungen einer Synchronmaschine zeigen. Außerdem kann ein Spannungsband identifiziert werden, in der einer der Regler keine Reaktion zeigt. Als Ausblick kann die Umsetzung der diskutierten Änderungen und Verbesserungen auf das Regelschema angemerkt werden. Des Weiteren eröffnet eine Untersuchung der Applikation auf einen Phasenschiebertransformator weitere Möglichkeiten.

I confirm that I have written this master thesis unaided and without using sources other than those listed and that this thesis has never been submitted to another examination authority and accepted as part of an examination achievement, neither in this form nor in a similar form. All content that was taken from a third party either verbatim or in substance has been acknowledged as such.

Erlangen, 02nd May 2025

Sign

Contents

1	Revitalization of the OLTC	1
1.1	Research Interests	2
1.2	Readers Guide	3
2	Fundamentals	5
2.1	Voltage Stability Basics	5
2.1.1	Analytical Stability Limits of Simple Static Power Systems	7
2.1.2	Evaluation of Time Series Calculation	10
2.2	Power System Modeling	12
2.2.1	Transformer Electric Model and Behavior	12
2.2.2	Further Considerations of a Transformer Model	16
2.2.3	Use of Power System Simulation Tools	17
2.3	On-Load Tap Changer Controls	17
2.3.1	Commonly Used On-Load Tap Changer Control	18
2.3.2	Advancement: Fast Switching Module and its Control	18
2.4	Summary in Short and Simple Terms	21
3	Methodical Modeling	22
3.1	Transformer Equipment Modeling	22
3.1.1	Software Architecture Design	22
3.1.2	Implementing a II-Representative Circuit with Variable Ratio	24
3.1.3	Tap Changer Control Modeling	27
3.2	Application of Voltage Stability	33
3.2.1	Generation of Nose Curves	33
3.2.2	Combination of Static Methods with Time Domain Solutions	37
3.2.3	Using Voltage Envelopes for Criticality Evaluation	37
3.3	Summary in Short and Simple Terms	39
4	Validation Setup and Results	40
4.1	Representative Electrical Networks	40
4.2	Validation Steps	42
4.2.1	Validation of the Modeled Transformer with Variable Tap Position	43
4.2.2	Parenthesis: Accountability of the Load Model	46
4.2.3	Validation of the OLTC Control Schemes	47
4.2.4	Validation of the FSM Control Scheme	50
4.2.5	Voltage Stability Rating Plausibility	56

4.3	Model Limitations and Improvements	61
4.4	Summary in Short and Simple Terms	62
5	Application Study	63
5.1	Voltage Stability after a Short-Circuit Fault	63
5.2	Interaction with Machines without Control	67
5.3	Summary in Short and Simple Terms	70
6	Discussion of the Results	71
6.1	Integration in diffpssi	71
6.2	Evaluation Current FSM Control	73
6.3	Development Potential of the FSM and its Control	75
7	Summary and Outlook	79
	Acronyms	XI
	Symbols	XI
	List of Figures	XIII
	List of Tables	XV
	Bibliography	XVI
	Appendix	A-1

1 Revitalization of the OLTC

As first inventions regarding induction and induction coils were published in the early 19th century, nobody knew the impact these ideas could have. The first developments and rivalry between power system grids, Direct Current (DC) vs. Alternating Current (AC), was tending towards the latter side. The use and spread of an AC power system was enlarged by the transformer, making the utilization of multiple different voltage levels seamless. Long transmission lines were now facilitated through reducing losses under higher voltages. [1], [2]

This operational unit is still in heavy use today. Later developments like the On-Load Tap Changer (OLTC) enabled a variation in the transformer ratio under load, and therefore controlling load flows, compensate variations in voltage levels, or compensate currents in meshed grids [3]. Now, with the restructuring of centralized power grids with large shares of synchronous machines, towards decentralized, smaller, and inverted-based electrical power generation, the transformer could be labelled outdated. But the developments and ideas are ongoing like the invention of Maschinenfabrik Reinhausen GmbH [4].

Considering a combination of reliable and proven mechanical OLTC transformers, with the dynamic capabilities of power electronics, their invention targets the supportive handling of the faster dynamics of wind and solar generators, as well as flexible prosumers. The added Fast Switching Module (FSM) could help these units staying resilient to disturbances for a longer time, and therefore the grid to remain in a stable operational window.

1.1 Research Interests

A novel control method for this FSM was developed by Burlakin, Scheiner, Mehlmann, *et al.* [5]. The transformer is connecting an off-shore wind farm with a sea cable to a Point of Common Coupling (PCC). Additionally, a Variable Shunt Controller (VSC) is connected via a FSM equipped transformer for compensation of the cable [6]. These control schemes are in the interest of this thesis, next to a developed power system simulation tool from the institute of electrical energy systems at the Friedrich-Alexander-Universität Erlangen-Nuremberg [7]. The tool is called *diffpssi*, based on Python and the package *PyTorch*, and with that allowing for model parameter optimizations.

The main idea is the extension of this power system simulation model with a capable variable ratio transformer. Additionally, a standard discrete OLTC controller is implemented, supplemented by the control scheme for the FSM. The capabilities of this improved FSM module and its new control shall be investigated and compared to the standard OLTC control. As the central application of tap changing transformers is voltage support and indirect voltage stability enhancement [8], [9], the comparisons are taken from this side. With this background, following main research question can be formulated for this thesis.

Research Question of this Thesis

How do different control types and characteristics of transformers with On-Load Tap Changers (OLTCs) influence the voltage stability of a given system?

Therefore following questions or steps can be imagined as supportive:

1. How can voltage stability of a system be classified and be viewed at? Which indices, measurements, etc.?
2. Which transformer model has to be considered for voltage stability studies?
3. Which systems are useful to consider when showing effects? Which circumstances lead to a stability support, and which to a decrease? Where can limits be drawn?

As secondary question regarding the evaluation of the already presented FSM control scheme by Burlakin, Scheiner, Mehlmann, *et al.* [5], an improvement is sought. It shall be more focused in the later part. Therefore the assessments in the chapter 5 are valuable as well.

Additional Question of this Thesis

Can the already existing tap changer control of the Fast Switching Module (FSM) be improved towards a more operation oriented control?

This question has following thoughts, concerning the different characteristics and dynamics of the FSM:

1. Can the FSM be used as a „damping element“ in the system?
2. Does this possible different behavior of the FSM lead to different operating strategies?
3. What are thoughts on realizing such a strategy with different approaches on the FSM controller?

1.2 Readers Guide

The above-stated research interests, in combination with the yet not sufficient framework to use, make demands on the structure of this work. Therefore, it seems not sufficient trying to apply a completely standard sequence of chapters like „Introduction - Fundamentals - Methods - Results - Discussion“. Instead, the following structure is chosen to fulfill the research interests and to give a clear and understandable overview of the work.

- **Chapter 2: Fundamentals,**
illustrates and recalls fundamentals for stability assessments, modeling, and discussions;
- **Chapter 3: Methodical Modeling,**
describes the process of modeling in the tool *diffpssi*, and the implementation of voltage stability tools;
- **Chapter 4: Validation Setup and Result,**
shows the validation of the implemented models and tools with the help of common and simple test systems;
- **Chapter 5: Application Study,**
looks at the novel control methods from different perspectives and evaluates with an exemplary simulation set-up;

- **Chapter 6: Discussion,**
discusses the FSM control strategies, considering the fundamentals, verification, and case study results;
- **Chapter 7: Summary,**
summarizes with regards to the research questions, and looking towards research potential and future developments.

When reading this thesis, one might consider its motivation and prior knowledge for allocating attention to the different chapters. For someone interested in the strategic development of the FSM or OLTCs in general, the introduction with its research interests in section 1.1 is most important. Combined with the Summary and Outlook in chapter 7, the contents of the thesis, answer the research questions and some perspectives are included. For this level basic knowledge of power system stability and the electrical energy grid is sufficient. When one is also interested in the background of the research questions, the chapter 6 is additionally recommended. Eventually, chapter 2 gives a few basics for an eased understanding of the discussion itself. The third level demonstrates practical applications in the application studies (chapter 5). Lastly, if one wants to further improve or develop the tool *diffpssi* or the control strategies in particular, chapter 3 and chapter 4 are recommended. Additionally the referenced literature is giving valuable insights and information.

2 Fundamentals

The chapter shall introduce the basics for implementing an OLTC equipped transformer into an existing power system simulation framework. This considers the existing surrounding, provides more details on the electric behavior of the transformer itself and some control engineering theory for the corresponding OLTC. Because its main goal is increasing voltage stability [10], an index and assessment methods are considered as well.

2.1 Voltage Stability Basics

A practical introduction to voltage stability assessment, methods and indices is given in the standard and extending literature of Danish [11] and Cutsem and Vournas [12]. Further, some useful definitions about voltage sagging and practices are mentioned by Shoup, Paserba, and Taylor [13], some other best practices, current standards, and development potential is presented by Rueda-Torres, Annakage, Vournas, *et al.* [14].

Shoup, Paserba, and Taylor [13] is citing and summarizing short and precise definitions of *voltage dips*, *voltage sags*, *power system stability*, *voltage stability* and *short-term voltage stability*. For voltage stability following summary is given [13]:

„Voltage stability refers to the ability of a power system to maintain steady voltages at all buses in the system after being subjected to a disturbance from a given initial operating condition. It depends on the ability to maintain/restore equilibrium between load demand and load supply from the power system. Instability that may result occurs in the form of a progressive fall or rise of voltages of some buses. A possible outcome of voltage instability is a loss of load in an area, or tripping of transmission lines and other elements by their protective systems leading to cascading outages. Loss of synchronism of some generators may result from these outages or from operation under field current limit.“

The other definitions are added to section A.1 of this thesis, as they are quickly summarizing and narrowing down this complex topic.

As illustrated, the general cause for voltage instability is the missing support or compensation due to a lack of reactive power reserves. These can either be driven by insufficient generation capacities, transmission capabilities through the grid, or a reactive power demand build up at the load side, e.g. through a stalling of an induction motor. Triggers for these mechanisms can be various. As an example, the study network called *Nordic Test System* and its collapse [15] illustrates a big bandwidth of possible actions and reactions. Different other, smaller examples are described in Table 2.1.

Table 2.1: Voltage instability types and different time frames with examples [11].

No.	Type	Cause of incident	Time frames
1	Long-term	Slowly use up of reactive reserves and no outage	Several minutes to several hours
2	Classical	Key outage leads to reactive power shortage	One to five minutes
3	Short-term	Induction motor stalling leads to reactive power shortage	Five to fifteen seconds

As mentioned in the introduction, OLTCs are used for controlling or manipulating the load flow, counteracting currents in meshed grids or restoring loads after dynamic events. The first mentioned are static optimization processes, as only the last is of dynamic nature. This thesis investigates a dynamic controller, therefore the dynamic use cases and mechanisms are relevant. Restoring a load is meaning the slow re-build of a voltage level to the previous or as reference set voltage. As most loads power is dependent on the voltage, this is not only crucial for staying in the operating voltage limits, but also being able to sufficiently supply the customer. The process is described by Cutsem and Vournas [12], chapter 4.4.3. However, a normal longitudinal tapping OLTC is not capable of actively supporting voltage instabilities with reactive power supply. It can only manipulate or vary operating points by alternating the active power. But it can contribute secondarily as it is keeping the voltage in the operational band, and thereby prohibit units from disconnecting. The gained time could be sufficient, until other units can provide supplementary reactive power, e.g. inverters.

An important comment has to be added towards the dynamic behaviors and the connected analysis strategy towards this. This thesis aims to partly enlighten the dynamic influence of OLTC control strategies on the dynamic behavior of one power system. According to many standard literature, it is quite complicate to simplify states or predict stable or unstable operation potins of a power system in terms of voltage behavior [10]. Simply the complex interaction between different units, their control schemes and charac-

teristics, and at least the characteristics of protectional devices, are too many influences. As this thesis is only considering a few aspects of the previous mentioned, only a relative comparison can be targeted. The use of one stability index for this analysis or predictions is highly unlikely. Therefore mixtures of possible illustrations, analysis techniques or similar are used, enabling a discussion about the thesis scope, transformers and their tap changer control schemes.

2.1.1 Analytical Stability Limits of Simple Static Power Systems

When looking at a simple power system, consistent of a load, source, and an inductance $\underline{Z} = jX$, analytically deriving the behavior of voltage over power is in its simplest form. The resulting curves show how the system behaves in (quasi-) stationary scenarios. Following a system like Figure 2.2 is used. All equations and analysis methods can be re-read in standard literature like Machowski, Lubosny, Bialek, *et al.* [10], Kundur and Malik [8], or Cutsem and Vournas [12].




Figure 2.1: Simple load source system for deriving voltage power behaviors; own illustration after [8]–[10].

When looking at the load flow equations, the transferable power over the system from the reference to the load bus can be represented by

$$\begin{aligned}
 S &= P + jQ = \underline{V} \cdot \underline{I}^* \\
 &= \underline{V} \cdot \frac{\underline{E}^* - \underline{V}^*}{-jX} \\
 &= \frac{j}{X}(EV \cos \delta + jEV \sin \delta - V^2).
 \end{aligned}$$

These equations can be split up into the transferable active power in Equation 2.1 and the transferable reactive power in Equation 2.2, which might be more common in knowledge and use.

$$P = -\frac{EV}{X} \cdot \sin \delta \quad (2.1)$$

$$Q = -\frac{V^2}{X} + \frac{EV}{X} \cdot \cos \delta \quad (2.2)$$

After elimination of phase angle δ^1 , a second order equation dependent on V^2 can be obtained. Simplifying the terms and rearranging is giving the following Equation 2.3.

$$-P^2 - \frac{E^2}{X}Q + \left(\frac{E^2}{2X}\right)^2 \geq 0 \quad (2.3)$$

$$P \leq \frac{E^2}{2X} \quad \text{for} \quad Q = 0 \quad (2.4)$$

$$Q \leq \frac{E^2}{4X} \quad \text{for} \quad P = 0 \quad (2.5)$$

The easy intuitively accessed functions, which can be kept in mind are Figure 2.1.1 and Equation 2.5. These represent the functions of the voltage dependence on the active power, when setting the reactive power to zero, and vice versa. This accounts for power factors of $\cos \phi = 0$ or respectively $\sin \phi = 0$, or translated to the angle itself $\phi = \{0^\circ; 90^\circ\}^2$. One note to take here, is that the power factor is not consistently used. For load flow calculations mostly the sine and cosine representation of the angle between current and voltage is used, for stability analysis, often the tangent function is preferred. A table and plot comparison of relations between the functions cos, sin, and tan are included in the appendix section A.2. This also leads to the dependency of $\tan \phi$ in the plotting of the so called Nose Curves, the solutions of Equation 2.3.

The typical nose shape is visible for a simple network, with only considering reactances X as attributes of the line or transmission grid and a reference value at the reference bus set to $\underline{E} = 1 \angle 0$ p.u. Directly visible, that no static solution can be found, when surpassing a certain level of active power. This maximum often is referred to as the power transfer limit of the grid or network and can be calculated through . Aside from that there are two solutions possible for all the other values of the power smaller than the maximum power transfer limit. On the other side when looking at the V-Q curve from Figure 2.2 b), the

¹due to the setpoint of the reference voltage.

²for all angles in the interval of $\phi = [0^\circ, 180^\circ]$.




Figure 2.2: Power Voltage Curves resulting from maximum power transfer equations; Considering a Network impedance of $\underline{Z} = jX$ with $X = 0.15$ p.u. and a system base power of $S_{\text{sys;base}} = 2\,200$ MVA; Note, that $\arctan(0) = \arccos(1)$; own illustration after [8], [10], [12].

first thing to notice is the inverted axis compared to the P-V curves. This is a common practice, as the voltage is the more independent variable here [8]. Secondly the shape and the resulting values are different. The Q-V curve can be understood as the reactive power support at the load bus. One can obtain from the curve, that the values above the zero line account for a capacitive reactive power support, which is limited with the relation of Equation 2.5. The part in the negative region is related to an inductive support, due to the inductive nature of the transmission grids there is also no analytical limit. Although the maximum possible voltage magnitude restricts this infinitely continuing behavior. But what one can easily see is the continuously increasing voltage in order to equalize the missing compensation [8]. When looking at the voltage of the maximum active power transfer, and reading the reactive power for that, one would see a positive, meaning capacitive reactive power support at the load bus. This would be described as the natural power of the line, when fully compensating the reactances and operating the line without any reactive power, meaning $Q = 0$ Mvar. These curves can be transferred in the three dimensional space, with the axis P-Q-V giving a full observation of static power voltage relations. These described P-V curves are further used and implemented in subsection 3.2.1, especially with consideration to influences of the OLTC.

2.1.2 Evaluation of Time Series Calculation

The idea behind stability indices is monitoring the current voltage stability state of the power system in relation to the critical points or operational limits. This applies not only to static load flow cases, but for time series calculations of short circuits, load shedding or other disturbances. Reviewing possible indices, either for online monitoring or for subsequent analysis after a simulation, is out of the scope of this thesis. For static analysis, often the Jacobian Matrix is used as basis. The Newton-Raphson algorithm for load flow analysis is based on this construct, as well as many indices. Voltage stability can be mathematically formulated, if the Jacobian Matrix is not singular. [10], [11], [16]

Using solely the singularity of the Jacobian Matrix for determination of a stable system is numerically hard to solve and usually very error-prone. This problem leads to the necessity of applying other methods or indices for stability assessment. Further, the relation of the system state to the critical voltage collapse point is highly nonlinear in the Jacobian Matrix. This problem is addressed by the indices in various ways, leading to a more or less linearized relation [10], [11]. Danish [11] is proposing indices, that are also based on the Jacobian Matrix, and shows comparative characteristics between Jacobian Matrix and system variable based voltage stability indices. The before mentioned work of Doig Cardet [16] is focussing on these indices in particular. This thesis is thus not considering these static assessment based indices, as the simulative nature allows for easier static evaluation with simple nose curves.

Considering the nose curve from Figure 2.2, one can see a static solution around the maximum power transfer, that is way below the initial voltage. Moreover, considering grid codes and their connection rules for generation units, this voltage is outside any Fault-Ride-Through (FRT) behavior, and thus neither a static reasonable operation point. Therefore, not only to comply with grid codes, but to avoid operational unit failures due to high currents or high voltages, this FRT behavior shall be used as an envelope. This allows for easy comparison, either if the scenario is exceeding this grid code envelopes seen as critical, but also to calculate the significance of this violation. Scheiner, Burlakin, Strunz, *et al.* [17] and Wildenhues, Rueda, and Erlich [18] propose an index called Trajectory Violation Integral (TVI). The index integrates the envelope violation over the simulation time. Although they are not using grid code specific FRT curves, but a more generalized representation of such an envelope, this idea shall be implemented and used in this thesis.

The mathematical background shall be introduced in the following. First, the envelopes are computed according to Equation 2.6 and Equation 2.7. The typical used values for this envelope are $v_{st} = 0.9$ and $\beta \in [0.05, 0.1]$ according to Wildenhues, Rueda, and Erlich [18]. If one wants to choose the FRT curves as envelopes, the technical connection guide lines describe these curves for different generation units connected to different voltage level grids [19], [20].

$$T_{\text{low}}(t) = \frac{\left(\frac{t}{t_{\text{end}}} \cdot \exp\left(\frac{t}{t_{\text{end}}}\right)\right)^\beta}{\exp(\beta)}, \quad \forall t \in [t_f, t_{\text{end}}] \quad (2.6)$$

$$T_{\text{upp}}(t) = 2 - T_{\text{low}}(t) \quad (2.7)$$

The integral is then calculated as the the area between the two curves exceeding the envelope. The voltage difference equates the voltage violation in Equation 2.8. This is achieved through the case dependent function in Equation 2.9.

$$\text{TVI} = \int_{t_f}^{t_{\text{end}}} v_v(t) dt \quad (2.8)$$

$$v_v(t) = \begin{cases} T_{\text{low}}(t) - v(t) & \text{if } v(t) < T_{\text{low}}(t) \\ v(t) - T_{\text{upp}}(t) & \text{if } v(t) > T_{\text{low}}(t) \\ 0 & \text{otherwise} \end{cases} \quad (2.9)$$

As this index is dependent on one voltage value, measurement is typically done at each bus. The TVI then is calculated for every bus. One can calculate the TVI for the total system according to Equation 2.10. It can be understood as the envelope violation magnitude multiplied by the time.

$$\text{TVI}_{\text{tot}} = \sum_{i \in N_{\text{busbars}}} \text{TVI}_i \quad (2.10)$$

$$\text{CSI} = \frac{1}{N_{\text{busbars}}} \sum_{i=1}^{N_{\text{busbars}}} \text{TVI}_i \quad (2.11)$$

On the other hand one can calculate the Contingency Severity Index (CSI) with help of the TVI as displayed in Equation 2.11. This index is not only giving an approach to normalize the TVI regarding to grid sizes through the total number of busbars N_{busbars} . With this index, short circuit scenarios and their dynamic affect on various grids can

be compared. On the other hand it could be used as an average and related to the bus individual TVIs. This allows for evaluation of the most affected bus(es) in the system.

2.2 Power System Modeling

The simulation of power systems is a crucial tool, not only for stability studies, but for evaluating extensions or modifications in the planning process, the development of assistance systems for operational management, and many other applications. Due to the complexity of the systems, simulations are often simplified. Not only with model constraints, but as well in the way of calculations. Mainly separating between Electromagnetic Transient (EMT) and Root Mean Square (RMS) simulations, the latter is used in this thesis.

2.2.1 Transformer Electric Model and Behavior

Typical for RMS-modeling is the usage of symmetrical components, especially the positive sequence for balanced grid operation and test cases. An equivalent circuit for the positive sequence is shown in Figure 2.3 a), respectively reduced to the transformer ratio, the series impedances of the windings on the LV side \underline{Z}_1 and HV side \underline{Z}_2 , and the shunt branch affected by iron and magnetization losses $\underline{Z}_{\text{Fe},\mu}$. [8]–[10]

The transformer ratio is typically noted as $\underline{\vartheta}$. Generally speaking it is the ratio between the number of windings of the secondary side to the primary side, as noted in Equation 2.12. With the typically used calculation domain per unit³, the ratio becomes one for a non-variable transformer or an OLTC in the neutral tap position. A transformer ratio, which is only shifting current angles with the shifting angle ϕ , is represented through a complex number using the Euler Identity, as shown in Equation 2.13.

$$\vartheta = \frac{N_2}{N_1} \tag{2.12}$$

$$\underline{\vartheta} = \frac{N_2}{N_1} \cdot \exp\left(j \cdot \phi \cdot \frac{\pi}{180}\right) \tag{2.13}$$

³means standardization to a reference value; further information on page XII and Machowski, Lubosny, Bialek, *et al.* [10], Appendix A.




Figure 2.3: Two-Winding Transformer Circuit in the Positive Sequence; a) ideal representation with impedances on the HV side and b) simplified circuit with only the series impedance related on the HV side; own figure after [8]–[10].

The first simplification step is considering two assumptions. First, the iron and magnetization losses are neglectable. This can be illustrated with a short-circuit test of the transformer on the secondary side. During this test, one can obtain with the concept of a voltage divider, that

$$\underline{U}_{\text{Fe},\mu} \ll \underline{U}_{\text{T,rated}},$$

meaning that the shunt branch impedance is much greater than the series impedance of the transformer. Secondly, an equal distribution of the transformer impedances on the primary and secondary side is assumed. This leads to a symmetrical circuit of the transformer and the positive sequence equivalent circuit simplifies to Figure 2.3 b). Mathematically this is shortly expressible as Equation 2.14 to Equation 2.16. [8]–[10]

$$\underline{Z}_2 = R_2 + jX_2; \quad \underline{Z}_1 = R_1\vartheta^2 + jX_1\vartheta^2 \quad (2.14)$$

$$\underline{Z}_1 = \underline{Z}_2 \quad (2.15)$$

$$\underline{Z}_{\text{T}} = \underline{Z}_1 + \underline{Z}_2 \quad (2.16)$$

The before described simplification leads to only the necessity of considering the series impedance. Considering $\vartheta = 1$ in the per unit system, the Python framework *diffpssi* has been using this model with only the series impedance and no variable ratio, meaning no shunt branches, before.

When one wants to look at variable transformer ratios, either with representing vector groups, or implementing On-Load Tap Changers (OLTCs), this model of only considering the series impedance has to be extended. Using shunt branches, the variable ratio behavior can be represented in a Π -model, as shown in Figure 2.4. [8]–[10]




Figure 2.4: Π -representative circuit of an idealized transformer with a tap changer; own figure after [5], [9].

Looking at the transformer as a black box two-port, with the index one being the Low Voltage (LV) side, the index two being the High Voltage (HV) side, the admittance matrix considering the variable ratio behavior can be expressed as in Equation 2.17. The voltages and currents are defined as in Figure 2.3 part b). With re-arranging the equation, one can obtain the admittance matrix of the Π -model with to the HV side related values as in Equation 2.18. [5], [9]

$$\begin{bmatrix} \underline{I}_1 \\ \vartheta^* \underline{I}_2 \end{bmatrix} = \begin{bmatrix} \underline{Y}_T & -\underline{Y}_T \\ -\underline{Y}_T & \underline{Y}_T \end{bmatrix} \cdot \begin{bmatrix} \underline{U}_1 \\ \frac{1}{\vartheta} \underline{U}_2 \end{bmatrix} \quad (2.17)$$

$$\underline{\mathbf{Y}}_{\Pi,T} = \underline{\mathbf{Y}}_T \cdot \begin{bmatrix} 1 & -\frac{1}{\vartheta} \\ -\frac{1}{\vartheta^*} & \frac{1}{\vartheta\vartheta^*} \end{bmatrix} \quad (2.18)$$

For calculation of the individual shunt branches, one can apply the standard representation of two-ports consistent of a linear Π -circuit:

$$\begin{bmatrix} \underline{I}_1 \\ \underline{I}_2 \end{bmatrix} = \begin{bmatrix} \underline{Y}_{10} + \underline{Y}_{12} & -\underline{Y}_{12} \\ -\underline{Y}_{21} & \underline{Y}_{20} + \underline{Y}_{21} \end{bmatrix} \cdot \begin{bmatrix} \underline{U}_1 \\ \underline{U}_2 \end{bmatrix}$$

When equating this with Equation 2.18, the shunt branches can be calculated respectively giving the admittances written down as Equation 2.19, Equation 2.20, and Equation 2.21, as they are noted in Figure 2.4 as well. [5], [9]

$$\underline{Y}_{12} = \frac{1}{\underline{v} \cdot \underline{a}_T} \cdot \underline{Y}_T, \text{ and}$$

$$\underline{Y}_{21} = \frac{1}{\underline{v} \cdot \underline{a}_T^*} \cdot \underline{Y}_T \quad (2.19)$$

$$\underline{Y}_{10} = \left(1 - \frac{1}{\underline{v} \cdot \underline{a}_T}\right) \cdot \underline{Y}_T \quad (2.20)$$

$$\underline{Y}_{20} = \frac{1}{\underline{v}} \cdot \left(\frac{1}{\underline{v}} - \frac{1}{\underline{a}_T}\right) \cdot \underline{Y}_T \quad (2.21)$$

Reactances and resistances are referred to the base voltage and apparent power of the operational unit, such as the transformer. The power system simulation uses an user-defined base voltage and base apparent power, enabling the use of one single calculation domain. This is done to simplify the calculation and to make the results easily comparable to each other. Hence, the referred values have to be transformed from the equipment based values to the simulation based values. The relation for the transformer admittance is defined as follows. Generally speaking, this thesis is using and referring to the per unit based values, although it is not denoted in the index of the values.

$$\underline{Y}_{T, \text{ based}} = \underline{Y}_T \cdot \frac{S_n}{S_{n, \text{ sim}}} \quad (2.22)$$

$$\underline{Z}_{\text{line, based}} = \underline{Z}_{\text{line}} \cdot \frac{S_{n, \text{ sim}}}{V_{n, \text{ sim}}^2} \quad (2.23)$$

Displayed like in Equation 2.22, the characteristic of the operational unit is referred to the simulation base value. Similar, the impedance of the lines are calculated via Equation 2.23. This specialities are considered in the tap changer modeling, thus further information is given by Machowski, Lubosny, Bialek, *et al.* [10], Appendix A. Additionally, Glover, Overbye, and Sarma [21] are giving some transformer specific calculations and examples in chapter 3.3.

2.2.2 Further Considerations of a Transformer Model

The following described (possible) characteristics of transformers shall not be considered in this thesis. They are mentioned in case differences towards other simulation tools occur, which might consider these. However, they could be also seen as possible extension of this thesis. Some of them could target the stabilization of voltage instable scenarios better, e.g. phase shifting transformers. All of the following is a synthesis of different standard literature, but esp. [3], [8], [10], [22].

The first consideration are so called vector groups. These represent an internal interconnection scheme and are thus resulting in a different magnetic coupling of the single phase windings. Under the consideration of different treatments as star, delta or mixtures of them, the ratio is not only phase shifted, but can as well be differing by the factor $\sqrt{3}$. Relevant for the modeling is only the resulting phase rotation, as the overall ratio is already defined. The relevant ratio is dependent on the grid, the suitable transformer is then chosen after that.




Figure 2.5: Illustration of the voltage vectors for different regulating transformers; after [3].

When looking at regulatable transformers, there are three main types, as depicted in Figure 2.5. In this thesis only the longitudinal controlled transformer type is relevant and modeled. It is only capable of varying the voltage magnitude. The remaining two are either just regulating and changing the phase angle, and therefore the imaginary part of the voltage, or a mixture of the both first described. Important to note on the behalf of voltage stability is, that the longitudinal controller cannot actively act as a reactive power source. It can only influence the voltage and thus hold the bus or branch longer in a certain defined voltage band.

2.2.3 Use of Power System Simulation Tools

For this thesis two Power System Simulation tools are relevant. The first and main objective, *diffpssi* is an open source project from Georg Kordowich, member of the chair hosting this thesis. This open source tool provides a RMS domain simulation of Power Systems, considering passive grid elements, but dynamic and controlled models of Synchronous Machines, Inverters or similar as well. The project and the integration of a full Synchronous Machine model is presented in the published paper of Kordowich and Jaeger [7]. The project is based on Python dependencies like numpy, but can as well use the Python module *PyTorch* as backend. *PyTorch* allows the differentiation of simulation variables. Optimizing grid and machine parameters are possible. Future extensions and usage in topics like voltage stability and control strategies are also likely. For a better understanding of the following chapters, the reader should have basic knowledge about RMS simulation procedures. Basic descriptions are covered by Kundur and Malik [8], Machowski, Lubosny, Bialek, *et al.* [10], and Milano [9].

The second relevant tool is a commercial software called *PowerFactory* by the company *DIgSILENT*. Modeling of the power system elements is described in its technical references, but not open source like *diffpssi*. In this thesis it is used as comparative tool, as it is also widely used for power system studies and research. The accounted version is *DIgSILENT PowerFactory 2023 SP1*.

To give an overview of other open-source power system simulation projects, one can have a look at the referenced GitHub repository [23]. At the submission date of this thesis, this repository is getting updated on a regular basis. Wang, Shin, Numair, *et al.* [23] ranks around 140 open-source projects for power system analysis, grouped into 15 categories. If one wants to compare, investigate or look out for other functionalities, modeling techniques or software structures, this can be used as a starting point.

2.3 On-Load Tap Changer Controls

Regarding the planned specific evaluation of OLTC controls, this part of the Fundamentals section aims to clarify the status on currently used control methods. Further, it describes the advancements in adding a Fast Switching Module (FSM). For readers, that are not familiar with this module, it is quickly introduced, and the currently available control scheme is briefly described.

2.3.1 Commonly Used On-Load Tap Changer Control

A few basics are of interest for understanding differences between real world behavior, or possible ways of building up an OLTC transformer control. This control theory difference can be limiting as well for the results and objectives compared to the actual possible control in the field.

The target voltage is typically set from the control room of the grid operator, resulting from pre-calculated load flow analysis. This can be set hours before, day-ahead or even seasonal with the estimated loads of the grid. This value is set locally for each operating unit subsequently. The control is then operating locally and without further involvement of the grid operator. [10]

Typically the used controller in the field is a discrete controller, which can change tap positions under load within a time frame of around a few seconds. Practical tap steps are around 2 % of the overall transforming ratio. The control is set up with a dead band, to avoid unnecessary tap changes. It is necessary to note here, that this control and its mathematical characteristics contains logical elements, blocks, and delays, which cannot be translated in a typical control theory transfer function. This leads to the missing possibility to easily obtain mathematical stability for the control of the overall considered power system. [8], [10]

2.3.2 Advancement: Fast Switching Module and its Control




Figure 2.6: Control loop of a FSM; scheme based on Burlakin, Scheiner, Mehlmann, *et al.* [5].

The basic idea of the FSM is using a conventional OLTC, but connecting it with a power electronics based additional switching unit. The complete module and a detailed description can be found in [4] and [6]. This module is serial to the conventional tap changer, and can connect to additional windings, either as addition or subtraction. This

module can be used in any tap position of the OLTC. The FSM windings have to be located on the same core as the main and OLTC regulating windings. In contrast to the conventional OLTC not only the next lower or higher tap position can be accessed. Instead each FSM tap position is reachable from every other, introducing much bigger possible switching steps at one time. The tap increment Δm of the FSM is understood as factor of the conventional tap increment. Typically used values for Δm are 1 or 2, the number of tap positions is limited in the interval $[-4, 4]$. Considering an OLTC voltage change of 0.02 p.u. per tap, this results in a maximum change magnitude of 32 %. With a minimum time constant of 0.02 s^4 , large dynamic actions are possible. A scheme of the structure is added in Figure 2.7, where following items are numbered:

- ① **Main winding** with coarse change-over selector
- ② **Regulating winding** for the OLTC
- ③ **Regulating winding** for the FSM
- ④ **Tank**
- ⑤ **FSM** in a separate container




Figure 2.7: Schematic illustration of the FSM; from [6].

Going further into the grid relevant aspects, the operational control of this extended OLTC, Burlakin, Scheiner, Mehlmann, *et al.* [5] gives a first approach for a control scheme. This is based on the conventional understanding and control of OLTCs so far. The control loop can be observed in Figure 2.6. It is also implemented in the comparative tool *DIgSILENT PowerFactory*, just with one slight modification. The OLTC is not only activated after the FSM reached an extreme position, thus the last is not preferred for switching. The control enables the OLTC first when exceeding the deadband. The FSM is only getting activated, when the function for tap skipping is not zero anymore.

⁴limited by the zero crossing of the sinodal sinal; worst case when filtering a 50 Hz signal for one perios is 0.02 s.

Generally speaking, the control scheme is divided into two paths, the FSM and the OLTC part. The control scheme input v_f is the measurement delayed or filtered voltage at the controlled bus. Filtering is represented by a PT1 block with the filtering time constant T_f . Subtracted from the reference voltage v^* this is the voltage deviation, which is of interest for the tap changer. If the absolute voltage difference Δv is bigger than the deadband of the control, the function $e(t)$ is enabling the cascaded memory function $c_m(t)$, and for the OLTC path $e_k(t)$. In the depicted scheme in Figure 2.6 from [5] the OLTC is only activated, if the FSM is in one of its end positions. Subsequently, the function $c_k(t)$ is the memory function for the OLTC, both with their specific time constants τ_m and τ_k . The functions $f(t)$ are determining the tap change, which is applied to the respective tap position functions $m(t)$ and $k(t)$, with other words they are the derivatives. For the OLTC, this tap change function $f_k(t)$ can have values $\in [-1, 1]$ as output, while for the FSM function $f_m(t) \in [\gamma_{\min}, \gamma_{\max}]$ can be formulated. The amount of tap changes for the FSM is calculated through the function $\gamma(t)$, which embeds the tap skipping function $\eta(t)$. Together they define the tap change input as described in Equation 2.24 and Equation 2.25

$$\eta(t) = \text{floor}\left(\frac{|\Delta v(t)|}{db_v \cdot \Delta m}\right) \quad (2.24)$$

$$\gamma(t) = \begin{cases} \gamma_{\max} & \text{if } \eta(t) > \gamma_{\max} \\ \gamma_{\min} & \text{if } \eta(t) < \gamma_{\min} \\ \eta(t) & \text{otherwise} \end{cases} \quad (2.25)$$

for $\eta(t), \gamma(t) \in \mathbb{Z}$

Lastly, the transformer ratio dependent on the time step is formulated as

$$\vartheta(t) = \begin{cases} \vartheta_{\max} & \text{if } \vartheta > \vartheta_{\max} \\ \vartheta_{\min} & \text{if } \vartheta < \vartheta_{\min} \\ \vartheta_0 + \Delta v(k(t) - k_0 + m(t) \cdot \Delta m) & \text{otherwise.} \end{cases} \quad (2.26)$$

A more detailed description is given by Burlakin, Scheiner, Mehlmann, *et al.* [5], where standard values and their impact for the variables are described as well.

2.4 Summary in Short and Simple Terms

The fundamentals chapter introduced to resources for understanding the basics of voltage stability, especially considering the OLTC. An analytical derivation of power voltage characteristics in grid calculations has been introduced with the Nose Curve exemplary for a simple system. A suitable index is proposed for comparing Time Domain Solution (TDS) dynamics of different scenarios with the Trajectory Violation Integral (TVI).

The mathematical description of a variable ratio transformer is derived, further possible applications and improvements illustrated. The relevant power system simulation tools were introduced. As orientation, a collection of open-source tools is additionally referenced. Lastly, the new advancement regarding the FSM and its control proposal is described.

3 Methodical Modeling

This chapter focusses on the description of thoughts and structures of the implementation in Python. It is not evolving more than necessary details about the package *diffpssi*, but trying to comprehensible illustrate the structure of the algorithms themselves and the necessary bordering interfaces.

3.1 Transformer Equipment Modeling

This section focusses on the dynamics and model behavior of the transformer itself. It is split into the modeling of the Π -model and the tap changer control. For the last mentioned, there are different control schemes implemented and thus described in the subsequent section. In the beginning, the software structure of the *diffpssi* extension is roughly described, continuing with a dive into the mathematical relations, and specialities.

3.1.1 Software Architecture Design

The first scope of the *diffpssi* extension is to form a modular and easy to maintain class structure. The background is to enable support of adding other types of transformers or connected control circuits. A conceptual chart of this architecture is shown in Figure 3.1. It is representing only necessary packages, classes, and attributes for the transformer and its control.

The main class for the Power System Simulation, hosting the central data structures and results is called *PowerSystemSimulator*. Models, busbars, lines, but also transformer objects are connected to each other, and on top of that referenced in the main simulation object as groups represented by lists. The transformers shall be connected in the same way as before, but differing from the initially available transformer model considering just the serial impedance, a simple non-tapping transformer shall be integrated next to a longitudinal tap-changing one. The room for possible extension, meaning phase shifters or mixtures of these models can be kept by using an abstract class as interface.




Figure 3.1: Architecture of the implemented models in *diffpssi*; Using abstract classes for correct interfaces and improved reusability; only necessary packages, modules and classes are depicted.

This forces the inheriting classes to override the necessary methods, have at least the mandatory attributes. Copying existing and functional structures is easier as well.

The transformer itself is just a mathematical representation of the Π -model, considering a serial impedance and two shunt branches. Connected control units shall be excluded from this, to ensure modularity as well. Therefore a lot of different control tweaks can be easily implemented and tested. To provide a consistent interface here as well, the abstract class *Voltage_Controller* is used. Within this thesis implemented are a discrete and a continuous OLTC controller, and two discrete FSM controllers. These reference to the standardized control blocks as well, e.g. PT1 or integrating elements.

3.1.2 Implementing a Π -Representative Circuit with Variable Ratio

Before detailing in the software side of the implementation, some mathematical differences are explained. This results on the one hand from the major differences in the literature, especially between Machowski, Lubosny, Bialek, *et al.* [10] and Kundur and Malik [8], resp. Milano [9]. On the other hand, the derivation and constraints for usage are not intuitive or directly obvious. The use and mathematical description of the variable transformer model in the comparative software *DIgSILENT PowerFactory* is hence described in its technical reference manual.

Mathematical Description and Definitions

Firstly it is important to comment on the use of indices in this thesis, and especially within the following chapter. The index 1 is always referring to the LV side, the index 2 to the HV side. The impedances can be concentrated and related to either the LV, or as usual to the HV side of the transformer. The in subsection 2.2.1 used derivation is using a relation on the HV side. The same accounts for the definition of the OLTC ratio \underline{v} . The OLTC ratio \underline{v} in this thesis is always placed on the HV side.

This thesis focusses on an ideal tap changer model at first, other possible considerations from subsection 2.2.2 are neglected. As vector groups are as well not considered, the

tap ratio stays solely a rational number. Like previously mentioned, and consequently described, the ratio ϑ is then placed on the HV side of the transformer, and defined as:

$$\vartheta = 1 + k \cdot \Delta v \quad (3.1)$$

$$\text{with } k \in [k_{\min}; k_{\max}]; k_{\min} \equiv -k_{\max}$$

Within this definition, k_{\min} defines the minimum tap position, k_{\max} the maximum OLTC position. The variable Δv defines the change of the ratio in percent for alternating one position.

Mathematical Different Representations

The admittance matrix can be calculated through different ways. Looking into standard literature and surrounding papers around this thesis, it can be divided in two categories. Derived from either Machowski, Lubosny, Bialek, *et al.* [10], versus Kundur and Malik [8], Milano [9], or Burlakin, Scheiner, Mehlmann, *et al.* [5]. The main difference is, that the placement of the ratio, and the relation of the voltages is on the same side after Machowski, Lubosny, Bialek, *et al.* [10], and on opposite sides for the others like Burlakin, Scheiner, Mehlmann, *et al.* [5]. When one would use the admittance matrix after the definition of Machowski, Lubosny, Bialek, *et al.* [10] as

$$\underline{\mathbf{Y}}_{\Pi, T} = \begin{bmatrix} \underline{Y}_T & -\underline{\vartheta} \underline{Y}_T \\ \underline{\vartheta}^* \underline{Y}_T & -\underline{\vartheta}^* \underline{\vartheta} \underline{Y}_T \end{bmatrix}, \quad (3.2)$$

one would have to consider switching the bus indices and using the reciprocal ratio of ϑ at the same time. As the bus one in the matrix derivation of Machowski, Lubosny, Bialek, *et al.* [10] is the bus where the ratio ϑ is placed, and the bus would be considered as the *from_bus* in the simulation.

Another thought or way of representing a transformer with off-nominal ratio is described in section B.1, where the derivation logic after Machowski, Lubosny, Bialek, *et al.* [10] applies. There, the asymmetric behavior is not represented through the admittance matrix, as this is kept symmetric. The matrix is thus split up in a symmetric static

contribution accounted in the system admittance matrix and a variable part, respected through different current injections at each bus.

$$\vartheta_{\text{reciprocal}} = \frac{1}{1 + k \cdot \Delta v} \quad (3.3)$$

Design and Implementation of Algorithmics

As before described in the general architecture of the extension, interfacial methods and attributes are implemented. Starting with the necessary methods, which can be divided into expectations from the framework itself, the operational unit type transformer, and the novel consideration as dynamic model. From the framework itself, mainly the three methods *initialize()*, *enable_parallel_simulation()*, and *get_value()* are included. All submodels have to be initialized with the preset of the measurement voltage at the bus to be measured. This accounts only for the OLTC related transformers, all others pass this functionality. To enable parallel simulations, all attributes have to be set as tensors in the expected format of the simulations. This is achieved through multiplying the value with a tensor of the shape $(1, \text{parallel_sims})$. For accessing additional, or partly calculated values of interest in the model, the last method is computed. Although this is currently also an empty function, it can be extended and called by the recorder function of the simulation framework.

Necessary methods of the transformer unit type are the calculation of the static and dynamic admittance matrix. As for the transformer, and the current goal of implementation, both methods are identical. If one would want to implement also an automatic tap position configuration for load flow solving, this would provide the sufficient interface. In the method *calc_admittance()*, the before described transformer admittance matrix is calculated and inserted into the system admittance matrix at each time step. In the begining of this method, the current measurement bus voltage is aquired and handed to the output function of the connected voltage controller. This output function is giving back the transformer ratio dependent on the current bus voltage. The transformer ratio is then set as an attribute and the admittance then can be calculated and updated. As an initial value for performing load flow analysis, this ratio is set to 1 p.u.

In order to consider this model as dynamic, three methods have to be implemented in the transformer itself: *differential()*, *get_state_vector()*, and *set_state_vector()*. As the transformer itself is containing no dynamics, but its connected controllers do, these methods solely call the methods in the controllers accordingly.

The necessary attributes of the transformers allowing the functions to work properly are implemented as following. The admittance matrix is always set as attribute. This allows for evaluation and mapping through the recorder function. Every transformer has a name, a resistance, a reactance and a susceptance attribute, as well as the transformer ratio u , resp. u_1 for the solely longitudinal part. For the vector group angle rotation, the attribute *theta* is added. Additionally, the mandatory system related variables for the system base apparent power, the transformer apparent power, the voltages at both busbars, and the parallel simulations are necessary. Considering the direction of the transformer in the system, the set of variables declaring the bus name, id, and voltage of the „from“ bus is partly defining the installation. On top of these, tap side and the measurement bus are completing the clear identification.

Focussing more on the installation direction, following procedure is applied in the calculation of the admittance matrix, as it is handed over to the simulation just as a tensor. A dictionary would be possible as well, as it would namely declare the tap side and non tap side index and impedance. As used attributes, the attribute *from_bus* and *tap_side* receive either the flag *hv* or *lv*. For the later attribute the allocation is in the responsibility of the user, the first one is allocated through checking the voltages of the busbars. If the *from_bus* is the lower value of the voltages, the value *lv* is assigned, and vice versa. The admittance is then calculated for the base scenario, if the tap side of the transformer is not the *from_bus*. For this scenario Equation 2.18 is used. If the values match, then the admittance matrix indices are switched, and the admittance matrix is set as

$$\mathbf{Y}_{\Pi,T} = \mathbf{Y}_T \cdot \begin{bmatrix} \frac{1}{\vartheta\vartheta^*} & -\frac{1}{\vartheta^*} \\ -\frac{1}{\vartheta} & 1 \end{bmatrix}.$$

3.1.3 Tap Changer Control Modeling

As the tap changers, or voltage controllers for the longitudinal ratio of an OLTC, are solely controllers, and therefore can also be dissembled in just control blocks, the necessary methods for integration in the module *diffpssi* are limited. Therefore the abstract base class, used as an interface class here, is containing the functions *differential()*, *get_state_vector()*, *set_state_vector()*, and *get_output()* for the control purposes. Additionally, as every other dynamic class, both methods *initialize()* and *enable_parallel_simulation()* are included in the same way as described before as well. In case it is needed, every controller is specifying the function *update_vref()*, to update the reference voltage of the control. The only varied standard method is *get_output()*, but additional

needed ones are necessary dependent on the controller. These methods are detailed in the subsequent parts of this subsection. One important note shall be made before any logics are described, as these procedures for all OLTC or FSM control schemes are based on the assumption, that the admittance matrix is calculated at every time step. Using multiple step solvers is thus possible, because the differential functions as only time dependent component are coupled to the solver. The other algorithmics are decoupled from the solver, and thus protected from multiple calls, and following multiple switching events per time step.

Before going deeper into the control loops, two basic control blocks are implemented into the framework. The first one is the realization of a deadband block. This means that if the input value is smaller than a defined threshold, the output will be zero, otherwise it is returning the input value. The differential function for this block is not necessary, as it is just reacting on the input and not building up any dynamics or relations towards previous inputs. The only necessary concern is the enabling of parallel simulations as well, to stay consistent with data types in the calculation.

The second implemented basic block is an integrator, commonly known as I-block in control engineering. This block has got relations to previous inputs and therefore a differential function, as well as methods for setting and reading the state vector. This attribute is a storage for the state in the previous timestep, with the differential the next state can be calculated. As the method *get_output()* is only called by the models, this is the connection to input variables. An attribute input is set to the handed over value from that function, enabling the differential to be calculated. Additionally, the output is set to the current state of the control block times a constant multiplication factor k_i of the integrator. This integrator is extended by the possibility to set a limiter, as well to externally reset the state and the input variables of the object. The differential function for an integrator is the input variable times the time step. As this multiplication is done in the solver function of *diffpssi*, the return of the differential is solely the input value. The last part is the initialization process, where the first output of this block has to be set, meaning setting the current initial state as the wished or needed output divided through the multiplication factor k_i . This first output is then also returned.

Discrete Control Loop

This control method represents the currently most used and thus representative control scheme for OLTCs. With the mechanic nature of the switching mechanism, the con-

trol loop can only access discrete ratios within time frames of around a few seconds. Such a discrete control loop is described by Milano [9], [24]. A scheme of this control loop is shown in Figure 3.2. This control loop type is beneficial due to its accurate representability of current OLTC abilities.




Figure 3.2: Discrete control loop of an OLTC; from Milano [24].

The complete algorithmic scheme is included in Figure B.1. Starting the controller algorithmics as the function input is the voltage measurement at the desired busbar. As this is physically done in the real world with measurement devices, this value is affected by a time delay the device is taking until the value is passed to the control algorithmics. The user of this control block can decide, if he wants to consider this in the scheme, by passing a value as float or None to the init function for *pt_1*.

The voltage deviation is calculated, and passed through the deadband filter, after the previous deadband output is stored. With this, the sign of the voltage difference, or if it is constant, can be checked. This satisfies the condition, that the tap changer shall be resetted, if the voltage difference is falling below the deadband, or changing signs. The latter case is indicating an unstable or swinging behavior of the system, where a switch of the tap changer is not helping to stabilize the scenario.

Continuing in the algorithmics, the absolute sign value of the deadband filtered voltage is handed over as argument to the integrator of the time delay. Either the voltage does not exceed the deadband, so the sign function of numpy is returning zero, or it is exceeding the deadband and the integrator is incremented with the specified time delay. This is happening with no respect if the deviation in voltage is very large or just marginally over the deadband. At this point one could also think of a variable time delay in this algorithmics. If the integrator state is now exceeding the time delay attribute of the OLTC, a switching operation is triggered with calling the function *switching()* as described in the ongoing. After the possible switching, the new transformer ratio is calculated and

returned to the admittance calculation of the OLTC. Additionally, the integrator block is resetted as switching is completed.

The only additional method for the discrete standard OLTC scheme is called *switching()*. Fairly straight forward it is determining, whether the OLTC is in one of its end positions and trying to exceed this end position. The switching operation is then denied with returning zero as addition to the tap position. If however an end position is present, but the direction of the switch is resulting in an allowed tap changer position, the switch is passed with either plus or minus one, dependent on the direction of the shift.

Control Schemes for the Fast Switching module

The complete algorithmics is strongly oriented on the before described control loop from subsection 2.3.2 and the to this section connected literature [4]–[6]. In contrast to the shown ratio plot in Burlakin, Scheiner, Mehlmann, *et al.* [5], the ratio is not limited by a maximum or minimum. The only limitation is coming from the maximum tap positions. This is done because it is more simple to implement, more senseful and allows to obtain a wider bandwidth in validation and application in this thesis. The alterations are fairly small, for a better overview this thesis contains a summarizing program chart in Figure B.2. Similar to the before described discrete OLTC scheme, this controller has a *get_output()* method as main, a *switching()* method for both parts, the standard OLTC and the FSM, and in this case an added function for determining the taps to be skipped by the FSM. These methods are subsequently described.

The PT1 described measurement filter is implemented in these controllers the same way at the beginning. The voltage difference calculation and deadband filtering is applied as well. The enabling variables are calculated through the numpy sign method and given to the integrators controllers as respective argument. After that, the taps to be skipped for the FSM are calculated. The switching and resetting for each compartment is triggered, if the respective integrator is exceeding the values of the corresponding time delay constant. At least the transformer ratio is calculated and returned.

The main differing function in the controller classes for the FSM is the function *tap_skips()*. It is simply just the external computation of Equation 2.24 and Equation 2.25 in one simplification. In the following section an alternative version is described, but implemented in the same logic and at this point of the algorithm.

Switching the OLTC is equivalent to the switching in the discrete standard OLTC scheme. If this is triggered, the function is approving not trying to exceed the possible tap positions with a switch. The tap position k then is adjusted either by plus or minus one. If the OLTC is already in an end position, nothing is changed.

The switching method for the FSM is a bit different, concerning the possible skip of taps. Previously calculated tap skips are an input argument for this function. Depending on the voltage difference, the switching direction is defined. After that, the routine checks, if an addition of the tap skips is exceeding the possible tap positions for the FSM in a similar way as for the OLTC. If the tap skip is zero, then the voltage difference is too low. For the possible case of an addition, the tap skips are added to the current tap position m and it is saved subsequently. If the tap skips are exceeding the range, the according end position is selected as new FSM position.

Two different versions are implemented, as the in the papers described one [5], [6] does not match the in the comparison tool *DIGSILENT PowerFactory* available one. As differences can be described as preferring the FSM in the papers, versus the activation of the OLTC or the FSM is dependent on the voltage difference and the corresponding tap skipping function. The change from the before detailed implementation for the latter behavior is comparatively small. The simultaneously allocation of both enabling variables has to be removed, as only the FSM one has to be triggered in the first place. Only if the FSM is in one of its end positions, the OLTC is getting enabled. For comparative purposes, both are implemented as separate voltage controller classes in *diffpssi*.

Characterization of the Implemented Control Schemes

For characterization of the control output, two different approaches are selected. First, a step function is applied, for a maximum gradient inspection. Further, a continuous function is selected, incrementing the voltage difference on the control loop. This could be exponential, exponential decaying, or linear increasing. As the tap changer has maximum positions, and therefore also an operational band, the exponential decaying function is selected as second characterizing input following Equation 3.4.

$$i(t) = b - (b - 1) \cdot \exp(-a \cdot t) \quad (3.4)$$

with $a = 0.1$, $b = 1.1$




Figure 3.3: Characterization of the OLTC control loop for a) a continuous input and b) a step input; the input function simulates the to be regulated voltage, the output functions are characterized by $o(t) = i(t) \cdot \underline{\vartheta}_{\text{trafo}}$.

The shown characterizations are the result from multiplying the input function with the controller output and feed back in the control block with the next time input. This procedure is similar as one would calculate a simple control engineering feedback loop, according to following function:

$$o(t) = i(t) \cdot \vartheta_{\text{trafo}} \quad \text{for } \vartheta \in \mathbb{Z}.$$

One important observation can be drawn here. For the step input reaction in Figure 3.3 b), the curves of the FSM preferred and the voltage dependent control loop are congruent. The switching occurs approx. 0.2 s after the step to 1.1 p.u. input signal, and resulting in a tap position below the FSM deadband 0.025 p.u. The discrete OLTC shows a more delayed response, and just switching until the response is falling under its deadband of 0.05 p.u. In the continuous increase of the voltage in Figure 3.3 a) similar characteristics are obtainable. The major difference here is the earlier switching of the OLTC in the voltage dependent control *FSM model 2*. As the tap skipping function is returning a non-zero value later as the time constant of the OLTC is exceeded, switching of the OLTC is triggered earlier as well. Very clearly visible is also the magnitude of one FSM switch compared to the OLTC, as is expected to be roughly twice as big. These behaviors were expected in that ways and intended with the different control models.

3.2 Application of Voltage Stability

As previously discussed in section 2.1 concerning voltage stability, ensuring power quality is a secondary goal. Concerning that voltage stability, regardless of short- or long-time evaluation, is a topic of power quality, it is hard to determine a stable or instable operation point. In terms of static possible solutions, there are a lot of tools determining the critical points, as well as the current distance to it. Looking into the short-term, more dynamic assessment, there are less elegant solutions. This thesis is trying to keep the perspective on both, short- and long term voltage stability. The following is the approach to synthesize a toolset for voltage stability analysis, that is at least dynamically comparable. As Nose Curves are a valid and popular tool, they shall be implemented first. Afterwards the time series calculation is tried to be integrated in this static evaluation, including tap changer dependent behavior. Lastly, a more dynamic rating of a scenario shall be computed, enabling also the confirmity with grid codes for example.

3.2.1 Generation of Nose Curves

This section describes the implementation of a previously discussed static voltage analysis tool. The generation of Nose Curves helps in finding the critical loading of the system at the bus of interest, although it is static nature.

Basic Simplification Idea

Ajjarapu and Christy [25] and Ajjarapu [26] are presenting a method for numerical calculation of nose curves in their work. It is called *Continuation Power Flow* and is based on a modified Newton-Raphson method. The differences rely in a slightly different definition of the power flow equations, considering a load factor λ . Combined with a predictor-corrector iterative solver method, this algorithm is capable of nose curve calculation, and finding the critical loading of the system. While in the first work [25], only the upper part of the curve including the critical point is calculated, the second work [26] is capable of calculating the complete curve with both solutions. As the trade off between implementation effort and the benefits, this method is not exchanging the reduced and simplified one.

While this method would be appealing to implement, an additional load flow algorithm, solver, and wrapper seem not profitable for this thesis. An idea was occurring, just

iteratively using the available implemented standard Newton-Raphson algorithm, and implementing a wrapper around it. The proposed result should be the upper and stable nose curve branch, with the critical point of active power loading. This shall seem sufficient, as the lower branch solutions are not stable load flow solutions.

The often used parameterization of a function of voltage dependent on the active power and the power angle ϕ should be implemented. In mathematical term, this is expressed as Equation 3.5.

$$|V| : P \mapsto f(P, \phi) \quad (3.5)$$

$$Q : V \mapsto f(V, \phi) \quad (3.6)$$

Under consideration of a complex representation of voltage and powers, this algorithm can calculate $V - Q$ curves as well. Mathematically this is expressable as Equation 3.6.

Implementation Details

The implementation of the nose curve generation is realized as a class in the package *diffpssi.stability_lib.voltage*. Its class diagram with all attributes and methods is shown in Figure 3.4, an extended version is included in subsection B.4.4. For an easy and generic use of the *diffpssi* package, *PowerSystemSimulation* objects are used, as well as the function *do_load_flow()* from the package.

As the before mentioned idea, the method for running the calculation is an iterative wrapper of the load flow calculation. This can be as well applied for mutiple busbars as a list input. At first, the

grid and therefore models of the *PowerSystemSimulation* object has to be cleared with the method *reset_sim_parameters()*. Then the active power vector is iterated as load input, together with the power angle ϕ for the reactive power in the model. The callable for the model is called with load parameters for each load bus as the bus name, and a list with active and reactive power. The initials of this grid callable are used as the standard values, so only one bus can be varied at a time. The result is saved as a *pandas DataFrame* in a *dict*, with the keys being the bus names.

NoseCurve
res_variation
results
ps_sim
run_calculation
run_variation_calculation
plot_nose_curve
plot_nose_curve_variation
get_max_loadings
add_load_to_plot

Figure 3.4: Class diagram of the NoseCurve class in the package *diffpssi*.

The method *plot_nose_curve()* is used to plot the results, and is using the *matplotlib* package. Further, the method *get_max_loadings()* can provide details about the critical point. Giving back a dict with keys as bus names, the values itself are dicts with key of the power angle parameter $\tan \phi$ and the values as *pandas DataFrame*. The contained details are maximum active power P_{\max} , the reactive power Q at this point, and the voltage magnitude $|V|$ at the bus.

Additionally, the method *set_run_variation_calculation()* and its connected automated plotting method *plot_nose_curve_variation()* aims to calculate a nose curve parameter set under variation of a system parameter variation. This is realized through a callable function, enabling access to the desired object attribute. Additionally a list of variation values as to be handed over, for iteration over it and saving the result to a dictionary. This dictionary then can be plotted or accessed over the object as attribute. The OLTC tap dependent Nose Curves from Figure 4.19 are generated by this functionality

Results of the Nose Curve Generation

The following Figure 3.5 shows the generated nose curve for a simple grid as illustrated in Figure 4.3. The grid is characterized at Bus 1, with a varying power angle as parameter $\tan \phi$. The power angle $\tan \phi$ is used to vary the power factor of the load, thus representing different load characteristics, as

$$\tan \phi = \frac{Q}{P}.$$

Displayed are a few combinations with different load characteristics, leading to a different possible maximum active power transfer. Figure 3.6 shows the comparison between the analytical calculation and the implemented solution. The analytical calculation is carried out in the same way with identical values as in subsection 2.1.1. What seems conspicuous is the missing lower part of the curve, meaning the second possible solution when solving the power flow equations. Although this seems like a major drawback, the resulting curve contains all the necessary parts, where a stable solution can occur [12]. The solution is reaching exactly until the critical point of power transfer. After that, the load flow calculation does not converge anymore and raises an error. This error is caught and the iterative wrapper for the first power relation stops.




Figure 3.5: Exemplary generated nose curves for a simple generator load grid for various power angle level parameters $\tan \phi$; Applied on the grid of Figure 4.3 with a characterization at Bus 1.




Figure 3.6: Comparison between the analytical calculation and the implemented solution.

3.2.2 Combination of Static Methods with Time Domain Solutions

Adding a TDS to the static Nose Curve plot is fairly simple and straight forward. The basic idea is gathering the demanded power by the load as additional recorder function, to overlap the dimensions voltage and power in the static plot. Additionally using color alteration for the time dimension is keeping the evolvement information as well. This data is then just added to the plot of Nose Curves. The background on why this could give a valuable inside, is simply looking into how close to the static solutions of the grid can the system stay under dynamic equalization and control processes. The static solutions should theoretically match the long-term solutions or states after the equalization processes. As this dynamic solution is also conditional to the machine and machine controls for example, it could give explanations about missing capabilities from this point, as the nose curves just express the network limits.

Necessary for gathering the missing power information, the method *get_value()* has to be added to the static model *Bus* as well. There, specifically the apparent power S is calculated through the sum of the models current injections. With the basic relations

$$\begin{aligned}\underline{S} &= \underline{V} \cdot \underline{I}^*, \\ P &= \Re\{\underline{S}\}, \text{ and} \\ Q &= \Im\{\underline{S}\}\end{aligned}$$

one can then access the active power as recorder attribute. Important to note here is, that the current injection of a simple load cannot be calculated by default, as this model is solely adding a contribution to the admittance matrix of the system. Therefore this model does not consider current injections. As proposed workaround, a load attribute *i_inj* is calculated in each iteration of the method *get_admittance()* in the static model *Load* with the relation

$$\underline{I}_{inj} = \underline{S}_{load}(t) \cdot \frac{\underline{S}_{n,sys}}{\underline{V}(t)^*}.$$

3.2.3 Using Voltage Envelopes for Criticality Evaluation

The before described method TVI from subsection 2.1.2 is implemented as separate class *ViolationIntegral* in the package *diffpssi*. Automated simulations are not considered, as

ViolationIntegral
env : str env_params : dict result : complex
get_env(time : list) : list get_result(time : list, v_bb : list) : complex set_env_parameters(env_params : dict) : None t_low(time : list) : list t_upp(time : list) : list hvrt(time : list) : list lvrt(time : list) : list

Figure 3.7: Class diagram for the class ViolationIntegral.

they do not add significant practicability. Therefore, simply the results vector is just handed over. The class diagram is displayed in Figure 3.7.

As before described, not only the mathematical describable envelopes are added, but the Machine Type II FRT curves when connecting to the medium voltage grids from [19], [20] are added as well. Both envelopes are implemented as a function dependent on the time, giving back a vector in the length of the time vector and being comparable to the bus voltage solution from the power system simulation object. Envelope parameters can be set with the function *set_env_params()*, but can as well be read out through the function *get_env()*. Here the same logic applies as with the envelope functions before, as a vector with the length of the time vector is given back.

CriticalTimes
firt_env : str firt_time : list tvi_env : str tvi_time : list calculation_dict : list result : dict
add_env_parameters(time : list) : None get_result(time : list, voltages : list) : dict

Figure 3.8: Class diagram for the class CriticalTimes.

The class *CriticalTimes* is added as well as displayed in Figure 3.8. It is used to enable a calculation of all time steps, where the envelope(s) are violated. The method accounts just the time stamp, where the envelope is cut from inside to outside, instead of returning all time steps outside of the envelope(s). The envelopes can be added and results can be calculated through handing over a bus voltage result with time vector. Results

are stored as an attribute as well. The envelope functions are re-used from the class *ViolationIntegral*.

3.3 Summary in Short and Simple Terms

Summarizing this chapter of implementing models and tools, the necessary parts are achieved. A variable ratio transformer model with its specialities is implemented for non-complex ratios. The accounting voltage controllers are implemented within a given system allowing for easy access, troubleshooting or extension. The realization of some extended ideas is described for the modeling of control units.

Regarding the assessment tools for voltage stability, static nose curve calculation is now possible. This showing the capabilities of the grid, can be extended with a comparative look into the TDS, where the difference to the voltage generation units can be illustrated. A quantitative evaluation method between different scenarios is implemented with the Trajectory Violation Integral (TVI). With this, finding critical busbars seems possible as well.

4 Validation Setup and Results

The implementation validation step is important for estimating errors or sources in more complex system studies. As no real world data is present, the model cannot be verified. But with use of the commercially used software *DIgSILENT PowerFactory*, the results can be compared and checked for discrepancies. In combination with estimated behaviors from simple examples, e.g. also derived in literature, the implementations are plausibilized.

4.1 Representative Electrical Networks

The following section shall introduce the used power systems in the simulation with the Python framework, considering validation, and also extension meaning the performed application study in chapter 5. The models are chosen to represent different network sizes and complexities, thus allowing the objective of graded interaction levels of the developed (transformer) model. The models are based on the work of Machowski, Lubosny, Bialek, *et al.* [10], Kundur and Malik [8], *IEEE Guide for Load Modeling and Simulations for Power Systems* [27], and Van Cutsem, Glavic, Rosehart, *et al.* [15]. One important note to take for all the presented networks in the following, is the consequent absence of machine control units. Only where mentioned explicitly, they are used. Generally speaking, all parameters of the simulations are described in section C.1.

Single Machine Infinite Bus (SMIB) Model

One very popular and thus powerful electrical network for the verification of power system stability is the SMIB model. It is a compact and simplified model of a power system, allowing easy analytical calculation, verification and development. Mutual influences are comparably simple to understand and calculate, as the infinite bus is acting as a fixed grid connection point with a large adjoining grid. The generator is connected to the bus bar via a transmission line and a transformer. The model was largely discussed by Kundur and Malik [8], and is shown in Figure 4.1. The generator and the Infinite Bus Bar (IBB) are represented by synchronous machines, developed and discussed by

Kordowich and Jaeger [7]. The specific model details are included in subsection C.1.1, additionally the simulation setup for validation is detailed in subsection C.1.1.



Figure 4.1: Single Machine Infinite Bus (SMIB) model for verification and validation of the Python framework; own figure after [8], [10].

Further, this model shall be slightly modified according to Figure 4.2. A load is added at the secondary bus of the transformer. The parameterization in subsection C.1.1 already contains this modification.




Figure 4.2: Modified Single Machine Infinite Bus (SMIB) model with additional load.

Single Machine Load Model

Following model is often recommended [8], [10] for easy voltage control studies, in explicit for OLTCs. Similar to the SMIB model, it consists of one synchronous generator, busbars, and lines in a single branch. The Infinite Bus Bar (IBB) is thus removed and changed to a load. Because this thesis is focussing on OLTC transformers, the model is extended with one in between. The line in between the load and the transformer is removed, connecting the load directly. A single line representation is depicted in Figure 4.3. Further details about its configuration and simulation setup are included in subsection C.1.2.




Figure 4.3: Single line representation of a single machine load model; own illustration with characteristics from [8].

Table 4.1: Values for the standard parameters of an OLTC control.

Parameter	Value	Unit
Time constant T_1	5	s
Size of deadband db	0.05	p.u.
Tap ratio change per switch Δm	0.02	p.u.
Minimum transformer ratio m_{\min}	0.9	p.u.
Maximum transformer ratio m_{\max}	1.1	p.u.
Initial reference voltage v_{ref}	1.0	p.u.

Standard Values for the Control Schemes

Values for the standard parameters of both the discrete OLTC and FSM control are used. These are partly based on the work of [5], [7]. The parameters are described in Table 4.1 and Table 4.2.

4.2 Validation Steps

Following section shall guide through the validation process. Beginning with the new transformer Π -model, therefore looking deeper into characteristic behavior dependent on the rated apparent power and the longitudinal ratio. Proceeding with the three modeled control circuits and their behavior. Lastly, some applied plausibilisations shall be done with the implemented voltage stability rating tools.

Table 4.2: Values for the standard parameters of an FSM control.

Parameter	Value	Unit
Time constant FSM t_m	0.02	p.u.
Time constant OLTC t_k	5	p.u.
Size of deadband db	0.025	p.u.
Tap ratio change per switch FSM Δm	2	p.u.
Tap ratio change per switch OLTC Δk	0.02	p.u.
Maximum tap position FSM m_{\max}	4	p.u.
Minimum tap position FSM m_{\min}	-4	p.u.
Maximum tap position OLTC k_{\max}	10	p.u.
Minimum tap position OLTC k_{\min}	-10	p.u.
Initial reference voltage v_{ref}	1	p.u.
Maximum tap skips γ_{\max}	8	p.u.
Filtering time constant pt_1	0.01	p.u.

4.2.1 Validation of the Modeled Transformer with Variable Tap Position

As mentioned before, the base validation is concerning the basic transformer model. For this, a parameter variation and comparison to the results from *DIgSILENT PowerFactory* shall give a good representation of the accuracy. The varied parameters are the apparent rated power S_n of the transformer, the longitudinal ratio ϑ , the transformer reactance X , and the phase shifting angle ϕ , resulting from the applied vector group. The last two parameters are not included, because the transformer reactance is passively included in the ratio. The reason for excluding the vector angle ϕ relies in the not congruent results. Where not varied, the apparent power of the transformer is set to $S_{n,\text{trafo}} = 4\,400$ MVA, and the machine size of the grid is set to $S_{\text{ibb}} = 11\,000$ MVA. The accounted event is a short-circuit on bus zero during the simulation timesteps between 1 s and 1.05 s.

Variation of the Apparent Power

The rated apparent power S_n shall be varied in three steps as described in Equation 4.1. The used grid model is the before described SMIB model. This is showing some predictable dynamics, but enabling a relative uncomplicated and easy to overview trou-




Figure 4.4: Absolute errors comparing the tool *diffpssi* with the software *DIgSILENT PowerFactory*; One plot each for every parameter variation, concerning the errors for each bus.

bleshooting, if necessary. The used grid parameters staying as described before, only the transformer apparent power is varied.

$$S_n \in \{1\,100; 2\,200; 4\,400\} \text{ MVA} \quad (4.1)$$

The used model for the comparative tool *DIgSILENT PowerFactory* is as well included in the *diffpssi* repository. A plot of both results is depicted in Figure C.1 Comparing similar parameters of both tools in one diagram, is possible by evaluating Figure C.2 in section C.2. The three split diagrams account for each bus, where nearly no difference is obtainable.

Supporting this observation is the comparison of errors as illustrated in Figure 4.4. The error is not exceeding 0.005 p.u. in any case. One note to make here is, that due to the per unit nature of the calculation the initial values are often around 1 p.u. Therefore the separate calculation of a relative error is neglected, as the absolute error is containing more information, and thus not surpassing the feel of relative nature. Following this argumentation, the maximum relative error shall be around 0.05 % for this parameter variation.

Variation of the Longitudinal Ratio




Figure 4.5: Error comparison of varying the longitudinal ratio as parameter between *diffpsi* and *DIgSILENT PowerFactory*.

In similar way as the validation approach for the rated apparent power, the longitudinal ratio shall be varied. Therefore the same network, with identical parameters is used,

only that at this time the rated apparent power is fixed as well and the longitudinal ratio of the transformer is fixed during the simulation time according to following variation:

$$\vartheta \in \{0.9; 1.0; 1.1\} \text{ p.u} \quad (4.2)$$

Looking into the results, in the same form as previously. On the left side of Figure C.3 the result from the Python module *diffpssi* is shown, the right side is accounting for the validation tool *DIGSILENT PowerFactory*. The focussed comparison for the fixed ratio of 0.9 p.u. is included in section C.2. Figure 4.5 is showing absolute errors in the same manner as well. The obtainable error for this case is comparably high, excluding for the reductive ratio of 0.9 p.u. This increases with simulation time, to around a factor of 10 of the other errors. But still, this error is in a margin of lower than 1 %.

4.2.2 Parenthesis: Accountability of the Load Model




Figure 4.6: Comparison of the constant impedance model for each bus between the Python module *diffpssi* and *DIGSILENT PowerFactory*.

A static load model with quadratic dependency on the voltage had been implemented in the Python module before. The load model can thus be classified as constant impedance model, or often referred as constant impedance model [27]. As this is playing a role in the chain of accumulating errors, following parenthesis shall give a feeling what contribution is generated through this load model. For this evaluation the Single Line with Load model from section 4.1 is used, with a load jump from $P = 400$ MW to $P = 800$ MW at

the time stamp 1 s, while $Q = 0$ Mvar at every time step. The overall simulation time is set to 20 s. Other parameters are set as described in section 4.1.




Figure 4.7: Absolute error of the already implemented constant impedance model over time; Accounted for both busbars zero and one.

Figure 4.6 shows the time series computation for each bus compared between both tools *diffssi* and *DIgSILENT PowerFactory*. Visible is the more extreme of the overshoot and the convergence value over time of the Python package. Looking at the absolute error comparison for each bus in Figure 4.7, an increase over time is shown with peak offsets of around 0.006 p.u.. This accounts for an error lower than 1 % in this scenario.

4.2.3 Validation of the OLTC Control Schemes

To begin with the validation of the implemented control schemes, a basic strategy is accounted for all the considered models and verification setups. The characterization of the control loop feedbacks has already been carried out in the modeling chapter subsection 3.1.3. To validate the in-simulation behavior of the control loops, two different scenarios are accounted for the OLTC and the FSM. First, the Simple Load against Machine grid is used with the declared parameters as in section 4.1. To bring the system in a dynamic state, a load jump is added at the simulation time point $t = 1$ s. All differing values are pointed out in the validation result presentation later on. Secondly, the more complex version of a SMIB model with a connected load at bus one is used to account for a different scenario including a load flow direction change. It is expected, that neither

DIgSILENT PowerFactory or *diffpssi* would be able to react on this supposed load flow direction change.

Application of the before described Logic

The first consideration for validation of the OLTC control is the simple single machine load model. The applied load change is shifting the real power of the load from $P = 400$ MW to $P = 800$ MW at the simulation timestep 1 s.




Figure 4.8: Time Domain Solution (TDS) of the standard discrete OLTC control scheme; Result of the extended or modified SMIB model with additional load.

When comparing the time series solution from Figure 4.8 for both bus voltages, one can obtain a similar course of the curves. Nearly no deviation is visible, and the tap changes of the OLTC are visible at the exact times. A similar picture is drawn, when looking at the absolute error of this scenario in Figure 4.9. In the areas of time, where the switching occurs, peaks of errors are visible, showing either numerical issues or a one timestep offset at the switching times. Such a shift of one timestep could result from a different configuration of the conditional statements. After the half of the simulation time, a new (quasi-) stationary state is showing nearly no error. This error is close to 0 p.u., showing a even less error than previously illustrated subsection 4.2.2.

Taking in consideration the second verification scenario, applying the discrete OLTC control scheme to the extended SMIB model with added load, one can obtain the TDS visible in Figure C.6. For reasons of not adding further information, this plot is just




Figure 4.9: Comparison of the standard discrete OLTC control scheme applied on the extended SMIB model with additional load; One plot for each bus with data from *diffpssi* and *DIgSILENT PowerFactory*; Additional plot for showing the absolute error for each bus.

added to the appendix. The added event at time step 1 s is a load jump at bus 1 from $P = 100$ MW to $P = 1100$ MW, while $Q = 0$ Mvar at each time step. Comparing the results for each bus between the two tools *diffpssi* and *DIgSILENT PowerFactory* Figure 4.10 gives an overview.

Two observations can be drawn, when looking at the evolution of the bus voltage magnitudes. First, the tap changing of the OLTC is not addressing the problem of letting the voltage drifting away. The control is supporting the destabilization of the voltage at bus two, and hence the connected machine. Secondly, although the initial evolution of the voltages after the load increase event is showing similar results with small deviation between the two tools, the first OLTC intervention is happening at a different time step. All following ones are as well time shifted between the two tools, ending up with a absolute static offset voltage as in the previous scenario of nearly 0 p.u.

When looking deeper in the model and its signals, one can obtain, that the OLTC control is thus switching correctly. As displayed in Figure 4.11, the deadband filter is correctly surpassing just values greater than the deadband, otherwise zero. As well as the longitudinal ratio on the other side, where switching intervals of 5 s are visible, considering the time constant and the constant overshoot of the voltage difference of greater than the deadband, the control mechanisms seem to operate fine and plausible.




Figure 4.10: Comparison of the standard discrete OLTC control scheme applied on the extended SMIB model with additional load; One plot for each bus with data from *diffpssi* and *DIgSILENT PowerFactory*; Additional plot for showing the absolute error for each bus.

4.2.4 Validation of the FSM Control Scheme

The idea and proceeding of the validation of the FSM is carried out similar to the subsection before. First, a simple single machine load model is used, with the same parameters as described in section 4.1. Extending this model, a second look into the extended SMIB model is done. Here the parameterization stays the same as well.

As described in the modeling chapter, specifically subsection 3.1.3, of the FSM module control, two control methods are implemented. First, as described in the paper of Burlakin, Scheiner, Mehlmann, *et al.* [5] with preferring the switching of the FSM, and secondly the dependence on the function of tap skipping. As only the last model is available in the tool *DIgSILENT PowerFactory*, only this can be compared and validated. The other control scheme is implemented similarly and used as well for further studies.




Figure 4.11: Internal signals of the OLTC control in the extended SMIB model; a) the longitudinal transformer ratio u_1 or mathematically referred as ϑ , b) the deadband filtered voltage difference signal v_{dead} .

Voltage Difference Dependent Activation




Figure 4.12: TDS and error comparison for a FSM control scheme based on the voltage difference applied on the extended SMIB model.

The first comparison, looking at the simple single machine load model and the voltage dependent FSM activation, Figure 4.12 is showing the buswise comparison for the TDS. Nearly no spreading apart can be obtained, which is supported by Figure 4.15. This plot is showing the absolute error between *diffpssi* and *DIgSILENT PowerFactory*. Each




Figure 4.13: TDS and error comparison for a FSM control scheme based on the voltage difference applied on the extended SMIB model.

switching operation is connected with a short peak, approximately a numerical error. After all possible switching operations took place, the static error is settling around 0 p.u., similar as all control scheme errors before.




Figure 4.14: Internal signals for a FSM control scheme switching dependent on the voltage deviation.

Continuing with the extended SMIB model and a load increase event from $P = 100$ MW to $P = 700$ MW at 1 s, Figure 4.15 is showing the TDS including the error comparison. The switching events are clearly visible and around a similar time, although due to the more complex behavior not congruent. The static offsets after a simulation time of 120 s are converging to 0 p.u. absolute error, while peaks occur to around 0.1 p.u.. These peak errors occur just for a short time and can be connected to the time shifted switching operations.




Figure 4.15: TDS and error comparison for a FSM control scheme based on the voltage difference applied on the simple scenario.

Looking deeper into the signal processing of the control scheme, one can obtain a beginning with the OLTC as first acting part in Figure 4.14. The voltage difference is exceeding the deadband, but not large enough to activate the FSM module yet. Later on in the evolution the FSM is getting activated, but not dependent on the OLTC switching or tap position.

Preferring the FSM over the Normal OLTC




Figure 4.16: Internal signals for a FSM control scheme preferring the FSM.

For the simple load against machine model no different result to the before presented could be found. The less drastic increase in voltage magnitude difference is resulting in the same switching behavior and module activation as with the voltage dependent FSM control. Therefore the FSM is acting just as an increase in switchable tap positions, and following the reachable transformer ratio spread.

Accounting for the second validation set up, the same network is chosen as for the validation of the first FSM control scheme. The event magnitude is increased to a change from $P = 100$ MW to $P = 1100$ MW. Because no implemented version of this control was available for the tool *DIgSILENT PowerFactory*, no comparison can be drawn. The result, a TDS as alternative to the before illustrated behavior, can be evaluated through Figure C.10, where one can clearly distinguish between the first four switches as related to the FSM. The magnitude is apparently twice as big as the following switches.

When looking into the signal processing of this setup, Figure 4.16 is illustrating this behavior. The OLTC tap switching mechanism is only activated after the FSM is reaching one of its maximum positions. Although this scenario is connected to a larger jump in power as event, and thus with a steeper ramp up of the bus voltages, one can obtain from Figure C.10 that the preferred switching is not connected to this. The bus voltage

is exceeding the deadband clearly longer than 5 s, this is the remaining criteria for activation of the OLTC. But the voltage is increasing until the tap skipping function is exceeded for the characteristic time of the FSM. The switching behavior is thus not only differing in the preference of the tap changers, but as well how much voltage deviation is accepted until a tap change is induced.




Figure 4.17: Illustration of the deaf band with the FSM preferring FSM control scheme.

One quite interesting error in this switching logic is the problem of a „deaf area“ between the deadband and $\Delta m \cdot v_{db}$. If the occurring event is causing a rise in voltage deviation between these two values, but not exceeding the limit, the FSM control is not being activated. Therefore no tap changing occurs, and because the FSM does not reach any extreme position, the normal OLTC control is not getting activated as well. Therefore the tap changing transformer is not doing anything, and acting sort of „deaf“ to the voltage deviation in that band. Figure 4.17 is illustrating such a scenario, with considering the extended SMIB model, having a load increase at 1 s from $P = 100$ MW to $P = 700$ MW.

4.2.5 Voltage Stability Rating Plausibility

This subsection is looking at the implemented tools, helping to evaluate voltage stability. Some parts can be validated through external sources, others can just be tried to plausibilize with the obtainable and expected behavior.

Nose Curve Validation

As previously illustrated in subsection 3.2.1, the Nose Curve calculation for simple cases is congruent with the analytical calculation. When looking at more complex cases, *DIgSILENT PowerFactory* is providing such a voltage curve calculation tool as well. When only scaling one load at a desired bus, with variation of the loads on considering a constant power angle $\tan \phi$, one can compare it to the proposed and implemented algorithm in this thesis. The desired network is the IEEE 9-bus network from [28]. Considering a variation of the load at bus five, with its constant power angle $\tan \phi = 0.4$, one can compare the solutions in Figure 4.18. All other loads stay constant, so that the maximum power transfer is reached in both simulation environments at around 405 MW. An interesting observation can be drawn in the beginning of the curve, where *DIgSILENT PowerFactory* is naturally starting at the initial load operational power. Apart from that, the curves are congruent as well.

Extension of Nose Curves: Plausibility

The next extensions of interest are the intersection points with the different load models at the bus, the include of TDS, and the insertion of tap position dependent characteristics. Figure 4.19 is targeting the last mentioned point and illustrating in dashed red lines the different tap dependent nose curves of a simple load machine network from section 4.1. The discrete possible tap ratios are defined as following set:

$$\mathbf{R} := \{0.9 + n \cdot 0.02\} \quad \forall \{n \in \mathbb{N} \mid 0 \leq n \leq 10\}$$

Clearly visible are these transformer ratios for an unloaded grid. The evolution of all tap positions deviating from the initial, or normal tap position illustrated as blue line, can be described as equidistant. Resulting in the same critical maximum loading of the grid, but at different voltages. This could be expected, as this OLTC is solely a longitudinal




Figure 4.18: Comparison of Nose Curve generation between *diffpssi* and *DIgSILENT PowerFactory* for the IEEE 9-bus system at bus 5; Load only scaled at bus 5 and with constant $\tan \phi = 0.4$.




Figure 4.19: Nose curves dependent on the tap changer ratio for a simple load network.

tap changer, with no phase shifting capabilities at all. The maximum transferable power shall thus not be different, as the transformer alone cannot support any reactive power.





Figure 4.20: Nose Curve with added TDS and the power of a constant impedance load dependent on the voltage as intersection point.

When concerning the first two visualization extensions, the inclusion of a TDS and the load behavior in the static plot, one can obtain the results from Figure 4.20. The more pale the scatter points get, the further the point is in time of the simulation. The base scenario for this figure is the simple grid model, with an continuous linear load increase over time starting at the base load of $P = 400$ MW and $Q = 0$ Mvar. The load could then be described in dependence of the time t as

$$s(t) = s_0 + 80 \text{ MVA} \cdot t,$$

resulting in a maximum active power of approx. $P = 10^4$ MW after the complete simulation time of 120 s. One important note on this figure is the usage of machine controllers, explicitly a Simple Exciter System (SEXS), Governor (GOV), and a Power System Stabilizer (PSS). The parameterization of these models is included in subsection C.1.3. The apparent power of the machine is set to 2 200 MVA, while its active power delivery is at $P = 1\,998$ MW.

Now looking into the TDS for a machine without controllers, and the grid with a simple, non-tapping transformer, Figure 4.21 shows a comparison on machine sizes. The voltage is not following the static solutions of the grid, because the mechanical torque at the



(a) 2200 MVA

(b) 11000 MVA

Figure 4.21: Nose Curve and TDS for a simple load system; Considering a machine without controllers and continuous load increase; Left side showing a machine with 2200 MVA size, on the right 11000 MVA.

machine is constant, the exciter voltage is not adapted either. Hence, the voltage is breaking in, and falling faster, than the network is limiting. The voltage dipping is slower or with a lower gradient on the power, if the machine is bigger. If a tap changer would have been added to the network, the curve would follow the same course, with parallel shifted points, similar to the illustrations in Figure 4.19 and Figure 4.20. But here the limitations or maximum loading points of the network cannot be reached as well.

Envelope Violation Index

The following shall demonstrate the usage of the Trajectory Violation Integral (TVI), when a scenario is either stable or unstable. Using a standard SMIB from section 4.1, and an added short circuit event from the time step 1 s until either 1.1 s for the stable scenario, and 1.17 s for the unstable scenario. Now one can calculate the TVI of each bus, the CSI of the overall system, and relate all busbars to the average of the system. Further, the time stamps, where the voltage envelope is cut, can be returned. The shown envelope in Figure 4.22 can be replaced by a set of FRT-curves as well.

The TVI for bus one in the shown stable scenario is approx. 0.06, regarding the instable scenario 5.2. The voltage envelope violation time could be calculated for the instable scenario for each exit of the envelope, if the voltage has been inside it the timestep before. Regarding the CSI for this system, it can be calculated to approx. 5.8, where bus one is roughly as critical as the system, bus zero is less critical with a TVI of around 3.9, and bus two is the most critical with a value of 8.5. The IBB in this scenario is connected to




Figure 4.22: Voltage envelope for a stable scenario.

bus zero, the short circuit event on bus one harms the stability of the connected machine at bus two. Bus one itself is supplied and strongly connected with the IBB, thus making the bus two, which is isolated during the fault, the most critical one.




Figure 4.23: Voltage envelope for an instable scenario.

4.3 Model Limitations and Improvements

Concluding either the model of the transformer and its control schemes, they both can be classified as valid in comparison to the commercial software *DIgSILENT PowerFactory*. For the given and illustrated parameters, this can be stated. With the exception of a complex transformer ratio, meaning a phase shifting part, the results are in the expected range of error. The control schemes show similar switching logic and times. Although the connecting error chain must not be neglected, and depending on the application already a few percent alteration can make a huge difference. For example a difference of one percent can become an error of ten percent, if the objected voltage band is 0.1 p.u.

The reduction of the error in the TDS from only assessing the load model to the addition of the OLTC control schemes seems plausible. The control scheme is holding the voltage closer to the reference value. The load model has the lowest error near the reference value. The further apart, the bigger the error, so that the accumulation of errors over the simulation time gets limited with the addition of an OLTC control scheme.

Regarding the slightly different switching behavior, especially with the more sensitive FSM control can be argued with the dependence on a hand full of factors and errors. As the system converges into a congruent steady state after the dynamics, it seems thus comparable. Although it has to be kept in mind, that real switching times can differ, so that coincidences of switching at the right time have to be ruled out through slight variations for example. Further from the two small differing FSM control schemes can be deviated, that a significant differing behavior can result already from small tweaks. A globalized control scheme cannot catch or stabilize every possible scenario, as the user is likelier to have a particular application.

Switching the perspective to the assessment of voltage stability, there are other conclusions. On the one hand it becomes also visually clear, that static stable solutions considering the voltage of a power system are decoupled from the possible dynamics. If the system has no perspective on finding a static stable convergent, the dynamics solely will not be stable as well, except supportive operating units can be activated in time. The other way round, meaning having a stable possible convergent, does not mean that with neglecting the dynamics a stable convergent must be found. Even for the network limitations compared to limitations on voltage stability from machines a similar scenario can be observed. If the network can transmit the load at the necessary stable voltages, the machine could possibly run out of power reserves, so that unstability occurs. The same way that a grid can limit the transmission of sufficient power, when the generation

units are provide capabilities. Thus, the critical points can often lie beyond or above the voltage bands for specific power points. OLTCs can help stabilize this convergence by shifting the power voltage curves in the right direction. Looking at the size of the machines, a similar perspective can be drawn. Bigger machines help staying closer to the static solution set with the same rate of load change. When now dynamics are starting to occur as well, the TVI can help with the static solution set, and the evaluation of the machines, if the system is more or less likely to become stable compared to other scenarios. The impact of OLTCs on the static solutions can be estimated, even the dynamics can be compared to the static behavior.

4.4 Summary in Short and Simple Terms

Summarizing this chapter, the modeled transformer implementation and therefore connected control schemes deliver similar and comparable results to the commercial software *DIgSILENT PowerFactory*. Although the solutions are not always congruent, they can be classified as absolutely valid. Numerical errors, small modeling differences, or a different behavior of the surrounding simulation environment cause small deviations. These do not hinder the significance and capabilities of the extended tool *diffpssi*. Looking further into the constructed tools for voltage stability analysis, these are showing partly congruent behavior with the software *DIgSILENT PowerFactory* as well. The extension of the nose curves and the TVI show functional behavior, making conclusive predictions, claims or statements. They can thus be used to compare system states with regards to voltage stability expectations and voltage dynamics.

5 Application Study

This part of the thesis aims to apply the developed and implemented model to a scenario of possible interest. Ideas, that have come up during the implementation and validation of the models, shall be picked up here and used as a demonstration for *diffpssi*. On the other hand, they can give more hints and discussion potential for the research questions targeting the FSM. The constitution of the following sections is differing compared to the rest of the thesis. Each section will look at a specific idea or area, where a hypothesis or expectation is presented, before it gives a look into the results.

5.1 Voltage Stability after a Short-Circuit Fault

Exploring the basic behavior and differences between the tap changer control scheme is best possible with simplified set-ups. As the validation in subsection 4.2.3 already considers the most simple networks with only a load and a generator as source, this part is taking another machine as external grid into consideration. This means, that the standard SMIB model from section 4.1 is used, all differing presets are shown in Table 5.1. The applied transformer in particular, is set with the standard parameters for each control from Table 4.1 and Table 4.2. One important deviation from the transformer installation before, is the bus of measurements. As the active and voltage dependent unit is located on the LV side bus two, this is set at the controlled one. The measurement at this bus is used as input for the controller. Following control schemes are part of the comparisons:

1. Standard Transformer without a control scheme
2. Discrete OLTC control
3. Voltage dependent FSM control
4. FSM preferring control

Table 5.1: Parameter set for case study two; all other, not described parameters stay constant to the reference network in section 4.1.

Parameter	Value	Unit
Apparent power IBB S_{ibb}	5 000	MVA
Apparent power transformer $S_{n,trafo}$	2 200	MVA

The considered event for this setup and scenario is a three phase short-circuit fault, located at bus one for the time steps between 1 s and 1.07 s. As the stability of the bus voltages can also be harmed after a longer period of time, a simulation time for 120 s is applied. Also, this time period should indicate tap hunting, if it occurs.




Figure 5.1: TDS for case study one of the transformer ratios for comparing the control schemes.

First, looking at the bus voltages alone and neglecting other factors is central. The hypothesis, that the FSM can support the voltage stability of the system for a longer time period is tested. As the OLTC control can vary and thus support, an improved

TDS should be visible. The FSMs have a bigger ratio range, and can switch faster. Dependent on the used scheme also with a smaller deadband as the OLTC, why these should increase the time voltage can be held in the relevant band even more.

Looking into the first plot of results, Figure 5.1 showcases the different reaction of the control schemes on the same scenario. The discrete OLTC controller slowly reacts, after the machine does not swing any more. From the initial state, the transformer ratio reduces to its maximum end position with a ratio of $u_1 = 0.9$ p.u.. Both FSM modules jump to the end position just a few milliseconds in the fault, while the respective OLTC parts remain in the initial states, accounting for a ratio of $u_1 = 0.84$ p.u.. After that, depending on the enabling functions and tap skipping, the voltage dependent control switches also with the OLTC part back to higher ratios. The FSM preferring control uses the only the FSM, as the module is not long enough in one of its end positions. Interestingly, both result in a stable state at least until the end of the simulation time, but with different ratios. While the voltage dependent control stays static after around 50 s with a ratio of $u_1 = 1.04$ p.u., the FSM preferring control overshoots and switches back. This means the control switches back and forth, and is kind of oscillating around a middle transformer ratio. The conventional OLTC on the other hand switches in the opposite direction as both FSM modules. This behavior comes from the missing voltage overshoot due to the switch of the FSM controls during the fault, especially visible in Figure 5.3. The values higher than the reference voltage have then be compromised. For the OLTC the voltage begins to go down as result from the fault, so it tries to compensate by lowering the ratio.

Table 5.2: Time stamps for the first envelope cuts of each bus and controller in case study one; values in the unit s.

Control Scheme	Bus 0	Bus 1	Bus 2
Simple Transformer	29.520	29.030	28.430
Discrete OLTC Control	45.905	44.810	52.525
Voltage Dependent FSM Control	-	-	-
FSM preferring Control	-	-	-

The before obtained switches of the tap changers are visible in the TDS plots of the bus voltages as well. Figure 5.2 shows the control schemes compared through the bus voltages in the subplots. A voltage envelope is inserted with a dashed black line, considered for the parameters of $\beta = 0.1$, $v_{st} = 0.9$ p.u., and $t_f = 1.06$ s. Here, the before described characteristics of switching back and forth of the FSM preferring control can be observed.




Figure 5.2: TDS for case study one split into busbars for comparing the control schemes; The black dashed lines account for an TVI envelope with the parameters $\beta = 0.1$, $v_{st} = 0.9$ p.u., and $t_f = 1.06$ s.

Further, all tap changer controls indicate an improvement in stability. While the base scenario without any tap changer control exceeds the envelope at around 29 s, the discrete OLTC already increases the time to around 45 s. The FSM controlled tap changers result in stable bus voltages over the complete simulation, while none of the voltages violates the envelope. The exact results are included in Table 5.2.

Table 5.3: Results for the TVI and the CSI for case study one; Values in the unit p.u. · s; in the text no unit is used, in order to avoid confusion with time values.

Control Scheme	Bus 0	Bus 1	Bus 2	CSI
Simple Transformer	36.19	42.50	135.36	71.35
Discrete OLTC Control	31.51	31.39	98.03	53.64
Voltage Dependent FSM Control	0	0	92.7	30.9
FSM preferring Control	0	0	92.7	30.9

Accounting for the TVI¹ values in Table 5.3, this visual based statement is supported as well. The most critical scenario is represented with us of the simple transformer, with a CSI of over 70 s. Both FSM controls result in the most stable with a CSI of around 30 s, while the discrete OLTC is in the middle with around 50 s. Since this is the evaluation of the whole system, the values for the single busbars are also calculated before. Here, in every of the four scenarios or control types, bus two is the most critical, with always being the only one above the CSI.

5.2 Interaction with Machines without Control

For the second investigation, looking into the interaction with synchronous machines, the same simulation setup as in case study one is chosen. Including two machines and all four OLTC and FSM control possibilities, this scenario including the short-circuit event shall indicates a power and therefore machine rotor swinging. The same parameterization and set-up of the controllers is chosen as in the previous section.

Considering the different time constants and enabling functionalities of the FSM controllers resp. the standard OLTC controller applied to the grid, are expected to trigger different responses. Especially because these shorter time constants protrude into the typical voltage swings of machines after a short circuit event. Short circuit events demand a quick response, thus small changes or shifts in timing of switches or different

¹in the text no unit is used, in order to avoid confusion with time values.

enabling functions can have a significant influence. As the active power transfer from a bus to another can be expressed as denoted in Equation 2.1, the variable ratio transformer is expected to manipulate this power transfer. The electrical power is one input parameter in the differential equations of a synchronous generator [8], [10] and therefore has an influence on the machine swings.




Figure 5.3: TDS for case study two split into busbars for comparing the control schemes; The result has been zoomed to the limits $x \in [0, 8]$ s and $y \in [0.7, 1.2]$ p.u..

Zooming into the plot of the bus voltages in Figure 5.3, a different recovery from the short-circuit is visible. Especially in the beginning the discrete OLTC control and the uncontrolled scenario come back faster at bus zero and one. These two are identical over the shown time period, as no switches of the OLTC occur in that time interval. Bus two is inverted, as the FSM controllers result in a faster ramp-up. The first few milliseconds after the fault clearing, the FSM related curves are congruent, until the first switch of the FSM preferred scheme takes place and the voltages split up. One can see the ongoing switching in this zoom very well, as well as the spread of the voltages. Even after just 8 s, the voltages at the critical bus two spread in a band, which is approx. 0.1 p.u. wide.

Focussing on the electrical power output of the synchronous machine at bus two, one can see the difference in Figure 5.3. Before the fault the system is in steady state, while during the fault the ejected power falls to zero. The clearing of the fault re-raises the power and shows a swinging around the previous steady state for around 6 s. Here, one can see a similar perspective as before with the bus voltages, as the FSM power curves are congruent in the first half swing, while the curve of the OLTC controlled and the simple transformer scenario already split apart. The initial peak of the FSM scenarios is higher, but become similar compared to the others until the end. A second observation is the shorter swinging frequency of the FSM cases.

Looking into the machine speeds in Figure 5.5, one can see a nearly identical picture. One difference has to be mentioned, as the peaks of machine speed do not vary as big as the electrical power compared over the four scenarios. But again, the OLTC and simple transformer scenarios are congruent, the FSM ones oscillate faster. The oscillation is eliminated after around 6 s.




Figure 5.4: TDS for case study two considering the electrical power P_e for comparing the control schemes; considered machine is at bus two; the result has been zoomed to the limits $x \in [0, 8]$ s and $y \in [-0.1, 1.5]$ p.u..




Figure 5.5: TDS for case study two considering the machine speed ω for comparing the control schemes; considered machine is at bus two; the result has been zoomed to the limits $x \in [0, 8]$ s and $y \in [-0.01, 0.01]$ p.u..

5.3 Summary in Short and Simple Terms

The small excursion on application studies shows an exemplary investigation on the different behaviors of a standalone transformer, versus different tap changer control schemes. The increased stability of faster switching tap changers is illustrated and numerically quantified by an index, ranking how long and how much a bandwidth of accepted voltages is violated. The cut of this bandwidths is labelled with a timestamp. Additionally, the electrical active power injected in the system by the generator can be quantified and alternated through the variable ratio of the fast switching transformer. Hence, one can obtain a shortend frequency of the synchronous machine swinging.

6 Discussion of the Results

This chapter discusses all chapters combined, with found aspects, expected or unexpected behaviors, or comparisons. Singular discussions in each chapter are avoided, to maintain a high level view on the FSM. Nevertheless, details do matter here and are included in the summarized evaluation. The structure of this chapter does not hold up with the before used structure. This shall make use of the combined discussion, more orientating on the found aspects, than the done work.

6.1 Integration in *diffpssi*

First, the done implemetation in the tool of choice, *diffpssi* is discussed. Conspicuities, current existing restrictions of the assessments, as well as missing ones are elaborated. At last, a further idea of utilizing the benefits of *diffpssi* is illustrated.

Implementation of the Models

As the results for the model validation are already described in chapter 4, there is a relatively short discussion on the accounted errors. The errors show overall low values in comparison to the commercial software *DIgSILENT PowerFactory*. The variable ratio transformer itself has errors of maximum in the one digit percent range. As this can also account for solver or time step issues, the Python framework is giving competitive results. Considering the injected errors of the already implemented load model, the results of the control schemes are even less error prone. It is assumed, that because of the longer time period of holding the voltages closer to the reference value, the error can even be dropped. Peaks only occur during the switching of tap positions of the OLTC or FSM, where not only solver issues, but the time filtering or else can accumulate for a very short time. The logic of the FSM controls only shows correct results, as also confirmed by chapter 5.

As the only comparison for the voltage stability tools can be drawn with respect to the Nose Curves, these deliver very good results as well. The curves are congruent, making it hard to visually spread them apart, both compared analytically and with *DIgSILENT*

PowerFactory. The other tools show a logic behavior, as the visual inspections allow for the same claims as the algorithmics. Only one results seems somehow suspect, as the TVI calculation shows even a violation area for the stable cases of one bus in chapter 5, specifically Table 5.3. It was not possible to investigate on the cause of this unexpected behavior so far.

Currently Existing Restrictions

However there are some restrictions to the Python framework, considering the applicability on voltage stability studies. As only static load models or synchronous machines can be represented as loads, the characteristics of a realistic grid is very limited. Further, *diffpssi* only contains the constant impedance load model. Often pointed out by Cutsem and Vournas [12], Kundur and Malik [8], or Danish [11], the bottleneck for remaining stable voltage levels are induction machines. These are currently not available in *diffpssi*, so a lot of studies will not show the same characteristics as one would be able to conduct with comparative (commercial) software. If this model would be available in the future, even combinations with inverters as supporting reactive power source, or connected controllers could be tested very easily. Nevertheless this package is suited well for basic developments of single components, such as a tap changer controller. The logic and algorithmics are implemented fast and allow for a transparent debugging. The easy and close connection with Python does make the package especially great for direct evaluation of results. Either in plotting and visualization, for statistic assessments, or even batch calculations, but as well for further processing and calculations with the results.

Additionally, the variety of available transformer types is also very limited. There are a lot of different technologies possible to consider, from line drop compensations over phase shifting transformers or Wide-Area Monitoring Protection and Control (WAMPAC) approaches. Even simpler things, like parallel transformers, and the related complications with circular currents cannot be addressed with *diffpssi* or this thesis. Regarding transformers, Sarimuthu, Ramachandramurthy, Agileswari, *et al.* [29] is presenting a review paper considering a few of these topics as an overview. When looking at the possible damping factor from the FSM control, one could also think of something like a „machine drop compensation“ for further development.

Missing Assessments in this Thesis

Looking at the integrity of the implemented models, there are a few edge cases or considerations, which are excluded. These however could be beneficial, depending on the application of the technologies. A parameter variation for the FSM characteristics has not been carried out. The standard values presented by Burlakin, Scheiner, Mehlmann, *et al.* [5] have continuously been used, as they are comparable and show conclusive results so far. However for different use cases, voltage and power levels or dynamic loads, also other parameters have to be considered. On top of that and regarding the different basic use cases for transformers, only a transformer connecting a machine was used in this thesis. As transformers for complete power plants, virtual power plants, connecting Battery Energy Storage Systems (BESSs), grid coupling, etc. [3] is usually also covered, these application could also be of interest. The later on discussed control improvements could be not implemented and evaluated as well.

Increasing the Benefits of *diffpssi*

One further interesting application of the Python package *diffpssi* is the possibility for parameter differentiation based on *PyTorch*. Kordowich and Jaeger [7] uses this for an optimization approach, allowing to optimize certain defined simulation parameters to acquire a defined system behavior. For example, the dampening of the synchronous machine swinging after a short-circuit event can be increased. The idea is, to apply this method also on the FSM control scheme, thus optimizing its behavior, e.g. number of switch operations, power oscillation damping or other things. As the tap changer model and its control is already implemented, one could make use of this functionality.

6.2 Evaluation Current FSM Control

The FSM control schemes are analyzed in the following, which characteristics, benefits, and current drawbacks exist. Lastly, further investigations on the control schemes are named, as they are not included in this thesis any more.

Characteristics of the FSM controls

The results as differences are mainly illustrated in the chapter 5, but in some terms visible in chapter 4 as well. The increased stabilization through the FSM control can be confirmed for both switching only with the FSM part and with both dependent on the voltage deviation. The envelopes are not cut after the fault at all, while the OLTC scheme can only postpone the rapid fall a few seconds. Even if one would want to argue, that with the accounted FSM schemes, the control has a wider range of operation. One can clearly see in the TDS, that the rapid intervention of the FSM is holding the voltage closer to the reference value a lot earlier. On top of that, considering the FSM preferring control, no single switch of the OLTC has occurred, and yet the system is stable for a longer period of time.

One main finding in this thesis is the back propagation of the FSM control on the oscillation behavior of synchronous machines after the fault. Clearly, an influence through the ratio is visible, if not even the crucial part to stabilizing the whole system after the fault. Thus the FSM as well help stabilize a system with more and faster dynamics compared to the OLTC. Another finding is the accounted dead band in subsection 4.2.4, which has especially be considered for different combinations of deadband size and switching magnitude of the FSM. As one can also see in Figure 5.1, the FSM ratios are not vastly different from the OLTC, but just are coarser per tap change. As this is leading to a lot less switches of the OLTC and therefore less use of the mechanical switching contacts, both FSM controls seem to have an optimal behavior somewhere in between them. Utilizing the FSM where possible and only short- or mid-term fluctuations occur. And using the OLTC where the load flow and voltage has to be influenced long-term, enabling the most dynamic capabilities.

Further Investigations

Regarding the further investigations of the FSM control schemes, one aspect has to be mentioned. The next step would be an assessment with machine controllers, as gaining insights on how these controllers would interact. If one would want to use a FSM equipped controller as a machine or power plant connector to the grid, this is a crucial part. As the short control times already have an influence on the machine dynamics, they could also interfere with the short term considering machine controllers, like exciters [10]. This expectation holds true for inverter controllers as well.

Regarding the topic increasing voltage stability through a FSM, an even bigger potential is the application on to a phase shifting transformer in particular. As these transformers are also able to change the voltage angle difference between two nodes, this could have an even bigger impact as the standard longitudinal tap changer. When the time until destabilization of the system can be further increased by that, the system cannot only be designed with more risk, but as well withstand larger disturbances.

6.3 Development Potential of the FSM and its Control

This section introduces a few ideas for improvements of the FSM voltage controller. Based on the conducted application studies from chapter 5 and the before deducted discussions, these ideas are not implemented and tested.

Alternative Tap Skipping Logic

The first idea is concerning the function *tap_skip()* in the voltage controller of the FSMs. Especially as the in subsection 4.2.4 illustrated results show a dead band for the FSM preferred control loop, this logic is to be questioned for the voltage deviation dependent switching. In the latter logic, this function *tap_skip()* is making a big influence on the dynamic behavior. If one would try to formulate the current tap skipping function from Equation 2.24 in words, something in the following form could describe it:

How many times does the deadband fit into the voltage deviation? The tap skips are then considered under the amplifying factor of the FSM applied on the tap addition of the OLTC Δm .

As the deadband has less to do with the impact of a FSM switch, and it is already respected within the controller activation of both OLTC and FSM contribution, this relation to the dynamics seems obsolete. An alternative and seemingly more targeted approach would be:

How many switches of the FSM would the current offset voltage bring back to the reference value? In translated terms meaning: How many times does one FSM switch fit into the voltage deviation?

This being translated in mathematical terms, according to Equation 2.24 and the respect of $\eta(t) \in \mathbb{Z}$ and the OLTC voltage addition per tap, the new function for calculating the ideal tap skips by the FSM is formulated in Equation 6.1.

$$\eta(t) = \text{floor}\left(\frac{|\Delta v(t)|}{\Delta k \cdot \Delta m}\right) \quad (6.1)$$

This approach should be more accurate for different pairs of preset values, meaning the size of the deadband, the added voltage per tap, the amplifying factor of the FSM, etc. It is expected, that the current logic results in a plausible way, as the ratio addition per tap of the OLTC is near the size of the deadband. This means, that the proposed function is very similar for the present and in this thesis mainly used parameterization of the FSM control loop. However, it is expected that the proposal is thus more robust and better working for the applied cases and more variations in the configuration.

One comment on this proposal and the original function idea has to be made anyway. Either logic solely considers the influence of the tap changer, but no load or grid dynamics at all. Even the time constants do not have an influence on the switching behavior. As this could also be beneficial for fast responses, the large impact of the novel FSM equipped tap changers in a very short time can also irritate other control units or counteract to processes and destabilize a grid area unnecessarily. Thus a true voltage difference or voltage difference gradient based control scheme, under consideration of the individual minimum possible time constants would appear to be logically the best solution. Such an approach is described in the following.

Operational Oriented FSM Control

The time constants of both parts, the OLTC and the FSM, are relevant as they model the minimal needed duration of the switching. This minimal time is based on mechanical or electric limitations, such as the mechanical movement of the OLTC tap changer. In the current schemes they are not represented as a limitation, but more just as a delay. For example, if the voltage difference falls within the deadband, the integrators or time delays are reset to their initial state. If the falling within was just an error or a short swing, so the deadband is suddenly exceeded again after a very short time. As the switch of the OLTC would mechanically move, this sudden exceed would then let the time delay start from the beginning. While in reality the physical switch has not been given enough time to reach its starting position, the next switch could be achieved faster.

As before described, the longer time constants of the OLTC come from the mechanical switch movement, which are not the case for the FSM. Therefore the maximum dynamic ability to react on voltage deviations is a lot higher for the FSM. Keeping this dynamic capability means according to the findings of section 5.2, that damping reserves for e.g. short-circuit events is held in reserve. With the move from the preferred FSM switching to the voltage dependent activation, a significant step was made towards dynamic influences instead of just a „range extender“. One could think of even improving this behavior, as keeping the dynamic capabilities through re-arranging the positions of k and m . In more static cases a preset of one of the tap changers position, e.g. the more dynamic m , can be restored with keeping the overall ratio constant. This could be possible through coordinated counter switching of the OLTC and the FSM. When considering, that the range of an OLTC is typically around $k \in [-10, 10]$, the FSM seems very limited with $m \in [-4, 4]$. One important influence at this point, is the amplification of the FSM, meaning the factor multiplied with the OLTC tap skip change as FSM voltage deviation per skip. Therefore not all overall tap ratios are representable dependent on the restricted part of the logic and the factor relationships. This would utilize the OLTC better on a long-term perspective, as not only the FSM would be used for small dynamic deviations. The described behavior could be named as corrective supervision or monitoring.

In order to select or deselect the FSM or OLTC, the current approach through the tap skipping function seems hands-on and sufficient. As before described, it does not account for different time constants and thus durations until the voltage deviation can be corrected. This calculation is a retrospective procedure, as only the current value is referenced to the voltage setpoint. If this deviation became too big, the FSM switching is initiated.

In contrast to that, if one would account for the current voltage gradient in addition to the current deviation, a prediction over the time constant modeled switching limitation can be given. This would bring the controller in a mode, where the switching activation would be anticipated. Further a gradient could easily help to determine which part, the FSM for more dynamic action or the OLTC for more static actions, should be used. With this idea one could even imagine neglecting a voltage deadband, as a time deadband would be more applicable towards swing characteristics. As swings, or then damping of swings in a system, would symptomatically end in the same characteristics as tap hunting, this in between mode could be realized. The proposed changes can be realized with a split control path, divided into a preset calculation and a physical switching representation transacting this on to the transformer. These two compartments are then forked with

a corrective supervision to realize off-nominal transformer ratios with optimal dynamic capabilities as presetted by the operator.

Dynamic Measurement and Reference Voltage Setpoints

The last, least expected approach to be profitable, is the area of measurement and reference setting. On the one hand, it could be imagined, tracking the voltages at both busbars and thus getting insights on the load flow direction. The load flow direction, in combination with the relative positioning of slack busbars to the transformer, are expected to define the switching direction of the tap changer transformers. Additionally dynamic setpoints are imagined to be calculated as references. This means, that a new load flow calculation is done every time the load in the network or at least network area changes. With considering a direct supply of only a load, or at least a construct summarizeable as one load, an additional block in the control scheme representing Nose Curves can be imagined as suitable approach. This representation static possible solutions could allow for an automated reference voltage and initial tap changer position. Especially when considering the before described operational oriented control.

7 Summary and Outlook

Concluding this master thesis, a variable ratio transformer model is implemented in a power system simulation framework, based on Python. On top of that, the transformer is equipped with different tap changer control circuits, also satisfying the logic of a novel tap changing technology, the Fast Switching Module (FSM), with an increased dynamic capability. Methods and tools for the evaluation of voltage stability are implemented, the calculation of different nose curves, and an index accounting for the violation integral of a voltage band.

These implementations are compared and validated against the commercial software *DIgSILENT PowerFactory*. An application study is looking into the functionalities and the back propagation on machine dynamics in a simple Single Machine Infinite Bus (SMIB) model.

1. How do different control types and characteristics of transformers with On-Load Tap Changers (OLTCs) influence the voltage stability of a given system?

Considering the first, and main research question, it can be stated, that an increased dynamic capability of a transformer does help stabilizing the bus voltages in a network. Due to the interaction of the fast tapping control with the connected machines, the power and speed oscillations can be slightly damped. Faster reaction on voltage runaways is possible. This increased system stability can be quantified by the Trajectory Violation Integral (TVI), considering a voltage bandwidth as an envelope. Additionally, the critical time of leaving this operational voltage bandwidth can be postponed, enabling other facilities to react with sufficient reactive power supply.

2. Can the already existing tap changer control of the Fast Switching Module (FSM) be improved towards a more operation oriented control?

Answering this questions is highly dependent on the interest of the operational use. As every tap change of the mechanical OLTC is wearing the switch mechanism, while the FSM does not, a grid node with high dynamics will demand other strategies as an either static one. The higher dynamic capability allows more dynamic use cases, than for example just managing the load flow in a network. Especially considering a possible damping moment, the use as a supplementary power oscillation damping is conceivable.

Nevertheless, some improvements targeting also the operational use, are discussed within this thesis. This takes a different voltage dependent enabling into account, which could allow for more variability in the controller parameterization. Further, a new control proposal is illustrated, ensuring more flexibilities and generic use for different applications. An additional integration into the control of synchronous generator is possible, when considering the tap changing transformer as connection to the network.

Some further investigation has to be done either way. The interaction between power plant controllers and the FSM can become a crucial part. Additionally, one might consider implementing also induction machines to the Python module, allowing to look at more voltage threatening scenarios. Additionally, an optimization of the control parameters to different grids or application scenarios would contribute to the understanding and the capabilities as well.

Looking into the future of the FSM, a big topic is the application on phase shifting transformers. Connecting virtual power plants or Battery Energy Storage System (BESS) can become an application for the FSM equipped transformers as well. As the heavy use of inverters in this topic, the advanced transformer could account for side uses as power oscillation damping, enabling more flexibilities in the use of differing operational points for example.

Acronyms

AC	Alternating Current
BESS	Battery Energy Storage System
CIGRE	Conseil International des Grands Réseaux Électriques
CSI	Contingency Severity Index
DC	Direct Current
EMT	Electromagnetic Transient
FRT	Fault-Ride-Through
FSM	Fast Switching Module
GOV	Governor
HV	High Voltage
IBB	Infinite Bus Bar
IEEE	Institute of Electrical and Electronics Engineers
LV	Low Voltage
OLTC	On-Load Tap Changer
PCC	Point of Common Coupling
PSS	Power System Stabilizer
RMS	Root Mean Square
SEXS	Simple Exciter System
SG	Synchronous Generator
SMIB	Single Machine Infinite Bus
TDS	Time Domain Solution
TVI	Trajectory Violation Integral
VSC	Variable Shunt Controller
WAMPAC	Wide-Area Monitoring Protection and Control

Symbols

δ	$^{\circ} / \text{deg}$	Voltage phase angle
ϕ	$^{\circ} / \text{deg}$	Power angle or power factor (as cos, sin, or tan)
ω	$\frac{1}{\text{s}}$	Machine rotor speed
$\underline{\vartheta}$	-	Transformer ratio; complex if phase shifting
\underline{E}	V	Reference voltage
H_{gen}	s	Inertia constant of a Synchronous Generator (SG)
\underline{I}	A	Current
P	W	Active power
Q	var	Reactive power
R	Ω	Ohmic resistance
\underline{S}	VA	Apparent power
\underline{V}	V	Voltage
\underline{X}	Ω	Reactance
\underline{Y}	$\frac{1}{\Omega} / \text{S}$	Admittance
\underline{Z}	Ω	Impedance

Following notation is commonly used for mathematical and physical symbols:

- Phasors or complex quantities are underlined (e.g. \underline{I})
- Arrows on top mark a spatial vector (e.g. \vec{F})
- Boldface upright denotes matrices or vectors (e.g. \mathbf{F})
- Roman typed symbols are units (e.g. s)
- Lower case symbols denote instantaneous values (e.g. i)
- Upper case symbols denote RMS or peak values (e.g. I)
- Subscripts relating to physical quantities or numerical variables are written italic (e.g. I_1)
- Boldface italic denotes sets (e.g. \mathbf{R})

In the simulations and calculations the per unit system (p.u.) is preferred, thus normalizing all values with a base value. For more information about this per-unit system please refer to Machowski, Lubosny, Bialek, *et al.* [10], specifically Appendix A.1 provides a detailed description and explanation. Additionally, Glover, Overbye, and Sarma [21], chapter 3.3 can be considered with some transformer specific calculations.

List of Figures

2.1	Simple load source system for deriving voltage power behaviors	7
2.2	Power Voltage Curves resulting from maximum power transfer equations	9
2.3	Two-Winding Transformer Circuit in the Positive Sequence	13
2.4	Π -representative circuit of an idealized transformer with a tap changer .	14
2.5	Illustration of the voltage vectors for different regulating transformers . .	16
2.6	Control loop of a Fast Switching Module (FSM)	18
2.7	Schematic illustration of the FSM	19
3.1	Architecture of the implemented models in <i>diffpssi</i>	23
3.2	Discrete control loop of an OLTC; from Milano [24].	29
3.3	Characterization of the OLTC control loops	32
3.4	Class diagram of the NoseCurve class in the package <i>diffpssi</i>	34
3.5	Exemplary generated nose curve for a simple generator - load grid	36
3.6	Comparison between the analytical calculation and the implemented solution	36
3.7	Class diagram for the class ViolationIntegral	38
3.8	Class diagram for the class CriticalTimes	38
4.1	Single line representation of the SMIB model	41
4.2	Modified Single Machine Infinite Bus (SMIB) model with additional load	41
4.3	Single line representation of a single machine load model	42
4.4	Model error comparison concerning the variation of the rated apparent power	44
4.5	Error comparison of varying the longitudinal ratio as parameter between <i>diffpssi</i> and <i>DIgSILENT PowerFactory</i>	45
4.6	Comparison of the constant impedance model for each bus	46
4.7	Absolute error comparison of the constant impedance model	47
4.8	Time Domain Result of the OLTC control scheme applied on the extended SMIB network	48
4.9	Bus and Error Comparison for the standard discrete OLTC scheme applied on the extended SMIB model with load	49
4.10	Bus and Error Comparison for the standard discrete OLTC scheme applied on the extended SMIB model with load	50
4.11	Internal signals of the OLTC control in the extended SMIB model	51
4.12	TDS and error comparison for a FSM control scheme based on the voltage difference applied on the extended SMIB model	51

4.13	TDS and error comparison for a FSM control scheme based on the voltage difference applied on the extended SMIB model	52
4.14	Internal signals for a FSM control scheme switching dependent on the voltage deviation	52
4.15	TDS and error comparison for a FSM control scheme based on the voltage difference applied on the simple scenario	53
4.16	Internal signals for a FSM control scheme preferring the FSM	54
4.17	Illustration of the „deaf band“ with the FSM preferring FSM control scheme	55
4.18	Comparison of Nose Curve generation between <i>diffpssi</i> and <i>DIgSILENT PowerFactory</i> for the IEEE 9-bus system	57
4.19	Nose curves dependent on the tap changer ratio for a simple load network	57
4.20	Nose Curve with added TDS and the power of a constant impedance load dependent on the voltage as intersection point.	58
4.21	Nose Curve and TDS for a simple load system without machine controllers	59
4.22	Voltage envelope for a stable scenario	60
4.23	Voltage envelope for an instable scenario	60
5.1	TDS for case study one of the transformer ratios for comparing the control schemes	64
5.2	TDS for case study one split into busbars for comparing the control schemes	66
5.3	TDS for case study two split into busbars for comparing the control schemes	68
5.4	TDS for case study two considering the electrical power	69
5.5	TDS for case study two considering the machine speed	70

List of Tables

2.1	Voltage instability types and different time frames	6
4.1	Values for the standard parameters of an OLTC control	42
4.2	Values for the standard parameters of an FSM control	43
5.1	Parameter set for case study two	64
5.2	Time stamps for the first envelope cuts of each bus and controller in case study one	65
5.3	Results for the TVI and the CSI for case study one	67

Bibliography

- [1] T. P. Hughes, *Networks of Power: Electrification in Western Society, 1880-1930*, Softshell Books ed. Baltimore: Johns Hopkins University Press, 1993, ISBN: 978-0-8018-4614-4 978-0-8018-2873-7.
- [2] W. G. Hurley and W. H. Wölflé, *Transformers and Inductors for Power Electronics: Theory, Design and Applications*, Reprinted with corrections. Chichester: Wiley, 2014, ISBN: 978-1-119-95057-8.
- [3] A. J. Schwab, *Elektroenergiesysteme: Smarte Stromversorgung Im Zeitalter Der Energiewende*, 7. Auflage. Berlin [Heidelberg]: Springer Vieweg, 2022, ISBN: 978-3-662-64773-8.
- [4] Maschinenfabrik Reinhausen GmbH, “Method and Device for Changing a Transformation Ratio, an Impedance, or a Voltage Used for Excitation”, WO/2023/217517, 2023.
- [5] I. Burlakin, E. Scheiner, G. Mehlmann, *et al.*, “Enhanced Voltage Control in Off-shore Wind Farms with Fast-Tapping on-Load Tap-Changers”, in *23rd Wind & Solar Integration Workshop*, Helsinki, Finland, Oct. 2024.
- [6] I. Burlakin, E. Scheiner, G. Mehlmann, *et al.*, “Enhancing Variable Shunt Reactors with a Power Electronic Fast-Switching Module”, in *Power Transformers and Reactors (A2)*, Paris: CIGRE, Aug. 2024.
- [7] G. Kordowich and J. Jaeger, *A Physics Informed Machine Learning Method for Power System Model Parameter Optimization*, Sep. 2023. arXiv: 2309.16579 [cs, eess]. (visited on 09/02/2024).
- [8] P. S. Kundur and O. P. Malik, *Power System Stability and Control*, Second edition. New York Chicago San Francisco Athens London Madrid Mexico City Milan New Delhi Singapore Sydney Toronto: McGraw Hill, 2022, ISBN: 978-1-260-47354-4.
- [9] F. Milano, *Power System Modelling and Scripting* (Power Systems), 1. ed. Heidelberg: Springer, 2010, ISBN: 978-3-642-13668-9.
- [10] J. Machowski, Z. Lubosny, J. W. Bialek, and J. R. Bumby, *Power System Dynamics: Stability and Control*, Third edition. Hoboken, NJ, USA: John Wiley, 2020, ISBN: 978-1-119-52636-0.
- [11] M. S. S. Danish, *Voltage Stability in Electric Power System: A Practical Introduction*. Berlin: Logos-Verl, 2015, ISBN: 978-3-8325-3878-1.

- [12] T. Cutsem and C. Vournas, *Voltage Stability of Electric Power Systems*. Boston, MA: Springer US, 1998, ISBN: 978-0-387-75535-9. DOI: 10.1007/978-0-387-75536-6. (visited on 10/24/2024).
- [13] D. Shoup, J. Paserba, and C. Taylor, “A survey of current practices for transient voltage dip/sag criteria related to power system stability”, in *IEEE PES Power Systems Conference and Exposition, 2004.*, Oct. 2004, 1140–1147 vol.2. DOI: 10.1109/PSCE.2004.1397688. (visited on 04/15/2025).
- [14] J. L. Rueda-Torres, U. Annakage, C. Vournas, *et al.*, “Evaluation of Voltage Stability Assessment Methodologies in Modern Power Systems with Increased Penetration of Inverter-Based Resources (tr 126)”, 2024. DOI: 10.17023/SA3K-AZ76. (visited on 12/02/2024).
- [15] T. Van Cutsem, M. Glavic, W. Rosehart, *et al.*, “Test Systems for Voltage Stability Studies”, *IEEE Transactions on Power Systems*, vol. 35, no. 5, pp. 4078–4087, Sep. 2020, ISSN: 0885-8950, 1558-0679. DOI: 10.1109/TPWRS.2020.2976834. (visited on 11/08/2024).
- [16] C. E. Doig Cardet, “Analysis on Voltage Stability Indices”, M.S. thesis, RWTH Aachen, 2010. (visited on 02/04/2025).
- [17] E. Scheiner, I. Burlakin, N. Strunz, A. Raab, G. Mehlmann, and M. Luther, “Impact of Time Constants of Reactive Power Sources on Short-Term Voltage Stability”, in *2022 IEEE Transportation Electrification Conference & Expo (ITEC)*, Jun. 2022, pp. 161–165. DOI: 10.1109/ITEC53557.2022.9813987. (visited on 04/13/2025).
- [18] S. Wildenhues, J. L. Rueda, and I. Erlich, “Optimal Allocation and Sizing of Dynamic Var Sources Using Heuristic Optimization”, *IEEE Transactions on Power Systems*, vol. 30, no. 5, pp. 2538–2546, Sep. 2015, ISSN: 1558-0679. DOI: 10.1109/TPWRS.2014.2361153. (visited on 04/13/2025).
- [19] *Technische Regeln Für Den Anschluss Von Kundenanlagen an Das Höchstspannungsnetz Und Deren Betrieb (TAR Höchstspannung)*, Technische Anschlussregelung, 2018.
- [20] *Technische Regeln Für Den Anschluss Von Kundenanlagen an Das Mittelspannungsnetz Und Deren Betrieb (TAR Mittelspannung)*, 2023.
- [21] J. D. Glover, T. J. Overbye, and M. S. Sarma, *Power System Analysis & Design*, Sixth edition. Boston, MA: Cengage Learning, 2017, ISBN: 978-1-305-63213-4.
- [22] D. Oeding and B. R. Oswald, *Elektrische Kraftwerke und Netze*, 8. Auflage. Berlin [Heidelberg]: Springer Vieweg, 2016, ISBN: 978-3-662-52702-3. DOI: 10.1007/978-3-662-52703-0.

-
- [23] J. Wang, S. Shin, M. Numair, P. Meira, and alexe15, *Ps-wiki/best-of-ps: Update: 2025.04.03*, Zenodo, Apr. 2025. DOI: 10.5281/ZENODO.15133452. (visited on 04/07/2025).
- [24] F. Milano, “Hybrid Control Model of Under Load Tap Changers”, *IEEE Transactions on Power Delivery*, vol. 26, no. 4, pp. 2837–2844, Oct. 2011, ISSN: 0885-8977, 1937-4208. DOI: 10.1109/TPWRD.2011.2167521. (visited on 09/02/2024).
- [25] V. Ajjarapu and C. Christy, “The Continuation Power Flow: A Tool for Steady State Voltage Stability Analysis”, *IEEE Transactions on Power Systems*, vol. 7, no. 1, pp. 416–423, Feb. 1992, ISSN: 08858950. DOI: 10.1109/59.141737. (visited on 03/26/2025).
- [26] V. Ajjarapu, Ed., *Computational Techniques for Voltage Stability Assessment and Control* (Power Electronics and Power Systems). Boston, MA: Springer US, 2007, ISBN: 978-0-387-26080-8. DOI: 10.1007/978-0-387-32935-2. (visited on 03/26/2025).
- [27] *IEEE Guide for Load Modeling and Simulations for Power Systems*, 2022. DOI: 10.1109/IEEESTD.2022.9905546. (visited on 11/08/2024).
- [28] P. M. Anderson and A. A. Fouad, *Power System Control and Stability* (IEEE Press Power Engineering Series), 2nd ed. Piscataway, N.J: IEEE Press ; Wiley-Interscience, 2003, ISBN: 978-0-471-23862-1.
- [29] C. R. Sarimuthu, V. K. Ramachandaramurthy, K. Agileswari, and H. Mokhlis, “A review on voltage control methods using on-load tap changer transformers for networks with renewable energy sources”, *Renewable and Sustainable Energy Reviews*, vol. 62, pp. 1154–1161, Sep. 2016, ISSN: 13640321. DOI: 10.1016/j.rser.2016.05.016. (visited on 09/26/2024).

Appendix

A	Fundamentals	A-2
A.1	Voltage Stability Basics: Definitions	A-2
A.2	Comparison of Trigonometric Functions	A-3
B	Modeling	A-5
B.1	Alternative Current Injection Model	A-5
B.2	Program Structure for the discrete OLTC Control	A-6
B.3	Program Structure for the discrete FSM Control	A-7
B.4	Class Diagrams	A-8
B.4.1	Extended Class Diagram of the OLTC Transformer	A-8
B.4.2	Extended Class Diagram of the Discrete OLTC Control	A-8
B.4.3	Extended Class Diagram of the Discrete FSM Control	A-9
B.4.4	Class Diagram of the Class Nose Curves	A-9
C	Validation	A-10
C.1	Details About Used Networks	A-10
C.1.1	Single-Machine Infinite Bus-Bar Model	A-10
C.1.2	Simple Load Model	A-12
C.1.3	Machine Controller Parameters	A-14
C.1.4	Tap Changer Controller Parameters	A-15
C.2	Additional Plots from the II-Model Validation	A-17
C.3	Additional Plots from the Tap Changer Control Schemes	A-20
C.3.1	OLTC validation	A-20
C.3.2	FSM validation	A-22

A Fundamentals

A.1 Voltage Stability Basics: Definitions

All of the following definitions are direct citations, and therefore the same wording as in the paper of Shoup, Paserba, and Taylor [13]. The definitions are short, precise and summarized resp. synthesized from papers and report from Conseil International des Grands Réseaux Électriques (CIGRE)¹ and Institute of Electrical and Electronics Engineers (IEEE).

Voltage dip:

„A temporary reduction of the voltage at a point in the electrical system below a threshold. If during a voltage dip the voltage falls below an interruption threshold, the event is sometimes considered to be both a dip and an interruption.“

Voltage sag:

„An rms variation with a magnitude between 10 % and 90 % of nominal and a short duration between 0.5 cycles and one minute.“

Power system stability:

„Power system stability is the ability of an electric power system, for a given initial operating condition, to regain a state of operating equilibrium after being subjected to a physical disturbance, with most system variables bounded so that practically the entire system remains intact.“

Voltage stability:

„Voltage stability refers to the ability of a power system to maintain steady voltages at all buses in the system after being subjected to a disturbance from a given initial operating condition. It depends on the ability to maintain/restore equilibrium between load demand and load supply from the power system. Instability that may result occurs in the form of a progressive fall or rise of voltages of some buses. A possible outcome of voltage instability is a loss

¹french for International Council on Large Electric Systems

of load in an area, or tripping of transmission lines and other elements by their protective systems leading to cascading outages. Loss of synchronism of some generators may result from these outages or from operation under field current limit.“

Short-term voltage stability:

„Short-term voltage stability involves dynamics of fast acting load components such as induction motors, electronically controlled loads and HVDC converters. The study period of interest is in the order of several seconds, and analysis requires solutions of appropriate system differential equations; that is similar to analysis of rotor angle stability. Dynamic modeling of loads is often essential. In contrast to angle stability, short-circuits near loads are important. The term transient voltage stability is deprecated.“

A.2 Comparison of Trigonometric Functions




Figure A.1: Plot comparison of trigonometric functions.

Trigonometric functions are used as relation between apparent power S , active P and reactive power Q . While in discription of dynamics, the planning of networks or connection of machines, often the cosinodal function and therefore its value is present in the feeling of (engineering) people. In stability analysis often the tan function is used, simply because its directly connecting onle active and reactive power, and because some athematic reformulations are possible with that. Figure A.1 is illustrating relations of these functional values to the angle in rad and degree, while Table A.1 gives a numerical connection. This shall increase the feeling and evaluation of this thesis readers.

Table A.1: Comparison of trigonometric functions dependent on the angle ϕ in degree or radians

Angle in $^{\circ}$	Angle in rad	sin	cos	tan
0	0	0	1	0
10	0.1745	0.1736	0.9848	0.1763
20	0.3490	0.3420	0.9397	0.3640
30	0.5236	0.5	0.8660	0.5774
40	0.6981	0.6428	0.7660	0.8391
50	0.8727	0.7660	0.6428	1.1918
60	1.0472	0.8660	0.5	1.7321
70	1.2217	0.9397	0.3420	2.7475
80	1.3962	0.9848	0.1736	5.6713
90	1.5708	1	0	\nexists
120	2.0944	0.8660	-0.5	-1.7321
150	2.6180	0.5	-0.8660	-0.5774
180	3.1416	0	-1	0

B Modeling

B.1 Alternative Current Injection Model

Machowski, Lubosny, Bialek, *et al.* [10] describes another way of modeling a OLTC transformer with variable ratio. This model is looking at the shunt brnaches as current injections, which are added to the individual busses. Beneficial, the system admittance matrix is staying symmetrical, while the different transformer state(s) are represented by the different current injections. This can be mathematically expressed by following set of equations:

$$\begin{aligned} \begin{bmatrix} \underline{I}_1 \\ -\underline{I}_2 \end{bmatrix} &= \begin{bmatrix} \underline{Y}_T & -\underline{Y}_T \\ -\underline{Y}_T & \underline{Y}_T \end{bmatrix} \begin{bmatrix} \underline{U}_1 \\ \underline{U}_2 \end{bmatrix} - \begin{bmatrix} \Delta \underline{I}_1 \\ \Delta \underline{I}_2 \end{bmatrix}, \text{ where} \\ \begin{bmatrix} \Delta \underline{I}_1 \\ \Delta \underline{I}_2 \end{bmatrix} &= \begin{bmatrix} \underline{0} & (\vartheta - 1)\underline{Y}_T \\ -(\vartheta^* + 1)\underline{Y}_T & (\vartheta^* \vartheta + 1)\underline{Y}_T \end{bmatrix} \begin{bmatrix} \underline{U}_1 \\ \underline{U}_2 \end{bmatrix} \text{ leading to} \\ \underline{\mathbf{Y}}_{\Pi, T, \text{Current Injection}} &= \begin{bmatrix} \underline{Y}_T & -\underline{Y}_T \\ -\underline{Y}_T & \underline{Y}_T \end{bmatrix} - \begin{bmatrix} \underline{0} & (\vartheta - 1)\underline{Y}_T \\ -(\vartheta^* + 1)\underline{Y}_T & (\vartheta^* \vartheta + 1)\underline{Y}_T \end{bmatrix} \end{aligned}$$

B.2 Program Structure for the discrete OLTC Control




Figure B.1: Program or algorithmic structure for the control scheme of the OLTC control.

B.3 Program Structure for the discrete FSM Control




Figure B.2: Program or algorithmic structure for the control scheme of the FSM control; the sketched red substitution accounts for the difference between the FSM preferring (black) and the voltage dependent enabling (red).

B.4 Class Diagrams

B.4.1 Extended Class Diagram of the OLTC Transformer




Figure B.3: Class Diagram of the OLTC transformer model; requires connection to a voltage controller.

B.4.2 Extended Class Diagram of the Discrete OLTC Control




Figure B.4: Class Diagram of the OLTC voltage controller.

B.4.3 Extended Class Diagram of the Discrete FSM Control

FSM1
...
differential : tensor get_output : float get_state_vector : tensor set_state_vector(x : tensor) : None switching_k(voltage : float) : None switching_m(voltage : float, tap_skips : int) : None tap_skips(voltage : float) : int

Figure B.5: Class Diagram of the FSM voltage controller.

B.4.4 Class Diagram of the Class Nose Curves

NoseCurve
res_variation : dict results : dict ps_sim : object
run_calculation(bus : list) : dict run_variation_calculation(bus : list) : dict plot_nose_curve(busses : list) : object plot_nose_curve_variation(busses : list) : object get_max_loadings(busses : list) : dict add_load_to_plot(load : list, bus : str, current_plot : object) : object

Figure B.6: Complete class diagram of the class Nose Curves; including all attributes and methods with data types, returns, and inputs.

C Validation

C.1 Details About Used Networks

For all simulation networks and accounted grids, the following presets are used.

Parameter	Value	Unit
Simulation base apparent power S_{base}	2 200	s
Simulation base frequency f	60	Hz
Simulation base voltage \underline{V}	100	kV

C.1.1 Single-Machine Infinite Bus-Bar Model

The simulation set-up for the SMIB model is detailed in the following. Starting with the Busses, the voltages are set to

$$\underline{V}_{\text{B0}} = 100 \text{ kV}$$

$$\underline{V}_{\text{B1}} = 100 \text{ kV}$$

$$\underline{V}_{\text{B2}} = 10 \text{ kV}$$

The line reactance is set to $X = 0.0484$ p.u.. It connects bus zero with bus one. The possible added load connects to bus one. The applied transformer parameters are as follows. The transformer connects bus one with bus two.

Parameter	Value	Unit
Apparent Power S_n	4 400	MVA
Resistance R	0	p.u.
Reactance X	0.15	p.u.
Power angle difference ϕ	0	p.u.

For the generator at bus zero the values are set to:

Parameter	Value	Unit
Apparent Power S_n	11 000	p.u.
Nominal voltage \underline{V}_n	100	kV
Active power output P	-1 998	MW
Voltage setpoint \underline{V}	0.995	p.u.
Inertia H	3.5e7	s
Damping D	0	p.u.
Reactance X_d	1.81	p.u.
Reactance X_q	1.76	p.u.
Reactance $X_{d,t}$	0.3	p.u.
Reactance $X_{q,t}$	0.65	p.u.
Reactance $X_{d,st}$	0.23	p.u.
Reactance $X_{q,st}$	0.23	p.u.
Time constant $T_{d0,t}$	8	s
Time constant $T_{q0,t}$	1	s
Time constant $T_{d0,st}$	0.03	s
Time constant $T_{q0,st}$	0.07	s

For the generator at bus two the values are set to:

Parameter	Value	Unit
Apparent Power S_n	2 200	p.u.
Nominal voltage \underline{V}_n	10	kV
Active power output P	1 998	MW
Voltage setpoint \underline{V}	1	p.u.
Inertia H	3.5	s
Damping D	0	p.u.
Reactance X_d	1.81	p.u.
Reactance X_q	1.76	p.u.
Reactance $X_{d,t}$	0.3	p.u.
Reactance $X_{q,t}$	0.65	p.u.
Reactance $X_{d,st}$	0.23	p.u.
Reactance $X_{q,st}$	0.23	p.u.
Time constant $T_{d0,t}$	8	s
Time constant $T_{q0,t}$	1	s
Time constant $T_{d0,st}$	0.03	s
Time constant $T_{q0,st}$	0.07	s

C.1.2 Simple Load Model

The simulation set-up for the SMIB model is detailed in the following. Starting with the Busses, the voltages are set to

$$\underline{V}_{B0} = 10 \text{ kV}$$

$$\underline{V}_{B1} = 100 \text{ kV}$$

The applied transformer parameters are as follows. The transformer connects bus zero with bus one.

Parameter	Value	Unit
Apparent Power S_n	2 200	MVA
Resistance R	0	p.u.
Reactance X	0.15	p.u.
Power angle difference ϕ	0	p.u.

For the generator at bus zero the values are set to:

Parameter	Value	Unit
Apparent Power S_n	2 200	p.u.
Nominal voltage \underline{V}_n	10	kV
Active power output P	-1 998	MW
Voltage setpoint \underline{V}	1	p.u.
Inertia H	3.5	s
Damping D	0	p.u.
Reactance X_d	1.81	p.u.
Reactance X_q	1.76	p.u.
Reactance $X_{d,t}$	0.3	p.u.
Reactance $X_{q,t}$	0.65	p.u.
Reactance $X_{d,st}$	0.23	p.u.
Reactance $X_{q,st}$	0.23	p.u.
Time constant $T_{d0,t}$	8	s
Time constant $T_{q0,t}$	1	s
Time constant $T_{d0,st}$	0.03	s
Time constant $T_{q0,st}$	0.07	s

C.1.3 Machine Controller Parameters

Table C.1: Machine controller parameters for the Governor (GOV).

Parameter	Value	Unit
R	0.05	p.u.
D_t	0.02	p.u.
V_{\min}	0	p.u.
V_{\max}	1	p.u.
T_1	0.5	s
T_2	2	s
T_3	2	s

Table C.2: Machine controller parameters for the Simple Exciter System (SEXS).

Parameter	Value	Unit
K	100	-
T_a	4	s
T_b	10	s
T_e	0.1	s
E_{\min}	-10	-
E_{\max}	10	-

Table C.3: Machine controller parameters for the Power System Stabilizer (PSS).

Parameter	Value	Unit
K	50	-
T_1	10	s
T_1	0.5	s
T_2	0.5	s
T_3	0.5	s
T_4	0.5	s
H_{lim}	0.03	p.u.

C.1.4 Tap Changer Controller Parameters

Table C.4: Values for the standard parameters of an OLTC control.

Parameter	Value	Unit
Time constant T_1	5	s
Size of deadband db	0.05	p.u.
Tap ratio change per switch Δm	0.02	p.u.
Minimum transformer ratio m_{min}	0.9	p.u.
Maximum transformer ratio m_{max}	1.1	p.u.
Initial reference voltage v_{ref}	1.0	p.u.

Table C.5: Values for the standard parameters of an FSM control.

Parameter	Value	Unit
Time constant FSM t_m	0.02	p.u.
Time constant OLTC t_k	5	p.u.
Size of deadband db	0.025	p.u.
Tap ratio change per switch FSM Δm	2	p.u.
Tap ratio change per switch OLTC Δk	0.02	p.u.
Maximum tap position FSM m_{\max}	4	p.u.
Minimum tap position FSM m_{\min}	-4	p.u.
Maximum tap position OLTC k_{\max}	10	p.u.
Minimum tap position OLTC k_{\min}	-10	p.u.
Initial reference voltage v_{ref}	1	p.u.
Maximum tap skips γ_{\max}	8	p.u.
Filtering time constant pt_1	0.01	p.u.

C.2 Additional Plots from the Π -Model Validation




Figure C.1: Voltage results of the Π -modeled transformer in the SMIB model between PowerFactory and the Python framework; Variation of the rated apparent power S_n ; Left column is showing the data for the Python module *diffpssi*, on the right the comparative tool *DIgSILENT PowerFactory*.




Figure C.2: Comparison of one variation parameter between *diffpssi* and *DIgSILENT PowerFactory*; each plot focussing on one bus in the variation of the rated apparent power S_n .




Figure C.3: Comparison of the Π -modeled transformer in the SMIB model between PowerFactory and the Python framework.




Figure C.4: Comparison of one variation parameter between *diffpssi* and *DIgSILENT PowerFactory*; each plot focussing on one bus in the variation of the longitudinal transformer ratio ϑ .

C.3 Additional Plots from the Tap Changer Control Schemes

C.3.1 OLTC validation

The plots and results for the simple single machine load model.




Figure C.5: Time Domain Solution (TDS) for standard discrete OLTC control scheme applied to the simple load network.

The plots and results for the extended SMIB model with load.




Figure C.6: Time Domain Solution (TDS) of the standard discrete OLTC control scheme; Result of the extended or modified SMIB model with additional load.




Figure C.7: Internal signal of the standard discrete OLTC control: The integrator signal, representing the time constant for enabling the switching operation.

C.3.2 FSM validation

The plots and results for the simple single machine load model.




Figure C.8: Signal evolution for the voltage difference dependent FSM control scheme; Plot of the deadband filtered voltage difference v_{dead} for the simple load validation case.

The plots and results for the extended SMIB model with load.




Figure C.9: TDS for a FSM control scheme switching based on the voltage difference.




Figure C.10: Differing TDS for a FSM control scheme preferring the FSM.