Hazard Assessment Form

Version Control

Version	Date	Author	Notes	Approved By:	Date:
1	N/A	Wendy	New Form Created		
2	16-Dec-2025	Megha	Added extra columns Generic Information Section Revised Formatting and fillable PDF conversion		
3	28-Jan-2026	Sandra	First Version of Hazards for Maxim Mechanical Group Inc.	Peter Godler	Feb 4, 2026

Hazard Assessment Form

Date of Assessment:	**January 28, 2026**	**Job/position:**	**Plumber**	**Date Reviewed:**	**Feb 11, 2026**
Assessment performed by:	**Sandra Tutka**	**Supervisor:**	**BJ Wilson**	**Date Implemented:**	**Feb 25, 2026**

		Inherent Risk Before Controls				**Residual Risk After Controls**		
Task	**Hazards Present**	**Likelihood**	**Severity**	**Risk Level**	**Hierarchy of Control in Place**	**Likelihood**	**Severity**	**Risk Level**
installing / repairing piping systems	Heavy lifting, awkward postures, Back injuries, muscle strains, shoulder injuries	**Probable (3)**	**Moderate (2)**	**6**	**Engineering:** Pipe stands, lifts, material carts. **Administrative:** Team lifts, safe lifting training, **job planning. PPE:** Gloves, steel-toe boots.	**Possible (2)**	**Moderate (2)**	**4**
Cutting, threading, or grinding pipe	Flying debris, sparks, sharp edges, noise. Eye injuries, cuts.	**Probable (3)**	**Moderate (2)**	**6**	**Engineering:** Machine guards, spark containment. **PPE**: Safety glasses + face shield, cut-resistant gloves, hearing protection.	**Possible (2)**	**Minimal (1)**	**2**
Welding / soldering / brazing	Respiratory irritation, burns, fire, eye damage UV radiation	**Expected (4)**	**Serious (3)**	**12**	**Elimination:** Prefabrication **Engineering:** Local exhaust ventilation, fire blankets. **Administrative:** Hot work permit, fire watch. **PPE:** Welding helmet, gloves, FR clothing, respirator if required.	**Possible (2)**	**Moderate (2)**	**4**
Working at heights (ladders, lifts)	Falls from height, falling tools/materials	**Probable (3)**	**Catastrophic (4)**	**12**	**Engineering:** Guardrails, lift platforms. **Administrative**: Fall protection plan, ladder safety training**. PPE:** Fall arrest harness, hard hat.	**Possible (2)**	**Minimal (1)**	**2**

Hazard Assessment Form

Working in mechanical rooms	Congested spaces, hot surfaces, noise damage, burns, struck-by injuries	**Probable (3)**	**Serious (3)**	**9**	**Engineering**; adequate lighting, communication device **Administrative**: Housekeeping, restricted access. **PPE**: Gloves, long sleeves, hearing protection.	**Remote (1)**	**Moderate (2)**	**2**
Confined space entry (tanks, pits, vaults)	Low oxygen, toxic gases, Asphyxiation, poisoning, fatality	**Probable (3)**	**Catastrophic (4)**	**12**	**Elimination**: Use external access methods if possible. **Engineering**: Ventilation systems, gas monitors. **Administrative**: Confined space program, entry permits, rescue plan.	**Possible (2)**	**Moderate (2)**	**4**
Pressure testing piping systems	Line rupture, flying debris, sudden release of pressure. Struck-by injuries, lacerations, hearing damage	**Possible (2)**	**Serious (3)**	**6**	**Administrative**: Test procedures, exclusion zones. **PPE**: Face shield, gloves, hearing protection.	**Possible (2)**	**Minimal (1)**	**2**
Working around energized systems	Electrical shock from electrical equipment, water near power	**Possible (2)**	**Catastrophic (4)**	**8**	**Engineering**: proper grounding. **Administrative**: Lockout/tagout (LOTO), coordination with electricians. **PPE**: Dielectric gloves, safety boots.	**Remote (1)**	**Minimal (1)**	**1**
Demolition / removal of old piping	Cuts, struck-by injuries, exposure to unknown substances and materials	**Probable (3)**	**Moderate (2)**	**6**	**Elimination**: Use machinery. **Engineering**: Dust control, debris containment. **Administrative**: Safe demo procedures. **PPE**: Cut-resistant gloves, respirator.	**Possible (2)**	**Moderate (2)**	**4**
Use of power tools (drills, saws)	Kickback injurie, vibration, noise, hearing loss	**Expected (4)**	**Serious (3)**	**12**	**Engineering**: guards. **Administrative**: Tool inspection program, training. **PPE**: Gloves, hearing protection, eye protection.	**Possible (2)**	**Minimal (1)**	**2**
Trenching for underground plumbing	Cave-ins, engulfment, water ingress, crushing	**Possible (2)**	**Serious (3)**	**6**	**Engineering**: Trench boxes, shoring, utility locates. **Administrative**: Excavation permits, competent supervision. **PPE**: Hard hat, high-vis, boots.	**Remote (1)**	**Serious (3)**	**3**

Hazard Assessment Form

Working in hot or cold environments	Dehydration, heat stroke, frostbite	**Possible (2)**	**Serious (3)**	**6**	**Engineering**: Heated/cooled break areas. **Administrative**: Work-rest cycles, hydration. **PPE**: Weather-appropriate PPE.	**Possible (2)**	**Minimal (1)**	**2**
Slips, trips, and falls on job sites	Uneven ground, debris, wet surfaces	**Expected (4)**	**Moderate (2)**	**8**	**Engineering**: cable management. **Administrative**: Good housekeeping, site orientation. **PPE**: Slip-resistant, steel-toe boots.	**Possible (2)**	**Minimal (1)**	**2**
Exposure to chemicals (glues, solvents, cleaners)	Dermatitis, respiratory irritation, dizziness	**Possible (2)**	**Moderate (2)**	**4**	**Elimination**: Low-VOC products. **Engineering**: Ventilation. **Administrative**: WHMIS training, SDS documentation. **PPE**: Gloves, goggles, respirator if required.	**Remote (1)**	**Minimal (1)**	**1**
Interaction with other trades / mobile equipment	Struck-by moving equipment, dropped materials, serious injury, fatality	**Probable (3)**	**Catastrophic (4)**	**12**	**Engineering**: Barriers, defined walkways. **Administrative**: Site safety meetings, traffic control plans. **PPE**: High-visibility clothing, hard hat, safety boots.	**Probable (3)**	**Moderate (2)**	**6**
Exposure to opioids or other controlled substances	accidental contact, inhalation, or ingestion which may result in overdose, respiratory depression, or other serious health effects	**Possible (2)**	**Catastrophic (4)**	**8**	**Elimination:** Avoid entering high-risk environments. **Engineering**: Use barriers, proper ventilation. **Administrative:** Training on hazard recognition, safe handling procedures, incident response, naloxone training **PPE:** gloves, masks	**Remote (1)**	**Moderate (2)**	**4**

Hazard Assessment Form

Level of Risk Chart

Likelihood: The likelihood parameter looks at the chance of a negative situation occurring.

Severity: Severity measures the degree of harm that exposure to the hazard could result in.

The level of risk is determined by the equation: **Likelihood x Severity = Risk** as per the table below.

Risk Chart		Likelihood of Occurrence			
		Expected (4) Very likely to happen	**Probable (3)** Could happen	**Possible (2)** A chance it could happen	**Remote (1)** Very unlikely to happen
Severity	**Catastrophic (4)** Death, critical injury, property damage over $10K	16	12	8	4
	Serious (3) Medical Aid, lost time, property damage over $5K	12	9	6	3
	Moderate (2) First Aid, Minor illness, Property damage over $1K	8	6	4	2
	Minimal (1) No injury, minor damage	4	3	2	1

The risk score is then used to determine a risk category which will dictate actions required to manage the risk.

Risk Score Level	Risk Category	Action Required
16	Severe	Stop work immediately, implement controls to reduce the risk
9-12	High	Consider additional controls to reduce the risk. Create a Safe Work (Job) Procedure
4 -8	Medium	Consider additional controls, Create a Safe Work Practice
1 - 3	Low	Minimal risk, monitor the operation

Hazard Assessment Form