Hazard Assessment Form

Version Control

Version	Date	Author	Notes	Approved By:	Date:
1	N/A	Wendy	New Form Created		
2	16-Dec-2025	Megha	Added extra columns Generic Information Section Revised Formatting and fillable PDF conversion		
3	30-Jan-2026	Sandra	First Version of Hazards for Maxim Mechanical Group Inc.	Peter Godler	Feb 4, 2026

Hazard Assessment Form

Date of Assessment:	January 30, 2026	Job/position:	Gas Fitter	Date Reviewed:	Feb 4, 2026
Assessment performed by:	Sandra Tutka	Supervisor:	BJ Wilson	Date Implemented:	Feb 25, 2026

		Inherent Risk Before Controls				Residual Risk After Controls		
Task	**Hazards Present**	**Likelihood**	**Severity**	**Risk Level**	**Hierarchy of Control in Place**	**Likelihood**	**Severity**	**Risk Level**
Installing large-bore piping and gas lines	Heavy materials, awkward postures, injuries, crushed fingers, muscle strains	**Probable (3)**	**Moderate (2)**	6	**Engineering**: Pipe stands, chain falls, mechanical lifts. **Administrative**: Lift planning, team lifts, rigging procedures. **PPE**: Gloves, steel-toe boots.	**Possible (2)**	**Minimal (1)**	2
Rigging and positioning pipe spools	Struck-by, caught-between, fatal injury	**Probable (3)**	**Catastrophic (4)**	12	**Engineering**: Certified lifting devices, tag lines. **Administrative**: Qualified riggers, exclusion zones, lift plans. **PPE**: Hard hat, high-vis, gloves.	**Possible (2)**	**Minimal (1)**	2
Cutting, beveling, grinding pipe	Flying debris, sparks, sharp edges, noise. Eye injuries, cuts.	**Probable (3)**	**Moderate (2)**	6	**Engineering**: Machine guards, spark containment. **PPE**: Safety glasses + face shield, cut-resistant gloves, hearing protection.	**Possible (2)**	**Minimal (1)**	2
Welding on gas or process piping	Fumes, UV radiation, fire/explosion risk	**Probable (3)**	**Catastrophic (4)**	12	**Elimination:** Prefabrication **Engineering:** Local exhaust ventilation, fire blankets. **Administrative:** Hot work permit, fire watch. **PPE:** Welding helmet, gloves, FR clothing, respirator if required.	**Possible (2)**	**Moderate (2)**	4
Purging, pressure testing, and commissioning gas lines	Line rupture, flying debris, sudden release of pressure. Struck-by injuries, lacerations, hearing damage	**Possible (2)**	**Serious (3)**	6	**Administrative:** Test procedures, exclusion zones. **PPE:** Face shield, gloves, hearing protection.	**Possible (2)**	**Minimal (1)**	2

Hazard Assessment Form

Working around live gas systems	Gas leaks, fire, explosion, oxygen displacement	**Probable (3)**	**Catastrophic (4)**	**12**	**Elimination**: Isolate and de-energize. **Engineering**: Gas detection systems, ventilation. **Administrative**: Lockout/tagout, gas monitoring, permit. **PPE**: Flame-resistant clothing, gas monitor.	**Possible (2)**	**Moderate (2)**	**4**
Confined space work (vaults, boiler rooms, tanks)	Low oxygen, toxic gases, Asphyxiation, poisoning, fatality	**Probable (3)**	**Catastrophic (4)**	**12**	**Elimination**: Use external access methods if possible. **Engineering**: Ventilation systems, gas monitors. **Administrative**: Confined space program, entry permits, rescue plan.	**Possible (2)**	**Moderate (2)**	**4**
Working at heights (scissor lifts)	Falls from height, falling tools/materials	**Probable (3)**	**Catastrophic (4)**	**12**	**Engineering**: Guardrails, lift platforms. **Administrative**: Fall protection plan, ladder safety training. **PPE**: Fall arrest harness, hard hat.	**Possible (2)**	**Minimal (1)**	**2**
Demolition or tie-ins to existing systems	Explosion, chemical exposure, burns, Line rupture, flying debris, sudden release of pressure	**Probable (3)**	**Serious (3)**	**9**	**Elimination**: Use machinery. **Engineering**: Dust control, debris containment. **Administrative**: Safe dem procedures. **PPE**: Cut-resistant gloves, respirator.	**Possible (2)**	**Moderate (2)**	**4**
Use of power tools (drills, saws)	Kickback injurie, vibration, noise, hearing loss	**Expected (4)**	**Serious (3)**	**12**	**Engineering**: guards. **Administrative**: Tool inspection program, training. **PPE**: Gloves, hearing protection, eye protection.	**Possible (2)**	**Minimal (1)**	**2**
Exposure to industrial noise	Noise-induced hearing loss	**Possible (2)**	**Serious (3)**	**6**	**Engineering**: Noise-dampening barriers. **PPE**: Hearing protection.	**Possible (2)**	**Minimal (1)**	**2**
Work in extreme temperatures (boiler rooms, outdoors)	Dehydration, heat stroke, frostbite	**Possible (2)**	**Serious (3)**	**6**	**Engineering**: Heated/cooled break areas. **Administrative**: Work-rest cycles, hydration. **PPE**: Weather-appropriate PPE.	**Possible (2)**	**Minimal (1)**	**2**
Slips, trips, and falls on job sites	Uneven ground, debris, wet surfaces	**Expected (4)**	**Moderate (2)**	**8**	**Engineering**: cable management. **Administrative**: Good housekeeping, site orientation. **PPE**: Slip-resistant, steel-toe boots.	**Possible (2)**	**Minimal (1)**	**2**

Hazard Assessment Form

Exposure to chemicals (glues, solvents, cleaners)	Dermatitis, respiratory irritation, dizziness	**Possible (2)**	**Moderate (2)**	**4**	**Substitution:** Low-VOC products. **Engineering:** Ventilation. **Administrative:** WHMIS training, SDS access. **PPE:** Gloves, goggles, respirator if required.	**Remote (1)**	**Minimal (1)**	**1**
Interaction with other trades / mobile equipment	Struck-by moving equipment, dropped materials, serious injury, fatality	**Probable (3)**	**Catastrophic (4)**	**12**	**Engineering:** Barriers, defined walkways. **Administrative**: Site safety meetings, traffic control plans. **PPE:** High-visibility clothing, hard hat, safety boots.	**Probable (3)**	**Moderate (2)**	**6**

Hazard Assessment Form

Level of Risk Chart

Likelihood: The likelihood parameter looks at the chance of a negative situation occurring.

Severity: Severity measures the degree of harm that exposure to the hazard could result in.

The level of risk is determined by the equation: **Likelihood x Severity = Risk** as per the table below.

Risk Chart		Likelihood of Occurrence			
		Expected (4) Very likely to happen	**Probable (3)** Could happen	**Possible (2)** A chance it could happen	**Remote (1)** Very unlikely to happen
Severity	**Catastrophic (4)** Death, critical injury, property damage over $10K	16	12	8	4
	Serious (3) Medical Aid, lost time, property damage over $5K	12	9	6	3
	Moderate (2) First Aid, Minor illness, Property damage over $1K	8	6	4	2
	Minimal (1) No injury, minor damage	4	3	2	1

The risk score is then used to determine a risk category which will dictate actions required to manage the risk.

Risk Score Level	Risk Category	Action Required
16	Severe	Stop work immediately, implement controls to reduce the risk
9-12	High	Consider additional controls to reduce the risk. Create a Safe Work (Job) Procedure
4 -8	Medium	Consider additional controls, Create a Safe Work Practice
1 - 3	Low	Minimal risk, monitor the operation

Hazard Assessment Form