



MAXIM MECHANICAL GROUP INC.

Main Shop: 55 Grencer Rd.,
Bradford ON L3Z 2A6
Ph: 905.778.9449
Accounting: 42 Nobleton Lakes Dr.,
Nobleton ON L0G 1N0
Ph: 905.859.5433
Email: maximmechinc@gmail.com

Project/Site: VIA RAIL - TMC - INTERIM 2

Date:

Building/Location: FUEL SUPPORT BUILDING &/OR FUELING CANOPY

PM Checklist - DEF SYSTEM - TANKS

Component	TAG	REFERENCE DWG	Visually inspect for anything abnormal	Check for leaks	Check heater is powered, operational and temperature is consistent.	Review the Fluid Management System levels and points. If issues create work order and contact National Energy Equipment for repairs	Inspect tank and level sensor: Ensure there are no signs of corrosion, leakage or damage.	Comments
DEF 15,000LT TANK	TANK#1	MC_A_M5400						
DEF 15,000LT TANK	TANK#2	MC_A_M5400						

Note: This filled out checklist has been reviewed. Its completion is approved as noted:

Inspected By: _____
Completed By: _____
Date: _____



MAXIM MECHANICAL GROUP INC.

Main Shop: 55 Grencer Rd.,
Bradford ON L3Z 2A6
Ph: 905.778.9449
Accounting: 42 Nobleton Lakes Dr.,
Nobleton ON L0G 1N0
Ph: 905.859.5433
Email: maximmechinc@gmail.com

Project/Site: VIA RAIL - TMC - INTERIM 2

Date:

Building/Location: FUEL SUPPORT BUILDING &/OR FUELING CANOPY

PM Checklist - DEF SYSTEM - VALVES

Component	TAG	REFERENCE DWG	Lubricate moving parts (if needed) to prevent sticking	Check for leaks	Check for wear: Inspect seals and replace if leaking			Comments
MOTORIZED VALVE 1	MV-1	MC_A_M5400						
MOTORIZED VALVE 2	MV-2	MC_A_M5400						
MOTORIZED VALVE 3	MV-3	MC_A_M5400						
MANUAL	MV-#	MC A M5400						

Note: This filled out checklist has been reviewed. Its completion is approved as noted:

Inspected By: _____
Completed By: _____
Date: _____



MAXIM MECHANICAL GROUP INC.

Main Shop: 55 Greener Rd.,
Bradford ON L3Z 2A6
Ph: 905.778.9449
Accounting: 42 Nobleton Lakes Dr.,
Nobleton ON L0G 1N0
Ph: 905.859.5433
Email: maximmechinc@gmail.com

Project/Site: VIA RAIL - TMC - INTERIM 2

Date:

Building/Location: FUEL SUPPORT BUILDING &/OR FUELING CANOPY

PM Checklist - DEF SYSTEM - FILTERS

Component	TAG	REFERENCE DWG	Inspect the differential pressure around the filter, make a log, the differential pressure should be minimal and consistent, if it above normal, this is an indication the filter needs to be replaced	Inspect and replace, if sediment building up, create work order to clean filter housing	Check for wear: Inspect seals and replace if leaking			Comments
INCOMING DEF FLUID FILTER	F-1	TMC_A_M5400						
OUTGOING DEF FLUID FILTER	F-2	TMC_A_M5400						

Note: This filled out checklist has been reviewed. Its completion is approved as noted:

Inspected By: _____
Completed By: _____
Date: _____



MAXIM MECHANICAL GROUP INC.

Main Shop: 55 Grencer Rd.,
Bradford ON L3Z 2A6
Ph: 905.778.9449
Accounting: 42 Nobleton Lakes Dr.,
Nobleton ON L0G 1N0
Ph: 905.859.5433
Email: maximmechinc@gmail.com

Project/Site: VIA RAIL - TMC - INTERIM 2

Date:

Building/Location: FUEL SUPPORT BUILDING &/OR FUELING CANOPY

PM Checklist - DEF SYSTEM - DEF DISPENSERS

Component	TAG	REFERENCE DWG	Ensure the Solenoid valve is opening and closing when Dispenser is unlocking	Test all the solenoid valves for responsiveness	Visually inspect: check piping system for leaks	Ensure heater is operational (winter)	Inspect Nozzle for leaks. If nozzle is leaking, replace with spare & create work order for repair leak within nozzle. Follow manufacturers recommendations	Inspect the DEF isolation valve to the dispenser, ensure opens and closes with ease. Add lubrication to the valve stem as necessary
DEF DISPENSER STATION 1	FP-03-1	TMC_A_M5400						
DEF DISPENSER STATION 2	FP-03-2	TMC_A_M5400						
DEF DISPENSER STATION 3	FP-03-3	TMC_A_M5400						
DEF DISPENSER STATION 4	FP-03-4	TMC_A_M5400						

Note: This filled out checklist has been reviewed. Its completion is approved as noted:

Inspected By: _____
Completed By: _____
Date: _____



MAXIM MECHANICAL GROUP INC.

Main Shop: 55 Grencer Rd.,
Bradford ON L3Z 2A6
Ph: 905.778.9449
Accounting: 42 Nobleton Lakes Dr.,
Nobleton ON L0G 1N0
Ph: 905.859.5433
Email: maximmechinc@gmail.com

Project/Site: VIA RAIL - TMC - INTERIM 2

Date:

Building/Location: FUEL SUPPORT BUILDING &/OR FUELING CANOPY

PM Checklist - DEF SYSTEM - PIPING

Component	TAG	REFERENCE DWG	Visually inspect the piping system	Check for any leaks & abnormal noises	Check all valves & ensure they are properly opening and closing. If there are any leaks or sticking/bypassing valves - create work order to repair			
DEF PIPING SYSTEM	DEF PIPING	TMC_A_M5400						
DEF PIPING SYSTEM	DEF PIPING	TMC_A_M5400						
DEF PIPING SYSTEM	DEF PIPING	TMC_A_M5400						

Note: This filled out checklist has been reviewed. Its completion is approved as noted:

Inspected By: _____

Completed By: _____

Date: _____



MAXIM MECHANICAL GROUP INC.

Main Shop: 55 Grencer Rd.,
Bradford ON L3Z 2A6
Ph: 905.778.9449
Accounting: 42 Nobleton Lakes Dr.,
Nobleton ON L0G 1N0
Ph: 905.859.5433
Email: maximmechinc@gmail.com

Project/Site: VIA RAIL - TMC - INTERIM 2

Date:

Building/Location: FUEL SUPPORT BUILDING &/OR FUELING CANOPY

PM Checklist - DEF SYSTEM - FLOW METERS

Component	TAG	REFERENCE DWG	Check for any leaks or abnormal noises, ensure metering volume is consistent for given timeframe (volume vs time)	Verify the volume on HMI screen is within tolerance of the volume provided from DEF supply vendor, make note. If accuracy has fluctuated from the log, more than, recalibration is required. Refer to manufacturers recommendations				Comments
INCOMING FLOW METER	FM-1	TMC_A_M5400						
OUTGOING FLOW METER	FM-2	TMC_A_M5400						

Note: This filled out checklist has been reviewed. Its completion is approved as noted:

Inspected By: _____
Completed By: _____
Date: _____



MAXIM MECHANICAL GROUP INC.

Main Shop: 55 Grencer Rd.,
Bradford ON L3Z 2A6
Ph: 905.778.9449
Accounting: 42 Nobleton Lakes Dr.,
Nobleton ON L0G 1N0
Ph: 905.859.5433
Email: maximmechinc@gmail.com

Project/Site: VIA RAIL - TMC - INTERIM 2

Date:

Building/Location: FUEL SUPPORT BUILDING &/OR FUELING CANOPY

PM Checklist - DEF SYSTEM - PRESSURE & TEMPERATURE TRANSDUCERS

Component	TAG	REFERENCE DWG	Check calibration: Ensure accuracy with visual gauges nearby and reset if required. Refer to manufacturers maintenance manual	Inspect for wear: Clean and recalibrate IF REQUIRED. Refer to manufacturers recommendations.					Comments
DIFFERENTIAL PRESSURE SWITCH INCOMING FLUID FILTER	DPTR-1	TMC_A_M5400							
DIFFERENTIAL PRESSURE SWITCH OUTGOING FLUID FILTER	DPTR-2	TMC_A_M5400							
THERMOWELL TEMP. SENSOR	THS-1	TMC_A_M5400							
THERMOWELL TEMP. SENSOR	THS-2	TMC_A_M5400							
PRESSURE TRANSMITTER SENSOR	PT-2	TMC_A_M5400							

Note: This filled out checklist has been reviewed. Its completion is approved as noted:

Inspected By: _____
Completed By: _____
Date: _____



MAXIM MECHANICAL GROUP INC.

Main Shop: 55 Grencer Rd.,
Bradford ON L3Z 2A6
Ph: 905.778.9449
Accounting: 42 Nobleton Lakes Dr.,
Nobleton ON L0G 1N0
Ph: 905.859.5433
Email: maximmechinc@gmail.com

Project/Site: VIA RAIL - TMC - INTERIM 2

Date:

Building/Location: FUEL SUPPORT BUILDING &/OR FUELING CANOPY

PM Checklist - DEF SYSTEM - PUMPS

Component	TAG	REFERENCE DWG	Inspect air valve, check for proper cycling and clean as necessary.	Check system pressure, ensure air and fluid pressure are within range	Check FRL gauge is holding pressure, there is no air leaks & ensure Air solenoids are opening and closing as required.	Clean air filter, ensure no clogging.	If pumps become loud, check the exhaust for leaks, replace as needed	Comments
PUMP 1	P1	TMC_A_M5400						
PUMP 2	P2	TMC_A_M5400						

Note: This filled out checklist has been reviewed. Its completion is approved as noted:

Inspected By: _____
Completed By: _____
Date: _____

SAND DISPENSERS 7	FP-01-07	TMC_A_M5300									
SAND DISPENSERS 8	FP-01-08	TMC_A_M5003									

Note: This filled out
checklist has been
reviewed. Its
completion is
approved as noted:

Inspected By:

Completed By:

Date:



MAXIM MECHANICAL GROUP INC.

Main Shop: 55 Grecoer Rd.,
Bradford ON L3Z 2A6
Ph: 905.778.9449
Accounting: 42 Nobleton Lakes Dr.,
Nobleton ON L0G 1N0
Ph: 905.859.5433
Email: maximmechinc@gmail.com

Project/Site: VIA RAIL - TMC - INTERIM 2

Date:

Building/Location: FUEL SUPPORT BUILDING &/OR FUELING CANOPY

PM Checklist - SANDING SYSTEM - SILO DUST COLLECTOR

Component	TAG	REFERENCE DWG	Visual inspection of equipment and confirm all safety devices active	Monitor for abnormal noise and vibration	Check control panel and and test functionality	Check filter element differential pressure and surface condition	check compressed air pressure and drain moisture	Check air pressure (5-6bar) & inspect air hose connection for wear to tear	Test all the solenoid valves for responsiveness	VCP Presure control valve- Visual inspection of wer, damage or seal integrity & Clean accumulated dust from vlave exterior	AKO VF/VMC Pinch Valve - Visual inspection of valve body and control lines	KAT Truck Pipe Connection - Visual inspection of housing, connectors, hardware and sensor dust or build up around inductive sensor	Goetze PRV (681 Type) - Check for leaks, corrosion, and gauge accuracy, tighten mechanical fastners	Comments
SILO DUST COLLECTOR	SAND SILO	TMC_A_M5003												

Note: This filled out checklist has been reviewed. Its completion is approved as noted:

Inspected By: _____
Completed By: _____
Date: _____



MAXIM MECHANICAL GROUP INC.

Main Shop: 55 Grencer Rd.,
Bradford ON L3Z 2A6
Ph: 905.778.9449
Accounting: 42 Nobleton Lakes Dr.,
Nobleton ON L0G 1N0
Ph: 905.859.5433
Email: maximmechinc@gmail.com

Project/Site: VIA RAIL - TMC - INTERIM 2

Date:

Building/Location: FUEL SUPPORT BUILDING &/OR FUELING CANOPY

PM Checklist - WWF SYSTEM - TANKS

Component	TAG	REFERENCE DWG	Visually inspect for anything abnormal	Review the Fluid Management System levels and points. If issues create work order and contact National Energy Equipment for repairs				Comments
WWF 2,270LT TANK	TANK#1	TMC_A_M5300						

Note: This filled out checklist has been reviewed. Its completion is approved as noted:

Inspected By: _____
Completed By: _____
Date: _____



MAXIM MECHANICAL GROUP INC.

Main Shop: 55 Grencer Rd.,
 Bradford ON L3Z 2A6
 Ph: 905.778.9449
Accounting: 42 Nobleton Lakes Dr.,
 Nobleton ON L0G 1N0
 Ph: 905.859.5433
 Email: maximmechinc@gmail.com

Project/Site: VIA RAIL - TMC - INTERIM 2

Date: _____

Building/Location: FUEL SUPPORT BUILDING &/OR FUELING CANOPY

PM Checklist - WWF SYSTEM - VALVES

Component	TAG	REFERENCE DWG	Visually inspect for anything abnormal	Lubricate moving parts (if needed) to prevent sticking	Check for leaks	Check for wear: Inspect seals and replace if leaking	Inspect for corrosion or wear and replace parts as needed	Comments
MOTORIZED VALVE 4	MV-4	TMC_A_M5300						
MANUAL VALVES	MV-#	TMC_A_M5400						

Note: This filled out checklist has been reviewed. Its completion is approved as noted:

Inspected By: _____
 Completed By: _____
 Date: _____



MAXIM MECHANICAL GROUP INC.

Main Shop: 55 Grencer Rd.,
Bradford ON L3Z 2A6
Ph: 905.778.9449
Accounting: 42 Nobleton Lakes Dr.,
Nobleton ON L0G 1N0
Ph: 905.859.5433
Email: maximmechinc@gmail.com

Project/Site: VIA RAIL - TMC - INTERIM 2

Date:

Building/Location: FUEL SUPPORT BUILDING &/OR FUELING CANOPY

PM Checklist - WWF SYSTEM - FILTERS

Component	TAG	REFERENCE DWG	Inspect the differential pressure around the filter, make a log, the differential pressure should be minimal and consistent, if it above normal, this is an indication the filter needs to be replaced.	Inspect and replace, if sediment building up, create work order to clean filter housing	Check for wear: Inspect seals and replace if leaking			Comments
INCOMING WWF FLUID FILTER	F-3	TMC_A_M5300						
OUTGOING WWF FLUID FILTER	F-4	TMC_A_M5300						

Note: This filled out checklist has been reviewed. Its completion is approved as noted:

Inspected By: _____
Completed By: _____
Date: _____



MAXIM MECHANICAL GROUP INC.

Main Shop: 55 Grencer Rd.,
Bradford ON L3Z 2A6
Ph: 905.778.9449
Accounting: 42 Nobleton Lakes Dr.,
Nobleton ON L0G 1N0
Ph: 905.859.5433
Email: maximmechinc@gmail.com

Project/Site: VIA RAIL - TMC - INTERIM 2

Date:

Building/Location: FUEL SUPPORT BUILDING &/OR FUELING CANOPY

PM Checklist - WWF SYSTEM - DISPENSERS

Component	TAG	REFERENCE DWG	Ensure hose reel operational & retracting mechanism is working well	Visually check for leaks around pipe fittings	Ensure the WWF reel is supplying adequate flow	If nozzle is leaking, replace with spare & repair leak within nozzle. Follow manufacturers recommendations	Inspect the WWF isolation valve to the dispenser, ensure opens and closes with ease. Add lubrication to the valve stem as necessary	Inspect the WWF Dispensing Nozzle, ensure there is no leaks & the visual gauge is working
WWF REEL	FP-04-1	TMC_A_M5300						
WWF REEL	FP-04-2	TMC_A_M5300						
WWF REEL	FP-04-3	TMC_A_M5300						
WWF REEL	FP-04-4	TMC_A_M5300						

Note: This filled out checklist has been reviewed. Its completion is approved as noted:

Inspected By: _____
Completed By: _____
Date: _____



MAXIM MECHANICAL GROUP INC.

Main Shop: 55 Grencer Rd.,
Bradford ON L3Z 2A6
Ph: 905.778.9449
Accounting: 42 Nobleton Lakes Dr.,
Nobleton ON L0G 1N0
Ph: 905.859.5433
Email: maximmechinc@gmail.com

Project/Site: VIA RAIL - TMC - INTERIM 2

Date:

Building/Location: FUEL SUPPORT BUILDING &/OR FUELING CANOPY

PM Checklist - WWF SYSTEM - PIPING

Component	TAG	REFERENCE DWG	Visually inspect the piping system	Check for any leaks & abnormal noises	Check all valves & ensure they are properly opening and closing. If there are any leaks or sticking/bypassing valves - create work order to repair			
WWF PIPING SYSTEM	WWF PIPING	TMC_A_M5300						
WWF PIPING SYSTEM	WWF PIPING	TMC_A_M5300						
WWF PIPING SYSTEM	WWF PIPING	TMC_A_M5300						

Note: This filled out checklist has been reviewed. Its completion is approved as noted:

Inspected By: _____

Completed By: _____

Date: _____



MAXIM MECHANICAL GROUP INC.

Main Shop: 55 Gencer Rd.,
Bradford ON L3Z 2A6
Ph: 905.778.9449
Accounting: 42 Nobleton Lakes Dr.,
Nobleton ON L0G 1N0
Ph: 905.859.5433
Email: maximmechinc@gmail.com

Project/Site: VIA RAIL - TMC - INTERIM 2

Date:

Building/Location: FUEL SUPPORT BUILDING &/OR FUELING CANOPY

PM Checklist - WWF SYSTEM - FLOW METERS

Component	TAG	REFERENCE DWG	Check for any leaks or abnormal noises, ensure metering volume is consistent for given timeframe (volume vs time)	Verify the volume on HMI screen is within tolerance of the volume provided from DEF supply vendor, make note. If accuracy has fluctuated from the log, more than, recalibration is required. Refer to manufacturers recommendations	Check for wear: Inspect seals and replace if leaking				Comments
INCOMING WWF FLOW	FM-3	TMC_A_M5300							
OUTGOING WWF FLOW	FM-4	TMC_A_M5300							

Note: This filled out checklist has been reviewed. Its completion is approved as noted:

Inspected By: _____
Completed By: _____
Date: _____



MAXIM MECHANICAL GROUP INC.

Main Shop: 55 Grencer Rd.,
Bradford ON L3Z 2A6
Ph: 905.778.9449
Accounting: 42 Nobleton Lakes Dr.,
Nobleton ON L0G 1N0
Ph: 905.859.5433
Email: maximmechinc@gmail.com

Project/Site: VIA RAIL - TMC - INTERIM 2

Building/Location: FUEL SUPPORT BUILDING &/OR FUELING CANOPY

Date:

PM Checklist - WWF SYSTEM - PRESSURE & TEMPERATURE TRANSDUCERS

Component	TAG	REFERENCE DWG	Visually inspect for anything abnormal	Review the Fluid Management System levels and points. If issues create work order and contact National Energy Equipment for repairs				Comments
DIFFERENTIAL PRESSURE SWITCH OUTGOING FLUID FILTER	DPTR-2	TMC_A_M5400						
THERMOWELL TEMP. SENSOR	THS-1	TMC_A_M5400						
THERMOWELL TEMP. SENSOR	THS-2	TMC_A_M5400						
PRESSURE TRANSMITTER SENSOR	PT-1	TMC_A_M5300						
PRESSURE TRANSMITTER SENSOR	PT-2	TMC_A_M5400						

Note: This filled out checklist has been reviewed. Its completion is approved as noted:

Inspected By: _____
Completed By: _____
Date: _____



MAXIM MECHANICAL GROUP INC.

Main Shop: 55 Grencer Rd.,
Bradford ON L3Z 2A6
Ph: 905.778.9449
Accounting: 42 Nobleton Lakes Dr.,
Nobleton ON L0G 1N0
Ph: 905.859.5433
Email: maximmechinc@gmail.com

Project/Site: VIA RAIL - TMC - INTERIM 2

Date:

Building/Location: FUEL SUPPORT BUILDING &/OR FUELING CANOPY

PM Checklist - WWF SYSTEM - PUMPS

Component	TAG	REFERENCE DWG	Inspect air valve, check for proper cycling and clean as necessary.	Check system pressure, ensure air and fluid pressure are within range.	Check FRL gauge is holding pressure, there is no air leaks & ensure Air solenoids are opening and closing as required.	Clean air filter, ensure no clogging.	If pumps become loud, check the exhaust for leaks, replace as needed. If there is a pressure loss, replace with spare pump &/or repair the diaphragm with wet kit & replace air valve with dry kit.	Comments
WWF PUMP 3	P3	TMC_A_M5300						
WWF PUMP 4	P4	TMC_A_M5300						

Note: This filled out checklist has been reviewed. Its completion is approved as noted:

Inspected By: _____
Completed By: _____
Date: _____