

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Report Data Compiled from 2014-2019

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
1	Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Fire	Column5	Column6	Column7	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Column11	Column12
2		Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification						Date	Time
3	PG&E	6/10/14	15:14	40.2059900	-122.2533300	Vegetation	Rural	< 0.25 Acres	Fire Agency	Red Bluff FD	101545144		12,000	Conductor	Overhead	Yes	6/10/14	15:14
4	PG&E	6/12/14	6:30	38.0437500	-122.7462400	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire et al	102230371	AT&T	12,000	Conductor	Overhead	Yes	6/12/14	6:30
5	PG&E	6/13/14	9:19	36.9334800	-121.3885490	Vegetation	Rural	< 0.25 Acres	Fire Agency	Hollister FD	101703071	AT&T	21,000	Conductor	Overhead	Yes	6/13/14	9:19
6	PG&E	6/14/14	8:47	37.4190500	-122.1807700	Vegetation	Rural	< 3 meters	Unknown		100275552	AT&T	12,000	Conductor	Overhead	Yes	6/14/14	8:47
7	PG&E	6/14/14	11:01	37.1309150	-121.0919180	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL Fire	Pole 000/013	None	70,000	Conductor	Overhead	Yes	6/14/14	11:01
8	PG&E	6/15/14	9:47	37.1307740	-121.0714100	Vegetation	Rural	< 0.25 Acres	Fire Agency		23633 Schulties Rd, Los Gatos		12,000	Conductor	Overhead	Yes	6/15/14	9:47
9	PG&E	6/15/14	17:28	37.0707710	-121.9349810	Vegetation	Urban	< 3 meters	Self Extinguished		4239 Teakwood Ct, Concord		0 - 750	Conductor	Overhead	Yes	6/15/14	17:28
10	PG&E	6/15/14	20:55	39.8678600	-122.1973690	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101500605		12,000	Conductor	Overhead	Yes	6/15/14	20:55
11	PG&E	6/16/14	15:37	38.1681700	-120.6074690	Vegetation	Rural	< 0.25 Acres	Fire Agency		101280871	AT&T	0 - 750	Conductor	Overhead	No		
12	PG&E	6/17/14	13:49	38.6667940	-122.5963970	Vegetation	Rural	< 3 meters	Fire Agency	Cal Fire	102247824		12,000	Conductor	Overhead	Yes	6/17/14	13:49
13	PG&E	6/17/14	14:50	40.9605800	-124.0439590	Vegetation	Rural	< 0.25 Acres	Unknown		100979528	AT&T	0 - 750	Conductor	Overhead	Yes	6/17/14	14:50
14	PG&E	6/17/14	16:47	34.6860900	-120.4373230	Vegetation	Rural	< 3 meters	Self Extinguished		101894765		12,000	Conductor	Overhead	Yes	6/17/14	16:47
15	PG&E	6/17/14	21:24	38.4180400	-121.1404610	Vegetation	Rural	10 - 99 Acres	Unknown		Twr. 052/320	None	115,000	Conductor	Overhead	Yes	6/17/14	21:24
16	PG&E	6/18/14	10:01	37.8010980	-121.2021560	Vegetation	Urban	26 - 99 Acres	Fire Agency	Manteca FD	102085311	Verizon	17,000	Conductor	Overhead	Yes	6/18/14	10:01
17	PG&E	6/18/14	18:29	37.3175090	-120.5049050	Vegetation	Urban	< 0.25 Acres	Fire Agency	Cal Fire	101162090	AT&T	0 - 750	Capacitor Bank	Overhead	No		
18	PG&E	6/19/14	16:32	37.9314600	-121.2999000	Vegetation	Urban	< 0.25 Acres	Unknown		102133758	AT&T	0 - 750	Conductor	Overhead	No		
19	PG&E	6/19/14	18:54	38.7801990	-121.5007240	Vegetation	Rural	26 - 99 Acres	Fire Agency		101297449	AT&T	12,000	Conductor	Overhead	Yes	6/19/14	18:54
20	PG&E	6/20/14	9:47	34.8650990	-120.3206720	Vegetation	Rural	< 0.25 Acres	Unknown		101862409		12,000	Conductor	Overhead	Yes	6/20/14	9:47
21	PG&E	6/20/14	12:00	39.6663370	-122.1968810	Vegetation	Rural	< 0.25 Acres	Unknown		100422609		0 - 750	Capacitor Bank	Overhead	No		
22	PG&E	6/20/14	14:15	40.7802300	-121.5028700	Vegetation	Rural	< 0.25 Acres	Fire Agency		101520035	Frontier	12,000	Conductor	Overhead	Yes	6/20/14	14:15
23	PG&E	6/21/14	6:49	38.3753000	-122.5494000	Vegetation	Rural	< 0.25 Acres	Fire Agency		3111 WARM SPRINGS RD, GLEN ELLEN		12,000	Conductor	Overhead	Yes	6/21/14	6:49
24	PG&E	6/21/14	14:36	38.3644400	-122.2626490	Vegetation	Rural	< 3 meters	Fire Agency	Cal Fire	102286053	AT&T	12,000	Conductor	Overhead	Yes	6/21/14	14:36
25	PG&E	6/22/14	8:19	34.8943960	-120.4244590	Vegetation	Urban	< 3 meters	Unknown		101186405	Verizon	12,000	Conductor	Overhead	Yes	6/22/14	8:19
26	PG&E	6/23/14	6:04	37.5046800	-120.0074200	Vegetation	Urban	< 0.25 Acres	Unknown		Pole 007/019	None	70,000	Conductor	Overhead	Yes	6/23/14	6:04
27	PG&E	6/23/14	17:45	39.0640240	-121.0224860	Vegetation	Rural	26 - 99 Acres	Fire Agency		BET. MTR# 1007517420 & FUCO 7495		12,000	Conductor	Overhead	Yes	6/23/14	17:45
28	PG&E	6/24/14	7:11	36.7495400	-121.6570600	Vegetation	Rural	< 0.25 Acres	Fire Agency	Salinas FD	101712215	AT&T	12,000	Conductor	Overhead	Yes	6/24/14	7:11
29	PG&E	6/24/14	7:48	37.9037000	-121.6791620	Other	Urban	< 3 meters	Fire Agency	Contra Costa FD	100485898	AT&T	0 - 750	Conductor	Overhead	No		
30	PG&E	6/24/14	14:31	39.7856800	-121.9065900	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	Mtr 36P580	None	12,000	Conductor	Overhead	Yes	6/24/14	14:31
31	PG&E	6/24/14	16:56	37.9740140	-121.3464620	Vegetation	Urban	< 0.25 Acres	Unknown		103190493		12,000	Conductor	Overhead	Yes	6/24/14	16:56
32	PG&E	6/24/14	17:12	38.1109730	-122.5645120	Vegetation	Urban	26 - 99 Acres	Fire Agency	Novato Fire Department	102223842		0 - 750	Conductor	Overhead	No		
33	PG&E	6/25/14	1:36	36.8908500	-121.7174600	Vegetation	Rural	< 0.25 Acres	Unknown		101697469	AT&T	0 - 750	Conductor	Overhead	No		
34	PG&E	6/25/14	8:51	34.8830400	-120.2776190	Vegetation	Rural	26 - 99 Acres	Fire Agency		LD SIDE MTR 1008835806		12,000	Conductor	Overhead	Yes	6/25/14	8:51
35	PG&E	6/25/14	8:53	39.0110100	-120.8960600	Vegetation	Rural	26 - 99 Acres	Unknown		Main Line N/O buck to 20340 Spring Garden # 1004520726		12,000	Conductor	Overhead	Yes	6/25/14	8:53
36	PG&E	6/25/14	21:47	37.9976830	-121.7691860	Vegetation	Rural	< 0.25 Acres	Unknown		100455766		21,000	Conductor	Overhead	Yes	6/25/14	21:47
37	PG&E	6/26/14	0:15	36.8002500	-119.7937790	Vegetation	Urban	< 0.25 Acres	Fire Agency	Fresno Fire Dept	100854012	AT&T	12,000	Conductor	Overhead	Yes	6/26/14	0:15
38	PG&E	6/28/14	23:04	37.8992070	-121.8608780	Vegetation	Rural	< 0.25 Acres	Unknown		100483886		21,000	Transformer	Overhead	Yes	6/28/14	23:04
39	PG&E	6/29/14	7:59	38.7794000	-121.5055490	Vegetation	Rural	< 0.25 Acres	Fire Agency		101297918	AT&T	0 - 750	Transformer	Overhead	Yes	6/29/14	7:59
40	PG&E	6/29/14	8:23	39.0919800	-121.5430700	Vegetation	Urban	< 0.25 Acres	Unknown		SB 15745 ARBOGA RD 500' S/O FURNEAUX RD 2 SP EAST		12,000	Conductor	Overhead	Yes	6/29/14	8:23
41	PG&E	6/29/14	19:53	38.5208000	-123.0606700	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	3600 E. AUSTIN CREEK RD		12,000	Conductor	Overhead	Yes	6/29/14	19:53
42	PG&E	6/30/14	14:08	38.4491800	-122.8127700	Vegetation	Rural	< 0.25 Acres	Unknown		102022582	AT&T	0 - 750	Conductor	Overhead	No		
43	PG&E	6/30/14	18:25	39.1449270	-122.1318820	Vegetation	Rural	< 0.25 Acres	Unknown		101629033		12,000	Conductor	Overhead	Yes	6/30/14	18:25
44	PG&E	6/30/14	20:02	36.8080200	-119.9101390	Vegetation	Urban	< 0.25 Acres	Unknown		100625545	AT&T	21,000	Conductor	Overhead	Yes	6/30/14	20:02
45	PG&E	7/1/14	3:46	37.9004730	-121.2602580	Vegetation	Rural	< 0.25 Acres	Unknown		2 POLES EAST OF C3412		12,000	Conductor	Overhead	Yes	7/1/14	3:46
46	PG&E	7/1/14	6:43	38.0062300	-122.6430300	Vegetation	Rural	26 - 99 Acres	Fire Agency	West Marin Fire	102258915	AT&T	12,000	Conductor	Overhead	Yes	7/1/14	6:43
47	PG&E	7/1/14	9:45	37.4266900	-119.8809500	Vegetation	Rural	26 - 99 Acres	Unknown		101065832		21,000	Conductor	Overhead	Yes	7/1/14	9:45
48	PG&E	7/1/14	14:36	38.8648700	-121.7025500	Vegetation	Rural	< 0.25 Acres	Fire Agency	Yolo FD	101593404	Verizon	12,000	Conductor	Overhead	Yes	7/1/14	14:36
49	PG&E	7/1/14	18:43	37.0854220	-121.7607380	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	6770 Croy Rd, Morgan Hill		0 - 750	Conductor	Overhead	Yes	7/1/14	18:43
50	PG&E	7/2/14	13:17	38.2545710	-122.0509280	Vegetation	Urban	< 0.25 Acres	Fire Agency		101556512	AT&T	12,000	Conductor	Overhead	Yes	7/2/14	13:17
51	PG&E	7/2/14	14:29	40.4736600	-122.4737300	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101481261		12,000	Conductor	Overhead	Yes	7/2/14	14:29
52	PG&E	7/2/14	17:17	35.0533510	-119.4087900	Vegetation	Rural	< 0.25 Acres	Fire Agency		Mtr. 1004492840		0 - 750	Transformer	Overhead	Yes	7/2/14	17:17
53	PG&E	7/3/14	11:37	37.3348840	-120.8510170	Vegetation	Rural	< 0.25 Acres	Unknown		101207072	AT&T	12,000	Conductor	Overhead	Yes	7/3/14	11:37
54	PG&E	7/3/14	19:22	39.4914530	-121.5384690	Vegetation	Rural	< 0.25 Acres	Unknown		100369965		12,000	Other	Subsurface	Yes	7/3/14	19:22
55	PG&E	7/3/14	20:28	40.6583840	-122.3214760	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	T1192		12,000	Other	Padmounted	Yes	7/3/14	20:28
56	PG&E	7/4/14	1:40	39.3337230	-121.1391380	Vegetation	Rural	26 - 99 Acres	Fire Agency	Cal Fire	100001697		12,000	Transformer	Overhead	Yes	7/4/14	1:40
57	PG&E	7/4/14	6:52	37.1840190	-121.7416040	Vegetation	Rural	< 3 meters	Unknown		Sw 73367		21,000	Other	Overhead	Yes	7/4/14	6:52
58	PG&E	7/5/14	3:30	35.4959500	-120.7291500	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101934121		12,000	Conductor	Overhead	Yes	7/5/14	3:30
59	PG&E	7/5/14	5:33	37.2493520	-121.0126450	Other	Rural	< 3 meters	Fire Agency		101219229		0 - 750	Conductor	Overhead	No		
60	PG&E	7/5/14	10:09	39.7785380	-121.5900380	Vegetation	Rural	< 0.25 Acres	Fire Agency	Butte County FD	100399511		12,000	Transformer	Overhead	Yes	7/5/14	10:09
61	PG&E	7/5/14	23:17	39.8197700	-121.6262220	Vegetation	Rural	< 0.25 Acres	Fire Agency		100355517		12,000	Conductor	Overhead	Yes	7/5/14	23:17
62	PG&E	7/6/14	17:00	37.9469100	-122.0936090	Vegetation	Rural	< 0.25 Acres	Fire Agency	Contra Costa FD	100460181	AT&T	0 - 750	Conductor	Overhead	No		
63	PG&E	7/6/14	19:19	38.7489000	-123.2849800	Vegetation	Rural	26 - 99 Acres	Fire Agency	Cal Fire	6 SPANS FROM EOL TWD FUCO 4605		12,000	Conductor	Overhead	Yes	7/6/14	19:19
64	PG&E	7/7/14	20:43	36.8493900	-119.8799860	Vegetation	Urban	< 0.25 Acres	Fire Agency		NE of D9200		21,000	Conductor	Overhead	Yes	7/7/14	20:43
65	PG&E	7/7/14	23:49	37.0326640	-120.3104760	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101090847	AT&T	12,000	Conductor	Overhead	Yes	7/7/14	23:49
66	PG&E	7/8/14	11:07	37.9053570	-121.2198500	Vegetation	Rural	< 0.25 Acres	Unknown		102131509		12,000	Capacitor Bank	Overhead	Yes	7/8/14	11:07
67	PG&E	7/8/14	11:41	36.7016130	-121.5768130	Vegetation	Rural	< 0.25 Acres	Unknown		101722884	AT&T	12,000	Conductor	Overhead	Yes		

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Column5	Column6	Column7	Column8	Column9	Column10	Column11	Column12	Column13	Column14	Column15	Column16
Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time		
87	PG&E	7/20/14	3:07	37.4522840	-122.2524110	Other	Urban	Structure Only	Fire Agency	Redwood City FD	1045 Silver Hill Rd, Redwood City		12,000	Conductor	Overhead	Yes	7/20/14	3:07
88	PG&E	7/20/14	12:23	37.6760780	-119.7969260	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	NPS	Twr. 038/224		70,000	Conductor	Overhead	Yes	7/20/14	12:23
89	PG&E	7/20/14	12:44	38.3931390	-121.5937400	Vegetation	Rural	< 0.25 Acres	Unknown		101652420		21,000	Conductor	Overhead	Yes	7/20/14	12:44
90	PG&E	7/21/14	9:57	37.5928900	-121.3416720	Vegetation	Rural	< 0.25 Acres	Fire Agency		3401 Gaffery Rd, Vernalis		12,000	Conductor	Overhead	Yes	7/21/14	9:57
91	PG&E	7/22/14	14:53	37.0858500	-121.6695500	Vegetation	Rural	< 0.25 Acres	Unknown		100607514		0 - 750	Conductor	Overhead	No		
92	PG&E	7/22/14	20:09	37.9516280	-120.4597190	Vegetation	Rural	< 0.25 Acres	Unknown		101912452		0 - 750	Conductor	Overhead	Yes	7/22/14	20:09
93	PG&E	7/23/14	12:16	35.2909980	-120.6593170	Other	Urban	Structure Only	Fire Agency	San Luis Obispo FD	103351214		12,000	Conductor	Overhead	Yes	7/23/14	12:16
94	PG&E	7/24/14	1:04	37.0812740	-122.4428840	Vegetation	Rural	< 3 meters	Fire Agency	Cal Fire	1 SP SS OF MTR 1008516620		12,000	Conductor	Overhead	Yes	7/24/14	1:04
95	PG&E	7/24/14	10:59	40.0240030	-122.0955900	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101537326		0 - 750	Conductor	Overhead	No		
96	PG&E	7/24/14	11:56	38.3914700	-122.9305300	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	2 SPANS LOAD SIDE OF 1691		12,000	Conductor	Overhead	Yes	7/24/14	11:56
97	PG&E	7/24/14	15:26	37.4465390	-122.2719340	Vegetation	Rural	26 - 9.99 Acres	Fire Agency		Pole 000/019		60,000	Conductor	Overhead	Yes	7/24/14	15:26
98	PG&E	7/24/14	15:51	39.8368310	-121.7038940	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	4 & 5 POLES S/O OF LR 2028		12,000	Conductor	Overhead	Yes	7/24/14	15:51
99	PG&E	7/24/14	19:28	39.0450030	-121.1727940	Vegetation	Rural	26 - 9.99 Acres	Unknown		16243 Tierra Rd, Grass Valley		12,000	Conductor	Overhead	Yes	7/24/14	19:28
100	PG&E	7/25/14	12:16	39.6491530	-121.8713570	Vegetation	Rural	< 3 meters	Unknown		100356542		0 - 750	Conductor	Overhead	No		
101	PG&E	7/26/14	5:02	39.2614500	-121.5745900	Vegetation	Rural	< 0.25 Acres	Self Extinguished		Twr. 001/110		115,000	Other	Overhead	Yes	7/26/14	5:02
102	PG&E	7/26/14	15:26	37.6655100	-119.8416500	Vegetation	Rural	1000 - 4999 Acres	Fire Agency	NPS	101084253		12,000	Conductor	Overhead	Yes	7/26/14	15:26
103	PG&E	7/27/14	4:17	37.7925760	-120.7750140	Other	Rural	Structure Only	Fire Agency	Oakdale FD	102334307		17,000	Conductor	Overhead	Yes	7/27/14	4:17
104	PG&E	7/27/14	6:54	35.6004700	-121.1154800	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	MAIN LINE LOAD SIDE FUSE TAP 5027		12,000	Conductor	Overhead	Yes	7/27/14	6:54
105	PG&E	7/27/14	16:30	35.5720140	-121.0578980	Vegetation	Rural	< 0.25 Acres	Fire Agency		Pole 014/099		70,000	Conductor	Overhead	Yes	7/27/14	16:30
106	PG&E	7/27/14	17:40	37.4481800	-119.9094980	Vegetation	Rural	26 - 9.99 Acres	Fire Agency		101087619		21,000	Conductor	Overhead	Yes	7/27/14	17:40
107	PG&E	7/28/14	0:46	37.3144520	-121.0158390	Other	Urban	Structure Only	Fire Agency		101229360		12,000	Conductor	Overhead	Yes	7/28/14	0:46
108	PG&E	7/28/14	16:00	37.6855500	-121.7313290	Vegetation	Urban	< 3 meters	Unknown		967 Lynn St, Livermore		12,000	Conductor	Overhead	Yes	7/28/14	16:00
109	PG&E	7/28/14	19:05	39.6681900	-123.6441700	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	Mtd 41 125		12,000	Conductor	Overhead	Yes	7/28/14	19:05
110	PG&E	7/30/14	4:36	36.8765040	-121.6645970	Vegetation	Rural	< 0.25 Acres	Unknown		101699196		21,000	Conductor	Overhead	Yes	7/30/14	4:36
111	PG&E	7/30/14	10:42	39.3286240	-121.3836450	Vegetation	Rural	< 0.25 Acres	Unknown		101292419		12,000	Conductor	Overhead	Yes	7/30/14	10:42
112	PG&E	7/30/14	17:35	38.6482930	-120.6930860	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101403817		21,000	Unknown	Overhead	Yes	7/30/14	17:35
113	PG&E	7/31/14	12:41	37.8782200	-122.4633940	Vegetation	Urban	< 0.25 Acres	Fire Agency	Tiburon	102295755		12,000	Conductor	Overhead	Yes	7/31/14	12:41
114	PG&E	7/31/14	15:00	39.0424200	-122.9205900	Vegetation	Urban	< 0.25 Acres	Fire Agency	Lakeport Fire Dept.	102164900		0 - 750	Conductor	Overhead	Yes	7/31/14	15:00
115	PG&E	7/31/14	22:08	38.5342800	-120.0570800	Vegetation	Rural	26 - 9.99 Acres	Unknown		4 SPANS SOUTH OF LR-2404		12,000	Conductor	Overhead	Yes	7/31/14	22:08
116	PG&E	8/1/14	16:17	39.6253200	-121.4523800	Vegetation	Rural	< 0.25 Acres	Unknown		709 Encina Grande Road		0 - 750	Other	Overhead	No		
117	PG&E	8/2/14	0:04	37.6063140	-122.3898310	Vegetation	Urban	< 0.25 Acres	Unknown		Twr. 000/002		115,000	Conductor	Overhead	Yes	8/2/14	0:04
118	PG&E	8/2/14	10:38	36.6118400	-119.3056800	Vegetation	Rural	< 0.25 Acres	Unknown		100710225		12,000	Fuse	Overhead	Yes	8/2/14	10:38
119	PG&E	8/3/14	16:11	39.6443750	-121.7880330	Vegetation	Rural	< 0.25 Acres	Unknown		MTR 1007460127		12,000	Conductor	Overhead	Yes	8/3/14	16:11
120	PG&E	8/4/14	4:18	37.1062600	-121.6366690	Vegetation	Urban	< 0.25 Acres	Fire Agency	Cal Fire	100606026		21,000	Conductor	Overhead	No		
121	PG&E	8/5/14	0:08	38.7804600	-121.4893690	Vegetation	Rural	< 0.25 Acres	Fire Agency		101297005		12,000	Conductor	Overhead	Yes	8/5/14	0:08
122	PG&E	8/5/14	2:57	38.5704300	-121.1022700	Vegetation	Rural	< 0.25 Acres	Unknown		7150 MEARS DR #A AUBURN		12,000	Conductor	Overhead	Yes	8/5/14	2:57
123	PG&E	8/5/14	12:03	39.2154990	-121.3029290	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	Str. 010/122		60,000	Conductor	Overhead	Yes	8/5/14	12:03
124	PG&E	8/5/14	14:50	37.3419700	-121.6319900	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	MTR 1009312709		0 - 750	Transformer	Overhead	Yes	8/5/14	14:50
125	PG&E	8/5/14	16:13	37.5534100	-119.9395000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	MTR 1006385335		0 - 750	Conductor	Overhead	No		
126	PG&E	8/5/14	17:12	36.9187600	-119.6168700	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100735159		12,000	Conductor	Overhead	No		
127	PG&E	8/5/14	21:41	38.0031100	-122.3270500	Vegetation	Urban	< 0.25 Acres	Fire Agency	Contra Costa FD	101426924		0 - 750	Conductor	Overhead	No		
128	PG&E	8/8/14	18:17	40.0011200	-122.2260790	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101530848		12,000	Conductor	Overhead	Yes	8/8/14	18:17
129	PG&E	8/9/14	2:53	38.3011000	-122.8963300	Vegetation	Rural	< 0.25 Acres	Unknown		2 SPANS SOURCE SIDE OF 30501 SHORLINE		12,000	Conductor	Overhead	Yes	8/9/14	2:53
130	PG&E	8/9/14	15:36	36.6851770	-119.0449600	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	MTR1005057583		12,000	Conductor	Overhead	Yes	8/9/14	15:36
131	PG&E	8/11/14	9:23	37.9118400	-120.3488900	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	2 SPAN LOADSIDE FCO 20835		17,000	Conductor	Overhead	Yes	8/11/14	9:23
132	PG&E	8/11/14	14:35	39.6725230	-121.4983170	Vegetation	Rural	< 0.25 Acres	Unknown		Twr 022/146		230,000	Other	Overhead	Yes	8/11/14	14:35
133	PG&E	8/12/14	8:58	36.7405700	-121.7676400	Vegetation	Rural	< 3 meters	Unknown		S/S MONTE RD 4 SPANS S/O NASHUA RD, C		21,000	Other	Overhead	Yes	8/12/14	8:58
134	PG&E	8/12/14	9:42	39.2632400	-121.5974890	Other	Rural	Structure Only	Unknown		101287419		12,000	Conductor	Overhead	Yes	8/12/14	9:42
135	PG&E	8/12/14	15:38	38.7771100	-120.2657500	Vegetation	Rural	26 - 9.99 Acres	Fire Agency		WEST SIDE OF SW 6161		21,000	Conductor	Overhead	Yes	8/12/14	15:38
136	PG&E	8/14/14	10:46	38.0123950	-120.5860520	Vegetation	Rural	< 3 meters	Unknown		101272971		17,000	Conductor	Overhead	Yes	8/14/14	10:46
137	PG&E	8/14/14	14:57	38.5099100	-122.8371300	Vegetation	Rural	< 0.25 Acres	Fire Agency		102028597		0 - 750	Conductor	Overhead	Yes	8/14/14	14:57
138	PG&E	8/15/14	11:01	40.5840531	-122.4446948	Vegetation	Rural	< 0.25 Acres	Fire Agency	Redding Fire Dept	101473764		12,000	Conductor	Overhead	Yes	8/15/14	11:01
139	PG&E	8/16/14	7:30	39.2938500	-121.6378000	Vegetation	Rural	< 0.25 Acres	Unknown		mtr # 1007536106		12,000	Conductor	Overhead	Yes	8/16/14	7:30
140	PG&E	8/17/14	7:27	37.3220200	-119.6344690	Vegetation	Rural	< 0.25 Acres	Unknown		RISER 100393		12,000	Conductor	Overhead	Yes	8/17/14	7:27
141	PG&E	8/17/14	17:33	35.0578500	-118.9174880	Other	Rural	Structure Only	Unknown		100175838		12,000	Conductor	Overhead	Yes	8/17/14	17:33
142	PG&E	8/19/14	3:06	37.6325800	-122.4526290	Other	Urban	Structure Only	Fire Agency		100316145		12,000	Conductor	Overhead	Yes	8/19/14	3:06
143	PG&E	8/19/14	21:05	37.8165080	-120.1321820	Vegetation	Rural	< 3 meters	Fire Agency	Groveland Fire	23111 ELMORE RD, GROVELAND		17,000	Conductor	Overhead	Yes	8/19/14	21:05
144	PG&E	8/20/14	14:22	38.8305400	-121.2014190	Vegetation	Urban	< 0.25 Acres	Fire Agency		100051560		12,000	Conductor	Overhead	Yes	8/20/14	14:22
145	PG&E	8/20/14	16:07	40.1937990	-123.7677550	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	103316088		12,000	Conductor	Overhead	Yes	8/20/14	16:07
146	PG&E	8/21/14	0:00	37.3964600	-121.0715810	Vegetation	Rural	< 0.25 Acres	Unknown		Eastin Rd, south of Hwy 33, Crows Landing		12,000	Conductor	Overhead	No		
147	PG&E	8/23/14	8:36	37.9862900	-120.3918290	Vegetation	Urban	< 0.25 Acres	Fire Agency	Cal Fire	101049418		17,000	Conductor	Overhead	No		
148	PG&E	8/24/14	11:08	37.9471917	-121.3182650	Vegetation	Urban	< 0.25 Acres	Fire Agency	Stockton FD	102109203		12,000	Conductor	Overhead	Yes	8/24/14	11:08
149	PG&E	8/27/14	6:51	38.3603100	-122.0177800	Vegetation	Urban	< 0.25 Acres	Unknown		foothill w/o auburn, Vacaville		12,000	Conductor	Overhead	Yes	8/27/14	6:51
150	PG&E	8/27/14	15:19	38.5929500	-122.9183300	Vegetation	Rural	< 0.25 Acres	Unknown		3103 MILL CREEK RD		12,000	Conductor	Overhead	Yes	8/27/14	15:19
151	PG&E	8/28/14	0:00	40.3886240	-122.4068490	Vegetation	Rural	< 3 meters	Unknown		Gas Point Rd and Happy Valley Rd, Cottonwood		0 - 750	Conductor	Overhead	No		
152	PG&E	8/28/14	13:51	36.26														

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Report Data Compiled from 2014-2019

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
2	Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
3	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin												
171	PG&E	9/15/14	19:22	37.2451500	-122.0096090	Vegetation	Urban	< 3 meters	Fire Agency		15200 FRUITVALE AVE		12,000	Conductor	Overhead	Yes	9/15/14	19:22
172	PG&E	9/16/14	12:56	38.4518180	-122.3729410	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	102254607	AT&T	21,000	Unknown	Overhead	Yes	9/16/14	12:56
173	PG&E	9/17/14	8:36	36.8311900	-121.5582400	Vegetation	Rural	26 - 9.99 Acres	Fire Agency		101720674		21,000	Conductor	Overhead	Yes	9/17/14	8:36
174	PG&E	9/17/14	11:49	39.7575300	-122.2202000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency		100367963	AT&T	12,000	Conductor	Overhead	Yes	9/17/14	11:49
175	PG&E	9/17/14	14:47	37.2304500	-121.9058390	Vegetation	Urban	< 0.25 Acres	Fire Agency		100547281	AT&T	0 - 750	Other	Overhead	No		
176	PG&E	9/18/14	13:00	39.5520990	-121.9085300	Vegetation	Rural	300 - 999 Acres	Fire Agency	Cal Fire	12th pole s/of Fuse 1619	None	12,000	Conductor	Overhead	Yes	9/18/14	13:00
177	PG&E	9/19/14	8:44	39.2620000	-121.3770700	Vegetation	Rural	< 0.25 Acres	Fire Agency		1w/1927		12,000	Conductor	Overhead	Yes	9/19/14	8:44
178	PG&E	9/20/14	0:00	38.5631180	-121.5274870	Vegetation	Urban	< 0.25 Acres	Fire Agency	West Sacramento FD	Jefferson Blvd and Stone Blvd, West Sacramen		0 - 750	Lightning Arrestor	Overhead	No		
179	PG&E	9/20/14	7:02	37.4552300	-122.2511300	Vegetation	Urban	< 0.25 Acres	Unknown		100300898	AT&T	12,000	Conductor	Overhead	Yes	9/20/14	7:02
180	PG&E	9/21/14	4:54	39.6883933	-121.8541433	Vegetation	Rural	< 3 meters	Fire Agency	Cal Fire	100438591		12,000	Conductor	Overhead	Yes	9/21/14	4:54
181	PG&E	9/23/14	10:05	39.1103850	-121.3338280	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Beale AFB	Pole 007/138		60,000	Conductor	Overhead	Yes	9/23/14	10:05
182	PG&E	9/23/14	10:53	38.8150300	-120.9024100	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	6871 Marshall rd lotus		21,000	Conductor	Overhead	Yes	9/23/14	10:53
183	PG&E	9/25/14	2:58	37.3886900	-121.9971900	Vegetation	Urban	< 0.25 Acres	Fire Agency		100549375	AT&T	12,000	Conductor	Overhead	Yes	9/25/14	2:58
184	PG&E	9/25/14	20:27	35.4405000	-118.8611000	Vegetation	Rural	< 0.25 Acres	Unknown		Riser 823277		12,000	Conductor	Overhead	Yes	9/25/14	20:27
185	PG&E	9/27/14	14:03	37.0003100	-121.5657400	Vegetation	Urban	< 0.25 Acres	Unknown		Monterey Rd x Las Animas Ave, Gilroy		0 - 750	Conductor	Overhead	No		
186	PG&E	9/27/14	17:54	40.3773570	-122.3385890	Vegetation	Rural	< 3 meters	Unknown		MTR# 100679394		12,000	Conductor	Overhead	Yes	9/27/14	17:54
187	PG&E	9/29/14	14:26	36.7995300	-121.7692790	Vegetation	Rural	< 0.25 Acres	Fire Agency	Monterey County FD	2 POLES SS OF 5877		12,000	Conductor	Overhead	Yes	9/29/14	14:26
188	PG&E	9/30/14	11:41	37.0764483	-120.1965500	Vegetation	Rural	< 0.25 Acres	Customer		22491 Fairmead Blvd, Chowchilla		0 - 750	Other	Overhead	No		
189	PG&E	9/30/14	14:08	37.5302700	-122.3227800	Vegetation	Urban	< 3 meters	Unknown		100265805	AT&T	12,000	Conductor	Overhead	Yes	9/30/14	14:08
190	PG&E	10/1/14	12:02	37.9248100	-121.2084300	Vegetation	Rural	< 3 meters	Fire Agency	Stockton FD	5252 E. Mariposa Rd, Stockton		0 - 750	Other	Overhead	No		
191	PG&E	10/1/14	12:18	39.7260580	-121.8604800	Vegetation	Urban	< 0.25 Acres	Fire Agency	Cal Fire	1920 WEBB AVE, Chico		0 - 750	Conductor	Overhead	No		
192	PG&E	10/1/14	13:24	37.5950940	-122.3050930	Vegetation	Urban	< 0.25 Acres	Fire Agency		2030 So. Delaware, San Mateo		12,000	Conductor	Overhead	Yes	10/1/14	13:24
193	PG&E	10/1/14	15:04	35.6316000	-119.2569050	Vegetation	Rural	< 0.25 Acres	Unknown		Service pole at SW SW 26 25, Wasco		0 - 750	Conductor	Overhead	No		
194	PG&E	10/4/14	16:09	37.9450940	-121.9676150	Vegetation	Urban	< 3 meters	Fire Agency		100465887	AT&T	0 - 750	Conductor	Overhead	No		
195	PG&E	10/4/14	17:00	39.9606967	-122.1483850	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	SSI/ ORANGEWOOD RD, 800' E/O PIEMONT RD, RICHFIELD		0 - 750	Conductor	Overhead	Yes	10/4/14	17:00
196	PG&E	10/5/14	10:12	37.6802390	-122.4706840	Vegetation	Urban	< 0.25 Acres	Fire Agency	Daly City FD	Capacitor C821		0 - 750	Capacitor Bank	Overhead	No		
197	PG&E	10/5/14	22:32	37.1224850	-121.9994360	Vegetation	Rural	26 - 9.99 Acres	Unknown		100519255		21,000	Conductor	Overhead	Yes	10/5/14	22:32
198	PG&E	10/6/14	8:53	38.8925900	-122.7376600	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	2 SPANS PAST FUSES 2309		12,000	Conductor	Overhead	Yes	10/6/14	8:53
199	PG&E	10/7/14	11:31	35.0720230	-120.5905160	Vegetation	Rural	< 0.25 Acres	Fire Agency	SLO FD	at Fuse 8047		12,000	Conductor	Subsurface	Yes	10/7/14	11:35
200	PG&E	10/8/14	14:21	34.6455160	-120.4118330	Vegetation	Rural	< 3 meters	Fire Agency	Santa Barbara FD	MTR#1008628785		12,000	Conductor	Overhead	Yes	10/8/14	14:21
201	PG&E	10/9/14	8:25	37.9589417	-121.3342667	Other	Urban	Structure Only	Fire Agency	Stockton FD	2711 Pixie Dr		12,000	Conductor	Overhead	Yes	10/9/14	8:25
202	PG&E	10/9/14	19:10	38.4619500	-123.0418300	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101955217	AT&T	12,000	Conductor	Overhead	Yes	10/9/14	19:10
203	PG&E	10/10/14	14:41	38.1721017	-122.6282000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	969 SAN ANTONIO RD.		12,000	Conductor	Overhead	Yes	10/10/14	14:41
204	PG&E	10/11/14	10:19	39.5765200	-121.3053800	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Butte FD	100373776	AT&T	12,000	Conductor	Overhead	Yes	10/11/14	10:19
205	PG&E	10/12/14	10:59	38.5917250	-121.5387000	Vegetation	Rural	Structure Only	Fire Agency		1535 HOBSON AVE		0 - 750	Conductor	Overhead	Yes	10/12/14	10:59
206	PG&E	10/12/14	12:02	38.5902667	-121.5349117	Vegetation	Rural	< 0.25 Acres	Fire Agency	West Sacramento FD	101608435	AT&T	0 - 750	Conductor	Overhead	Yes	10/12/14	12:02
207	PG&E	10/12/14	16:53	38.2865483	-122.4804667	Vegetation	Rural	< 0.25 Acres	Fire Agency	Sonoma FD	APPROX 5 SPAN LOAD SIDE 3635		0 - 750	Conductor	Overhead	No		
208	PG&E	10/13/14	9:19	38.1838050	-121.8546050	Vegetation	Rural	< 0.25 Acres	Fire Agency		3 POLES E/OF 10313		21,000	Conductor	Overhead	Yes	10/13/14	9:19
209	PG&E	10/14/14	7:33	36.2506133	-119.8615800	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Kings County FD	MURPHY RANCH RD E/O AVENAL CUTOFF RD		12,000	Conductor	Overhead	Yes	10/14/14	7:33
210	PG&E	10/14/14	11:04	37.9613410	-121.7646900	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Contra Costa FD	30630 C/O 13559		21,000	Conductor	Overhead	No		
211	PG&E	10/14/14	14:32	39.5898250	-122.1938540	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100425132		21,000	Conductor	Overhead	Yes	10/14/14	14:32
212	PG&E	10/16/14	16:26	39.0541620	-121.4235530	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	WHEATLAND FIRE	101303519	AT&T	12,000	Conductor	Overhead	Yes	10/16/14	16:26
213	PG&E	10/17/14	13:41	40.0163440	-122.2252140	Vegetation	Rural	< 0.25 Acres	Unknown		Pole BA 28299	AT&T	60,000	Conductor	Overhead	Yes	10/17/14	13:41
214	PG&E	10/20/14	1:23	38.0271917	-121.9419650	Vegetation	Urban	< 3 meters	Fire Agency	CONTRA COSTA	100450134	AT&T	0 - 750	Conductor	Overhead	No		
215	PG&E	10/20/14	13:30	38.7825333	-122.6926283	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	3 SPANS SOURCESIDE OF MTR#1008647890		12,000	Conductor	Overhead	Yes	10/20/14	13:30
216	PG&E	10/21/14	2:54	37.3964280	-121.8395970	Vegetation	Rural	< 3 meters	Fire Agency	SJFR	3 SP W/O 2089		12,000	Conductor	Overhead	Yes	10/21/14	2:54
217	PG&E	10/22/14	16:45	38.3791580	-120.5007300	Vegetation	Rural	< 0.25 Acres	Fire Agency	West Point Fire	101251221		0 - 750	Conductor	Overhead	No		
218	PG&E	10/22/14	20:51	39.0067740	-120.7437200	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	Sw 49	None	60,000	Switch	Overhead	Yes	10/22/14	20:51
219	PG&E	10/23/14	12:45	35.4218200	-119.0278900	Vegetation	Urban	< 3 meters	Fire Agency	KERN COUNTY FD	100143992	AT&T	12,000	Conductor	Overhead	Yes	10/23/14	12:45
220	PG&E	10/25/14	3:04	40.2956700	-123.8269867	Vegetation	Rural	< 3 meters	Fire Agency	Cal Fire	2374 ELK CRK MTR#1008024164		12,000	Conductor	Overhead	Yes	10/25/14	3:04
221	PG&E	10/25/14	10:52	38.3781200	-120.5116000	Vegetation	Rural	< 3 meters	Fire Agency	West Point Fire	101249034		0 - 750	Unknown	Overhead	No		
222	PG&E	10/25/14	14:35	37.0557667	-121.0560933	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	1 POLE N/OF MTR #1009070700.		12,000	Conductor	Overhead	Yes	10/25/14	14:35
223	PG&E	10/25/14	14:45	36.5575100	-121.9279490	Vegetation	Urban	< 3 meters	Fire Agency	city fire dept	101739963	AT&T	0 - 750	Conductor	Overhead	Yes	10/25/14	14:45
224	PG&E	10/26/14	22:24	34.5351600	-120.2968170	Vegetation	Rural	< 3 meters	Fire Agency	Santa Barbara CO	@ MTR #1008719129		12,000	Conductor	Overhead	Yes	10/26/14	22:24
225	PG&E	10/27/14	6:34	34.8659867	-120.3783817	Vegetation	Rural	< 3 meters	Fire Agency	Santa Barbara CO	101872138	Verizon	12,000	Conductor	Overhead	No		
226	PG&E	10/28/14	12:01	38.8168500	-122.5660700	Vegetation	Rural	< 3 meters	Fire Agency	Cal Fire	102208452	AT&T	12,000	Conductor	Overhead	Yes	10/28/14	12:01
227	PG&E	10/28/14	16:34	38.2142500	-122.2571677	Vegetation	Rural	< 0.25 Acres	Fire Agency	American Cyn Fire / CAL Fire	102230370	AT&T	12,000	Conductor	Overhead	No		
228	PG&E	10/29/14	13:22	39.4802950	-122.2492700	Vegetation	Rural	< 3 meters	Fire Agency	WILLOWS FIRE DEPT	RISER POLE LOAD SIDE OF STEP UP BANK	62006	21,000	Lightning Arrestor	Overhead	Yes	10/29/14	13:22
229	PG&E	11/1/14	9:10	37.1859320	-122.0012030	Vegetation	Rural	< 3 meters	Fire Agency	Cal Fire/ Santa Clara County Fire	100551454	Verizon	12,000	Conductor	Overhead	Yes	11/1/14	9:10
230	PG&E	11/1/14	20:52	41.1343830	-124.1521100	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	100980319		12,000	Conductor	Overhead	Yes	11/1/14	20:52
231	PG&E	11/5/14	8:34	38.4444710	-122.2492990	Vegetation	Rural	< 3 meters	Fire Agency	Cal Fire	102291451	AT&T	12,000	Conductor	Overhead	Yes	11/5/14	8:34
232	PG&E	11/6/14	10:42	36.9811100	-120.0264980	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	15882 WATSON RD MADERA		12,000	Conductor	Overhead	Yes	11/6/14	10:42
233	PG&E	11/6/14	14:56	37.0567450	-120.8149750	Vegetation	Rural	< 3 meters	Self Extinguished		101201387	AT&T	0 - 750	Conductor	Overhead	No		
234	PG&E	11/7/14	6:12	35.3169500	-120.6796090	Vegetation	Urban	< 3 meters	Fire Agency	Cal Fire	FUSE 11065		12,000	Conductor	Overhead	Yes	11/7/14	6:12
235	PG&E	11/8/14	15:02	38.														

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
2	Utility Name	Fire Start	Column1	Location	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
255	PG&E	12/30/14	9:00	38.4058600	-120.5153240	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	674 SMITTY LN		12,000	Conductor	Overhead	Yes	12/30/14	9:00
256	PG&E	12/30/14	15:53	38.0165160	-122.1366200	Other	Urban	Structure Only	Fire Agency	MARTINEZ FIRE	100444078		21,000	Conductor	Overhead	Yes	12/30/14	15:53
257	PG&E	01/08/15	15:18	37.36631	-121.88317	Other	Rural	< 0.25 Acres	Fire Agency	SJFD	100566657	None	12,000	Conductor	Subsurface	Yes	1/8/15	15:18
258	PG&E	01/10/15	13:07	38.08903	-122.20869	Vegetation	Urban	< 0.25 Acres	Utility, PG&E		100217759		12,000	Conductor	Overhead	Yes	1/10/15	13:07
259	PG&E	01/16/15	7:07	38.77533	-122.70044	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	102167494	Pacific Bell	0 - 750	Conductor	Overhead	No		
260	PG&E	01/28/15	3:51	37.05394	-122.15867	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE			12,000	Conductor	Overhead	Yes	1/28/15	3:51
261	PG&E	02/06/15	6:01	38.00589	-121.02213	Vegetation	Rural	< 3 meters	Fire Agency		6661 Ryan Ranch Road, El Dorado Hills		21,000	Conductor	Overhead	Yes	2/6/15	6:01
262	PG&E	02/06/15	14:08	38.40321	-121.01808	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	loadsides of 40283		12,000	Conductor	Overhead	Yes	2/6/15	14:08
263	PG&E	02/07/15	15:13	38.08712	-122.54963	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	NOVATO FIRE DEPARTMENT			12,000	Conductor	Overhead	Yes	2/7/15	15:13
264	PG&E	02/07/15	18:38	40.46741	-123.85446	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	mile marker 36.61, hwy 36, bridgeville		12,000	Conductor	Overhead	Yes	2/7/15	18:38
265	PG&E	02/13/15	16:01	35.36284	-118.96615	Vegetation	Urban	< 0.25 Acres	Fire Agency	Bakersfield FD	512 Wilma Street, Bakersfield		0 - 750	Conductor	Overhead	Yes	2/13/15	16:01
266	PG&E	02/16/15	11:08	37.58966	-120.85233	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101206051		12,000	Conductor	Overhead	Yes	2/16/15	11:08
267	PG&E	02/17/15	16:46	39.76284	-121.58268	Vegetation	Urban	< 3 meters	Fire Agency	butte county	100324934	Pacific Bell	12,000	Conductor	Overhead	Yes	2/17/15	16:46
268	PG&E	02/22/15	14:20	38.01600	-122.18318	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Capay	101592201		21,000	Conductor	Overhead	Yes	2/22/15	14:20
269	PG&E	02/23/15	2:05	39.30273	-121.01749	Vegetation	Rural	< 3 meters	Fire Agency	NEVADA CITY FIRE	100086316		12,000	Conductor	Overhead	Yes	2/23/15	2:05
270	PG&E	02/23/15	13:25	38.50455	-122.74081	Vegetation	Rural	< 0.25 Acres	Fire Agency	RINCON VALLEY	BEHIND 4870 CARRIAGE LN SANTA ROSA		12,000	Conductor	Overhead	Yes	2/23/15	13:25
271	PG&E	02/25/15	2:34	36.75618	-119.78001	Vegetation	Urban	< 3 meters	Fire Agency	CITY OF FRESNO	100869017	Pacific Bell	12,000	Fuse	Overhead	Yes	2/25/15	2:34
272	PG&E	02/25/15	16:42	34.89210	-120.50397	Vegetation	Rural	< 3 meters	Customer				0 - 750	Conductor	Overhead	Yes	2/25/15	16:42
273	PG&E	03/04/15	18:44	38.99945	-122.75451	Vegetation	Rural	< 0.25 Acres	Fire Agency	Kelseyville FD	102156367	Pacific Bell	12,000	Conductor	Overhead	Yes	3/4/15	18:44
274	PG&E	03/07/15	13:35	38.70909	-122.64837	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	14417 western mine rd, Middletown		12,000	Conductor	Overhead	Yes	3/7/15	13:35
275	PG&E	03/09/15	9:36	38.73283	-120.75239	Building	Urban	Structure Only	Unknown			Pacific Bell	12,000	Conductor	Overhead	Yes	3/9/15	9:36
276	PG&E	03/14/15	2:30	38.90381	-122.75790	Vegetation	Rural	< 0.25 Acres	Unknown		9210 Wildcat Road, Kelseyville		12,000	Conductor	Overhead	Yes	3/14/15	2:30
277	PG&E	03/14/15	14:17	38.82525	-121.13632	Vegetation	Rural	< 3 meters	Fire Agency	LOOMIS FIRE	10011369	Pacific Bell	0 - 750	Conductor	Overhead	No		
278	PG&E	03/14/15	22:09	36.89154	-121.71191	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	103525395		21,000	Conductor	Overhead	Yes	3/14/15	22:09
279	PG&E	03/15/15	3:26	35.36933	-118.92804	Vegetation	Urban	< 0.25 Acres	Fire Agency	KERN COUNTY FIRE DEPT	100216241	Pacific Bell	0 - 750	Unknown	Overhead	No		
280	PG&E	03/15/15	3:38	38.93396	-119.78022	Vegetation	Rural	< 3 meters	Unknown			None	21,000	Conductor	Overhead	Yes	3/15/15	3:38
281	PG&E	03/15/15	22:47	38.33457	-120.53253	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	103106530		12,000	Conductor	Overhead	Yes	3/15/15	22:47
282	PG&E	03/19/15	20:11	37.84163	-122.12176	Vegetation	Urban	< 3 meters	Fire Agency	moraga fire	100498544	Pacific Bell	12,000	Conductor	Overhead	Yes	3/19/15	20:11
283	PG&E	03/21/15	10:46	40.16448	-122.28939	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	101546309	Pacific Bell	12,000	Conductor	Overhead	Yes	3/21/15	10:46
284	PG&E	03/21/15	11:03	36.56658	-121.51428	Vegetation	Rural	< 0.25 Acres	Fire Agency	Monterey Regional	101758338	Pacific Bell	12,000	Conductor	Overhead	Yes	3/21/15	11:03
285	PG&E	03/31/15	13:33	37.11247	-120.94326	Vegetation	Rural	< 3 meters	Fire Agency	COUNTY FIRE	101199839		0 - 750	Conductor	Overhead	Yes	3/31/15	13:33
286	PG&E	04/02/15	9:44	39.67722	-121.49198	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	100338726		12,000	Conductor	Overhead	Yes	4/2/15	9:44
287	PG&E	04/04/15	16:49	38.88245	-122.59135	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	20748 Jerusalem Grade Road, Middletown		12,000	Other	Overhead	Yes	4/4/15	16:49
288	PG&E	04/11/15	17:16	40.54619	-122.23427	Vegetation	Rural	< 0.25 Acres	Unknown		101491414		12,000	Conductor	Overhead	Yes	4/11/15	17:16
289	PG&E	04/12/15	12:35	40.18609	-122.21385	Vegetation	Rural	< 0.25 Acres	Fire Agency	NOT SURE 2ND ON SITE (1ST LX	101544984		12,000	Conductor	Overhead	Yes	4/12/15	12:35
290	PG&E	04/14/15	11:09	38.02151	-121.60999	Vegetation	Rural	< 3 meters	Fire Agency	EAST CONTRA COSTA	100505773	Pacific Bell	0 - 750	Conductor	Overhead	Yes	4/14/15	11:09
291	PG&E	04/14/15	12:35	38.17891	-121.69384	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	AIRPORT RD BTW 2CD & 3RD P/S/O CHURCH RD		21,000	Conductor	Overhead	Yes	4/14/15	12:35
292	PG&E	04/15/15	12:35	39.11523	-121.57110	Vegetation	Urban	< 3 meters	Unknown		101319105	Pacific Bell	0 - 750	Conductor	Overhead	Yes	4/15/15	12:35
293	PG&E	04/16/15	17:35	38.20541	-122.14755	Vegetation	Rural	< 3 meters	Fire Agency	FAIRFIELD FD	5B 17513		12,000	Conductor	Overhead	Yes	4/16/15	17:35
294	PG&E	04/17/15	14:34	37.00413	-119.73927	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	MADERA COUNTY	101118401		21,000	Conductor	Overhead	Yes	4/17/15	14:34
295	PG&E	04/18/15	0:07	38.68576	-121.00839	Vegetation	Urban	< 3 meters	Fire Agency	cameron park F.D.	around 1-7464		21,000	Conductor	Overhead	Yes	4/18/15	3:07
296	PG&E	04/19/15	9:18	38.57637	-119.88898	Vegetation	Rural	< 0.25 Acres	Self Extinguished		100826688	Pacific Bell	12,000	Conductor	Overhead	Yes	4/19/15	9:18
297	PG&E	04/19/15	13:01	37.15710	-120.41450	Vegetation	Rural	< 0.25 Acres	Unknown		101013878		12,000	Conductor	Overhead	Yes	4/19/15	13:01
298	PG&E	04/20/15	18:18	36.97431	-120.01758	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	MFD	101211344	Pacific Bell	12,000	Conductor	Overhead	Yes	4/20/15	18:18
299	PG&E	04/21/15	17:01	34.93126	-120.44048	Vegetation	Urban	< 3 meters	Self Extinguished		101919414	Verizon	12,000	Conductor	Overhead	Yes	4/21/15	17:01
300	PG&E	04/24/15	6:06	38.05007	-121.49664	Vegetation	Rural	< 3 meters	Fire Agency	unknown	leeve rd s/o herman and helans resort		21,000	Conductor	Overhead	Yes	4/24/15	6:06
301	PG&E	04/24/15	17:47	37.55864	-121.91962	Vegetation	Rural	< 0.25 Acres	Fire Agency	Alameda County	Base of C/O pole 9435		12,000	Unknown	Overhead	Yes	4/24/15	17:47
302	PG&E	04/26/15	16:50	34.85467	-120.52399	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Santa Barbara County Fire Dept	2 poles load side 7455	None	12,000	Conductor	Overhead	Yes	4/26/15	16:50
303	PG&E	04/27/15	12:54	35.48709	-120.67561	Vegetation	Rural	< 3 meters	Unknown		103310601		21,000	Conductor	Overhead	Yes	4/27/15	12:54
304	PG&E	04/28/15	13:57	36.75043	-119.74831	Vegetation	Urban	< 3 meters	Fire Agency	FRESNO CITY FIRE	100842188		12,000	Conductor	Overhead	Yes	4/28/15	13:57
305	PG&E	04/28/15	14:20	39.79716	-121.89074	Vegetation	Rural	< 3 meters	Unknown		100435592	Pacific Bell	12,000	Conductor	Overhead	Yes	4/28/15	14:20
306	PG&E	04/30/15	0:26	37.24014	-122.24720	Vegetation	Rural	< 0.25 Acres	Unknown		1145 VERDE R		12,000	Conductor	Overhead	Yes	4/30/15	0:26
307	PG&E	05/02/15	16:51	37.32843	-119.64296	Vegetation	Rural	< 0.25 Acres	Fire Agency	MADERA COUNTY	103768995		12,000	Conductor	Overhead	Yes	5/2/15	16:51
308	PG&E	05/02/15	17:30	38.20382	-121.26438	Vegetation	Rural	< 0.25 Acres	Unknown		103765745	Pacific Bell	12,000	Conductor	Overhead	Yes	5/2/15	17:30
309	PG&E	05/06/15	17:17	37.42727	-119.88028	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	BOOSTER 8179 INDIAN PEEK N/O MIWUK	None	21,000	Other	Overhead	Yes	5/6/15	17:17
310	PG&E	05/06/15	23:10	38.81040	-122.32918	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	BLACK BUTTE		12,000	Lightning Arrestor	Overhead	Yes	5/6/15	23:10
311	PG&E	05/07/15	8:06	38.23789	-121.58751	Vegetation	Rural	< 0.25 Acres	Unknown		101331086		0 - 750	Conductor	Overhead	No		
312	PG&E	05/08/15	5:55	38.77559	-121.50642	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	fire dept	mt # 03650R		0 - 750	Fuse	Overhead	Yes	5/8/15	5:55
313	PG&E	05/09/15	13:10	39.23429	-121.24683	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	100000103	None	21,000	Conductor	Overhead	Yes	5/9/15	13:10
314	PG&E	05/09/15	21:37	39.28477	-121.02192	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	100004095	Pacific Bell	12,000	Fuse	Overhead	Yes	5/9/15	21:37
315	PG&E	05/10/15	15:03	37.66494	-122.43218	Vegetation	Urban	< 0.25 Acres	Fire Agency	San Mateo FD	100282481	Pacific Bell	12,000	Conductor	Overhead	Yes	5/10/15	15:03
316	PG&E	05/10/15	16:07	37.78316	-120.79332	Vegetation	Rural	< 0.25 Acres	Fire Agency	Oakdale	9956 Dillwood rd.		17,000	Conductor	Overhead	Yes	5/10/15	16:07
317	PG&E	05/11/15	7:19	38.12335	-121.37083	Vegetation	Rural	10 - 99 Acres	Fire Agency	woodbridge fd	102075242	Pacific Bell	21,000	Conductor	Overhead	Yes	5/11/15	7:19
318	PG&E	05/11/15	16:07	35.92534	-120.86691	Vegetation	Rural	< 3 meters	Unknown		LR 7064 JUMP		12,000	Conductor	Overhead	Yes	5/11/15	16:07
319	PG&E	05/11/15	16:18	39.28045	-123.20674	Vegetation	Rural	< 0.25 Acres	Fire Agency	REDWOOD VALLEY FIRE	9502 EAST RD., REDWOOD VALLEY		0 - 750	Conductor	Overhead	Yes	5/11/15	16:18
320	PG&E	05/12/15	23:57	39.18514	-121.68041	Vegetation	Rural	< 3 meters	Fire Agency	YUBA CITY	101303383	Pacific Bell	0 - 750					

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
2	Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
339	PG&E	05/31/15	7:07	38.78237	-121.48018	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Pleasant Grove Fire Dept. Station #	3700 Sankey Rd, Pleasant Grove		12,000	Unknown	Overhead	Yes	5/31/15	7:07
340	PG&E	05/31/15	9:27	37.97745	-121.32671	Vegetation	Urban	< 0.25 Acres	Customer		102057703	Pacific Bell	12,000	Conductor	Overhead	No		
341	PG&E	05/31/15	11:31	37.27325	-120.47098	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101152842	Pacific Bell	0 - 750	Conductor	Overhead	No		
342	PG&E	05/31/15	11:55	37.72185	-120.79311	Vegetation	Rural	< 3 meters	Customer	NONE	102340604	None	0 - 750	Conductor	Overhead	No		
343	PG&E	06/03/15	9:33	38.68957	-121.62161	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE			12,000	Conductor	Overhead	Yes	6/3/15	9:33
344	PG&E	06/03/15	13:44	38.62701	-121.07659	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	103035299		21,000	Conductor	Overhead	Yes	6/3/15	13:44
345	PG&E	06/03/15	17:09	35.36123	-119.00622	Vegetation	Urban	< 0.25 Acres	Fire Agency	KCFD AND BCFD	100150055	Pacific Bell	0 - 750	Conductor	Overhead	No		
346	PG&E	06/04/15	13:17	39.26939	-123.78411	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE			12,000	Conductor	Overhead	Yes	6/4/15	13:17
347	PG&E	06/04/15	15:44	39.46837	-121.56128	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	powerhouse hill rd 2spans e on ophir rd		12,000	Conductor	Overhead	Yes	6/4/15	15:44
348	PG&E	06/04/15	18:38	38.58801	-121.51709	Vegetation	Urban	< 3 meters	Fire Agency	west sacramento FD	101565849	Pacific Bell	12,000	Unknown	Overhead	Yes	6/4/15	18:38
349	PG&E	06/04/15	20:00	38.69160	-120.86058	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101412760	Pacific Bell	12,000	Conductor	Overhead	Yes	6/4/15	20:00
350	PG&E	06/05/15	1:25	38.34607	-122.39979	Vegetation	Rural	< 0.25 Acres	Fire Agency		4870 REDWOOD		21,000	Conductor	Overhead	Yes	6/5/15	1:25
351	PG&E	06/05/15	9:58	40.10703	-123.71422	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	100986799		12,000	Conductor	Overhead	Yes	6/5/15	9:58
352	PG&E	06/05/15	14:40	37.95777	-120.45191	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101012484		17,000	Conductor	Overhead	Yes	6/5/15	14:40
353	PG&E	06/05/15	15:15	36.77591	-119.77027	Vegetation	Urban	< 0.25 Acres	Fire Agency	CITY OF FRESNO	100857009	Pacific Bell	0 - 750	Transformer	Overhead	Yes	6/5/15	15:15
354	PG&E	06/05/15	22:13	38.77290	-121.46992	Vegetation	Rural	< 3 meters	Fire Agency	WATER	100064053		12,000	Capacitor Bank	Overhead	Yes	6/5/15	22:13
355	PG&E	06/06/15	11:24	39.80295	-121.90643	Vegetation	Rural	< 3 meters	Unknown		100433862	Pacific Bell	12,000	Conductor	Overhead	Yes	6/6/15	11:24
356	PG&E	06/06/15	12:00	36.98282	-120.03324	Vegetation	Rural	< 0.25 Acres	Unknown		101015092		12,000	Lightning Arrestor	Overhead	Yes	6/6/15	12:00
357	PG&E	06/06/15	15:38	39.04089	-123.40189	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	11480 ANDERSON VALLEY WAY @ BRIDGE		12,000	Conductor	Overhead	Yes	6/6/15	15:38
358	PG&E	06/06/15	21:17	38.00575	-121.23822	Vegetation	Rural	< 0.25 Acres	Fire Agency	COUNTY FIRE	102135759	Pacific Bell	12,000	Conductor	Overhead	Yes	6/6/15	21:17
359	PG&E	06/07/15	5:05	36.69060	-119.74880	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	FRESNO FIRE	103339346		12,000	Conductor	Overhead	Yes	6/7/15	5:05
360	PG&E	06/07/15	14:53	36.32160	-121.28363	Vegetation	Rural	< 0.25 Acres	Fire Agency	monterey county	peach and thorne greenfield	Pacific Bell	12,000	Unknown	Overhead	Yes	6/7/15	14:53
361	PG&E	06/07/15	17:48	38.21794	-121.07624	Vegetation	Rural	100 - 299 Acres	Fire Agency	Saltum fire protection district.	605 278361		21,000	Conductor	Overhead	Yes	6/7/15	17:48
362	PG&E	06/08/15	14:18	38.17956	-120.95899	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	102048579	Pacific Bell	12,000	Conductor	Overhead	Yes	6/8/15	14:18
363	PG&E	06/08/15	16:12	38.11554	-122.55622	Vegetation	Rural	< 3 meters	Fire Agency	novato fire	front yard 9 equestrian ct		0 - 750	Conductor	Overhead	No		
364	PG&E	06/08/15	18:15	39.82356	-123.80931	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	2 spans loadside 1741		12,000	Conductor	Overhead	Yes	6/8/15	18:15
365	PG&E	06/08/15	17:38	37.95820	-121.94406	Vegetation	Urban	< 3 meters	Unknown		77325		0 - 750	Conductor	Overhead	Yes	6/8/15	17:38
366	PG&E	06/08/15	18:32	37.94040	-122.07949	Vegetation	Urban	< 3 meters	Fire Agency	CONTRA COSTA FIRE	100462348	Pacific Bell	0 - 750	Fuse	Overhead	Yes	6/8/15	18:32
367	PG&E	06/09/15	1:19	40.54242	-122.23906	Vegetation	Rural	< 3 meters	Customer		101490096	Frontier	12,000	Transformer	Overhead	Yes	6/9/15	1:19
368	PG&E	06/09/15	11:51	36.48888	-119.58237	Building	Rural	Structure Only	Fire Agency	tulare county fire	4390 ave 352		12,000	Conductor	Overhead	Yes	6/9/15	11:51
369	PG&E	06/09/15	13:10	38.11758	-121.15094	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	WATERLOO MORADA FIRE DIST	102076487		21,000	Conductor	Overhead	Yes	6/9/15	13:10
370	PG&E	06/09/15	15:24	38.36510	-122.25410	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	load side 2987	Yes	21,000	Conductor	Overhead	Yes	6/9/15	15:24
371	PG&E	06/09/15	16:20	38.38222	-122.43156	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	102269716	Pacific Bell	21,000	Unknown	Overhead	Yes	6/9/15	16:20
372	PG&E	06/09/15	21:21	38.93940	-121.24670	Vegetation	Rural	< 3 meters	Unknown		100035304	Pacific Bell	12,000	Conductor	Overhead	Yes	6/9/15	21:21
373	PG&E	06/10/15	12:00	39.13763	-121.63145	Vegetation	Urban	< 0.25 Acres	Fire Agency	YUBA CITY	101320887		12,000	Conductor	Overhead	Yes	6/10/15	12:00
374	PG&E	06/10/15	17:02	36.96710	-120.03052	Vegetation	Rural	< 3 meters	Unknown		101216691	Pacific Bell	0 - 750	Conductor	Overhead	No		
375	PG&E	06/10/15	21:43	37.63812	-121.89433	Vegetation	Rural	< 3 meters	Fire Agency	PLEASANTON FIRE DEPT	100927124	Pacific Bell	12,000	Conductor	Overhead	Yes	6/10/15	21:43
376	PG&E	06/11/15	18:32	38.82212	-121.30805	Vegetation	Urban	< 0.25 Acres	Fire Agency	CITY OF ROCKLIN/ CAL FIRE	103661493		21,000	Switch	Overhead	Yes	6/11/15	18:32
377	PG&E	06/12/15	9:04	39.39398	-122.22991	Vegetation	Rural	< 0.25 Acres	Fire Agency	WILLOWS FIRE DEPT.	103026792		21,000	Conductor	Overhead	Yes	6/12/15	9:04
378	PG&E	06/12/15	9:24	37.07699	-120.30027	Vegetation	Rural	< 3 meters	Self Extinguished		103049449		0 - 3 meters	Conductor	Overhead	Yes	6/12/15	9:24
379	PG&E	06/12/15	10:48	38.42747	-122.85903	Vegetation	Rural	< 0.25 Acres	Fire Agency		102023459	Pacific Bell	12,000	Conductor	Overhead	Yes	6/12/15	10:48
380	PG&E	06/12/15	13:07	40.40775	-122.41037	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE DEP.	ACROSS STREET FROM 4139 OLD HAPPY VALLEY RD		12,000	Lightning Arrestor	Overhead	No		
381	PG&E	06/12/15	18:01	37.92517	-122.07817	Vegetation	Urban	< 3 meters	Fire Agency	WALNUT CREEK FIRE	100478251	Pacific Bell	0 - 750	Transformer	Overhead	Yes	6/12/15	18:01
382	PG&E	06/12/15	23:32	39.23077	-121.15594	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	10903 PROSPECTOR RD ROUGH AND REAL	Pacific Bell	21,000	Conductor	Overhead	Yes	6/12/15	23:32
383	PG&E	06/13/15	12:50	36.27221	-118.91221	Vegetation	Rural	< 3 meters	Fire Agency	Kern Co Fire Dept	103779942		0 - 750	Conductor	Overhead	No		
384	PG&E	06/14/15	12:19	39.74316	-121.84249	Vegetation	Urban	< 3 meters	Fire Agency	CHICO FIRE DEPT	100426666	Pacific Bell	0 - 750	Conductor	Overhead	No		
385	PG&E	06/14/15	13:50	36.96333	-119.87030	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	12915 mesa, madera		21,000	Conductor	Overhead	Yes	6/14/15	13:50
386	PG&E	06/15/15	15:35	37.18518	-121.75950	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	San Jose city	100618215	Pacific Bell	21,000	Conductor	Overhead	Yes	6/15/15	15:35
387	PG&E	06/16/15	10:40	38.00621	-122.10918	Vegetation	Urban	26 - 9.99 Acres	Unknown		Tw 008/058		115,000	Conductor	Overhead	Yes	6/16/15	10:40
388	PG&E	06/16/15	11:27	39.03816	-122.92637	Vegetation	Rural	< 0.25 Acres	Fire Agency	LAKEPORT FIRE	102165174	Pacific Bell	0 - 750	Conductor	Overhead	Yes	6/16/15	11:27
389	PG&E	06/17/15	10:32	37.76881	-120.90776	Vegetation	Rural	< 3 meters	Fire Agency	Escalon fire dept.			17,000	Conductor	Overhead	Yes	6/17/15	10:32
390	PG&E	06/17/15	15:49	37.35161	-120.64202	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	8503 LONGVIEW ATWATER		0 - 750	Conductor	Overhead	No		
391	PG&E	06/17/15	18:35	35.30324	-119.01164	Vegetation	Urban	< 3 meters	Fire Agency	BCFD	100155778	Pacific Bell	21,000	Conductor	Overhead	Yes	6/17/15	18:35
392	PG&E	06/19/15	12:14	34.83564	-120.38433	Vegetation	Rural	10 - 99 Acres	Fire Agency	SANTA BARBARA COUNTY FIRE D	103015189		12,000	Conductor	Overhead	Yes	6/19/15	12:14
393	PG&E	06/19/15	20:09	39.15973	-121.48652	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101308410	Pacific Bell	0 - 750	Conductor	Overhead	Yes	6/19/15	20:09
394	PG&E	06/20/15	1:28	36.25480	-119.64348	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE			12,000	Conductor	Overhead	Yes	6/20/15	1:28
395	PG&E	06/21/15	1:32	39.03097	-121.34400	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	100021218		12,000	Conductor	Overhead	Yes	6/21/15	1:32
396	PG&E	06/21/15	3:17	39.09559	-121.54211	Vegetation	Rural	10 - 99 Acres	Fire Agency	Wheatland fire dept	Transmission Sw 159 on the Peace - Rio-Oso	15kv line	115,000	Transformer	Overhead	Yes	6/21/15	3:17
397	PG&E	06/21/15	12:07	36.72248	-121.76673	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	NORTH COUNTY FIRE DEPARTMENT	#1428	None	21,000	Conductor	Overhead	No		
398	PG&E	06/21/15	12:10	37.92730	-122.31824	Vegetation	Urban	< 0.25 Acres	Fire Agency	RICHMOND	KEY BLVD		4,000	Conductor	Overhead	Yes	6/21/15	12:10
399	PG&E	06/21/15	12:31	38.83173	-121.16423	Vegetation	Rural	< 3 meters	Fire Agency	penryn fire dept	100509933	Pacific Bell	0 - 750	Transformer	Overhead	No		
400	PG&E	06/21/15	12:46	38.00167	-121.29768	Vegetation	Urban	< 0.25 Acres	Fire Agency	STOCKTON F.D	102138737		12,000	Conductor	Overhead	Yes	6/21/15	12:46
401	PG&E	06/21/15	13:31	37.37504	-119.61162	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	103204866		0 - 750	Conductor	Overhead	No		
402	PG&E	06/22/15	11:58	39.17373	-121.06674	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	SENTINIAL WY		12,000	Conductor	Overhead	Yes	6/22/15	11:58
403	PG&E	06/22/15	18:56	36.98705	-121.53811	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Gilroy city fire			21,000	Conductor	Overhead	Yes	6/22/15	18:56
404	PG&E	06/23/15	16:23	39.05512	-121.56103	Vegetation	Rural	< 0.25 Acres	Fire Agency	LINDA FIRE DEPT	102354046		12,000	Conductor	Overhead	Yes	6/23/15	16:23
405	PG&E	06/23/15	19:06	37.94531	-1													

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Column5	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
2	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin												
423	PG&E	06/28/15	14:47	38.22141	-122.24268	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	102278099	Pacific Bell	12,000	Conductor	Overhead	Yes	6/28/15	14:47
424	PG&E	06/28/15	17:15	35.55270	-120.73140	Vegetation	Rural	< 0.25 Acres	Fire Agency	templeton fire	347 puffin		21,000	Conductor	Overhead	Yes	6/28/15	17:15
425	PG&E	06/28/15	20:40	37.93764	-120.60907	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	101282825		17,000	Conductor	Overhead	Yes	6/28/15	20:40
426	PG&E	06/28/15	21:07	39.74048	-121.49737	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	DEADWOOD RD. JARBO GAP		12,000	Conductor	Overhead	Yes	6/28/15	21:07
427	PG&E	06/29/15	1:06	35.35164	-119.03234	Vegetation	Urban	< 0.25 Acres	Fire Agency	Bakersfield FD	100145659	Pacific Bell	12,000	Conductor	Overhead	Yes	6/29/15	1:06
428	PG&E	06/29/15	6:26	37.56461	-122.39297	Vegetation	Rural	< 3 meters	Fire Agency	burlingame fire	100311342	Pacific Bell	4,000	Conductor	Overhead	Yes	6/29/15	6:26
429	PG&E	06/29/15	7:43	38.30431	-119.93889	Vegetation	Rural	< 0.25 Acres	Self Extinguished		rd 33 1/2 n/o ave 12 at 5451		12,000	Conductor	Overhead	Yes	6/29/15	7:43
430	PG&E	06/29/15	18:45	39.11714	-121.67248	Vegetation	Urban	< 3 meters	Fire Agency	OLIVEHURST FIRE	101319193	Pacific Bell	0 - 750	Conductor	Overhead	No		
431	PG&E	06/30/15	0:05	35.40119	-120.62223	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	santa margarita ch SS c/o 6631		12,000	Conductor	Overhead	Yes	6/30/15	0:05
432	PG&E	06/30/15	5:40	35.20864	-119.00801	Vegetation	Rural	< 3 meters	Fire Agency	KC Fire	100127938	Pacific Bell	12,000	Conductor	Overhead	Yes	6/30/15	5:40
433	PG&E	06/30/15	17:54	37.73402	-121.93813	Vegetation	Urban	< 3 meters	Fire Agency	SRFD	100901822	Pacific Bell	21,000	Transformer	Overhead	Yes	6/30/15	17:54
434	PG&E	06/30/15	18:18	36.21991	-121.75343	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	loadside of 88973	unknown	12,000	Conductor	Overhead	Yes	6/30/15	18:18
435	PG&E	07/01/15	9:17	38.57154	-122.54428	Vegetation	Rural	26 - 9.99 Acres	Unknown				12,000	Conductor	Overhead	Yes	7/1/15	9:17
436	PG&E	07/01/15	12:57	39.41463	-121.37899	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE			12,000	Conductor	Overhead	Yes	7/1/15	12:57
437	PG&E	07/02/15	12:59	37.01684	-120.63577	Vegetation	Rural	< 0.25 Acres	Unknown				12,000	Conductor	Overhead	Yes	7/2/15	12:59
438	PG&E	07/02/15	14:06	38.79257	-121.50153	Vegetation	Rural	< 0.25 Acres	Fire Agency	unknown	101299516	None	0 - 750	Conductor	Overhead	No		
439	PG&E	07/02/15	22:52	37.85606	-120.94458	Vegetation	Rural	< 0.25 Acres	Fire Agency	OAKDALE F.D.	W/SIDE VALLEY HOME RD @ LAMBUTH RD	Pacific Bell	17,000	Conductor	Overhead	Yes	7/2/15	22:52
440	PG&E	07/03/15	3:23	35.67850	-120.95670	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	1 soan 1 conductor 1 span load side transformer formtr 10084932		21,000	Conductor	Overhead	Yes	7/3/15	3:23
441	PG&E	07/03/15	12:12	35.38600	-120.85705	Vegetation	Urban	< 0.25 Acres	Fire Agency	Morro Bay city	101848318		12,000	Conductor	Overhead	Yes	7/3/15	12:12
442	PG&E	07/03/15	19:21	36.53499	-119.50036	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	County, CDF	40952 Road 32 Kingsburg		12,000	Conductor	Overhead	Yes	7/3/15	19:21
443	PG&E	07/04/15	1:14	38.95660	-121.04336	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	100037226		12,000	Other	Overhead	Yes	7/4/15	1:14
444	PG&E	07/04/15	7:37	38.83140	-119.89259	Vegetation	Urban	< 0.25 Acres	Unknown		103291813		115,000	Conductor	Overhead	Yes	7/4/15	7:37
445	PG&E	07/04/15	14:14	37.88920	-121.61349	Vegetation	Rural	< 3 meters	Fire Agency	FIRE DEPARTMENT	15001 HWY 4 2W/O DISCOVERY BAY	None	21,000	Conductor	Overhead	Yes	7/4/15	14:14
446	PG&E	07/05/15	9:42	35.53230	-120.73706	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE			0 - 750	Conductor	Overhead	No		
447	PG&E	07/05/15	21:21	38.65237	-120.62782	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	one span east of c/o 1055		21,000	Conductor	Overhead	Yes	7/5/15	21:21
448	PG&E	07/07/15	3:02	36.02176	-120.19985	Vegetation	Rural	< 0.25 Acres	Fire Agency	FRESNO CAL FIRE	1 POLE E/O 9718F OFF SUTTER AVE		21,000	Conductor	Overhead	Yes	7/7/15	3:02
449	PG&E	07/07/15	5:52	36.75931	-121.29536	Vegetation	Rural	< 0.25 Acres	Fire Agency	Hollister City	25 Mile south of Bolado Park on Airline Hwy		21,000	Conductor	Overhead	Yes	7/7/15	5:52
450	PG&E	07/07/15	10:42	39.11377	-121.06550	Vegetation	Rural	< 0.25 Acres	Unknown				12,000	Conductor	Overhead	Yes	7/7/15	10:42
451	PG&E	07/07/15	15:27	35.15496	-120.54420	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	303corralitos cwn rd	Pacific Bell	12,000	Conductor	Overhead	Yes	7/7/15	15:27
452	PG&E	07/07/15	22:02	37.00333	-121.56442	Vegetation	Rural	< 0.25 Acres	Self Extinguished		100614011	Verizon	21,000	Conductor	Overhead	Yes	7/7/15	22:02
453	PG&E	07/08/15	11:23	39.22397	-121.06350	Vegetation	Urban	< 0.25 Acres	Fire Agency	CAL FIRE	100094468	Pacific Bell	12,000	Conductor	Overhead	Yes	7/8/15	11:23
454	PG&E	07/11/15	8:57	38.21878	-122.23333	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	mid span from 5267		12,000	Conductor	Overhead	Yes	7/11/15	8:57
455	PG&E	07/11/15	15:38	38.18389	-121.88356	Vegetation	Rural	< 0.25 Acres	Fire Agency	unknown	FUSE C/O 10313 LITTLE HONKER BAY RD & 20 SPANS E/O 103		21,000	Conductor	Overhead	Yes	7/11/15	15:38
456	PG&E	07/12/15	1:32	39.95203	-122.23034	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101528676	None	0 - 750	Conductor	Overhead	No		
457	PG&E	07/12/15	15:27	35.25623	-120.68390	Vegetation	Urban	< 3 meters	Customer		101936544	Pacific Bell	0 - 750	Conductor	Overhead	No		
458	PG&E	07/12/15	17:04	37.47130	-122.42559	Vegetation	Rural	< 0.25 Acres	Fire Agency	COUNTY FIRE	1 s w c509		12,000	Conductor	Overhead	Yes	7/12/15	17:04
459	PG&E	07/12/15	19:47	39.51180	-122.19838	Vegetation	Rural	< 3 meters	Fire Agency	WILLOWS FIRE DEPT.	100403587		0 - 750	Conductor	Overhead	Yes	7/12/15	19:47
460	PG&E	07/13/15	14:16	37.26548	-121.98035	Vegetation	Urban	< 3 meters	Fire Agency	campbell	100523574	Pacific Bell	12,000	Capacitor Bank	Overhead	Yes	7/13/15	14:16
461	PG&E	07/13/15	17:04	37.98903	-122.35911	Vegetation	Rural	< 0.25 Acres	Fire Agency	RICHMOND FIRE DEPT & CCC FI	101435021	Pacific Bell	12,000	Conductor	Overhead	Yes	7/13/15	17:04
462	PG&E	07/14/15	12:37	38.02696	-122.13531	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	arbutle fire demp	102308149		0 - 750	Conductor	Overhead	Yes	7/14/15	12:37
463	PG&E	07/14/15	20:38	38.26308	-122.02102	Vegetation	Urban	< 3 meters	Fire Agency	CAL FIRE	Pole 0101899 - SAND CREEK RD CORTINA SC	Pacific Bell	12,000	Conductor	Overhead	Yes	7/14/15	20:38
464	PG&E	07/14/15	20:38	38.24395	-122.54054	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101997187	Pacific Bell	12,000	Conductor	Overhead	Yes	7/14/15	20:38
465	PG&E	07/15/15	9:00	36.96968	-121.73512	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	101795728		21,000	Conductor	Overhead	Yes	7/15/15	9:00
466	PG&E	07/15/15	19:14	36.89846	-121.69053	Vegetation	Rural	< 0.25 Acres	Fire Agency	city	101710538		21,000	Conductor	Overhead	Yes	7/15/15	19:14
467	PG&E	07/16/15	19:11	37.19894	-119.77123	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	20334 ROAD 400		12,000	Conductor	Overhead	Yes	7/16/15	19:11
468	PG&E	07/16/15	19:27	37.76190	-120.82127	Vegetation	Urban	< 3 meters	Self Extinguished		102333491	Pacific Bell	0 - 750	Conductor	Overhead	Yes	7/16/15	19:27
469	PG&E	07/17/15	0:20	36.96718	-119.64365	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	100651276		0 - 750	Conductor	Overhead	Yes	7/17/15	0:20
470	PG&E	07/17/15	0:53	34.86820	-120.32300	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	SANTA BARBARA COUNTY FIRE D	EAST OF SISQUOUC SUB		12,000	Conductor	Overhead	Yes	7/17/15	0:53
471	PG&E	07/17/15	17:18	38.55961	-121.64346	Vegetation	Rural	< 3 meters	Unknown		In mid span between 2 poles. @ 46735 co. rd. 32B davis		12,000	Conductor	Overhead	Yes	7/17/15	17:18
472	PG&E	07/18/15	17:00	38.83826	-123.62968	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	off HWY 1 PA		12,000	Conductor	Overhead	Yes	7/18/15	17:00
473	PG&E	07/18/15	18:59	39.71199	-123.32836	Vegetation	Rural	26 - 9.99 Acres	Unknown				12,000	Conductor	Overhead	Yes	7/18/15	18:59
474	PG&E	07/19/15	9:44	35.21499	-120.61437	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	101930875		12,000	Conductor	Overhead	Yes	7/19/15	9:44
475	PG&E	07/19/15	19:36	38.65629	-121.79353	Vegetation	Urban	< 3 meters	Fire Agency	WOODLAND FIRE DEPT.	BASE OF TRANSMISSION / DISTRIBUTION POLE = 1/P/S/O FU		0 - 750	Conductor	Overhead	No		
476	PG&E	07/20/15	15:15	37.76203	-120.86537	Vegetation	Urban	< 0.25 Acres	Fire Agency	OAKDALE CITY FIRE			0 - 750	Conductor	Overhead	No		
477	PG&E	07/21/15	8:44	39.11813	-123.20113	Vegetation	Rural	< 0.25 Acres	Fire Agency	UKIAH FIRE	102178810	Pacific Bell	0 - 750	Unknown	Overhead	No		
478	PG&E	07/21/15	10:46	37.18055	-121.06247	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	e/o dmc s/o cottonwood		12,000	Conductor	Overhead	Yes	7/21/15	10:46
479	PG&E	07/22/15	11:03	38.12063	-122.24813	Vegetation	Urban	< 3 meters	Fire Agency	VALLEJO FD	102308149		0 - 750	Conductor	Overhead	No		
480	PG&E	07/22/15	14:21	38.79342	-120.71402	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	sl 3204 slope dr		12,000	Conductor	Overhead	Yes	7/22/15	14:21
481	PG&E	07/23/15	13:14	36.23983	-119.77674	Vegetation	Rural	< 0.25 Acres	Fire Agency	KINGS COUNTY	103242492	YES	12,000	Conductor	Overhead	Yes	7/23/15	13:14
482	PG&E	07/23/15	20:04	38.00746	-121.84819	Vegetation	Rural	< 0.25 Acres	Unknown		Tower 006/081		60,000	Unknown	Overhead	Yes	7/23/15	20:04
483	PG&E	07/24/15	4:10	38.45227	-121.71819	Vegetation	Rural	< 0.25 Acres	Fire Agency	Dixon fire dept	101755623	Pacific Bell	12,000	Conductor	Overhead	Yes	7/24/15	4:10
484	PG&E	07/24/15	14:30	36.69127	-119.03117	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	46970 DUNLAP RD	YES	0 - 750	Transformer	Overhead	Yes	7/24/15	14:30
485	PG&E	07/25/15	14:52	38.92645	-121.29455	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	wise rd west of gladding lincoln	None	12,000	Conductor	Overhead	Yes	7/25/15	14:52
486	PG&E	07/25/15	19:34	39.78477	-121.86082	Vegetation	Urban	< 0.25 Acres	Fire Agency	CAL FIRE	3668 hicks lane, Chico		12,000	Conductor	Overhead	Yes	7/25/15	19:34
487	PG&E	07/26/15	12:25	39.15861	-121.06344	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	15499 ALLISON RANCH RD		12,000	Conductor	Overhead	Yes	7/26/15	12:25
488	PG&E	07/27/15</																

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Column5	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
2	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin												
507	PG&E	08/01/15	14.30	34.95239	-120.29522	Vegetation	Rural	10 - 99 Acres	Unknown		101866639		12,000	Conductor	Overhead	Yes	8/1/15	14.30
508	PG&E	08/02/15	8.08	37.53385	-120.32769	Vegetation	Rural	< 0.25 Acres	Unknown		Pole 013/002		70,000	Conductor	Overhead	Yes	8/2/15	8.08
509	PG&E	08/02/15	13.48	37.87996	-122.52679	Vegetation	Urban	< 0.25 Acres	Fire Agency	mill valley FD	102276049	Pacific Bell	0 - 750	Conductor	Overhead	No		
510	PG&E	08/02/15	16.24	37.63172	-120.15471	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101076992		21,000	Conductor	Overhead	Yes	8/2/15	16.24
511	PG&E	08/03/15	0.07	40.50560	-122.34702	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	COTTONWOOD FIRE DEPT	101503428	Pacific Bell	12,000	Conductor	Overhead	Yes	8/3/15	0.07
512	PG&E	08/03/15	17.53	38.33610	-121.18939	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	Pole 000/008		60,000	Conductor	Overhead	Yes	8/3/15	17.53
513	PG&E	08/04/15	16.05	40.08234	-121.15383	Vegetation	Rural	< 0.25 Acres	Fire Agency	USFS	100441220		0 - 750	Fuse	Overhead	Yes	8/4/15	16.05
514	PG&E	08/04/15	17.57	37.98791	-120.22898	Vegetation	Rural	< 0.25 Acres	Unknown		Str. 007/019	None	70,000	Conductor	Overhead	Yes	8/4/15	17.57
515	PG&E	08/05/15	15.13	37.31997	-120.50507	Vegetation	Urban	< 0.25 Acres	Fire Agency	CAL FIRE	101162540		0 - 750	Capacitor Bank	Overhead	No		
516	PG&E	08/06/15	12.10	38.22687	-121.02613	Vegetation	Rural	< 0.25 Acres	Fire Agency	city of lone fire dept	103194904	Verizon	21,000	Conductor	Overhead	Yes	8/6/15	12.10
517	PG&E	08/06/15	16.18	39.27542	-122.07580	Vegetation	Rural	< 0.25 Acres	Unknown		6 POLES ELR 3036		12,000	Conductor	Overhead	Yes	8/6/15	16.18
518	PG&E	08/07/15	6.24	37.50238	-122.10573	Vegetation	Rural	< 0.25 Acres	Unknown				12,000	Conductor	Overhead	Yes	8/7/15	6.24
519	PG&E	08/07/15	6.32	37.84005	-122.18234	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	100498058	Pacific Bell	12,000	Conductor	Overhead	Yes	8/7/15	6.32
520	PG&E	08/07/15	16.59	38.89175	-122.16936	Vegetation	Rural	10 - 99 Acres	Fire Agency	EVERY BODY	101500955	Pacific Bell	12,000	Conductor	Overhead	Yes	8/7/15	16.59
521	PG&E	08/08/15	7.42	39.20066	-121.21365	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	100076217	Pacific Bell	0 - 750	Transformer	Overhead	No		
522	PG&E	08/08/15	16.03	41.28443	-124.07568	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	PARKS SERVICE	100978185	Verizon	12,000	Conductor	Overhead	Yes	8/8/15	16.03
523	PG&E	08/10/15	11.30	37.94464	-121.96981	Vegetation	Urban	< 0.25 Acres	Fire Agency	CONTRA COSTA FIRE	1 pole west of c/o 7069	None	21,000	Conductor	Overhead	Yes	8/10/15	11.30
524	PG&E	08/10/15	12.41	36.88775	-121.81578	Vegetation	Rural	< 3 meters	Self Extinguished			None	0 - 750	Conductor	Overhead	No		
525	PG&E	08/10/15	21.58	38.52958	-120.81642	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	101235918		0 - 750	Conductor	Overhead	Yes	8/10/15	21.58
526	PG&E	08/11/15	4.26	36.12892	-121.01473	Vegetation	Rural	< 0.25 Acres	Fire Agency	unknown	101278045		12,000	Conductor	Overhead	Yes	8/11/15	4.26
527	PG&E	08/12/15	17.38	40.21534	-123.68814	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	1 SP LD SD METER 1007960761		12,000	Conductor	Overhead	Yes	8/12/15	17.38
528	PG&E	08/13/15	3.46	37.20721	-119.79430	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	44385 SAVAGE RD COARSEGOLD		21,000	Conductor	Overhead	Yes	8/13/15	3.46
529	PG&E	08/13/15	3.57	38.77573	-121.85849	Vegetation	Rural	< 3 meters	Fire Agency	DONT KNOW - COUNTY? THEY	4051 KLUCK PG&E POLE AT FUSES 79079	None	12,000	Conductor	Overhead	Yes	8/13/15	3.57
530	PG&E	08/13/15	23.55	37.40768	-121.85385	Vegetation	Urban	< 0.25 Acres	Fire Agency	MILPITAS FD	100558502	Pacific Bell	12,000	Fuse	Overhead	Yes	8/13/15	23.55
531	PG&E	08/14/15	10.22	39.82885	-122.08507	Vegetation	Rural	< 0.25 Acres	Fire Agency	ORLAND FD(FIRE DEPT)	4 TH AVE W/O 1/4 MI. CLARK RD		0 - 750	Conductor	Overhead	No		
532	PG&E	08/14/15	15.09	40.98287	-121.78016	Vegetation	Rural	< 0.25 Acres	Unknown		101514540		21,000	Conductor	Overhead	Yes	8/14/15	15.09
533	PG&E	08/14/15	17.44	37.88943	-120.49334	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	ENTRANCE TO 14650 HWY 108, JAMESTOWN		17,000	Conductor	Overhead	Yes	8/14/15	17.44
534	PG&E	08/15/15	12.26	38.83442	-121.66135	Vegetation	Rural	< 3 meters	Customer		101713223	Pacific Bell	12,000	Conductor	Overhead	Yes	8/15/15	12.26
535	PG&E	08/15/15	13.41	37.96072	-122.57094	Vegetation	Urban	< 0.25 Acres	Fire Agency	COUNTY FIRE			12,000	Conductor	Overhead	Yes	8/15/15	13.41
536	PG&E	08/16/15	7.35	35.45724	-120.65674	Vegetation	Rural	< 3 meters	Utility PG&E		8932 SAN GABRIEL RD. SW C/O OF LOT. At	None	0 - 750	Conductor	Overhead	Yes	8/16/15	7.35
537	PG&E	08/16/15	12.04	37.59395	-122.00663	Vegetation	Urban	< 0.25 Acres	Fire Agency	ALCO FIRE/UNION CITY			12,000	Conductor	Overhead	Yes	8/16/15	12.04
538	PG&E	08/16/15	20.59	38.59631	-121.52662	Vegetation	Urban	< 3 meters	Fire Agency	west sacramento FD	101606084	Pacific Bell	12,000	Conductor	Overhead	Yes	8/16/15	20.59
539	PG&E	08/17/15	8.37	37.07567	-122.02303	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101800237	Pacific Bell	0 - 750	Conductor	Overhead	No		
540	PG&E	08/17/15	14.29	36.72160	-119.83147	Vegetation	Rural	< 3 meters	Fire Agency	FRESNO FD			12,000	Conductor	Overhead	Yes	8/17/15	14.29
541	PG&E	08/17/15	17.33	38.83366	-123.55335	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	14 spans load side 2345		12,000	Conductor	Overhead	Yes	8/17/15	17.33
542	PG&E	08/17/15	20.57	36.68672	-119.06123	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	46371 ORCHARD DRIVE		12,000	Conductor	Overhead	Yes	8/17/15	20.57
543	PG&E	08/18/15	8.03	39.08673	-122.92360	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	at base of pole across from 3838 Hill rd Lakeport		0 - 750	Unknown	Overhead	No		
544	PG&E	08/18/15	20.36	39.20201	-121.07844	Vegetation	Rural	< 0.25 Acres	Fire Agency	CO. & CDF	3 LOC HIDDEN VALLEY : OLD AUBURN RD 1		12,000	Conductor	Overhead	Yes	8/18/15	20.36
545	PG&E	08/19/15	0.07	38.88616	-121.07449	Vegetation	Urban	< 0.25 Acres	Unknown				12,000	Capacitor Bank	Overhead	Yes	8/19/15	0.07
546	PG&E	08/19/15	2.10	38.84854	-122.55138	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	STONYFORD FIRE DEPT	@ MTR # 1008056130		12,000	Conductor	Overhead	Yes	8/19/15	2.10
547	PG&E	08/19/15	2.20	38.28313	-123.29312	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	MTR#50001225	None	12,000	Conductor	Overhead	Yes	8/19/15	6.20
548	PG&E	08/19/15	13.42	37.79257	-120.77483	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Stanislaus Consolidated fire	102334306	Pacific Bell	17,000	Conductor	Overhead	Yes	8/19/15	13.42
549	PG&E	08/20/15	14.08	36.89894	-119.52129	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	100725569	None	12,000	Conductor	Overhead	Yes	8/20/15	14.08
550	PG&E	08/21/15	13.54	37.42948	-121.91416	Vegetation	Urban	< 3 meters	Customer		BACK YARD OF 296 ABBOTT		21,000	Conductor	Overhead	Yes	8/21/15	13.54
551	PG&E	08/22/15	20.38	38.77476	-120.85635	Vegetation	Rural	< 3 meters	Self Extinguished		at base of co pole 21721 - 720 Woodridge Rd.	Pacific Bell	12,000	Conductor	Overhead	Yes	8/22/15	20.38
552	PG&E	08/23/15	14.04	38.93344	-122.61999	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CL fire dept	7200 so. center dr	Pacific Bell	12,000	Conductor	Overhead	Yes	8/23/15	14.04
553	PG&E	08/23/15	14.15	37.33940	-120.43778	Vegetation	Rural	< 0.25 Acres	Utility PG&E		AT INTERSECTION OF HARBOR & DUNN		12,000	Lightning Arrestor	Overhead	Yes	8/23/15	14.15
554	PG&E	08/24/15	22.48	37.89605	-122.60110	Vegetation	Rural	< 3 meters	Fire Agency	marin county fire	200' east of pan toll rd 50' north of panoramic hwy		12,000	Unknown	Overhead	Yes	8/24/15	22.48
555	PG&E	08/25/15	9.12	38.33511	-123.04487	Vegetation	Rural	< 0.25 Acres	Fire Agency	Bodega bay fire dept	101974695	Pacific Bell	12,000	Conductor	Overhead	Yes	8/25/15	9.12
556	PG&E	08/25/15	14.01	39.14910	-121.59715	Vegetation	Urban	< 0.25 Acres	Customer		101338374	Pacific Bell	0 - 750	Conductor	Overhead	No		
557	PG&E	08/26/15	12.04	37.96382	-122.52432	Vegetation	Urban	< 0.25 Acres	Fire Agency	srd	102242504	Pacific Bell	12,000	Conductor	Overhead	Yes	8/26/15	12.04
558	PG&E	08/26/15	15.36	36.62450	-121.52891	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	MONTEREY COUNTY FIRE DEPT	101770699	Pacific Bell	12,000	Conductor	Overhead	Yes	8/26/15	15.36
559	PG&E	08/26/15	23.49	38.38972	-121.36528	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	101756678	None	21,000	Conductor	Overhead	Yes	8/26/15	23.49
560	PG&E	08/27/15	3.30	37.84480	-122.19922	Vegetation	Urban	< 0.25 Acres	Unknown		100487196	Pacific Bell	12,000	Conductor	Overhead	Yes	8/27/15	3.30
561	PG&E	08/27/15	18.00	37.40304	-121.90557	Vegetation	Urban	< 3 meters	Fire Agency	Milpitas F D	switches 1238 and 1114		21,000	Switch	Overhead	Yes	8/27/15	18.00
562	PG&E	08/28/15	3.14	36.60670	-119.89070	Vegetation	Rural	< 3 meters	Fire Agency	COUNTY FIRE	100710466		12,000	Conductor	Overhead	Yes	8/28/15	3.14
563	PG&E	08/28/15	7.08	38.80394	-121.30302	Vegetation	Urban	< 0.25 Acres	Fire Agency	lincoln fire	100089928	Pacific Bell	12,000	Conductor	Overhead	Yes	8/28/15	7.08
564	PG&E	08/28/15	11.48	38.85130	-121.14687	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	100055373	Pacific Bell	0 - 750	Conductor	Overhead	No		
565	PG&E	08/28/15	12.02	37.90471	-122.20584	Vegetation	Rural	< 0.25 Acres	Fire Agency	EB MUD	103623279		0 - 750	Conductor	Overhead	No		
566	PG&E	08/28/15	21.45	38.01982	-122.06136	Vegetation	Rural	< 0.25 Acres	Fire Agency	CONTRA COSTA FIRE	HWY 4 PORT CHICAGO WILLOW PASS		21,000	Conductor	Overhead	Yes	8/28/15	21.45
567	PG&E	08/28/15	22.05	37.80391	-121.20762	Vegetation	Urban	< 0.25 Acres	Fire Agency	Manteca Fire	102084916	Verizon	17,000	Conductor	Overhead	Yes	8/28/15	22.05
568	PG&E	08/29/15	3.30	38.63019	-122.83270	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	Dir road across from 3204 Rio Lindo Rd, Healdsburg		12,000	Conductor	Overhead	Yes	8/29/15	3.30
569	PG&E	08/30/15	17.05	38.40390	-120.55590	Vegetation	Rural	< 0.25 Acres	Fire Agency	centennial mine rd			12,000	Conductor	Overhead	Yes	8/30/15	17.05
570	PG&E	08/31/15	14.28	36.53251	-121.14620	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	29401 Hwy 25		21,000	Conductor	Overhead	Yes	8/31/15	14.28
571	PG&E	08/31/15	16.06	40.49147	-122.28348	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	101467437	Pacific Bell	12,000	Conductor	Overhead	Yes	8/31/15	16.06

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Column5	Column6	Column7	Column8	Column9	Column10	Column11	Column12	Column13	Column14	Column15	Column16
2	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	
591	PG&E	09/10/15	16.24	38.50487	-122.35346	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	103159970	Pacific Bell	21,000	Conductor	Overhead	Yes	9/10/15	16.24
592	PG&E	09/10/15	18.39	40.75692	-123.79577	Vegetation	Rural	26 - 999 Acres	Fire Agency	CAL FIRE	Pole 096/004		115,000	Conductor	Overhead	Yes	9/10/15	18.39
593	PG&E	09/11/15	6.38	37.52319	-122.26541	Other	Urban	Structure Only	Fire Agency	sc			12,000	Conductor	Overhead	Yes	9/11/15	6.38
594	PG&E	09/11/15	8.15	38.10938	-122.86999	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	102293992	Pacific Bell	12,000	Conductor	Overhead	Yes	9/11/15	8.15
595	PG&E	09/11/15	17.28	37.79722	-121.27472	Vegetation	Rural	26 - 999 Acres	Fire Agency	MANTEC/AILATHROP FIRE DEPT	102105463	Verizon	0 - 750	Capacitor Bank	Overhead	No		
596	PG&E	09/12/15	9.51	39.11644	-121.06930	Vegetation	Rural	26 - 999 Acres	Fire Agency	CAL FIRE	TOP OF AVALON PLACE, GRASS VALLEY TOWER NUMBER 15		115,000	Conductor	Overhead	Yes	9/12/15	9.51
597	PG&E	09/12/15	11.09	38.00894	-120.67409	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101394998		0 - 750	Conductor	Overhead	No		
598	PG&E	09/12/15	11.36	35.35576	-119.05495	Vegetation	Urban	< 3 meters	Fire Agency	Bakersfield FD	100194486	Pacific Bell	0 - 750	Conductor	Overhead	No		
599	PG&E	09/13/15	8.48	37.72455	-121.32594	Vegetation	Rural	< 3 meters	Fire Agency	TRACY FIRE DEPT	CRNR OF KASSON AND LORENZEN		12,000	Conductor	Overhead	Yes	9/13/15	8.48
600	PG&E	09/13/15	18.24	39.26731	-121.88308	Vegetation	Rural	< 0.25 Acres	Customer			None	0 - 750	Conductor	Overhead	No		
601	PG&E	09/15/15	22.05	36.58739	-119.56865	Vegetation	Rural	< 0.25 Acres	Fire Agency	COUNTY FIRE	100878350	Pacific Bell	0 - 750	Conductor	Overhead	Yes	9/15/15	22.05
602	PG&E	09/16/15	0.18	37.99140	-121.66822	Vegetation	Rural	< 3 meters	Fire Agency	EAST COUNTY FIRE	100457468		21,000	Conductor	Overhead	Yes	9/16/15	0.18
603	PG&E	09/18/15	16.23	37.86909	-121.20633	Vegetation	Rural	< 0.25 Acres	Fire Agency	FRENCH CAMP FIRE	IN CANAL AT 5027 FRENCH CAMP RD		12,000	Conductor	Overhead	Yes	9/18/15	16.23
604	PG&E	09/18/15	17.05	37.89920	-120.45508	Vegetation	Rural	26 - 999 Acres	Fire Agency	CAL FIRE	101019893		17,000	Conductor	Overhead	Yes	9/18/15	17.05
605	PG&E	09/19/15	9.51	38.47550	-122.90691	Vegetation	Rural	< 0.25 Acres	Fire Agency	FORESTVILLE	103334444		12,000	Conductor	Overhead	Yes	9/19/15	9.51
606	PG&E	09/20/15	18.53	39.86379	-121.65991	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE			12,000	Conductor	Overhead	Yes	9/20/15	18.53
607	PG&E	09/21/15	4.06	38.65867	-121.04035	Vegetation	Urban	< 0.25 Acres	Fire Agency	CAL FIRE	1of3@13833		21,000	Conductor	Overhead	Yes	9/21/15	4.06
608	PG&E	09/21/15	14.23	40.47863	-123.77105	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	mile marker 29.1, e of hairpin turn		12,000	Conductor	Overhead	Yes	9/21/15	14.23
609	PG&E	09/21/15	16.33	38.24517	-122.04115	Vegetation	Urban	< 0.25 Acres	Fire Agency	FAIRFIELD FIRE DEPT	REAR OF 900 TAFT		12,000	Conductor	Overhead	Yes	9/21/15	16.33
610	PG&E	09/22/15	0.44	39.00780	-122.89376	Vegetation	Rural	< 0.25 Acres	Fire Agency	LAKEPORT FIRE	102159765		12,000	Conductor	Overhead	Yes	9/22/15	0.44
611	PG&E	09/22/15	15.55	39.12244	-121.63922	Vegetation	Urban	< 0.25 Acres	Fire Agency	YUBA CITY	101300036	Pacific Bell	12,000	Conductor	Overhead	Yes	9/22/15	15.55
612	PG&E	09/22/15	20.07	38.47786	-121.98948	Vegetation	Rural	< 0.25 Acres	Fire Agency	WINTERS?	101577611	Pacific Bell	12,000	Conductor	Overhead	Yes	9/22/15	20.07
613	PG&E	09/24/15	1.40	37.69392	-122.33375	Vegetation	Urban	< 0.25 Acres	Unknown		101260605	Pacific Bell	12,000	Conductor	Overhead	Yes	9/24/15	1.40
614	PG&E	09/24/15	3.58	39.92032	-122.38691	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	103132877		0 - 750	Unknown	Overhead	No		
615	PG&E	09/24/15	4.30	38.67690	-123.31398	Vegetation	Rural	< 0.25 Acres	Unknown		Str. 041/007		80,000	Conductor	Overhead	Yes	9/24/15	4.30
616	PG&E	09/24/15	13.56	39.35078	-121.24544	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	9692 Rices-Texas Hill rd.	Pacific Bell	12,000	Conductor	Overhead	Yes	9/24/15	13.56
617	PG&E	09/25/15	13.31	37.26100	-120.73109	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	2 POLES EAST OF MTR#1009626581		12,000	Conductor	Overhead	Yes	9/25/15	13.31
618	PG&E	09/25/15	17.28	38.71686	-120.76934	Vegetation	Rural	< 0.25 Acres	Fire Agency	el dorado F.D	101405928	Pacific Bell	12,000	Conductor	Overhead	Yes	9/25/15	17.28
619	PG&E	09/26/15	14.24	37.98601	-121.23012	Vegetation	Rural	< 0.25 Acres	Fire Agency	waterloo/morada	102135315	Pacific Bell	0 - 750	Conductor	Overhead	No		
620	PG&E	09/28/15	4.42	38.78772	-121.20832	Vegetation	Urban	< 3 meters	Fire Agency	n/a	100588887	Pacific Bell	0 - 750	Capacitor Bank	Overhead	No		
621	PG&E	09/28/15	9.42	37.96233	-122.17651	Vegetation	Rural	26 - 999 Acres	Fire Agency	CAL FIRE	100458692	Pacific Bell	12,000	Conductor	Overhead	Yes	9/28/15	9.42
622	PG&E	09/28/15	18.10	38.13502	-122.47704	Vegetation	Rural	26 - 999 Acres	Fire Agency	CAL FIRE	1 mile north of 37 on lakeville		12,000	Conductor	Overhead	Yes	9/28/15	18.10
623	PG&E	09/29/15	2.52	38.33700	-121.86009	Vegetation	Rural	26 - 999 Acres	Fire Agency	VACAVILLE FD	FRY RD @ CLARK		21,000	Conductor	Overhead	Yes	9/29/15	2.52
624	PG&E	09/29/15	19.05	35.41976	-118.94989	Vegetation	Urban	< 0.25 Acres	Fire Agency	KERN COUNTY FIRE DEPARTMENT	100193545		12,000	Conductor	Overhead	Yes	9/29/15	19.05
625	PG&E	09/29/15	19.46	37.97786	-121.71949	Vegetation	Urban	< 0.25 Acres	Fire Agency	OAKLEY FIRE DEPARTMENT	100470700	Pacific Bell	0 - 750	Conductor	Overhead	No		
626	PG&E	09/30/15	16.41	37.35421	-122.15916	Vegetation	Rural	< 3 meters	Utility: PG&E		100520776	Pacific Bell	12,000	Conductor	Overhead	Yes	9/30/15	16.41
627	PG&E	09/30/15	17.25	38.57469	-120.68203	Vegetation	Rural	< 0.25 Acres	Fire Agency	el dorado county	7901 shenandoah in		21,000	Conductor	Overhead	Yes	9/30/15	17.25
628	PG&E	09/30/15	19.38	39.21883	-122.24643	Vegetation	Rural	< 0.25 Acres	Fire Agency	williams fire demp	101641855	None	12,000	Conductor	Overhead	Yes	9/30/15	19.38
629	PG&E	10/01/15	2.43	39.68657	-121.77421	Vegetation	Rural	< 3 meters	Fire Agency	NOT KNOWN-GONE ON ARRIVAL	100345398	Pacific Bell	0 - 750	Capacitor Bank	Overhead	No		
630	PG&E	10/01/15	11.28	37.50890	-120.34464	Vegetation	Rural	< 0.25 Acres	Unknown		Pole 019/007		70,000	Conductor	Overhead	Yes		
631	PG&E	10/01/15	3.14	39.62911	-122.11534	Vegetation	Rural	< 0.25 Acres	Fire Agency	HAYWARD	X ST FROM 25920 EDEN LANDING RD		0 - 750	Conductor	Overhead	No	10/1/15	11:28
632	PG&E	10/02/15	19.16	38.94544	-119.83020	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	101121403	None	21,000	Conductor	Overhead	Yes	10/2/15	19:16
633	PG&E	10/03/15	7.27	39.06326	-122.62369	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	2323 new long valley rd	Pacific Bell	0 - 750	Conductor	Overhead	No		
634	PG&E	10/03/15	21.11	39.73584	-121.68554	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	honey run rd at cutouts 16015		12,000	Conductor	Overhead	Yes	10/3/15	21:11
635	PG&E	10/03/15	22.51	39.11578	-122.88785	Vegetation	Rural	< 0.25 Acres	Fire Agency	north shore fire department,	102164828	Pacific Bell	12,000	Conductor	Overhead	Yes	10/3/15	22:51
636	PG&E	10/04/15	1.03	39.79228	-121.58029	Vegetation	Urban	< 3 meters	Fire Agency	CAL FIRE			12,000	Conductor	Overhead	Yes	10/4/15	1:03
637	PG&E	10/04/15	1.32	39.22788	-121.37735	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	in field at 6275 sandstone l		12,000	Conductor	Overhead	Yes	10/4/15	1:32
638	PG&E	10/04/15	8.26	38.81272	-121.20460	Vegetation	Urban	< 3 meters	Fire Agency	LOOMIS FIRE	C-126 TAYLOR RD AND SIERRA COLLEGE		0 - 750	Capacitor Bank	Overhead	No		
639	PG&E	10/04/15	14.35	39.47043	-121.68873	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	NORTH SIDE OF HWY 162, 1500' EAST OF RICETON HWY		12,000	Lightning Arrestor	Overhead	Yes	10/4/15	14:35
640	PG&E	10/04/15	17.42	39.11654	-122.89514	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	robin hill		12,000	Conductor	Overhead	Yes	10/4/15	17:42
641	PG&E	10/06/15	18.48	40.51057	-122.22413	Vegetation	Rural	26 - 999 Acres	Unknown		101468974	Frontier	12,000	Conductor	Overhead	Yes	10/6/15	18:48
642	PG&E	10/07/15	15.03	35.30789	-120.83281	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101924901	Pacific Bell	12,000	Conductor	Overhead	Yes	10/7/15	15:03
643	PG&E	10/08/15	13.47	35.54730	-120.77010	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	DEERFIELD RD S/O HIDDEN VALEY RD.		21,000	Conductor	Overhead	Yes	10/8/15	13:47
644	PG&E	10/09/15	6.32	38.36399	-122.91729	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	320 Freestone St. Freestone	Pacific Bell	0 - 750	Conductor	Overhead	No		
645	PG&E	10/09/15	19.03	38.38555	-122.53028	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101988271	Pacific Bell	12,000	Conductor	Overhead	Yes	10/9/15	19:03
646	PG&E	10/09/15	22.16	37.59083	-122.35023	Vegetation	Urban	< 3 meters	Fire Agency	central county fire, engine 34	at base of pole c0708	Pacific Bell	0 - 750	Transformer	Overhead	No		
647	PG&E	10/10/15	0.20	40.89020	-124.08834	Building	Urban	Structure Only	Fire Agency	CAL FIRE	100986524		0 - 750	Conductor	Overhead	Yes	10/10/15	0:20
648	PG&E	10/12/15	9.13	38.29190	-122.27061	Vegetation	Urban	< 3 meters	Customer		1111 Terrace Drive, Napa		0 - 750	Conductor	Overhead	Yes	10/12/15	9:13
649	PG&E	10/12/15	15.16	38.90206	-121.30109	Vegetation	Urban	26 - 999 Acres	Fire Agency	CAL FIRE	1800 HWY 65 LINCOLN	None	21,000	Conductor	Overhead	Yes	10/12/15	15:16
650	PG&E	10/12/15	17.25	36.70740	-121.32824	Vegetation	Rural	300 - 999 Acres	Fire Agency	CAL FIRE	Cienega Road X Linekin Road, San Benito Co		21,000	Conductor	Overhead	Yes	10/12/15	17:25
651	PG&E	10/13/15	14.38	37.79350	-120.92841	Vegetation	Rural	< 0.25 Acres	Fire Agency	Escalon Fire	102353307	None	17,000	Conductor	Overhead	Yes	10/13/15	14:38
652	PG&E	10/13/15	18.32	37.74209	-121.94394	Building	Urban	Structure Only	Fire Agency	SAN RAMON FD	100902269	None	0 - 750	Conductor	Overhead	No		
653	PG&E	10/14/15	14.17	37.33299	-120.50565	Vegetation	Urban	26 - 999 Acres	Fire Agency	CAL FIRE	3537 N HWY 59 MERCED		0 - 750	Conductor	Overhead	Yes	10/14/15	14:17
654	PG&E	10/15/15	18.51	36.50818	-119.79081	Building	Rural	Structure Only	Fire Agency	FRESNO COUNTY	100803812		12,000	Conductor	Overhead	Yes	10/15/15	18:51
655	PG&E	10/16/15	9.43	39.18704	-123.20151	Vegetation	Rural	< 3 meters	Unknown		102196855		12,000	Conductor	Overhead	Yes	10/16/15	9:43
656	PG&E	10/17/15	7.04	37.65736	-121.61965</													

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	
Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Column5	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	
2	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time		
675	PG&E	11/09/15	5:55	34.99841	-120.36340	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE			12,000	Conductor	Overhead	Yes	11/9/15	5:55	
676	PG&E	11/13/15	12:03	40.59231	-124.14003	Vegetation	Urban	< 3 meters	Fire Agency	CITY	100993131	Pacific Bell	12,000	Conductor	Overhead	Yes	11/13/15	12:03	
677	PG&E	11/15/15	13:47	37.24940	-121.91338	Other	Urban	Structure Only	Fire Agency		4879 Harwood Road, San Jose	None	12,000	Conductor	Overhead	Yes	11/15/15	13:47	
678	PG&E	11/15/15	16:30	37.00075	-121.88503	Vegetation	Rural	< 3 meters	Customer			Pacific Bell	21,000	Conductor	Overhead	Yes	11/15/15	16:30	
679	PG&E	11/21/15	10:36	38.06789	-120.18719	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	101045952	Pacific Bell	17,000	Conductor	Overhead	Yes	11/21/15	10:36	
680	PG&E	12/26/15	15:32	38.48758	-122.00210	Vegetation	Rural	< 3 meters	Customer			Pacific Bell	12,000	Conductor	Overhead	Yes	11/26/15	15:32	
681	PG&E	12/01/15	9:26	35.67148	-121.93025	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	ORD FERRY RD WEST OF 126147		12,000	Conductor	Overhead	Yes	12/1/15	9:26	
682	PG&E	12/01/15	12:03	35.67136	-120.99322	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101860660		21,000	Conductor	Overhead	Yes	12/1/15	12:03	
683	PG&E	12/02/15	9:40	39.17430	-122.16029	Vegetation	Rural	< 0.25 Acres	Unknown		Lt 30332		12,000	Conductor	Overhead	Yes	12/2/15	9:40	
684	PG&E	12/03/15	9:12	37.30438	-122.02024	Vegetation	Urban	Structure Only	Fire Agency	san jose fire dept	100522714	Pacific Bell	0 - 750	Conductor	Overhead	Yes	12/3/15	9:12	
685	PG&E	12/03/15	12:10	40.02767	-120.96522	Vegetation	Rural	< 0.25 Acres	Fire Agency	usfs	spanish creek campground		12,000	Conductor	Overhead	Yes	12/3/15	12:10	
686	PG&E	12/08/15	12:41	38.24886	-120.52284	Other	Rural	Structure Only	Unknown		7026 Railroad Flat Road, Mountain Ranch		12,000	Conductor	Overhead	Yes	12/8/15	12:41	
687	PG&E	12/10/15	11:19	36.21833	-119.99511	Other	Rural	Structure Only	Fire Agency	CAL FIRE			12,000	Conductor	Overhead	Yes	12/10/15	11:19	
688	PG&E	12/11/15	7:27	34.87881	-120.33081	Vegetation	Rural	< 3 meters	Customer		4 POLES LOAD SIDE OF SW 7807		12,000	Conductor	Overhead	Yes	12/11/15	7:27	
689	PG&E	12/22/15	2:44	38.27675	-122.50364	Building	Rural	Structure Only	Fire Agency	sonoma	102005111	Pacific Bell	12,000	Conductor	Overhead	Yes	12/22/15	2:44	
690	PG&E	12/28/15	19:29	34.96793	-120.45289	Vegetation	Urban	< 3 meters	Fire Agency	SANTA MARIA FIRE DEPT.	103158996		12,000	Conductor	Overhead	Yes	12/28/15	19:29	
691	PG&E	12/31/15	19:12	37.15678	-121.98682	Vegetation	Rural	< 0.25 Acres	Fire Agency	LOS GATOS MONTE SERENO SA	100518215	Verizon	21,000	Conductor	Overhead	Yes	12/31/15	19:12	
692	PG&E	1/21/16	21:32	40.55300	-124.11158	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire		PACIFIC BELL	12,000	Conductor	Overhead	Yes	1/21/16	21:32	
693	PG&E	1/23/16	15:41	39.94860	-122.37281	Vegetation	RURAL	< 0.25 Acres	Self Extinguished	N.A.	101524077		12,000	Conductor	Overhead	Yes	1/23/16	15:41	
694	PG&E	2/2/16	6:01	37.77553	-122.44109	Building	URBAN	Structure Only	Fire Agency	SFFD	101817610		PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	2/2/16	6:01
695	PG&E	2/5/16	20:50	40.01564	-122.43330	Vegetation	RURAL	< 0.25 Acres	Fire Agency	TEHAMA COUNTY & LOCAL VOL	101529688	None	12,000	Conductor	Overhead	Yes	2/5/16	20:50	
696	PG&E	2/8/16	3:55	39.78520	-121.50580	Vegetation	RURAL	< 0.25 Acres	Fire Agency	CAL FIRE/BUTTE COUNTY FIRE	100337507		12,000	Conductor	Overhead	Yes	2/8/16	3:55	
697	PG&E	2/17/16	21:16	40.66770	-124.22734	Building	RURAL	Structure Only	Fire Agency	CAL FIRE	101002728		0 - 750	Conductor	Overhead	Yes	2/17/16	21:16	
698	PG&E	2/26/16	15:40	36.83981	-119.79748	Building	URBAN	Structure Only	Self Extinguished		100640781	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	2/26/16	15:40	
699	PG&E	3/28/16	12:16	39.74275	-121.82024	Vegetation	URBAN	< 3 meters	Fire Agency	Chico FD	100338028	PACIFIC BELL	12,000	Conductor	Overhead	Yes	3/28/16	12:16	
700	PG&E	4/1/16	4:25	35.01641	-118.89213	Vegetation	RURAL	< 3 meters	Fire Agency	Kern County FD	100194594	None	12,000	Other	Overhead	Yes	4/1/16	4:25	
701	PG&E	4/2/16	3:48	35.37034	-118.97521	Vegetation	URBAN	< 0.25 Acres	Fire Agency	KCFD	102044829		0 - 750	Conductor	Overhead	No			
702	PG&E	4/2/16	7:06	35.03071	-120.52785	Vegetation	RURAL	< 3 meters	Fire Agency	SAN LUIS CO FIRE	101892796	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	4/2/16	7:06	
703	PG&E	4/3/16	6:54	40.41751	-122.21092	Other	RURAL	Structure Only	Fire Agency	COTTONWOOD FIRE DEPT	101488627	PACIFIC BELL	12,000	Conductor	Overhead	Yes	4/3/16	6:54	
704	PG&E	4/3/16	12:01	38.68044	-123.12496	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101968191		12,000	Conductor	Overhead	Yes	4/3/16	12:01	
705	PG&E	4/4/16	0:08	37.75674	-121.41933	Vegetation	URBAN	< 3 meters	Fire Agency	Tracy FD	102119421	PACIFIC BELL	12,000	Conductor	Overhead	Yes	4/4/16	0:08	
706	PG&E	4/7/16	17:07	35.34199	-119.01752	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Bakersfield FD	100245953		0 - 750	Conductor	Overhead	Yes	4/7/16	17:07	
707	PG&E	4/8/16	13:14	39.04293	-121.10020	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100086751	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	4/8/16	13:14	
708	PG&E	4/13/16	19:28	40.49535	-124.12191	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	103659313		12,000	Conductor	Overhead	Yes	4/13/16	19:28	
709	PG&E	4/14/16	14:16	36.15837	-119.56502	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Kings County FD	100766367		12,000	Other	Overhead	Yes	4/14/16	14:16	
710	PG&E	4/18/16	18:14	37.79381	-120.98419	Vegetation	URBAN	< 3 meters	Fire Agency	Escalante Fire	102332958	None	0 - 750	Other	Overhead	No			
711	PG&E	4/20/16	16:39	39.40237	-122.01414	Vegetation	RURAL	< 3 meters	Unknown	Unknown	101641171		12,000	Conductor	Overhead	Yes	4/20/16	16:39	
712	PG&E	4/21/16	3:20	38.19073	-122.24723	Vegetation	URBAN	< 0.25 Acres	Fire Agency	American Canyon FD	102259263	PACIFIC BELL	12,000	Conductor	Overhead	Yes	4/21/16	3:20	
713	PG&E	4/21/16	9:25	39.29298	-123.76901	Vegetation	RURAL	< 3 meters	Customer	N.A.	103312287		0 - 750	Other	Overhead	No			
714	PG&E	4/22/16	17:10	37.68750	-121.69848	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Brentwood FD	100596667	None	0 - 750	Transformer	Overhead	No			
715	PG&E	4/22/16	22:02	35.34916	-119.05375	Vegetation	URBAN	< 3 meters	Customer	N.A.	100156969	Yes	0 - 750	Conductor	Overhead	Yes	4/22/16	22:02	
716	PG&E	4/23/16	18:32	36.49084	-119.82925	Vegetation	RURAL	< 0.25 Acres	Fire Agency	city of selma	100818205		12,000	Conductor	Overhead	Yes	4/23/16	18:32	
717	PG&E	4/24/16	11:10	34.70896	-120.46117	Vegetation	URBAN	26 - 9.99 Acres	Fire Agency	Santa Barbara County FD	101898989		12,000	Conductor	Overhead	Yes	4/24/16	11:10	
718	PG&E	4/25/16	12:34	36.47607	-119.79041	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100875278		12,000	Conductor	Overhead	Yes	4/25/16	12:34	
719	PG&E	4/25/16	14:50	35.54445	-119.08687	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Kern County FD	100207184	None	12,000	Conductor	Overhead	Yes	4/25/16	14:50	
720	PG&E	4/27/16	14:02	36.51612	-119.25966	Vegetation	RURAL	< 3 meters	Unknown	Unknown	100755216	Pacific Bell	12,000	Conductor	Overhead	Yes	4/27/16	14:02	
721	PG&E	4/30/16	17:59	38.31420	-120.90148	Vegetation	RURAL	< 3 meters	Fire Agency	Kern County FD			12,000	Conductor	Overhead	Yes	4/30/16	17:59	
722	PG&E	4/30/16	16:40	37.00665	-120.63785	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Merced County FD	103083239		12,000	Conductor	Overhead	Yes	4/30/16	16:40	
723	PG&E	4/30/16	13:41	38.25879	-122.02549	Vegetation	URBAN	< 3 meters	Fire Agency	Fairfield FD	101560133	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	4/30/16	13:41	
724	PG&E	5/2/16	10:05	37.91481	-120.61782	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101283625	CALAVERAS TEL	17,000	Conductor	Overhead	Yes	5/2/16	10:05	
725	PG&E	5/9/16	17:05	35.98605	-119.42935	Vegetation	RURAL	< 3 meters	Unknown	Unknown	100634326		0 - 750	Other	Overhead	No			
726	PG&E	5/11/16	12:15	37.67808	-122.47884	Vegetation	URBAN	< 3 meters	Fire Agency	DALY CITY	103565907		0 - 750	Conductor	Overhead	Yes	5/11/16	12:15	
727	PG&E	5/12/16	10:47	35.30243	-120.71591	Vegetation	RURAL	< 3 meters	Self Extinguished	N.A.	101937429		12,000	Conductor	Overhead	Yes	5/12/16	10:47	
728	PG&E	5/12/16	13:35	40.45382	-124.04774	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101006413		12,000	Conductor	Overhead	Yes	5/12/16	13:35	
729	PG&E	5/12/16	20:15	35.19217	-120.45631	Vegetation	RURAL	< 3 meters	Self Extinguished	N.A.	101857280		12,000	Conductor	Overhead	Yes	5/12/16	20:15	
730	PG&E	5/14/16	15:06	37.96878	-121.67042	Vegetation	RURAL	< 0.25 Acres	Unknown	Unknown	100472239	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	5/14/16	15:06	
731	PG&E	5/14/16	22:06	39.16390	-121.56126	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Marysville FD	101312807		12,000	Switch	Overhead	Yes	5/14/16	22:06	
732	PG&E	5/15/16	15:54	36.79479	-119.39659	Vegetation	RURAL	100 - 239 Acres	Fire Agency	Cal Fire	100729685	None	12,000	Conductor	Overhead	Yes	5/15/16	15:54	
733	PG&E	5/16/16	8:59	37.92826	-121.21642	Vegetation	RURAL	< 3 meters	Fire Agency	Unknown	102130215	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/16/16	8:59	
734	PG&E	5/16/16	11:34	38.77343	-121.46921	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	103323287		12,000	Conductor	Overhead	Yes	5/16/16	11:34	
735	PG&E	5/17/16	10:01	35.23788	-118.96390	Vegetation	RURAL	< 3 meters	Fire Agency	KCFD	100135809		0 - 750	Transformer	Overhead	Yes	5/17/16	10:01	
736	PG&E	5/17/16	16:03	35.38565	-119.00746	Vegetation	URBAN	< 3 meters	Fire Agency	Bakersfield FD	100246655	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	5/17/16	16:03	
737	PG&E	5/18/16	18:24	39.73815	-123.15874	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire			12,000	Conductor	Overhead	Yes	5/18/16	18:24	
738	PG&E	5/18/16	15:45	35.55502	-120.68032	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Atascadero FD	101901773		21,000	Conductor	Overhead	Yes	5/18/16	15:45	
739	PG&E	5/18/16	20:04	40.47788	-122.40312	Vegetation	RURAL	< 3 meters	Fire Agency	County	102307139		12,000	Conductor	Overhead	Yes	5/18/16	20:04	
740	PG&E	5/19/16	1:42	34.66450	-120.39999	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Santa Barbara County FD	101916587								

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
2	Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
3	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin												
759	PG&E	5/31/16	10:20	39.19388	-122.09737	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Williams FD	101642880		12,000	Conductor	Overhead	Yes	5/31/16	10:20
760	PG&E	6/1/16	14:00	36.79769	-121.73159	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	cal fire and north county	101712734	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/1/16	14:00
761	PG&E	6/1/16	22:31	37.92808	-120.75384	Vegetation	RURAL	26 - 9.99 Acres	Unknown	Unknown	102343418		115,000	Conductor	Overhead	Yes	6/1/16	22:31
762	PG&E	6/2/16	14:23	38.59011	-121.80422	Vegetation	RURAL	< 3 meters	Unknown	Unknown	101557874		12,000	Transformer	Overhead	Yes	6/2/16	14:23
763	PG&E	6/2/16	14:57	37.06520	-121.56536	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	100607860	VERIZON CALIFO	0 - 750	Conductor	Overhead	Yes	6/2/16	14:57
764	PG&E	6/2/16	15:15	34.58968	-120.10855	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Sanita Barbara County FD	101918537		12,000	Conductor	Overhead	Yes	6/2/16	15:15
765	PG&E	6/2/16	16:58	36.68572	-121.80518	Vegetation	RURAL	< 0.25 Acres	Fire Agency	County	101746812		0 - 750	Conductor	Overhead	Yes	6/2/16	16:58
766	PG&E	6/3/16	12:16	38.64354	-120.89588	Vegetation	RURAL	10 - 99 Acres	Fire Agency	cal-fire and uafs	103119737		21,000	Conductor	Overhead	Yes	6/3/16	12:16
767	PG&E	6/3/16	16:45	35.40461	-119.03141	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Kern County FD	100242571	PACIFIC BELL	0 - 750	Transformer	Overhead	No		
768	PG&E	6/3/16	18:43	39.74820	-121.82316	Vegetation	URBAN	< 3 meters	Fire Agency	Chico FD	100344305	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	6/3/16	18:43
769	PG&E	6/3/16	20:53	37.43457	-121.87724	Vegetation	URBAN	< 3 meters	Fire Agency	Milpitas FD	100559460	PACIFIC BELL	0 - 750	Conductor	Overhead	No		
770	PG&E	6/4/16	22:15	38.51170	-122.93727	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire			12,000	Conductor	Overhead	Yes	6/4/16	22:15
771	PG&E	6/4/16	15:11	36.80489	-119.78712	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Fresno County FD	100828880	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	6/4/16	15:11
772	PG&E	6/4/16	15:51	38.30900	-121.76049	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Dixon FD	101568694		21,000	Conductor	Overhead	Yes	6/4/16	15:51
773	PG&E	6/4/16	20:38	37.43457	-121.87724	Vegetation	URBAN	< 3 meters	Fire Agency	Milpitas FD	100559460	PACIFIC BELL	0 - 750	Conductor	Overhead	No		
774	PG&E	6/5/16	16:57	36.86861	-119.61136	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire			12,000	Conductor	Overhead	Yes	6/5/16	16:57
775	PG&E	6/5/16	10:06	36.75041	-119.68683	Vegetation	RURAL	< 0.25 Acres	Utility: PG&E	N.A.	100780354	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/5/16	10:06
776	PG&E	6/5/16	15:44	40.34409	-123.70996	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	101009790		60,000	Conductor	Overhead	Yes	6/5/16	15:44
777	PG&E	6/6/16	19:48	38.91285	-121.11925	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire/placer fire	100050264	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/6/16	19:48
778	PG&E	6/7/16	13:55	36.93151	-119.86578	Vegetation	RURAL	< 3 meters	Utility: PG&E	N.A.	102115609	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	6/7/16	13:55
779	PG&E	6/7/16	18:19	36.98869	-120.63768	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Cal Fire	103214859		0 - 750	Other	Overhead	No		
780	PG&E	6/7/16	19:40	35.88520	-120.58295	Vegetation	RURAL	< 0.25 Acres	Unknown	Unknown	101943517		0 - 750	Conductor	Overhead	No		
781	PG&E	6/7/16	0:45	37.28555	-120.45169	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Cal Fire	103320600	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/7/16	0:45
782	PG&E	6/7/16	9:12	39.46294	-121.77233	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100378551	None	12,000	Conductor	Overhead	Yes	6/7/16	9:12
783	PG&E	6/8/16	11:20	39.30325	-121.52073	Vegetation	RURAL	< 3 meters	Customer	N.A.	101313693	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	6/8/16	11:20
784	PG&E	6/8/16	0:21	36.75666	-119.79698	Vegetation	URBAN	Structure Only	Fire Agency	Fresno FD	100884822		12,000	Conductor	Overhead	Yes	6/8/16	0:21
785	PG&E	6/8/16	16:50	35.67162	-120.59802	Building	RURAL	Structure Only	Fire Agency	Cal Fire	101867293	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	6/8/16	16:50
786	PG&E	6/9/16	14:26	38.70031	-120.84704	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101390214	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/9/16	14:26
787	PG&E	6/9/16	10:52	36.80579	-119.71026	Vegetation	URBAN	< 3 meters	Unknown	Unknown	100794383		21,000	Conductor	Overhead	Yes	6/9/16	10:52
788	PG&E	6/9/16	23:39	39.01479	-122.85698	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	102143661		12,000	Conductor	Overhead	Yes	6/9/16	23:39
789	PG&E	6/10/16	8:25	36.72962	-119.69974	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Fresno FD	102309139		12,000	Conductor	Overhead	Yes	6/10/16	8:25
790	PG&E	6/10/16	15:51	39.99335	-123.78829	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100992291		12,000	Conductor	Overhead	Yes	6/10/16	15:51
791	PG&E	6/10/16	15:57	38.17922	-120.66569	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	103809655		12,000	Conductor	Overhead	Yes	6/10/16	15:57
792	PG&E	6/11/16	19:45	39.32654	-121.39213	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101292512		0 - 750	Transformer	Overhead	Yes	6/11/16	19:45
793	PG&E	6/12/16	8:01	36.59356	-119.98875	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	100668862		12,000	Conductor	Overhead	Yes	6/12/16	8:01
794	PG&E	6/12/16	10:22	38.04911	-120.39761	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101042514		0 - 750	Conductor	Overhead	No		
795	PG&E	6/12/16	11:52	39.67992	-122.32165	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire/ORLAND	100405660		21,000	Conductor	Overhead	Yes	6/12/16	11:52
796	PG&E	6/12/16	13:10	38.25347	-122.06276	Vegetation	URBAN	< 3 meters	Fire Agency	Fieldview FD	101557178	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/12/16	13:10
797	PG&E	6/12/16	13:14	37.50960	-120.04623	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	101083986		0 - 750	Conductor	Overhead	Yes	6/12/16	13:14
798	PG&E	6/12/16	1:45	37.46430	-122.34590	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Unknown	100265854	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/12/16	1:45
799	PG&E	6/12/16	19:19	39.15914	-121.58961	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Marysville FD	101312163	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/12/16	19:19
800	PG&E	6/12/16	20:00	37.26941	-121.78935	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	San Jose FD	103434547	None	115,000	Conductor	Overhead	Yes	6/12/16	20:00
801	PG&E	6/13/16	5:51	39.46406	-121.88581	Vegetation	RURAL	< 3 meters	Fire Agency	COLUMA GLENN FIRE	101617882		12,000	Transformer	Overhead	Yes	6/13/16	5:51
802	PG&E	6/15/16	14:40	38.30793	-122.85530	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire			0 - 750	Conductor	Overhead	Yes	6/15/16	14:40
803	PG&E	6/15/16	13:09	38.44330	-120.75676	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	103169620		12,000	Conductor	Overhead	Yes	6/15/16	13:09
804	PG&E	6/15/16	13:44	38.43752	-122.67706	Vegetation	URBAN	< 3 meters	Customer	N.A.	102024321	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	6/15/16	13:44
805	PG&E	6/16/16	17:41	37.34057	-121.78229	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	San Jose FD	100576793	PACIFIC BELL	21,000	Conductor	Overhead	Yes	6/16/16	17:41
806	PG&E	6/16/16	7:22	37.86781	-121.63822	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Contra Costa County FD	100497743	PACIFIC BELL	21,000	Conductor	Overhead	Yes	6/16/16	7:22
807	PG&E	6/16/16	13:07	39.06810	-121.66052	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Yuba City FD	101329181		12,000	Lightning Arrestor	Overhead	Yes	6/16/16	13:07
808	PG&E	6/17/16	11:17	36.73252	-120.40494	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	102312507		0 - 750	Capacitor Bank	Overhead	Yes	6/17/16	11:17
809	PG&E	6/19/16	12:07	39.38113	-123.77370	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	102187888	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/19/16	12:07
810	PG&E	6/19/16	17:19	38.45078	-122.35458	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	cal fire-napa fire	102256859	PACIFIC BELL	21,000	Conductor	Overhead	Yes	6/19/16	17:19
811	PG&E	6/19/16	15:50	38.24252	-121.85355	Vegetation	RURAL	< 0.25 Acres	Fire Agency	RIO VISTA MONTEZUMA FIRE	101582754		21,000	Conductor	Overhead	Yes	6/19/16	15:50
812	PG&E	6/20/16	13:57	36.53565	-119.37897	Vegetation	URBAN	< 3 meters	Customer	N.A.	103238848		0 - 750	Conductor	Overhead	Yes	6/20/16	13:57
813	PG&E	6/20/16	16:45	41.06971	-123.67893	Vegetation	RURAL	< 3 meters	Fire Agency	Hoopa FD	101011420	VERIZON CALIFO	12,000	Conductor	Overhead	Yes	6/20/16	16:45
814	PG&E	6/21/16	20:49	35.53525	-120.84574	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101900832		12,000	Conductor	Overhead	Yes	6/21/16	20:49
815	PG&E	6/21/16	10:09	39.03942	-121.29275	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100024816	PACIFIC BELL	0 - 750	Conductor	Overhead	No		
816	PG&E	6/21/16	16:53	38.42328	-122.54477	Vegetation	RURAL	< 0.25 Acres	Fire Agency	KENWOOD FIRE XST	102036904	Yes	0 - 750	Conductor	Overhead	Yes	6/21/16	16:53
817	PG&E	6/21/16	18:01	39.28517	-123.20530	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire/Redwood Valley FD	102176908	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/21/16	18:01
818	PG&E	6/22/16	19:13	36.38751	-119.83496	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Kings County FD	100848643		0 - 750	Conductor	Overhead	Yes	6/22/16	19:13
819	PG&E	6/23/16	10:10	36.72434	-120.05834	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Fresno FD	100637712	KERMAN TELEPH	0 - 750	Conductor	Overhead	Yes	6/23/16	10:10
820	PG&E	6/23/16	19:19	36.62119	-120.35616	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	101937184	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	6/23/16	19:19
821	PG&E	6/23/16	21:33	38.12063	-121.95450	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Suisun Fire Protection District	101558702		0 - 750	Conductor	Overhead	Yes	6/23/16	21:33
822	PG&E	6/24/16	3:07	38.71917	-121.05460	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire/EDH FIRE DEPT	101376553		21,000	Conductor	Overhead	Yes	6/24/16	3:07
823	PG&E	6/24/16	14:38	40.22003	-122.28299	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101526647	PACIFIC BELL	0 - 750	Unknown	Overhead	Yes	6/24/16	14:38
824	PG&E	6/25/16																

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Column5	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
2	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	
843	PG&E	7/7/16	10:56	39.29658	-121.82628	Vegetation	RURAL	< 0.25 Acres	Fire Agency	LIVE OAK	101315522		12,000	Fuse	Overhead	Yes	7/7/16	10:56
844	PG&E	7/8/16	10:49	38.33731	-122.12112	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	102291118	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/8/16	10:49
845	PG&E	7/8/16	15:13	33.61428	-117.11102	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Unknown	103070565	None	0 - 750	Conductor	Overhead	No		
846	PG&E	7/9/16	10:05	35.13105	-120.60687	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Unknown	101924844		12,000	Conductor	Overhead	Yes	7/9/16	10:05
847	PG&E	7/9/16	14:57	38.50353	-121.78264	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Dixon FD	101559862	None	0 - 750	Conductor	Overhead	No		
848	PG&E	7/9/16	15:42	38.89276	-121.97476	Vegetation	RURAL	< 0.25 Acres	Fire Agency	DUGGAGAN FIRE	101602162	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	7/9/16	15:42
849	PG&E	7/9/16	19:22	37.31108	-121.83127	Vegetation	URBAN	< 3 meters	Fire Agency	San Jose FD	100592926	PACIFIC BELL	0 - 750	Unknown	Overhead	Yes	7/9/16	19:22
850	PG&E	7/12/16	14:18	35.34710	-120.38130	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	101879190		21,000	Conductor	Overhead	Yes	7/12/16	14:18
851	PG&E	7/13/16	10:20	37.32768	-122.07194	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire/scd	103510668		115,000	Conductor	Overhead	Yes	7/13/16	10:20
852	PG&E	7/14/16	13:44	35.38333	-118.92324	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Kern County FD	100119861		0 - 750	Capacitor Bank	Overhead	No		
853	PG&E	7/15/16	5:19	35.18390	-120.50180	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	101846594		12,000	Conductor	Overhead	Yes	7/15/16	5:19
854	PG&E	7/15/16	14:09	38.69651	-120.85983	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101412774	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/15/16	14:09
855	PG&E	7/15/16	14:26	38.13658	-122.70919	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	NOVATO FIRE AND OTHERS	102013570	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/15/16	14:26
856	PG&E	7/15/16	17:09	35.35653	-119.04094	Vegetation	URBAN	< 3 meters	Fire Agency	CITY	100194332	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	7/15/16	17:09
857	PG&E	7/16/16	0:58	36.43790	-121.91983	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101669758		12,000	Other	Overhead	Yes	7/16/16	0:58
858	PG&E	7/16/16	8:19	37.48278	-119.86999	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	101079104	None	0 - 750	Conductor	Overhead	No		
859	PG&E	7/16/16	20:26	38.49443	-122.49443	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Cal Fire	102265740	None	12,000	Conductor	Overhead	Yes	7/16/16	20:26
860	PG&E	7/18/16	7:39	36.75720	-119.78072	Vegetation	URBAN	< 3 meters	Self Extinguished	N.A.	100806906	PACIFIC BELL	0 - 750	Capacitor Bank	Overhead	Yes	7/18/16	7:39
861	PG&E	7/18/16	9:11	36.99768	-119.98296	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	101017131	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/18/16	9:11
862	PG&E	7/18/16	15:56	37.32207	-121.80553	Vegetation	URBAN	26 - 9.99 Acres	Fire Agency	San Jose FD	100579940		21,000	Conductor	Overhead	Yes	7/18/16	15:56
863	PG&E	7/18/16	17:14	36.91198	-121.79134	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	101699685	PACIFIC BELL	21,000	Switch	Overhead	Yes	7/18/16	17:14
864	PG&E	7/19/16	1:53	38.07558	-122.53964	Vegetation	RURAL	< 3 meters	Fire Agency	NOVATO FIRE DEPT	102305231		12,000	Other	Overhead	Yes	7/19/16	1:53
865	PG&E	7/19/16	14:41	39.25346	-122.06278	Vegetation	URBAN	< 3 meters	Fire Agency	Sanfield FD	101557178	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/19/16	14:41
866	PG&E	7/20/16	6:25	34.89329	-120.35134	Vegetation	RURAL	< 3 meters	Fire Agency	Nita Barbara County FD	101861585	VERIZON CALIFO	12,000	Conductor	Overhead	Yes	7/20/16	6:25
867	PG&E	7/20/16	19:15	37.77121	-121.81041	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100898986	PACIFIC BELL	21,000	Conductor	Overhead	Yes	7/20/16	19:15
868	PG&E	7/21/16	13:10	39.49649	-121.88558	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100416773		12,000	Conductor	Overhead	Yes	7/21/16	13:10
869	PG&E	7/21/16	13:30	39.16788	-121.71653	Vegetation	RURAL	< 0.25 Acres	Unknown	Unknown	101302589	PACIFIC BELL	12,000	Capacitor Bank	Overhead	Yes	7/21/16	13:30
870	PG&E	7/21/16	17:38	38.49410	-121.78740	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Dixon FD	101599745	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/21/16	17:38
871	PG&E	7/21/16	18:20	35.59224	-120.64739	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	103390807		21,000	Other	Overhead	Yes	7/21/16	18:20
872	PG&E	7/21/16	21:45	40.85656	-122.33873	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101455670	PACIFIC BELL	0 - 750	Conductor	Overhead	No		
873	PG&E	7/22/16	4:46	37.34653	-120.93287	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Merced County FD	101207784		12,000	Conductor	Overhead	Yes	7/22/16	4:46
874	PG&E	7/22/16	14:11	39.71213	-121.81363	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	100346440		12,000	Conductor	Overhead	Yes	7/22/16	14:11
875	PG&E	7/23/16	12:45	38.01926	-121.90209	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Contra Costa County FD	102345455		0 - 750	Capacitor Bank	Overhead	No		
876	PG&E	7/23/16	16:12	35.34310	-119.04305	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Bakersfield FD	100256351	Yes	0 - 750	Conductor	Overhead	Yes	7/23/16	16:12
877	PG&E	7/23/16	19:12	36.74092	-119.72730	Vegetation	URBAN	< 3 meters	Customer	N.A.	100820603	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	7/23/16	19:12
878	PG&E	7/24/16	16:24	38.01047	-122.19414	Vegetation	RURAL	10 - 99 Acres	Fire Agency	CCD	103049639		115,000	Conductor	Overhead	Yes	7/24/16	16:24
879	PG&E	7/25/16	10:14	37.47600	-120.57400	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	CAL FIRE MERCED	101195552		21,000	Conductor	Overhead	Yes	7/25/16	10:14
880	PG&E	7/25/16	15:32	38.35220	-120.71065	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	101263632	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/25/16	15:32
881	PG&E	7/27/16	15:29	38.83078	-122.18990	Vegetation	RURAL	< 0.25 Acres	Unknown	Unknown			21,000	Conductor	Overhead	Yes	7/27/16	15:29
882	PG&E	7/27/16	11:53	37.66492	-120.51339	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	101041792		17,000	Conductor	Overhead	Yes	7/27/16	11:53
883	PG&E	7/28/16	17:05	40.82687	-124.18250	Vegetation	RURAL	< 3 meters	Fire Agency	SAMOA PENINSULA FIRE DEPT	100968543		0 - 750	Conductor	Overhead	No		
884	PG&E	7/27/16	17:05	38.53916	-122.76559	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	102029945		80,000	Conductor	Overhead	Yes	7/27/16	17:05
885	PG&E	7/28/16	2:41	35.36740	-120.39770	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	101849904		21,000	Conductor	Overhead	Yes	7/28/16	2:41
886	PG&E	7/28/16	8:12	37.82070	-120.13880	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101037043		0 - 750	Other	Overhead	No		
887	PG&E	7/28/16	12:58	37.23706	-119.81572	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	103323932		21,000	Conductor	Overhead	Yes	7/28/16	12:58
888	PG&E	7/28/16	13:19	39.71267	-123.49731	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	102195566		12,000	Conductor	Overhead	Yes	7/28/16	13:19
889	PG&E	7/28/16	14:07	39.68718	-121.71852	Vegetation	RURAL	10 - 99 Acres	Fire Agency	Cal Fire	103653216		60,000	Conductor	Overhead	Yes	7/28/16	14:07
890	PG&E	7/28/16	14:24	37.82318	-120.13562	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	101037045		17,000	Other	Overhead	No		
891	PG&E	7/28/16	16:16	36.74999	-119.72965	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Fresno FD	100818516	PACIFIC BELL	0 - 750	Other	Overhead	Yes	7/28/16	16:16
892	PG&E	7/29/16	18:16	38.57695	-122.61868	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Selma Fire Department			12,000	Conductor	Overhead	Yes	7/29/16	18:16
893	PG&E	7/29/16	1:31	41.03964	-123.67403	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Hoopa FD	100962351		12,000	Conductor	Overhead	Yes	7/29/16	1:31
894	PG&E	7/29/16	15:47	39.04972	-121.51531	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101334767		0 - 750	Unknown	Overhead	Yes	7/29/16	15:47
895	PG&E	7/29/16	18:50	38.02042	-122.06195	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Contra Costa County FD	100446986		21,000	Conductor	Overhead	Yes	7/29/16	18:50
896	PG&E	7/30/16	11:04	35.19413	-118.91307	Vegetation	RURAL	< 0.25 Acres	Utility: PG&E	N.A.	100150295		12,000	Conductor	Overhead	Yes	7/30/16	11:04
897	PG&E	7/31/16	12:11	38.78271	-120.91682	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	101417359		21,000	Conductor	Overhead	Yes	7/31/16	12:11
898	PG&E	8/1/16	12:50	38.90443	-121.12742	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	100078299	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/1/16	12:50
899	PG&E	8/1/16	16:47	38.83192	-121.46936	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Unknown	101232397		0 - 750	Transformer	Overhead	Yes	8/1/16	16:47
900	PG&E	8/1/16	18:29	38.69583	-120.82832	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101412720	PACIFIC BELL	0 - 750	Conductor	Overhead	No		
901	PG&E	8/2/16	6:52	38.19697	-122.27570	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Napa/American Canyon FD	103154739		12,000	Conductor	Overhead	Yes	8/2/16	6:52
902	PG&E	8/2/16	16:15	37.03124	-119.43955	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Fresno County FD	100675986		12,000	Conductor	Overhead	Yes	8/2/16	16:15
903	PG&E	8/3/16	4:38	38.84738	-120.81196	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	cal fire garden valley fire	103809676		21,000	Conductor	Overhead	Yes	8/3/16	4:38
904	PG&E	8/3/16	12:41	39.26965	-120.60328	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	100001032		12,000	Conductor	Overhead	Yes	8/3/16	12:41
905	PG&E	8/3/16	19:41	40.38679	-122.28216	Building	URBAN	Structure Only	Fire Agency	COTTONWOOD FIRE DEPT	101492556	Pacific Bell	12,000	Conductor	Overhead	Yes	8/3/16	19:41
906	PG&E	8/4/16	12:19	35.94249	-119.38442	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Tulare County Fire Dept.	103074837		12,000	Conductor	Overhead	No		
907	PG&E	8/5/16	12:40	38.34067	-122.25777	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	102284869	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/5/16	12:40
908	PG&E	8/5/																

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
1	Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
2	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	
927	PG&E	8/14/16	22:50	37.49772	-122.37011	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100307761		12,000	Conductor	Overhead	Yes	8/14/16	22:50
928	PG&E	8/15/16	0:11	38.19738	-121.13376	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Clements fire dept	102075968		21,000	Capacitor Bank	Overhead	No		
929	PG&E	8/15/16	11:29	37.27735	-121.80903	Vegetation	URBAN	< 0.25 Acres	Fire Agency	San Jose FD	100588534	PACIFIC BELL	21,000	Other	Overhead	Yes	8/15/16	11:29
930	PG&E	8/15/16	15:43	37.87843	-120.44884	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	101020079		17,000	Conductor	Overhead	Yes	8/15/16	15:43
931	PG&E	8/16/16	13:18	40.34169	-123.88029	Vegetation	RURAL	< 0.25 Acres	Fire Agency	miranda/fruitland vol. calfire	100990019	None	12,000	Conductor	Overhead	Yes	8/16/16	13:18
932	PG&E	8/16/16	22:17	36.78699	-119.69569	Vegetation	URBAN	< 3 meters	Fire Agency	CLOVIS FIRE DEPT	100887618		12,000	Conductor	Overhead	Yes	8/16/16	22:17
933	PG&E	8/17/16	9:41	35.37087	-118.96842	Building	URBAN	Structure Only	Fire Agency	Kern County FD	100182417		21,000	Transformer	Overhead	Yes	8/17/16	9:41
934	PG&E	8/17/16	12:23	41.24946	-123.76707	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100315791		12,000	Conductor	Overhead	Yes	8/17/16	12:23
935	PG&E	8/17/16	14:02	39.63610	-121.74794	Vegetation	RURAL	< 3 meters	Customer	N.A.	100437069		60,000	Conductor	Overhead	Yes	8/17/16	14:02
936	PG&E	8/17/16	18:37	37.30779	-119.65105	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101020932		21,000	Conductor	Overhead	Yes	8/17/16	18:37
937	PG&E	8/18/16	15:22	36.81874	-119.44391	Vegetation	RURAL	< 3 meters	Self Extinguished	N.A.	100826791	VERIZON CALIFO	0 - 750	Conductor	Overhead	Yes	8/18/16	15:22
938	PG&E	8/18/16	18:12	37.59560	-122.08648	Vegetation	URBAN	< 3 meters	Fire Agency	union city fd	100935101	PACIFIC BELL	0 - 750	Fuse	Overhead	No		
939	PG&E	8/18/16	18:36	36.97014	-121.54598	Vegetation	RURAL	< 3 meters	Fire Agency	Santa Clara county fire	103553473		0 - 750	Capacitor Bank	Overhead	No		
940	PG&E	8/19/16	16:23	38.22351	-123.75500	Vegetation	RURAL	< 3 meters	Fire Agency	Albion-Little River FD	102206661		12,000	Conductor	Overhead	Yes	8/19/16	16:23
941	PG&E	8/20/16	18:51	36.45801	-119.34722	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Merced County FD	100729153	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/20/16	18:51
942	PG&E	8/21/16	13:02	38.44445	-122.24955	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	102291451	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/21/16	13:02
943	PG&E	8/22/16	16:10	37.96656	-120.23950	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Toulumne City FD	101043683		17,000	Conductor	Overhead	Yes	8/22/16	16:10
944	PG&E	8/23/16	16:03	36.87411	-119.68648	Vegetation	RURAL	< 3 meters	Customer	N.A.	100731257	None	0 - 750	Conductor	Overhead	Yes	8/23/16	16:03
945	PG&E	8/24/16	12:11	36.46335	-121.71202	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101750810	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/24/16	12:11
946	PG&E	8/24/16	14:19	36.84572	-119.87926	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Fresno FD	103277500		21,000	Conductor	Overhead	Yes	8/24/16	14:19
947	PG&E	8/25/16	12:04	36.97263	-119.38162	Vegetation	RURAL	< 3 meters	Utility: PG&E	N.A.	100651318	PONDEROSA	0 - 750	Conductor	Overhead	No		
948	PG&E	8/25/16	11:31	37.37341	-122.08696	Vegetation	URBAN	< 3 meters	Self Extinguished	N.A.	100516445	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/25/16	11:31
949	PG&E	8/27/16	5:37	36.04398	-120.11166	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Kings County FD	100326130		70,000	Conductor	Overhead	Yes	8/27/16	5:37
950	PG&E	8/27/16	19:33	36.96458	-122.05289	Vegetation	URBAN	< 0.25 Acres	Fire Agency	SC FIRE DEPT & CDF	101677596	PACIFIC BELL	21,000	Conductor	Overhead	Yes	8/27/16	19:33
951	PG&E	8/28/16	16:49	36.56186	-119.71860	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	100683911		12,000	Conductor	Overhead	Yes	8/28/16	16:49
952	PG&E	8/29/16	16:25	38.26928	-121.60294	Vegetation	RURAL	< 0.25 Acres	Fire Agency	SAC FIRE	101583637	FRONTIER	21,000	Conductor	Overhead	Yes	8/29/16	16:25
953	PG&E	8/30/16	16:01	36.59413	-121.82120	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Unknown	101734977		21,000	Conductor	Overhead	Yes	8/30/16	16:01
954	PG&E	8/30/16	16:14	38.05755	-122.16390	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Benicia FD	102284159	PACIFIC BELL	21,000	Conductor	Overhead	Yes	8/30/16	16:14
955	PG&E	8/30/16	19:27	39.92880	-122.12765	Vegetation	RURAL	< 0.25 Acres	Unknown	Unknown	103165395	Yes	12,000	Conductor	Overhead	Yes	8/30/16	19:27
956	PG&E	8/31/16	11:17	37.37206	-120.45039	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Merced County FD	101147802	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	8/31/16	11:17
957	PG&E	8/31/16	14:52	35.19180	-120.46971	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101942860		12,000	Conductor	Overhead	Yes	8/31/16	14:52
958	PG&E	8/31/16	19:43	38.15100	-121.68037	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	ISLETON	101665829	FRONTIER	21,000	Conductor	Overhead	Yes	8/31/16	19:43
959	PG&E	9/1/16	9:30	37.28144	-121.86030	Vegetation	URBAN	< 3 meters	Customer	N.A.	100617565	None	21,000	Conductor	Overhead	Yes	9/1/16	9:30
960	PG&E	9/1/16	13:08	38.46327	-122.81616	Vegetation	RURAL	< 3 meters	Fire Agency	WINDSOR AND SANTA ROSA FIRE	101956270	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/1/16	13:08
961	PG&E	9/2/16	12:42	38.36860	-122.75553	Vegetation	RURAL	< 3 meters	Fire Agency	Santa Rosa FD	101969369	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/2/16	12:42
962	PG&E	9/2/16	13:50	37.66811	-121.76805	Vegetation	URBAN	< 0.25 Acres	Fire Agency	LPFD	100954399		21,000	Conductor	Overhead	Yes	9/2/16	13:50
963	PG&E	9/3/16	20:12	39.32230	-121.98490	Vegetation	RURAL	< 3 meters	Unknown	Unknown	101614478		12,000	Conductor	Overhead	Yes	9/3/16	20:12
964	PG&E	9/3/16	20:58	36.80805	-119.62789	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Unknown	103299240		12,000	Conductor	Overhead	Yes	9/3/16	20:58
965	PG&E	9/5/16	8:26	39.52329	-122.14619	Vegetation	RURAL	< 0.25 Acres	Unknown	Unknown	100430821		21,000	Conductor	Overhead	Yes	9/5/16	8:26
966	PG&E	9/7/16	13:07	38.69206	-122.54447	Vegetation	URBAN	< 3 meters	Fire Agency	San Rafael FD	102349944	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/7/16	13:07
967	PG&E	9/7/16	9:56	36.55281	-121.64163	Vegetation	RURAL	26 - 9.99 Acres	Unknown	Unknown	102653028		60,000	Conductor	Overhead	Yes	9/7/16	9:56
968	PG&E	9/8/16	14:39	38.00133	-122.32902	Vegetation	URBAN	< 0.25 Acres	Fire Agency	PINOLE FIRE DEPT	101426911		12,000	Conductor	Overhead	Yes	9/8/16	14:39
969	PG&E	9/8/16	22:04	37.29175	-121.87109	Vegetation	URBAN	< 0.25 Acres	Fire Agency	San Jose FD	100598024	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/8/16	22:04
970	PG&E	9/9/16	10:57	36.85174	-119.62254	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Fresno County FD	100746408	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/9/16	10:57
971	PG&E	9/9/16	13:22	37.28367	-120.47405	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Cal Fire	101018780	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/9/16	13:22
972	PG&E	9/9/16	15:25	38.92020	-121.08588	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Cal Fire	100036304	PACIFIC BELL	12,000	Capacitor Bank	Overhead	Yes	9/9/16	15:25
973	PG&E	9/10/16	2:09	37.18617	-120.67754	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Merced County FD	101072400		12,000	Conductor	Overhead	Yes	9/10/16	2:09
974	PG&E	9/11/16	21:24	36.95261	-119.72629	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Unknown	100652942		21,000	Unknown	Overhead	Yes	9/11/16	21:24
975	PG&E	9/12/16	4:24	36.39990	-121.90201	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire Hwy 1 Carmel Hill	101669614		12,000	Conductor	Overhead	Yes	9/12/16	4:24
976	PG&E	9/12/16	12:38	38.78323	-120.60060	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	101421708	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/12/16	12:38
977	PG&E	9/12/16	18:47	36.53030	-119.30560	Vegetation	RURAL	< 0.25 Acres	Fire Agency	CUTLER FIRE	100807630	None	12,000	Conductor	Overhead	Yes	9/12/16	18:47
978	PG&E	9/12/16	20:42	37.35500	-121.93550	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Santa Clara county fire	100608192		12,000	Conductor	Overhead	Yes	9/12/16	20:42
979	PG&E	9/12/16	15:08	39.52556	-123.76550	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	102185070		12,000	Conductor	Overhead	Yes	9/12/16	15:08
980	PG&E	9/13/16	10:26	39.19131	-121.18186	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	100082849	PACIFIC BELL	21,000	Conductor	Overhead	Yes	9/13/16	10:26
981	PG&E	9/13/16	10:45	40.29579	-122.13182	Vegetation	RURAL	300 - 999 Acres	Fire Agency	Cal Fire	103702175		60,000	Conductor	Overhead	Yes	9/13/16	10:45
982	PG&E	9/14/16	21:16	37.34475	-121.07646	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	STANISLUAS COUNTY	101228545	None	12,000	Conductor	Overhead	Yes	9/14/16	21:16
983	PG&E	9/14/16	23:25	39.47982	-121.85154	Vegetation	RURAL	< 0.25 Acres	Unknown	Unknown	101618097		12,000	Conductor	Overhead	Yes	9/14/16	23:25
984	PG&E	9/15/16	15:56	37.11024	-121.85082	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100520198	VERIZON CALIFO	12,000	Conductor	Overhead	Yes	9/15/16	15:56
985	PG&E	9/16/16	20:56	39.83874	-121.70232	Vegetation	RURAL	10 - 99 Acres	Fire Agency	Cal Fire	100441760	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/16/16	20:56
986	PG&E	9/17/16	10:03	38.04945	-121.01430	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Unknown	102123492		12,000	Fuse	Overhead	Yes	9/17/16	10:03
987	PG&E	9/17/16	17:47	37.10117	-120.12887	Vegetation	RURAL	< 3 meters	Fire Agency	Unknown	101062487		12,000	Conductor	Overhead	Yes	9/17/16	17:47
988	PG&E	9/18/16	14:33	37.16185	-122.13470	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire & Boulder Creek Fire Dept.	103410909	Yes	12,000	Conductor	Overhead	Yes	9/18/16	14:33
989	PG&E	9/19/16	14:09	37.94585	-122.37201	Vegetation	RURAL	< 3 meters	Fire Agency	Unknown	101433385	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/19/16	14:09
990	PG&E	9/19/16	22:10	37.96530	-121.25794	Vegetation	URBAN	< 3 meters	Fire Agency	STOCKTON FIRE	102057961	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/19/16	22:10
991	PG&E	9/19/16	8:51	36.44586	-119.09188	Veget												

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
2	Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
1011	PG&E	9/28/16	16:21	37.14654	-121.66735	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Cal Fire	100601627		21,000	Conductor	Overhead	Yes	9/28/16	16:21
1012	PG&E	9/29/16	11:17	38.01782	-121.64836	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Contra Costa County FD	100457240	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/29/16	11:17
1013	PG&E	10/1/16	15:19	39.43838	-120.81597	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	State government forestry	100112411		12,000	Conductor	Overhead	Yes	10/1/16	15:19
1014	PG&E	10/2/16	15:51	38.21314	-122.13380	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Fairfield FD	101563172	PACIFIC BELL	12,000	Other	Overhead	Yes	10/2/16	15:51
1015	PG&E	10/2/16	18:41	39.88877	-121.68482	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	103358082		12,000	Other	Overhead	Yes	10/2/16	18:41
1016	PG&E	10/3/16	18:23	34.59666	-120.95212	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Santa Barbara County FD	101895043		12,000	Conductor	Overhead	Yes	10/3/16	18:23
1017	PG&E	10/4/16	2:04	38.06652	-122.19613	Vegetation	URBAN	26 - 9.99 Acres	Unknown	Unknown	103773890		21,000	Conductor	Overhead	Yes	10/4/16	2:04
1018	PG&E	10/4/16	12:50	35.20894	-119.23516	Vegetation	RURAL	< 3 meters	Fire Agency	County	103261812		12,000	Conductor	Overhead	Yes	10/4/16	12:50
1019	PG&E	10/5/16	16:23	35.29640	-118.77647	Vegetation	RURAL	10 - 99 Acres	Fire Agency	Kern County FD	100187871		12,000	Conductor	Overhead	Yes	10/5/16	16:23
1020	PG&E	10/6/16	22:06	35.43780	-119.68730	Vegetation	RURAL	< 0.25 Acres	Utility, PG&E	N.A.	100162148		21,000	Conductor	Overhead	Yes	10/6/16	22:06
1021	PG&E	10/7/16	8:17	37.98914	-121.04496	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Linden- Peters Fire Department	102119967		0 - 750	Transformer	Overhead	Yes	10/7/16	8:17
1022	PG&E	10/8/16	6:52	39.57172	-121.72955	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100396647		12,000	Conductor	Overhead	Yes	10/8/16	6:52
1023	PG&E	10/8/16	15:04	38.66859	-120.90911	Vegetation	RURAL	< 0.25 Acres	Customer	N.A.	101380856		0 - 750	Capacitor Bank	Overhead	Yes	10/8/16	15:04
1024	PG&E	10/8/16	16:31	39.00990	-122.61448	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	102152342		0 - 750	Transformer	Overhead	Yes	10/8/16	16:31
1025	PG&E	10/9/16	7:43	37.53617	-120.46687	Vegetation	RURAL	< 3 meters	Customer	N.A.	101197077		0 - 750	Conductor	Overhead	Yes	10/9/16	7:43
1026	PG&E	10/9/16	18:52	38.65602	-120.97252	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101376768		12,000	Conductor	Overhead	Yes	10/9/16	18:52
1027	PG&E	10/9/16	22:47	38.20590	-121.88890	Vegetation	RURAL	< 0.25 Acres	Fire Agency	MONTEZUMA FIRE DISTRICT	101662848		21,000	Conductor	Overhead	Yes	10/9/16	22:47
1028	PG&E	10/10/16	10:06	38.47560	-122.90790	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	103002019		12,000	Conductor	Overhead	Yes	10/10/16	10:06
1029	PG&E	10/11/16	11:30	38.80244	-119.81017	Vegetation	URBAN	< 3 meters	Fire Agency	Unknown	100857712	PACIFIC BELL	21,000	Conductor	Overhead	Yes	10/11/16	11:30
1030	PG&E	10/11/16	23:16	39.02008	-120.82943	Vegetation	RURAL	< 0.25 Acres	Fire Agency	cal fire foresthill fire	100025501		60,000	Conductor	Overhead	Yes	10/11/16	23:16
1031	PG&E	10/13/16	23:14	40.49015	-122.37286	Vegetation	RURAL	< 0.25 Acres	Fire Agency	SHASTA COUNTY FIRE	101502366	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	10/13/16	23:14
1032	PG&E	10/13/16	23:52	39.75448	-122.20083	Building	URBAN	Structure Only	Fire Agency	CITY OF ORLAND	100361735	PACIFIC BELL	12,000	Conductor	Overhead	Yes	10/13/16	23:52
1033	PG&E	10/14/16	1:32	40.50088	-121.91620	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101489328		12,000	Conductor	Overhead	Yes	10/14/16	1:32
1034	PG&E	10/14/16	4:32	40.52282	-121.68134	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	101513661		12,000	Conductor	Overhead	Yes	10/14/16	4:32
1035	PG&E	10/14/16	10:24	37.74494	-121.93685	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Contra Costa County FD	100902256		21,000	Other	Overhead	Yes	10/14/16	10:24
1036	PG&E	10/14/16	10:36	37.73480	-121.93400	Vegetation	URBAN	26 - 9.99 Acres	Fire Agency	Cal Fire	100902265		0 - 750	Conductor	Overhead	Yes	10/14/16	10:36
1037	PG&E	10/14/16	11:00	38.89625	-121.58915	Vegetation	RURAL	< 0.25 Acres	Fire Agency	placer	101334896	PACIFIC BELL	12,000	Other	Overhead	Yes	10/14/16	11:00
1038	PG&E	10/14/16	19:44	38.62446	-121.53822	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	100435570		0 - 750	Conductor	Overhead	Yes	10/14/16	19:44
1039	PG&E	10/15/16	15:34	37.32547	-120.31099	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	101142010	PACIFIC BELL	12,000	Conductor	Overhead	Yes	10/15/16	15:34
1040	PG&E	10/18/16	10:50	37.29993	-120.72945	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Unknown	101166039		12,000	Conductor	Overhead	Yes	10/18/16	10:50
1041	PG&E	10/18/16	16:20	38.47124	-122.65687	Vegetation	URBAN	< 3 meters	Fire Agency	CITY OF SANTA ROSA	101966406		0 - 750	Conductor	Overhead	Yes	10/18/16	16:20
1042	PG&E	10/19/16	10:42	38.50979	-122.44996	Vegetation	RURAL	< 0.25 Acres	Fire Agency	st helena	102242552	PACIFIC BELL	21,000	Conductor	Overhead	Yes	10/19/16	10:42
1043	PG&E	10/23/16	10:54	35.55451	-120.67080	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Cal Fire	101901785		21,000	Conductor	Overhead	Yes	10/23/16	10:54
1044	PG&E	10/23/16	14:16	38.22710	-121.04948	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	102074335	VERIZON CALIFO	21,000	Conductor	Overhead	Yes	10/23/16	14:16
1045	PG&E	10/23/16	18:10	38.02104	-120.59910	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	101272943		115,000	Conductor	Overhead	Yes	10/23/16	18:10
1046	PG&E	10/26/16	10:16	37.11994	-120.31132	Vegetation	RURAL	< 3 meters	Fire Agency	Chowchilla FD	101129171		12,000	Conductor	Overhead	Yes	10/26/16	10:16
1047	PG&E	10/31/16	17:04	36.66385	-119.74626	Vegetation	RURAL	26 - 9.99 Acres	Fire Agency	Fresno County FD	100808306		12,000	Conductor	Overhead	Yes	10/31/16	17:04
1048	PG&E	11/9/16	9:06	37.45316	-119.64132	Vegetation	RURAL	< 0.25 Acres	Fire Agency	US FOREST SERVICE	101017062		12,000	Conductor	Overhead	Yes	11/9/16	9:06
1049	PG&E	11/14/16	3:25	34.33969	-120.89022	Vegetation	URBAN	< 3 meters	Fire Agency	Cayucos fire	101853338	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	11/14/16	3:25
1050	PG&E	11/14/16	13:15	36.45772	-120.46198	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101895611		21,000	Conductor	Overhead	Yes	11/14/16	13:15
1051	PG&E	11/15/16	12:27	39.72747	-121.65571	Vegetation	RURAL	< 0.25 Acres	Fire Agency	CAL FIRE/BUTTE COUNTY FIRE	100327525	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/15/16	12:27
1052	PG&E	11/20/16	11:04	39.63262	-123.78228	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	102200173		12,000	Conductor	Overhead	Yes	11/20/16	11:04
1053	PG&E	11/26/16	12:10	35.32208	-118.78080	Vegetation	RURAL	< 0.25 Acres	Utility, PG&E	N.A.	102300399		12,000	Conductor	Overhead	Yes	11/26/16	12:10
1054	PG&E	01/01/17	15:57	38.66287	-121.74803	Vegetation	Urban	< 3 Meters	Fire Agency	Woodland fire dept. 504-666-8920	101589774	Unknown	0 - 750	Conductor	Overhead	Yes	1/1/17	15:57
1055	PG&E	01/10/17	15:55	38.75380	-121.15641	Building	Urban	Structure Only	Unknown	N.A.	100060579	Unknown	12,000	Conductor	Overhead	Yes	1/10/17	15:55
1056	PG&E	01/18/17	15:34	37.38388	-121.80884	Building	Urban	Structure Only	Unknown	N.A.	100564835	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	1/18/17	15:34
1057	PG&E	01/29/17	09:45	38.36159	-122.195091	Building	Urban	Structure Only	Fire Agency	Unknown	78550	Unknown	12,000	Transformer	Subsurface	Yes	1/29/17	09:45
1058	PG&E	02/03/17	10:00	37.56153	-122.02772	Vegetation	Urban	< 3 Meters	Fire Agency	Jeff	100938466	Unknown	12,000	Conductor	Overhead	Yes	2/3/17	10:00
1059	PG&E	02/07/17	04:50	38.43314	-122.71902	Building	Urban	Structure Only	Fire Agency	Santa Rosa Fire Dept	102014637	PACIFIC BELL	12,000	Conductor	Overhead	Yes	2/7/17	04:50
1060	PG&E	03/16/17	12:43	38.27175	-122.01971	Other	Urban	< 0.25 Acres	Fire Agency	Unknown	101561532	PACIFIC BELL	12,000	Conductor	Overhead	Yes	3/16/17	12:43
1061	PG&E	03/17/17	09:37	38.11532	-122.42216	Other	Rural	Structure Only	Fire Agency	911	102044732	PACIFIC BELL	21,000	Conductor	Overhead	Yes	3/17/17	09:37
1062	PG&E	03/19/17	17:06	39.76209	-121.85247	Vegetation	Urban	< 3 Meters	Fire Agency	CHICO FIRE DEPT 911	100441377	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	3/19/17	17:06
1063	PG&E	03/23/17	07:04	37.36975	-121.85218	Other	Urban	< 3 Meters	Fire Agency	SJFD disp 408-277-8950 Iolident# F170829041	103485262	Unknown	12,000	Transformer	Subsurface	Yes	3/23/17	07:04
1064	PG&E	03/28/17	12:15	34.88092	-120.41992	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	103397961	YES	12,000	Conductor	Overhead	Yes	3/28/17	12:15
1065	PG&E	04/01/17	14:54	37.18863	-120.95164	Vegetation	Rural	< 0.25 Acres	Fire Agency	engine 74 mrced fire agency	102318665	Unknown	12,000	Conductor	Overhead	Yes	4/1/17	14:54
1066	PG&E	04/04/17	13:29	35.68853	-120.76533	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101945026	None	12,000	Conductor	Overhead	Yes	4/4/17	13:29
1067	PG&E	04/04/17	14:54	37.29584	-121.93296	Vegetation	Urban	< 3 Meters	Customer	N.A.	100591136	None	12,000	Conductor	Overhead	Yes	4/4/17	14:54
1068	PG&E	04/10/17	16:35	35.61751	-119.74296	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	100128630	Unknown	21,000	Conductor	Overhead	No		
1069	PG&E	04/13/17	14:21	37.79671	-122.25210	Other	Urban	Structure Only	Fire Agency	MANTECA CITY	102104500	VERIZON CALIFO	17,000	Conductor	Overhead	Yes	4/13/17	14:21
1070	PG&E	04/16/17	15:14	35.58053	-119.14227	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103833904	Unknown	12,000	Conductor	Overhead	Yes	4/16/17	15:14
1071	PG&E	04/20/17	20:14	37.37407	-120.71688	Vegetation	Urban	< 3 Meters	Fire Agency	209-966-3621	101205903	Unknown	12,000	Transformer	Overhead	No		
1072	PG&E	04/23/17	7:10	36.07345	-120.93450	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101726333	Unknown	12,000	Conductor	Overhead	Yes	4/23/17	7:10
1073	PG&E	04/24/17	11:52	36.16990	-121.15129	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101718856	None	12,000	Conductor	Overhead	Yes	4/24/17	11:52
1074	PG&E	04/25/17	12:38	38.65832	-120.97622	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101376746	Unknown	0 - 750	Transformer	Overhead	Yes	4/25/17	12:38
1075	PG&E	04/25/17	18:26	36.23725	-119.78071	Other	Rural</											

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
2	Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
3	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	
1087	PG&E	05/06/17	1:56	37.32997	-120.83297	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103834182	Unknown	12,000	Conductor	Overhead	Yes	5/6/17	1:56
1088	PG&E	05/06/17	11:18	40.79512	-124.02902	Vegetation	Rural	< 3 Meters	Fire Agency	chief rick harden 7074423352	103661154	Unknown	12,000	Conductor	Overhead	Yes	5/6/17	11:18
1089	PG&E	05/06/17	12:43	40.76227	-124.16195	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100998152	Unknown	12,000	Conductor	Overhead	Yes	5/6/17	12:43
1090	PG&E	05/06/17	15:00	39.24580	-123.77854	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	102185559	Unknown	12,000	Conductor	Overhead	Yes	5/6/17	15:00
1091	PG&E	05/06/17	23:46	38.16537	-120.37372	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	100741510	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/6/17	23:46
1092	PG&E	05/09/17	11:15	40.05970	-122.18895	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	101531151	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/9/17	11:15
1093	PG&E	05/09/17	15:57	39.54650	-121.85667	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100404826	Unknown	12,000	Conductor	Overhead	No		
1094	PG&E	05/09/17	18:26	40.86892	-123.51559	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	todd wright fire chief. 5307392493	103796045	Unknown	12,000	Conductor	Overhead	Yes	5/9/17	18:26
1095	PG&E	05/12/17	15:16	38.85066	-121.31683	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102347828	Unknown	21,000	Conductor	Overhead	Yes	5/12/17	15:16
1096	PG&E	05/13/17	21:49	39.67845	-121.77802	Vegetation	Rural	< 0.25 Acres	Fire Agency	911	100355502	Unknown	12,000	Conductor	Overhead	Yes	5/13/17	21:49
1097	PG&E	05/14/17	11:59	38.07980	-122.86650	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	102247059	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/14/17	11:59
1098	PG&E	05/14/17	16:09	35.60167	-119.65665	Vegetation	Rural	10 - 99 Acres	Fire Agency	861-391-7000	100131572	Unknown	21,000	Conductor	Overhead	Yes	5/14/17	16:09
1099	PG&E	05/15/17	3:05	35.62610	-120.89616	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	101873299	Unknown	21,000	Conductor	Overhead	No		
1100	PG&E	05/15/17	13:05	38.19694	-121.40951	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102071491	Unknown	12,000	Transformer	Overhead	No		
1101	PG&E	05/15/17	16:00	37.17665	-119.81887	Vegetation	Rural	< 0.25 Acres	Fire Agency	SHAUN FAIRBANKS 559-683-4823	101108423	SIERRA	21,000	Conductor	Overhead	Yes	5/15/17	16:00
1102	PG&E	05/15/17	20:57	38.67253	-122.04559	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101589358	Unknown	21,000	Conductor	Overhead	Yes	5/15/17	20:57
1103	PG&E	05/16/17	17:21	35.37590	-119.14413	Vegetation	Urban	< 0.25 Acres	Fire Agency	324-6551	103264300	Unknown	12,000	Conductor	Overhead	Yes	5/16/17	17:21
1104	PG&E	05/17/17	14:49	37.22500	-120.48326	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	101154662	Unknown	12,000	Transformer	Overhead	Yes	5/17/17	14:49
1105	PG&E	05/17/17	15:13	36.24862	-121.03830	Other	Rural	10 - 99 Acres	Fire Agency	Unknown	101764465	None	12,000	Conductor	Overhead	Yes	5/17/17	15:13
1106	PG&E	05/19/17	9:37	40.03343	-122.09887	Vegetation	Rural	< 0.25 Acres	Fire Agency	INCIDENT NUMBER 004751	101534483	Unknown	0 - 750	Conductor	Overhead	Yes	5/19/17	9:37
1107	PG&E	05/19/17	10:52	37.20861	-121.09093	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	Pole 044/004	Unknown	115,000	Conductor	Overhead	Yes	5/19/17	10:52
1108	PG&E	05/20/17	11:36	39.65278	-119.80121	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102185559	Unknown	0 - 750	Conductor	Overhead	Yes	5/20/17	11:36
1109	PG&E	05/21/17	11:36	39.42773	-121.89795	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100739216	Unknown	12,000	Conductor	Overhead	Yes	5/21/17	11:36
1110	PG&E	05/21/17	22:47	38.06453	-122.56982	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	102238142	PACIFIC BELL	12,000	Transformer	Overhead	Yes	5/21/17	22:47
1111	PG&E	05/22/17	5:39	36.37529	-121.04797	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101770874	Unknown	21,000	Other	Overhead	No		
1112	PG&E	05/22/17	17:52	37.75450	-121.41930	Vegetation	Urban	< 0.25 Acres	Fire Agency	TRACY	102119359	Unknown	12,000	Conductor	Overhead	Yes	5/22/17	17:52
1113	PG&E	05/24/17	16:24	38.83404	-121.11965	Vegetation	Rural	< 3 Meters	Fire Agency	Fire Capt	103838109	None	12,000	Conductor	Overhead	Yes	5/24/17	16:24
1114	PG&E	05/25/17	11:09	37.45264	-121.88900	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	ERIC EMMANUELE OFFICE (408)586-3365 DIRECT (408)586-3383	100557380	Unknown	12,000	Transformer	Overhead	Yes	5/25/17	11:09
1115	PG&E	05/25/17	15:05	36.52168	-121.84729	Vegetation	Rural	< 0.25 Acres	Fire Agency	Buddy Bloxham 831-236-5659	101778611	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/25/17	15:05
1116	PG&E	05/25/17	16:55	38.98960	-122.96760	Vegetation	Rural	< 3 Meters	Utility: PG&E	N.A.	101974034	Unknown	12,000	Conductor	Overhead	Yes	5/25/17	16:55
1117	PG&E	05/29/17	18:29	39.22451	-121.37525	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101304842	PACIFIC BELL	12,000	Conductor	Overhead	No		
1118	PG&E	05/30/17	11:40	36.80045	-121.77018	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101707398	Unknown	12,000	Conductor	Overhead	Yes	5/30/17	11:40
1119	PG&E	05/31/17	2:06	36.75403	-121.22378	Vegetation	Rural	< 0.25 Acres	Fire Agency	Placer Co. fire	100603341	ROSEVILLE	12,000	Conductor	Overhead	Yes	5/31/17	2:06
1120	PG&E	05/31/17	5:24	37.02750	-120.07067	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101113852	Unknown	12,000	Conductor	Overhead	Yes	5/31/17	5:24
1121	PG&E	06/01/17	9:11	40.18301	-122.26654	Vegetation	Rural	< 0.25 Acres	Fire Agency	MARK FRITZ	101546068	Unknown	12,000	Conductor	Overhead	Yes	6/1/17	9:11
1122	PG&E	06/01/17	21:35	41.03570	-121.38690	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101950337	FRONTIER COMM	12,000	Conductor	Overhead	Yes	6/1/17	21:35
1123	PG&E	06/01/17	22:14	36.65394	-121.62918	Vegetation	Rural	< 3 Meters	Fire Agency	Saltinas FD	101732390	Unknown	12,000	Lightning Arrestor	Overhead	Yes	6/1/17	22:14
1124	PG&E	06/03/17	13:26	39.90174	-121.20569	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100043684	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/3/17	13:26
1125	PG&E	06/03/17	20:52	36.83229	-119.63327	Vegetation	Rural	< 3 Meters	Fire Agency	CLOVIS F.D. CHIEF Mike Gomez 559 906-1621 Incident #17cammu011185	100768082	Unknown	12,000	Conductor	Overhead	Yes	6/3/17	20:52
1126	PG&E	06/04/17	00:08	36.98200	-120.03471	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103837406	None	12,000	Conductor	Overhead	Yes	6/4/17	00:08
1127	PG&E	06/04/17	13:12	36.74591	-120.06018	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100645872	Unknown	12,000	Conductor	Overhead	Yes	6/4/17	13:12
1128	PG&E	06/05/17	0:52	38.23420	-121.21311	Vegetation	Rural	< 3 Meters	Unknown	N.A.	102083982	PACIFIC BELL	12,000	Transformer	Overhead	Yes	6/5/17	0:52
1129	PG&E	06/05/17	7:56	37.85680	-120.88150	Vegetation	Rural	< 0.25 Acres	Fire Agency	209 5523911	102333651	None	17,000	Conductor	Overhead	Yes	6/5/17	7:56
1130	PG&E	06/05/17	17:12	36.94243	-121.46123	Vegetation	Rural	10 - 99 Acres	Fire Agency	Leo Alvarez 831-6364324	101717332	Unknown	21,000	Conductor	Overhead	Yes	6/5/17	17:12
1131	PG&E	06/06/17	9:15	36.45426	-119.13382	Vegetation	Rural	< 0.25 Acres	Fire Agency	TIM ROGERS, 559-358-7120	102306658	Unknown	12,000	Conductor	Overhead	Yes	6/6/17	9:15
1132	PG&E	06/06/17	09:48	36.99857	-120.93690	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	101199765	Unknown	12,000	Conductor	Overhead	Yes	6/6/17	09:48
1133	PG&E	06/06/17	13:39	38.17110	-121.67825	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101666656	FRONTIER COMM	21,000	Fuse	Overhead	No		
1134	PG&E	06/07/17	13:25	35.09398	-119.41607	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100192567	Unknown	12,000	Conductor	Overhead	No		
1135	PG&E	06/07/17	10:13	39.56030	-122.10768	Vegetation	Rural	< 3 Meters	Utility: PG&E	N.A.	103838281	Unknown	12,000	Conductor	Overhead	Yes	6/7/17	10:13
1136	PG&E	06/08/17	5:33	36.23884	-120.30164	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	100743822	Unknown	12,000	Conductor	Overhead	Yes	6/8/17	5:33
1137	PG&E	06/08/17	0:26	37.12759	-120.01930	Vegetation	Rural	100 - 299 Acres	Fire Agency	Jeff Mc Carroll (559) 806 - 8815	103205823	Unknown	12,000	Conductor	Overhead	Yes	6/8/17	0:26
1138	PG&E	06/08/17	15:08	34.60580	-120.02140	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	SHAWN STEINER	101947678	Unknown	12,000	Conductor	Overhead	Yes	6/8/17	15:08
1139	PG&E	06/09/17	10:40	36.69663	-119.71863	Vegetation	Rural	< 0.25 Acres	Fire Agency	FRESNO COUNTY	100793555	Unknown	12,000	Conductor	Overhead	Yes	6/9/17	10:40
1140	PG&E	06/09/17	13:27	36.73820	-119.82038	Vegetation	Rural	< 0.25 Acres	Fire Agency	FFD INC # 703 4018	100895732	Unknown	12,000	Conductor	Overhead	Yes	6/9/17	13:27
1141	PG&E	06/09/17	17:20	35.79741	-120.53892	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	103406061	Unknown	12,000	Conductor	Overhead	Yes	6/9/17	17:20
1142	PG&E	06/10/17	07:37	35.43590	-120.49570	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101890429	Unknown	21,000	Conductor	Overhead	Yes	6/10/17	07:37
1143	PG&E	06/12/17	15:28	36.96720	-120.09309	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101136946	Unknown	12,000	Conductor	Overhead	Yes	6/12/17	15:28
1144	PG&E	06/12/17	18:04	35.36381	-118.82556	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	103371824	Unknown	12,000	Transformer	Overhead	Yes	6/12/17	18:04
1145	PG&E	06/13/17	14:30	37.85265	-122.18529	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	Tower 005/035c	Unknown	115,000	Conductor	Overhead	Yes	6/13/17	14:30
1146	PG&E	06/14/17	22:23	39.75591	-121.59343	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100324481	PACIFIC BELL	12,000	Fuse	Overhead	Yes	6/14/17	22:23
1147	PG&E	06/15/17	2:58	40.29899	-122.43185	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101511631	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/15/17	2:58
1148	PG&E	06/15/17	5:02	36.82613	-121.67456	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101712958	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/15/17	5:02
1149	PG&E	06/15/17	7:39	39.22756	-121.23476	Vegetation	Rural	< 0.25 Acres	Fire Agency	FIRE CHIEF	103676075	Unknown	21,000	Conductor	Overhead	Yes	6/15/17	7:39
1																		

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
2	Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
3	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	
1165	PG&E	06/18/17	20:16	38.88844	-122.02044	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101650987	None	12,000	Lightning Arrestor	Overhead	Yes	6/18/17	20:16
1166	PG&E	06/18/17	21:07	37.83974	-121.28643	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102085809	Unknown	12,000	Conductor	Overhead	Yes	6/18/17	21:07
1167	PG&E	06/18/17	22:12	38.53900	-122.79203	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	102029435	Unknown	12,000	Other	Overhead	Yes	6/18/17	22:12
1168	PG&E	06/18/17	23:12	36.75747	-119.66455	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100780126	PACIFIC BELL	12,000	Conductor	Overhead	No		
1169	PG&E	06/18/17	23:31	38.89731	-121.29467	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	103782395	Unknown	12,000	Conductor	Overhead	Yes	6/18/17	23:31
1170	PG&E	06/19/17	01:23	35.36762	-118.95521	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100252360	PACIFIC BELL	21,000	Conductor	Overhead	Yes	6/19/17	01:23
1171	PG&E	06/19/17	13:51	39.90633	-122.17660	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	103841797	YES	12,000	Conductor	Overhead	Yes	6/19/17	13:51
1172	PG&E	06/19/17	16:18	37.79272	-121.23058	Other	Urban	Structure Only	Utility: PG&E	N.A.	103582825	Unknown	17,000	Transformer	Subsurface	Yes	6/19/17	16:18
1173	PG&E	06/19/17	16:26	37.93783	-120.60897	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101282825	Unknown	17,000	Other	Overhead	No		
1174	PG&E	06/19/17	17:31	36.76288	-120.37580	Vegetation	Rural	< 3 Meters	Unknown	N.A.	10094343	Unknown	12,000	Transformer	Overhead	Yes	6/19/17	17:31
1175	PG&E	06/19/17	18:00	38.45496	-121.82416	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101594910	PACIFIC BELL	12,000	Lightning Arrestor	Overhead	Yes	6/19/17	18:00
1176	PG&E	06/19/17	20:22	38.10123	-120.86969	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101233468	Unknown	12,000	Transformer	Overhead	Yes	6/19/17	20:22
1177	PG&E	06/20/17	00:49	39.74900	-121.89975	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	100437523	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/20/17	00:49
1178	PG&E	06/20/17	09:12	39.19754	-121.49499	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101306700	Unknown	12,000	Conductor	Overhead	Yes	6/20/17	09:12
1179	PG&E	06/20/17	10:08	39.03668	-121.07630	Vegetation	Urban	< 3 Meters	Fire Agency	JERRY GOOD 530 268-0844	100023174	None	12,000	Conductor	Overhead	Yes	6/20/17	10:08
1180	PG&E	06/20/17	13:37	37.92473	-122.08954	Vegetation	Urban	< 3 Meters	Fire Agency	contra costa fire	100476159	PACIFIC BELL	12,000	Capacitor Bank	Overhead	Yes	6/20/17	13:37
1181	PG&E	06/20/17	15:17	40.11262	-123.76774	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	100987107	Unknown	12,000	Conductor	Overhead	Yes	6/20/17	15:17
1182	PG&E	06/20/17	11:51	40.31556	-124.06111	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101006039	Unknown	12,000	Conductor	Overhead	Yes	6/20/17	11:51
1183	PG&E	06/20/17	18:32	37.92810	-121.23323	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	102132644	Unknown	12,000	Conductor	Overhead	Yes	6/20/17	18:32
1184	PG&E	06/20/17	20:46	38.90764	-121.26030	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100085621	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/20/17	20:46
1185	PG&E	06/20/17	23:16	35.63750	-120.85660	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101873622	Unknown	12,000	Conductor	Overhead	Yes	6/20/17	23:16
1186	PG&E	06/21/17	08:41	39.16997	-122.15731	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101637081	Unknown	12,000	Conductor	Overhead	Yes	6/21/17	08:41
1187	PG&E	06/21/17	14:23	38.99208	-121.35362	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	100274699	PACIFIC BELL	12,000	Transformer	Overhead	Yes	6/21/17	14:23
1188	PG&E	06/22/17	9:36	38.39647	-120.47274	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101251777	Unknown	12,000	Conductor	Overhead	Yes	6/22/17	9:36
1189	PG&E	06/22/17	16:30	39.61307	-121.68724	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	100347529	None	12,000	Conductor	Overhead	Yes	6/22/17	16:30
1190	PG&E	06/22/17	18:07	38.75831	-120.71764	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101401088	Unknown	12,000	Conductor	Overhead	Yes	6/22/17	18:07
1191	PG&E	06/22/17	19:29	35.58886	-120.66910	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101912249	Unknown	21,000	Conductor	Overhead	Yes	6/22/17	19:29
1192	PG&E	06/23/17	13:00	39.30510	-122.48618	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	100329817	Unknown	0 - 750	Conductor	Overhead	Yes	6/23/17	13:00
1193	PG&E	06/23/17	20:09	40.38565	-122.28408	Vegetation	Urban	< 0.25 Acres	Fire Agency	kieth foster 530-347-4737	101050644	Unknown	12,000	Conductor	Overhead	Yes	6/23/17	20:09
1194	PG&E	06/23/17	19:23	39.78294	-121.86700	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100397376	None	12,000	Conductor	Overhead	Yes	6/23/17	19:23
1195	PG&E	06/24/17	10:31	38.94379	-121.04466	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100909318	PACIFIC BELL	12,000	Transformer	Overhead	Yes	6/24/17	10:31
1196	PG&E	06/24/17	14:51	38.36218	-120.76381	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101255656	Unknown	12,000	Fuse	Overhead	Yes	6/24/17	14:51
1197	PG&E	06/24/17	22:27	38.29083	-120.84900	Vegetation	Rural	10 - 99 Acres	Fire Agency	CONTACT BOBBY BOWMAN	101238865	None	12,000	Conductor	Overhead	Yes	6/24/17	22:27
1198	PG&E	06/25/17	18:18	37.32357	-120.55914	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101159230	Unknown	12,000	Conductor	Overhead	Yes	6/25/17	0.7625
1199	PG&E	06/25/17	0:23	39.40434	-123.38687	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	102193088	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/25/17	0.23
1200	PG&E	06/25/17	6:02	39.07743	-121.52937	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101314125	Unknown	12,000	Conductor	Overhead	Yes	6/25/17	6:02
1201	PG&E	06/25/17	15:37	34.93950	-119.69246	Vegetation	Rural	100 - 299 Acres	Fire Agency	805-686-5074	101019652	None	12,000	Conductor	Overhead	Yes	6/25/17	15:37
1202	PG&E	06/25/17	22:14	39.02503	-121.57873	Vegetation	Rural	< 3 Meters	Fire Agency	Olivehurst FD	101314072	Unknown	21,000	Conductor	Overhead	Yes	6/25/17	22:14
1203	PG&E	06/26/17	8:18	37.27331	-120.52573	Vegetation	Rural	< 0.25 Acres	Self Extinguished		103218794	Unknown	12,000	Conductor	Overhead	Yes	6/26/17	8:18
1204	PG&E	06/26/17	14:29	35.87817	-120.11694	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	MANNAGIN 559 386 555	103439376	Unknown	21,000	Conductor	Overhead	Yes	6/26/17	14:29
1205	PG&E	06/27/17	9:27	37.65588	-122.61762	Vegetation	Rural	10 - 99 Acres	Fire Agency	marin county fire	102280068	UNFILED	12,000	Conductor	Overhead	Yes	6/27/17	9:23
1206	PG&E	06/27/17	17:47	39.51284	-122.20333	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100341056	None	21,000	Conductor	Overhead	Yes	6/27/17	17:47
1207	PG&E	06/28/17	09:57	35.90555	-120.84214	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	101765453	Unknown	12,000	Conductor	Overhead	No		
1208	PG&E	06/28/17	13:09	34.92757	-119.62041	Building	Rural	Structure Only	Fire Agency	(805)683-2724	100190548	Unknown	21,000	Conductor	Overhead	Yes	6/28/17	13:09
1209	PG&E	06/29/17	18:31	38.44450	-122.89990	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	102021185	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	6/29/17	18:31
1210	PG&E	06/29/17	21:55	35.98040	-121.09557	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	103312369	Unknown	12,000	Transformer	Overhead	Yes	6/29/17	21:55
1211	PG&E	06/30/17	10:24	39.02621	-121.54317	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101341770	Unknown	21,000	Conductor	Overhead	Yes	6/30/17	10:24
1212	PG&E	06/30/17	01:20	39.82098	-121.58834	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103840463	YES	12,000	Conductor	Overhead	Yes	6/30/17	01:20
1213	PG&E	06/30/17	23:54	38.57941	-122.88349	Vegetation	Rural	< 3 Meters	Customer	N.A.	101958804	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/30/17	23:54
1214	PG&E	07/01/17	12:02	38.82093	-121.64183	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	Pole 003/039	Unknown	60,000	Conductor	Overhead	Yes	7/1/17	12:02
1215	PG&E	07/01/17	3:54	36.99950	-119.97648	Vegetation	Rural	< 0.25 Acres	Fire Agency	2099663621	101015895	Unknown	0 - 750	Conductor	Overhead	Yes	7/1/17	3:54
1216	PG&E	07/01/17	3:12	38.19517	-122.91971	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103855493	Unknown	12,000	Conductor	Overhead	Yes	7/1/17	3:12
1217	PG&E	07/01/17	10:41	39.27788	-121.68748	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101294919	Unknown	12,000	Other	Overhead	Yes	7/1/17	10:41
1218	PG&E	07/02/17	13:28	39.86055	-121.62736	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	Pole 000/017c	Unknown	60,000	Conductor	Overhead	Yes	7/2/17	13:28
1219	PG&E	07/02/17	3:49	36.95878	-120.89268	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101205043	Unknown	12,000	Conductor	Overhead	Yes	7/2/17	3:49
1220	PG&E	07/03/17	20:26	38.79229	-120.94384	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101388730	PACIFIC BELL	21,000	Conductor	Overhead	Yes	7/3/17	20:26
1221	PG&E	07/04/17	13:56	40.39303	-122.31503	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	101506140	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/4/17	13:56
1222	PG&E	07/04/17	16:16	38.97628	-121.13185	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100050181	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	7/4/17	16:16
1223	PG&E	07/04/17	20:16	40.42283	-122.39748	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	SCOTT CORN 530-448-2414	101481860	Unknown	0 - 750	Conductor	Overhead	Yes	7/4/17	20:16
1224	PG&E	07/05/17	3:25	38.68451	-121.01176	Vegetation	Urban	< 0.25 Acres	Fire Agency	JUSTIN RHAMES	101380157	PACIFIC BELL	21,000	Fuse	Overhead	Yes	7/5/17	3:25
1225	PG&E	07/05/17	11:58	39.21046	-121.22662	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	STEVE ROBERTSON 530 906 4892	100010286	Unknown	21,000	Conductor	Overhead	Yes	7/5/17	11:58
1226	PG&E	07/05/17	20:54	35.68475	-120.10996	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	661-324-6551 LOG325962	100171224	Unknown	21,000	Capacitor Bank	Overhead	No		
1227	PG&E	07/06/17	15:18	36.74020	-119.76128	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	100864107	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	7/6/17	15:18
1228	PG&E	07/06/17	14:02	39.														

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
2	Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ionization	Type	Was There an Outage	Date	Time
1246	PG&E	07/11/17	22:12	37.01217	-121.94972	Vegetation	Rural	< 3 Meters	Fire Agency	CAPT PHIL CRAMBLET 831-479-6842	101676689	PACIFIC BELL	21,000	Conductor	Overhead	Yes	7/11/17	22:12
1247	PG&E	07/12/17	16:04	40.65308	-122.33429	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	Structure 000/001	Unknown	60,000	Conductor	Overhead	Yes	7/12/17	16:04
1248	PG&E	07/12/17	05:51	38.39320	-121.80440	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101584920	Unknown	12,000	Conductor	Overhead	Yes	7/12/17	05:51
1249	PG&E	07/12/17	10:48	36.96254	-122.04632	Other	Urban	< 0.25 Acres	Fire Agency	Barbara Riley 661-5499 ext. 2	103222654	None	0 - 750	Conductor	Overhead	Yes	7/12/17	10:48
1250	PG&E	07/12/17	15:09	37.14908	-122.00371	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	103565794	Unknown	21,000	Conductor	Overhead	Yes	7/12/17	15:09
1251	PG&E	07/12/17	20:21	40.08083	-123.83389	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	103841917	Unknown	12,000	Conductor	Overhead	Yes	7/12/17	20:21
1252	PG&E	07/13/17	5:13	38.12011	-122.18577	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	Tower 025/173	Unknown	115,000	Conductor	Overhead	Yes	7/13/17	5:13
1253	PG&E	07/13/17	07:43	39.40638	-122.12630	Vegetation	Rural	< 3 Meters	Fire Agency	AXS-N/A FIRE NEAR POLE PER FD. NO STDBY. WANT CHECK OF POLE 530-458-0200	100406386	None	0 - 750	Conductor	Overhead	Yes	7/13/17	07:43
1254	PG&E	07/13/17	19:29	36.85038	-119.54996	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	chis waters bat.chief 559-281-4308	100728986	Unknown	0 - 750	Conductor	Overhead	No	7/14/17	17:54
1255	PG&E	07/14/17	17:54	37.70950	-121.29210	Vegetation	Rural	< 0.25 Acres	Fire Agency	TRACY	102070196	Unknown	12,000	Conductor	Overhead	Yes	7/14/17	17:54
1256	PG&E	07/15/17	14:34	39.62313	-121.53281	Vegetation	Rural	< 0.25 Acres	Fire Agency	russ fowler	100404385	Unknown	12,000	Conductor	Overhead	Yes	7/15/17	14:34
1257	PG&E	07/15/17	14:56	37.30740	-122.03550	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100538519	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	7/15/17	14:56
1258	PG&E	07/15/17	20:16	39.45902	-121.53134	Vegetation	Rural	< 3 Meters	Fire Agency	oroville station	100429093	Unknown	12,000	Conductor	Overhead	Yes	7/15/17	20:16
1259	PG&E	07/15/17	21:01	38.21284	-121.83399	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	101658237	Unknown	21,000	Conductor	Overhead	Yes	7/15/17	21:01
1260	PG&E	07/16/17	10:39	40.34139	-123.87861	Vegetation	Rural	< 3 Meters	Fire Agency	707-726-1280	100990019	Unknown	12,000	Conductor	Overhead	Yes	7/16/17	10:39
1261	PG&E	07/16/17	11:59	36.66692	-121.75148	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101761892	None	21,000	Fuse	Overhead	Yes	7/16/17	11:59
1262	PG&E	07/16/17	12:10	35.66129	-120.92200	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	101942626	Unknown	21,000	Conductor	Overhead	Yes	7/16/17	12:10
1263	PG&E	07/16/17	17:07	37.34415	-122.03630	Vegetation	Urban	< 3 Meters	Fire Agency	sunnyside fire	100532224	PACIFIC BELL	0 - 750	Transformer	Overhead	Yes	7/16/17	17:07
1264	PG&E	07/17/17	07:39	40.18532	-122.22279	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101943908	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/17/17	07:39
1265	PG&E	07/17/17	10:00	35.95905	-120.95152	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101765495	Unknown	12,000	Conductor	Overhead	Yes	7/17/17	10:00
1266	PG&E	07/17/17	18:58	38.88853	-121.98984	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Dunnigan Fire Dept	101602815	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/17/17	18:58
1267	PG&E	07/18/17	11:30	38.04843	-120.55653	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	Structure 012/071	Unknown	115,000	Conductor	Overhead	Yes	7/18/17	11:30
1268	PG&E	07/18/17	21:40	38.00311	-122.20926	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	Pole 000/002 to 000/003	Unknown	80,000	Conductor	Overhead	Yes	7/18/17	21:40
1269	PG&E	07/18/17	07:39	38.07038	-120.54518	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101269434	Unknown	0 - 750	Other	Overhead	Yes	7/18/17	07:39
1270	PG&E	07/18/17	11:45	36.83081	-119.86228	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100624764	PACIFIC BELL	21,000	Capacitor Bank	Overhead	Yes	7/18/17	11:45
1271	PG&E	07/19/17	5:52	37.09047	-119.60469	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	Tower 003/001	Unknown	115,000	Conductor	Overhead	Yes	7/19/17	5:52
1272	PG&E	07/19/17	09:33	35.34462	-118.86086	Vegetation	Rural	< 3 Meters	Unknown	N.A.	100159158	Unknown	12,000	Capacitor Bank	Overhead	Yes	7/19/17	09:33
1273	PG&E	07/19/17	17:19	39.41242	-123.81234	Vegetation	Rural	< 0.25 Acres	Fire Agency	DRUE RHOADS 707 964 5673	102201550	YES	12,000	Conductor	Overhead	Yes	7/19/17	17:19
1274	PG&E	07/20/17	20:57	37.73609	-122.49208	Building	Urban	Structure Only	Unknown	N.A.	101813719	Unknown	0 - 750	Conductor	Overhead	Yes	7/20/17	20:57
1275	PG&E	07/20/17	01:46	36.52545	-119.68200	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100830639	Unknown	0 - 750	Lightning Arrestor	Overhead	Yes	7/20/17	01:46
1276	PG&E	07/20/17	04:27	38.06420	-120.87106	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	chris costales 209 754 2735	102142834	Unknown	12,000	Conductor	Overhead	Yes	7/20/17	04:27
1277	PG&E	07/20/17	13:45	35.08036	-120.55383	Vegetation	Rural	10 - 99 Acres	Fire Agency	PAUL LEE 805 903-3416 INC # 8291	101941116	Unknown	12,000	Conductor	Overhead	Yes	7/20/17	13:45
1278	PG&E	07/20/17	17:00	37.92651	-121.23203	Vegetation	Urban	< 3 Meters	Customer	N.A.	103384380	PACIFIC BELL	12,000	Capacitor Bank	Overhead	Yes	7/20/17	17:00
1279	PG&E	07/21/17	13:27	38.26854	-120.93718	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	102145524	Unknown	12,000	Conductor	Overhead	Yes	7/21/17	13:27
1280	PG&E	07/21/17	20:26	41.06550	-121.39320	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101549629	Unknown	12,000	Conductor	Overhead	Yes	7/21/17	20:26
1281	PG&E	07/22/17	12:25	40.87950	-123.76380	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Josh , comander chief of forest service	100980577	Unknown	12,000	Conductor	Overhead	Yes	7/22/17	12:25
1282	PG&E	07/22/17	14:38	37.29945	-122.16306	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	100265488	Unknown	12,000	Conductor	Overhead	Yes	7/22/17	14:38
1283	PG&E	07/22/17	16:01	40.83143	-124.05389	Vegetation	Rural	< 0.25 Acres	Fire Agency	BATTALION CHIEF CURT WATKINS, 707-825 2000	100983827	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/22/17	16:01
1284	PG&E	07/23/17	09:22	40.64201	-122.23025	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAPT?	101459708	FRONTIER COMM	12,000	Conductor	Overhead	Yes	7/23/17	09:22
1285	PG&E	07/23/17	16:32	36.24055	-119.81283	Vegetation	Rural	< 0.25 Acres	Fire Agency	Brandon Jones (559) 852-2884	100783832	Unknown	12,000	Conductor	Overhead	Yes	7/23/17	16:32
1286	PG&E	07/23/17	18:25	39.67233	-123.53360	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	103823226	Unknown	12,000	Conductor	Overhead	Yes	7/23/17	18:25
1287	PG&E	07/23/17	19:41	36.21714	-119.90973	Vegetation	Rural	< 0.25 Acres	Fire Agency	Brandon Jones (559) 852-2884	103846605	Unknown	12,000	Conductor	Overhead	Yes	7/23/17	19:41
1288	PG&E	07/24/17	14:01	37.26349	-122.33643	Vegetation	Rural	< 0.25 Acres	Fire Agency	mike klink 650-879-0121	100322130	Unknown	0 - 750	Conductor	Overhead	Yes	7/24/17	14:01
1289	PG&E	07/24/17	16:07	37.25369	-121.96760	Vegetation	Urban	< 0.25 Acres	Fire Agency	C1702050039	103447162	Unknown	0 - 750	Conductor	Overhead	Yes	7/24/17	16:07
1290	PG&E	07/24/17	19:31	38.35192	-120.71029	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	1021263632	Unknown	12,000	Conductor	Overhead	Yes	7/24/17	19:31
1291	PG&E	07/24/17	21:45	35.60243	-120.92107	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	101860186	Unknown	12,000	Conductor	Overhead	Yes	7/24/17	21:45
1292	PG&E	07/25/17	15:51	38.37795	-122.53878	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	102031447	Unknown	12,000	Conductor	Overhead	Yes	7/25/17	15:51
1293	PG&E	07/25/17	19:12	39.59970	-121.44490	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100403612	Unknown	12,000	Conductor	Overhead	Yes	7/25/17	19:12
1294	PG&E	07/26/17	06:55	36.78124	-119.75525	Vegetation	Urban	< 3 Meters	Fire Agency	FRESNO FIRE, BATALION 1, FULMER 559 993 2661	100866522	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/26/17	06:55
1295	PG&E	07/28/17	14:02	40.99973	-121.95793	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	101512624	Unknown	12,000	Conductor	Overhead	Yes	7/28/17	14:02
1296	PG&E	07/28/17	16:57	35.47270	-120.99080	Vegetation	Rural	10 - 99 Acres	Fire Agency	TOM MCEWEN 805-903-3409	101933868	Unknown	12,000	Conductor	Overhead	Yes	7/28/17	16:57
1297	PG&E	07/28/17	19:20	35.72756	-120.99030	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	San Luis Obispo CDF	101945498	None	21,000	Conductor	Overhead	Yes	7/28/17	19:20
1298	PG&E	07/29/17	13:18	39.46313	-121.45951	Vegetation	Rural	< 0.25 Acres	Fire Agency	russ fowler 530 521 8056	103846763	Unknown	12,000	Conductor	Overhead	Yes	7/29/17	13:18
1299	PG&E	07/29/17	13:28	35.45229	-120.38344	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101895156	Unknown	0 - 750	Conductor	Overhead	Yes	7/29/17	13:28
1300	PG&E	07/29/17	14:52	37.05999	-122.00113	Vegetation	Urban	< 0.25 Acres	Fire Agency	Scotts Valley Fire Dept.	101679068	PACIFIC BELL	21,000	Conductor	Overhead	Yes	7/29/17	14:52
1301	PG&E	07/29/17	17:56	37.02507	-121.53583	Vegetation	Rural	< 3 Meters	Fire Agency	GEORGE MARSHALL	100610842	Unknown	21,000	Conductor	Overhead	Yes	7/29/17	17:56
1302	PG&E	07/29/17	18:08	37.94875	-121.34571	Vegetation	Rural	< 0.25 Acres	Fire Agency	911	102126507	Unknown	12,000	Conductor	Overhead	Yes	7/29/17	18:08
1303	PG&E	07/29/17	20:45	35.45171	-120.61711	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	101941008	Unknown	0 - 750	Conductor	Overhead	Yes	7/29/17	20:45
1304	PG&E	07/30/17	09:46	38.91318	-122.61788	Vegetation	Rural	< 0.25 Acres	Fire Agency	mike wink	102151066	None	0 - 750	Conductor	Overhead	Yes	7/30/17	09:46
1305	PG&E	07/31/17	12:58	37.09707	-122.27965	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101679025	Unknown	0 - 750	Conductor	Overhead	No	7/31/17	14:10
1306	PG&E	07/31/17	14:10	35.97865	-120.11100	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	100695130	Unknown	21,000	Conductor	Overhead	Yes	7/31/17	14:10
1307	PG&E	07/31/17	14:41	38.79675	-121.13288	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	103782414	Unknown	12,000	Conductor	Overhead	Yes	7/31/17	14:41
1308	PG&E	08/01/17	12:23	36.04123	-119.50529	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.								

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Column5	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
2	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin												
1320	PG&E	08/05/17	18:08	39.09683	-123.21466	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	102196629	Unknown	12,000	Conductor	Overhead	Yes	8/5/17	18:08
1321	PG&E	08/05/17	18:09	36.96750	-120.08993	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	Unknown	101136476	Unknown	12,000	Conductor	Overhead	Yes	8/5/17	18:09
1322	PG&E	08/05/17	19:21	36.76912	-119.61010	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100725102	Unknown	12,000	Other	Overhead	Yes	8/5/17	19:21
1323	PG&E	08/06/17	11:38	36.58574	-121.71213	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101747125	Unknown	12,000	Conductor	Overhead	Yes	8/6/17	11:38
1324	PG&E	08/06/17	18:21	40.60120	-122.23480	Vegetation	Rural	< 3 Meters	Fire Agency	17CASH4007992	101470083	Unknown	12,000	Other	Overhead	Yes	8/6/17	18:21
1325	PG&E	08/08/17	13:46	38.43664	-122.72596	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	Tower 005/090	None	115,000	Conductor	Overhead	Yes	8/8/17	13:46
1326	PG&E	08/08/17	0:36	35.42680	-119.05719	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100167715	PACIFIC BELL	12,000	Unknown	Subsurface	Yes	8/8/17	0:36
1327	PG&E	08/08/17	4:10	38.44985	-122.66849	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	102025742	PACIFIC BELL	12,000	Transformer	Overhead	Yes	8/8/17	4:10
1328	PG&E	08/08/17	11:27	37.04448	-121.63431	Vegetation	Urban	< 3 Meters	Utility, PG&E	N.A.	100613200	VERIZON CALIF	21,000	Capacitor Bank	Overhead	Yes	8/8/17	11:27
1329	PG&E	08/08/17	20:35	37.26367	-119.71027	Vegetation	Rural	< 0.25 Acres	Fire Agency	TROY CREEK1-209-966-3621	103793352	Unknown	0 - 750	Conductor	Overhead	Yes	8/8/17	20:35
1330	PG&E	08/09/17	11:29	38.65323	-120.62732	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	101402496	PACIFIC BELL	21,000	Conductor	Overhead	Yes	8/9/17	11:29
1331	PG&E	08/11/17	07:55	38.26485	-120.97476	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101253880	None	12,000	Conductor	Overhead	Yes	8/11/17	07:55
1332	PG&E	08/12/17	09:08	38.42680	-120.02860	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103391912	Unknown	12,000	Conductor	Overhead	Yes	8/12/17	09:08
1333	PG&E	08/13/17	13:11	38.50939	-122.77004	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	101961046	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/13/17	13:11
1334	PG&E	08/14/17	6:14	40.11642	-123.80645	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	100986364	Unknown	12,000	Conductor	Overhead	Yes	8/14/17	6:14
1335	PG&E	08/14/17	23:52	37.12721	-122.16895	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	Pole 015/127	None	60,000	Conductor	Overhead	Yes	8/14/17	23:52
1336	PG&E	08/14/17	07:56	39.17938	-120.97608	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100083743	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/14/17	07:56
1337	PG&E	08/15/17	19:28	39.50371	-121.27826	Vegetation	Rural	< 3 Meters	Unknown	N.A.	100396172	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/15/17	19:28
1338	PG&E	08/16/17	20:24	35.78134	-119.91533	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	Span 06 to 0/7	None	70,000	Conductor	Overhead	Yes	8/16/17	20:24
1339	PG&E	08/17/17	2:33	39.19342	-121.42271	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101304315	Unknown	12,000	Conductor	Overhead	Yes	8/17/17	2:33
1340	PG&E	08/17/17	15:15	39.37033	-121.04842	Vegetation	Rural	< 0.25 Acres	Fire Agency	PHIL MICHAEL 265-2894	100083029	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/17/17	15:15
1341	PG&E	08/18/17	17:09	37.09214	-121.66909	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100608897	VERIZON CALIF	21,000	Conductor	Overhead	Yes	8/18/17	17:09
1342	PG&E	08/19/17	11:31	37.68910	-121.05060	Vegetation	Rural	< 0.25 Acres	Unknown	Unknown	102253834	Unknown	17,000	Conductor	Overhead	Yes	8/19/17	11:31
1343	PG&E	08/19/17	21:16	40.57523	-122.29847	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101464623	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/19/17	21:16
1344	PG&E	08/20/17	11:38	39.27638	-122.14067	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101634861	Unknown	12,000	Conductor	Overhead	Yes	8/20/17	11:38
1345	PG&E	08/21/17	15:07	38.60798	-122.35312	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Aaron Latta 707 339 2918	102254922	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	8/21/17	15:07
1346	PG&E	08/21/17	19:31	39.72577	-121.82052	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100341323	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/21/17	19:31
1347	PG&E	08/22/17	14:17	38.49020	-122.89178	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	102001687	Unknown	0 - 750	Conductor	Overhead	Yes	8/22/17	14:17
1348	PG&E	08/24/17	6:32	36.59050	-119.59286	Vegetation	Rural	< 3 Meters	Fire Agency	ca fku 012333	100897456	Unknown	12,000	Conductor	Overhead	Yes	8/24/17	6:32
1349	PG&E	08/25/17	9:47	39.02509	-121.57752	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101314075	Unknown	21,000	Conductor	Overhead	Yes	8/25/17	9:47
1350	PG&E	08/26/17	7:10	38.82516	-121.39528	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100101888	Unknown	0 - 750	Conductor	Overhead	Yes	8/26/17	7:10
1351	PG&E	08/26/17	20:39	38.47073	-122.64717	Vegetation	Urban	< 3 Meters	Fire Agency	Santa Rosa Fire Dept	101966474	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/26/17	20:39
1352	PG&E	08/26/17	20:53	38.70657	-121.01929	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101382231	Unknown	0 - 750	Conductor	Overhead	Yes	8/26/17	20:53
1353	PG&E	08/27/17	18:11	37.99158	-121.34788	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	Unknown	103193823	Unknown	21,000	Conductor	Overhead	Yes	8/27/17	18:11
1354	PG&E	08/27/17	20:04	38.91654	-121.15100	Vegetation	Rural	< 0.25 Acres	Fire Agency	530-477-0641 x7, log 22629	100077184	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/27/17	20:04
1355	PG&E	08/27/17	22:16	37.35848	-120.85030	Vegetation	Rural	< 0.25 Acres	Fire Agency	CHRIS ALLEN 209-634-7086	103346364	Unknown	12,000	Conductor	Overhead	Yes	8/27/17	22:16
1356	PG&E	08/28/17	6:32	35.42183	-119.03040	Vegetation	Urban	< 0.25 Acres	Fire Agency	BCFD/KCFD 661-324-6551	103139674	Unknown	0 - 750	Conductor	Overhead	Yes	8/28/17	6:32
1357	PG&E	08/28/17	8:36	35.72450	-119.53414	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	100171751	Unknown	12,000	Conductor	Overhead	Yes	8/28/17	8:36
1358	PG&E	08/28/17	9:14	38.74430	-122.64906	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	103781065	Unknown	0 - 750	Conductor	Overhead	Yes	8/28/17	9:14
1359	PG&E	08/28/17	10:07	38.04720	-120.78589	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	FORESTHILL	100019525	Unknown	12,000	Conductor	Overhead	Yes	8/28/17	10:07
1360	PG&E	08/28/17	13:55	37.68570	-120.80670	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	102237313	None	0 - 750	Conductor	Overhead	Yes	8/28/17	13:55
1361	PG&E	08/28/17	14:06	38.63402	-122.41945	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	102253236	Unknown	21,000	Conductor	Overhead	Yes	8/28/17	14:06
1362	PG&E	08/28/17	14:23	38.50540	-120.75916	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101260228	PACIFIC BELL	12,000	Fuse	Overhead	Yes	8/28/17	14:23
1363	PG&E	08/28/17	14:59	40.28528	-123.87278	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	100905099	Unknown	12,000	Conductor	Overhead	Yes	8/28/17	14:59
1364	PG&E	08/28/17	23:56	40.11971	-123.64400	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	103844288	Unknown	12,000	Conductor	Overhead	Yes	8/28/17	23:56
1365	PG&E	08/29/17	6:08	38.23650	-122.46080	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101989898	Unknown	12,000	Conductor	Overhead	Yes	8/29/17	6:08
1366	PG&E	08/29/17	10:27	38.36871	-122.00121	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	101661402	PACIFIC BELL	12,000	Lightning Arrestor	Overhead	Yes	8/29/17	10:27
1367	PG&E	08/29/17	10:40	38.20657	-121.15763	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102082031	Unknown	12,000	Conductor	Overhead	Yes	8/29/17	10:40
1368	PG&E	08/29/17	12:49	37.45070	-119.64538	Vegetation	Rural	> 5000 Acres	Fire Agency	USFS	101017368	Unknown	12,000	Conductor	Overhead	Yes	8/29/17	12:49
1369	PG&E	08/29/17	15:54	38.30196	-122.54314	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	102026119	PACIFIC BELL	12,000	Fuse	Overhead	Yes	8/29/17	15:54
1370	PG&E	08/30/17	16:17	35.35283	-119.05377	Vegetation	Urban	< 0.25 Acres	Fire Agency	BCFD/KCFD 661-324-6551	100145828	Unknown	0 - 750	Conductor	Overhead	Yes	8/30/17	16:17
1371	PG&E	08/30/17	18:21	40.62430	-122.30386	Vegetation	Rural	< 0.25 Acres	Fire Agency	CASHU008896	103151338	YES	12,000	Conductor	Overhead	Yes	8/30/17	18:21
1372	PG&E	08/30/17	22:37	38.99933	-120.98871	Vegetation	Rural	< 3 Meters	Fire Agency	Andy 530-889-0111	100206238	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/30/17	22:37
1373	PG&E	08/30/17	22:39	38.16621	-121.93815	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	suisun	103850994	Unknown	12,000	Conductor	Overhead	Yes	8/30/17	22:39
1374	PG&E	08/31/17	6:42	35.61599	-120.85770	Vegetation	Rural	< 0.25 Acres	Fire Agency	Derrick	101860075	Unknown	21,000	Conductor	Overhead	Yes	8/31/17	6:42
1375	PG&E	08/31/17	11:33	37.13786	-121.99658	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100519201	Unknown	21,000	Conductor	Overhead	Yes	8/31/17	11:33
1376	PG&E	08/31/17	11:51	38.39169	-122.31951	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	102231943	PACIFIC BELL	21,000	Conductor	Overhead	Yes	8/31/17	11:51
1377	PG&E	08/31/17	21:07	41.06048	-124.10377	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100977438	Unknown	12,000	Conductor	Overhead	Yes	8/31/17	21:07
1378	PG&E	08/31/17	22:50	36.81501	-119.77632	Vegetation	Urban	< 3 Meters	Customer	N.A.	100851402	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	8/31/17	22:50
1379	PG&E	09/01/17	6:09	36.19499	-120.70786	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101705717	Unknown	12,000	Fuse	Overhead	Yes	9/1/17	6:09
1380	PG&E	09/01/17	8:00	37.37567	-119.88862	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101067028	Unknown	0 - 750	Conductor	Overhead	Yes	9/1/17	8:00
1381	PG&E	09/01/17	12:07	40.59381	-124.13596	Vegetation	Rural	< 3 Meters	Fire Agency	DISPATCH FIRE 707-725-7550	100993250	PACIFIC BELL	12,000	Lightning Arrestor	Overhead	No	9/1/17	12:07
1382	PG&E	09/01/17	12:52	37.16670	-121.70690	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100601982	VERIZON CALIF	21,000	Conductor	Overhead	Yes		

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Report Data Compiled from 2014-2019

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Column5	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
2	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	
1402	PG&E	09/06/17	20:08	37.29255	-122.29403	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100256917	Unknown	12,000	Conductor	Overhead	Yes	9/6/17	20:08
1403	PG&E	09/08/17	4:47	38.74778	-120.85905	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101391575	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/8/17	4:47
1404	PG&E	09/08/17	17:21	38.60388	-120.92748	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101379094	PACIFIC BELL	21,000	Conductor	Overhead	Yes	9/8/17	17:21
1405	PG&E	09/08/17	21:14	37.96038	-120.37636	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	John Lite 209-984-5623	101042521	Unknown	17,000	Conductor	Overhead	Yes	9/8/17	21:14
1406	PG&E	09/09/17	18:36	38.66181	-121.54766	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101768980	Unknown	12,000	Conductor	Overhead	Yes	9/9/17	18:36
1407	PG&E	09/10/17	1:22	39.22598	-121.49023	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	TYLER LOPEZ	101289867	None	12,000	Conductor	Overhead	Yes	9/10/17	1:22
1408	PG&E	09/10/17	16:30	37.30393	-120.92747	Vegetation	Rural	10 - 99 Acres	Fire Agency	Merced County FD	101163116	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/10/17	16:30
1409	PG&E	09/11/17	7:18	37.00083	-121.66674	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100621936	VERIZON CALIFO	0 - 750	Conductor	Overhead	No		
1410	PG&E	09/11/17	8:50	38.95146	-121.84204	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	101780954	PACIFIC BELL	21,000	Fuse	Overhead	Yes	9/11/17	8:50
1411	PG&E	09/11/17	23:50	40.86724	-124.08827	Vegetation	Urban	< 3 Meters	Fire Agency	BOB	100964579	Unknown	12,000	Conductor	Overhead	Yes	9/11/17	23:50
1412	PG&E	09/12/17	9:24	39.74095	-121.60787	Vegetation	Rural	< 0.25 Acres	Fire Agency	911	100330302	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/12/17	9:24
1413	PG&E	09/12/17	17:18	39.45106	-121.60519	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	tom klage 530 538-7888	100419482	Unknown	12,000	Conductor	Overhead	Yes	9/12/17	17:18
1414	PG&E	09/14/17	11:02	39.11112	-121.55647	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101320308	None	12,000	Switch	Overhead	Yes	9/14/17	11:02
1415	PG&E	09/14/17	12:09	39.50393	-121.54528	Vegetation	Urban	< 0.25 Acres	Fire Agency	530-538-2448	100372805	Unknown	12,000	Conductor	Overhead	Yes	9/14/17	12:09
1416	PG&E	09/14/17	14:06	40.29421	-123.81736	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100989497	Unknown	12,000	Conductor	Overhead	Yes	9/14/17	14:06
1417	PG&E	09/15/17	14:55	39.74607	-121.48853	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100335239	Unknown	12,000	Conductor	Overhead	Yes	9/15/17	14:55
1418	PG&E	09/17/17	15:05	38.64729	-119.38613	Vegetation	Rural	< 3 Meters	Customer	N.A.	100738741	VERIZON CALIFO	0 - 750	Conductor	Overhead	Yes	9/17/17	15:05
1419	PG&E	09/17/17	17:38	38.99459	-121.02607	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100209537	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/17/17	17:38
1420	PG&E	09/18/17	13:01	39.38885	-121.40538	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	103795057	Unknown	0 - 750	Conductor	Overhead	Yes	9/18/17	13:01
1421	PG&E	09/18/17	15:10	39.60135	-122.05551	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	103849874	Unknown	12,000	Conductor	Overhead	Yes	9/18/17	15:10
1422	PG&E	09/18/17	18:01	38.21975	-122.54300	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101997149	Unknown	12,000	Conductor	Overhead	Yes	9/18/17	18:01
1423	PG&E	09/18/17	19:01	38.07423	-122.82861	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102292215	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/18/17	19:01
1424	PG&E	09/18/17	23:50	37.90879	-120.48652	Vegetation	Rural	10 - 99 Acres	Fire Agency	incident commander geoff marshall 209-419-4407	101040882	Unknown	17,000	Conductor	Overhead	Yes	9/18/17	23:50
1425	PG&E	09/19/17	19:13	35.47836	-119.29591	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	10207112	Unknown	12,000	Conductor	Overhead	Yes	9/19/17	19:13
1426	PG&E	09/20/17	2:06	37.25988	-122.32223	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100322388	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/20/17	2:06
1427	PG&E	09/20/17	8:41	38.94037	-120.90142	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	Pole 26 - Arbunua Tap	None	70,000	Conductor	Overhead	Yes	9/20/17	8:41
1428	PG&E	09/21/17	8:39	39.61470	-121.72582	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	100347380	Unknown	0 - 750	Conductor	Overhead	Yes	9/21/17	8:39
1429	PG&E	09/22/17	14:28	36.09612	-120.05766	Vegetation	Rural	< 0.25 Acres	Fire Agency	SAME AS TAG. FD NOT STANDING BY UPON ARRIVAL	100663084	Unknown	12,000	Capacitor Bank	Overhead	No		
1430	PG&E	09/23/17	9:16	37.01267	-120.62562	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101181497	Unknown	12,000	Conductor	Overhead	Yes	9/23/17	9:16
1431	PG&E	09/23/17	14:17	40.65090	-122.29740	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	DARREN STEWART 448-2421	101467221	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/23/17	14:17
1432	PG&E	09/24/17	2:13	38.10460	-120.98901	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	Pole 016/297	Unknown	60,000	Conductor	Overhead	Yes	9/24/17	2:13
1433	PG&E	09/24/17	7:54	37.40144	-122.02740	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100515206	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/24/17	7:54
1434	PG&E	09/24/17	16:42	38.38690	-122.96670	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	DOUG JONES	101973946	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/24/17	16:42
1435	PG&E	09/25/17	19:49	36.81370	-121.72098	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	Tower 058/249	Unknown	230,000	Conductor	Overhead	Yes	9/25/17	19:49
1436	PG&E	09/26/17	17:44	38.06427	-122.80563	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	102228291	Unknown	12,000	Other	Overhead	Yes	9/26/17	17:44
1437	PG&E	09/27/17	9:11	39.01626	-122.86854	Vegetation	Rural	< 3 Meters	Customer	N.A.	102143577	PACIFIC BELL	12,000	Transformer	Overhead	Yes	9/27/17	9:11
1438	PG&E	09/27/17	12:12	38.48450	-121.35450	Vegetation	Rural	< 0.25 Acres	Fire Agency	bill lopez cell 530 521-8052	100429924	PACIFIC BELL	12,000	Fuse	Overhead	Yes	9/27/17	12:12
1439	PG&E	09/27/17	19:06	40.75920	-123.89500	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	103605812	Unknown	12,000	Conductor	Overhead	Yes	9/27/17	19:06
1440	PG&E	09/28/17	18:28	39.88840	-122.06700	Vegetation	Urban	< 3 Meters	Fire Agency	15101374-7070	103621905	Unknown	21,000	Conductor	Overhead	Yes	9/28/17	18:28
1441	PG&E	09/29/17	2:01	39.53714	-122.18567	Vegetation	Urban	< 3 Meters	Unknown	N.A.	100419384	Unknown	21,000	Transformer	Padmounted	Yes	9/29/17	2:01
1442	PG&E	09/30/17	15:08	37.41091	-121.17474	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	Tower 030/132	None	230,000	Conductor	Overhead	Yes	9/30/17	15:08
1443	PG&E	10/01/17	7:24	37.91400	-122.37710	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101437028	Unknown	12,000	Transformer	Overhead	Yes	10/1/17	7:24
1444	PG&E	10/01/17	16:11	39.79696	-122.11853	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103850270	Unknown	0 - 750	Conductor	Overhead	Yes	10/1/17	16:11
1445	PG&E	10/01/17	23:51	40.01920	-122.14520	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	MARK FRITZ	101534592	Unknown	12,000	Conductor	Overhead	Yes	10/1/17	23:51
1446	PG&E	10/02/17	2:55	37.33137	-120.52428	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	209-966-3621	101160137	Unknown	12,000	Conductor	Overhead	Yes	10/2/17	2:55
1447	PG&E	10/02/17	7:07	38.29490	-122.10660	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101658181	Unknown	0 - 750	Transformer	Overhead	Yes	10/2/17	7:07
1448	PG&E	10/02/17	12:22	39.63135	-122.00685	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	103224422	Unknown	12,000	Conductor	Overhead	Yes	10/2/17	12:22
1449	PG&E	10/02/17	14:56	38.91023	-120.91853	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	100110800	None	21,000	Other	Overhead	Yes	10/2/17	14:56
1450	PG&E	10/02/17	16:05	38.71820	-120.97560	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101375963	Unknown	21,000	Conductor	Overhead	Yes	10/2/17	16:05
1451	PG&E	10/02/17	17:30	38.36340	-122.28458	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	102282538	PACIFIC BELL	12,000	Conductor	Overhead	No		
1452	PG&E	10/03/17	17:48	35.10842	-119.37855	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	span 001/019 - 001/020	Unknown	70,000	Conductor	Overhead	Yes	10/3/17	17:48
1453	PG&E	10/04/17	12:20	37.81692	-121.27147	Vegetation	Rural	< 0.25 Acres	Fire Agency	LATHROP	102091094	Unknown	0 - 750	Other	Overhead	No		
1454	PG&E	10/04/17	23:42	38.65539	-120.99340	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101375442	PACIFIC BELL	12,000	Other	Overhead	Yes	10/4/17	23:42
1455	PG&E	10/05/17	0:20	38.00524	-121.79446	Vegetation	Rural	< 3 Meters	Fire Agency	911	100456226	Unknown	21,000	Switch	Subsurface	Yes	10/5/17	0:20
1456	PG&E	10/05/17	10:57	39.46836	-122.16704	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100343435	PACIFIC BELL	21,000	Other	Overhead	Yes	10/5/17	10:57
1457	PG&E	10/06/17	7:24	38.56070	-121.76425	Vegetation	Urban	< 3 Meters	Fire Agency	5307583600	101639481	PACIFIC BELL	12,000	Lightning Arrestor	Overhead	Yes	10/6/17	7:24
1458	PG&E	10/06/17	12:03	39.46450	-122.11238	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100344016	Unknown	21,000	Conductor	Overhead	Yes	10/6/17	12:03
1459	PG&E	10/06/17	16:04	40.97124	-124.03716	Vegetation	Rural	< 0.25 Acres	Fire Agency	JO BOB	100978977	Unknown	12,000	Conductor	Overhead	Yes	10/6/17	16:04
1460	PG&E	10/07/17	10:11	37.19890	-121.83250	Vegetation	Urban	< 0.25 Acres	Fire Agency	JOHN PAVLOFF	100600703	PACIFIC BELL	21,000	Other	Overhead	Yes	10/7/17	10:11
1461	PG&E	10/08/17	5:11	40.32520	-124.28810	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100987374	FRONTIER COMM	12,000	Conductor	Overhead	Yes	10/8/17	5:11
1462	PG&E	10/08/17	16:41	39.58900	-122.20150	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100341037	Unknown	0 - 750	Conductor	Overhead	Yes	10/8/17	16:41
1463	PG&E	10/08/17	16:43	40.88760	-123.99175	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	100972408	Unknown	12,000	Conductor	Overhead	Yes	10/8/17	16:43
1464	PG&E	10/08/17	17:39	38.53311	-121.54236	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101585529	Unknown	12,000	Conductor	Overhead	Yes	10/8/17	17:39
14																		

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
2	Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
1483	PG&E	10/10/17	13:36	38.93098	-123.30235	Vegetation	Rural	< 3 Meters	Customer	N.A.	102214553	Unknown	0 - 750	Conductor	Overhead	Yes	10/10/17	13:36
1484	PG&E	10/10/17	16:17	38.31478	-122.70673	Vegetation	Urban	26 - 9.99 Acres	Unknown	N.A.	101996286	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	10/10/17	16:17
1485	PG&E	10/10/17	16:29	37.25591	-121.95862	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100542800	VERIZON CALIFO	12,000	Conductor	Overhead	Yes	10/10/17	16:29
1486	PG&E	10/11/17	11:57	38.50153	-123.02367	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101974930	Unknown	12,000	Conductor	Overhead	Yes	10/11/17	11:57
1487	PG&E	10/11/17	16:41	38.67900	-121.94870	Vegetation	Rural	< 3 Meters	Fire Agency	ESPARTO FIRE PROTECTION DISTRICT- (530) 787-3300	101591668	Unknown	0 - 750	Conductor	Overhead	Yes	10/11/17	16:41
1488	PG&E	10/13/17	8:30	38.02343	-122.53764	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	102246021	Unknown	0 - 750	Transformer	Overhead	Yes	10/13/17	8:30
1489	PG&E	10/13/17	10:27	37.05607	-122.02057	Vegetation	Urban	< 0.25 Acres	Fire Agency	Scotts Valley Fire Dept.	101677721	Unknown	21,000	Conductor	Overhead	Yes	10/13/17	10:27
1490	PG&E	10/13/17	19:15	36.94153	-120.03973	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101224900	PACIFIC BELL	12,000	Conductor	Overhead	Yes	10/13/17	19:15
1491	PG&E	10/13/17	22:19	39.76485	-121.63075	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100325368	PACIFIC BELL	0 - 750	Transformer	Overhead	Yes	10/13/17	22:19
1492	PG&E	10/14/17	8:37	37.39437	-122.09155	Building	Urban	Structure Only	Fire Agency	Unknown	100513237	PACIFIC BELL	12,000	Transformer	Overhead	Yes	10/14/17	8:37
1493	PG&E	10/14/17	14:43	40.11215	-122.17368	Vegetation	Rural	< 0.25 Acres	Self Extinguished	N.A.	101539953	None	12,000	Fuse	Overhead	Yes	10/14/17	14:43
1494	PG&E	10/15/17	13:15	37.38553	-121.81327	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	SAJOSE FD	100563705	Unknown	12,000	Conductor	Overhead	Yes	10/15/17	13:15
1495	PG&E	10/16/17	12:10	36.58307	-121.93676	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101781248	PACIFIC BELL	12,000	Conductor	Overhead	Yes	10/16/17	12:10
1496	PG&E	10/16/17	12:20	37.71998	-122.06870	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100900970	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	10/16/17	12:20
1497	PG&E	10/16/17	12:26	36.66410	-121.09947	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Nick Shawkey E4462 209-402-1645 Cover Engine from Tuolumne Calaveras Unit	101689865	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	10/16/17	12:26
1498	PG&E	10/17/17	18:22	35.42566	-119.02972	Vegetation	Urban	< 3 Meters	Self Extinguished	N.A.	100144662	PACIFIC BELL	12,000	Capacitor Bank	Overhead	Yes	10/17/17	18:22
1499	PG&E	10/18/17	13:58	37.63605	-122.07925	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100524080	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	10/18/17	13:58
1500	PG&E	10/20/17	5:59	36.74749	-119.76295	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100859697	Unknown	12,000	Conductor	Overhead	Yes	10/20/17	5:59
1501	PG&E	10/20/17	6:18	39.29221	-121.01573	Vegetation	Rural	< 3 Meters	Fire Agency	PHILLIP NUNNINK INCIDENT # 27272	100087647	PACIFIC BELL	12,000	Conductor	Overhead	Yes	10/20/17	6:18
1502	PG&E	10/20/17	9:06	36.03599	-120.05797	Vegetation	Rural	300 - 999 Acres	Fire Agency	Unknown	Pole 009/009	Unknown	70,000	Conductor	Overhead	Yes	10/20/17	9:06
1503	PG&E	10/20/17	13:43	35.35300	-119.98730	Vegetation	Rural	10 - 99 Acres	Fire Agency	Kevin McLean Office(805)593-3421, Cell(805)903-3421	100136483	Unknown	12,000	Conductor	Overhead	Yes	10/20/17	13:43
1504	PG&E	10/20/17	13:45	34.55317	-120.83029	Vegetation	Rural	100 - 299 Acres	Fire Agency	Unknown	101921492	Unknown	12,000	Conductor	Overhead	Yes	10/20/17	13:45
1505	PG&E	10/20/17	14:00	36.92155	-119.72828	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100727124	Unknown	21,000	Fuse	Overhead	Yes	10/20/17	14:00
1506	PG&E	10/21/17	15:08	39.06400	-122.77645	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	102155186	PACIFIC BELL	12,000	Conductor	Overhead	Yes	10/21/17	15:08
1507	PG&E	10/21/17	16:05	37.59108	-122.00995	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	Unknown	103516949	Unknown	0 - 750	Conductor	Overhead	Yes	10/21/17	16:05
1508	PG&E	10/23/17	19:34	36.07720	-121.01900	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101763398	Unknown	12,000	Conductor	Overhead	Yes	10/23/17	19:34
1509	PG&E	10/23/17	21:24	37.37133	-122.34799	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100270421	Unknown	12,000	Conductor	Overhead	Yes	10/23/17	21:24
1510	PG&E	10/24/17	15:23	36.85988	-121.79474	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101789001	PACIFIC BELL	21,000	Conductor	Overhead	Yes	10/24/17	15:23
1511	PG&E	10/26/17	10:53	36.40356	-121.91219	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101777002	Unknown	12,000	Conductor	Overhead	Yes	10/26/17	10:53
1512	PG&E	10/28/17	15:26	39.45162	-123.38381	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	102209084	Unknown	12,000	Conductor	Overhead	Yes	10/28/17	15:26
1513	PG&E	10/28/17	20:08	35.02222	-118.76915	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100223850	Unknown	12,000	Fuse	Overhead	Yes	10/28/17	20:08
1514	PG&E	10/31/17	18:56	39.00345	-121.69065	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	Pole 010/208	Unknown	60,000	Conductor	Overhead	Yes	10/31/17	18:56
1515	PG&E	10/31/17	21:02	39.11189	-122.81633	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	Structure 020/003	Unknown	60,000	Conductor	Overhead	Yes	10/31/17	21:02
1516	PG&E	11/06/17	9:59	37.14600	-121.66753	Vegetation	Urban	< 0.25 Acres	Fire Agency	INCIDENT # 1717CASC008183	103570543	YES	21,000	Conductor	Overhead	Yes	11/6/17	9:59
1517	PG&E	11/06/17	15:06	38.29980	-122.50300	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101982913	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/6/17	15:06
1518	PG&E	11/08/17	07:11	37.73669	-120.34587	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101191714	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/8/17	07:11
1519	PG&E	11/08/17	14:53	37.79198	-122.22211	Building	Urban	Structure Only	Fire Agency	Unknown	101352529	Unknown	4,000	Conductor	Overhead	Yes	11/8/17	14:53
1520	PG&E	11/11/17	11:57	35.11908	-120.39364	Vegetation	Rural	< 0.25 Acres	Fire Agency	Jordan Dayley ph#929-3911,engine#3467	101931190	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/11/17	11:57
1521	PG&E	11/12/17	19:44	36.73779	-119.77691	Building	Urban	< 0.25 Acres	Fire Agency	capt will johnson	100871063	Unknown	12,000	Capacitor Bank	Overhead	Yes	11/12/17	19:44
1522	PG&E	11/14/17	07:43	37.32400	-120.81456	Vegetation	Rural	< 3 Meters	Fire Agency	cammu #022323	103853929	Unknown	12,000	Transformer	Overhead	Yes	11/14/17	07:43
1523	PG&E	11/17/17	09:53	37.08016	-120.01945	Other	Rural	< 3 Meters	Utility, PG&E	N.A.	101029626	Unknown	12,000	Fuse	Overhead	Yes	11/17/17	09:53
1524	PG&E	11/20/17	08:32	36.75835	-120.84385	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	101389405	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/20/17	08:32
1525	PG&E	11/20/17	20:05	35.49951	-118.90994	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	661-324-6551	103782809	None	0 - 750	Conductor	Overhead	Yes	11/20/17	20:05
1526	PG&E	11/21/17	11:55	37.61013	-121.33324	Vegetation	Rural	< 0.25 Acres	Fire Agency	tracy fire dept	102053617	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/21/17	11:55
1527	PG&E	11/22/17	13:44	36.75202	-121.66363	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	103154362	Unknown	12,000	Conductor	Overhead	Yes	11/22/17	13:44
1528	PG&E	11/23/17	16:29	37.77554	-120.69413	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101860971	Unknown	12,000	Conductor	Overhead	Yes	11/23/17	16:29
1529	PG&E	11/24/17	10:33	36.62133	-120.06165	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	KERMAN FIRE DEP.	100700090	Unknown	12,000	Conductor	Overhead	Yes	11/24/17	10:33
1530	PG&E	11/25/17	6:29	36.01436	-119.95559	Vegetation	Rural	< 3 Meters	Utility, PG&E	N.A.	100693913	Unknown	12,000	Conductor	Overhead	Yes	11/25/17	6:29
1531	PG&E	11/26/17	10:10	36.70981	-119.56321	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100815464	VERIZON CALIFO	0 - 750	Conductor	Overhead	Yes	11/26/17	10:10
1532	PG&E	11/27/17	06:23	36.69419	-121.65832	Vegetation	Urban	< 3 Meters	Fire Agency	831-758-7261	101723997	Unknown	12,000	Conductor	Overhead	Yes	11/27/17	06:23
1533	PG&E	11/27/17	11:11	37.12962	-122.31244	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100268264	Unknown	12,000	Conductor	Overhead	Yes	11/27/17	11:11
1534	PG&E	11/28/17	15:49	36.48747	-119.79086	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	100806272	Unknown	12,000	Other	Overhead	Yes	11/28/17	15:49
1535	PG&E	11/29/17	17:34	38.68410	-120.65461	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	101194500	PACIFIC BELL	21,000	Conductor	Overhead	Yes	11/29/17	17:34
1536	PG&E	12/07/17	12:25	34.71151	-120.17715	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	Pole 015/220	Unknown	115,000	Unknown	Overhead	No		
1537	PG&E	12/12/17	4:40	39.77107	-121.59727	Building	Urban	Structure Only	Fire Agency	paradise fire city department	100324902	PACIFIC BELL	12,000	Fuse	Overhead	Yes	12/12/17	4:40
1538	PG&E	12/13/17	12:13	35.59220	-120.64741	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103390807	Unknown	21,000	Other	Overhead	Yes	12/13/17	12:13
1539	PG&E	12/14/17	1:33	37.19789	-121.83746	Building	Rural	Structure Only	Fire Agency	Unknown	100622323	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	12/14/17	1:33
1540	PG&E	12/14/17	17:16	34.58783	-120.35663	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	101911004	VERIZON CALIFO	12,000	Conductor	Overhead	Yes	12/14/17	17:16
1541	PG&E	12/16/17	7:01	39.74474	-122.19612	Building	Urban	Structure Only	Fire Agency	ORLAND CITY FIRE DEPT	100428554	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	12/16/17	7:01
1542	PG&E	12/16/17	11:51	38.81706	-122.70412	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Shawn Ohare	102167231	PACIFIC BELL	12,000	Conductor	Overhead	Yes	12/16/17	11:51
1543	PG&E	12/16/17	13:39	37.97022	-121.64092	Vegetation	Rural	< 0.25 Acres	Fire Agency	FIRE CAPTAIN ON DUTY	100473121	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	12/16/17	13:39
1544	PG&E	12/16/17	16:03	35.65929	-120.49459	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103131190	Unknown	21,000	Conductor	Overhead	Yes	12/16/17	16:03
1545	PG&E	12/19/17	7:05	36.27152	-120.39270	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100745841	Unknown	12,000	Fuse	Overhead	Yes	12/19/17	7:05
1546	PG&E																	

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Column5	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
2	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	
1560	PG&E	2/7/18	5:44	40.65432	-122.51980	Vegetation	Rural	< 3 meters	Utility: PG&E	N.A.	103922730	Unknown	12,000	Conductor	Overhead	Yes	2/7/18	5:44
1561	PG&E	2/7/18	9:16	38.03686	-120.20956	Vegetation	Rural	< 3 meters	Fire Agency	Jason Podesta 209-586-3362	101038120	AT&T	17,000	Conductor	Overhead	Yes	2/7/18	9:16
1562	PG&E	2/9/18	18:56	39.15294	-122.22962	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101626240	Unknown	12,000	Conductor	Overhead	Yes	2/9/18	18:56
1563	PG&E	2/12/18	20:20	39.93953	-121.64937	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	100430947	Unknown	12,000	Conductor	Overhead	Yes	2/12/18	20:20
1564	PG&E	2/25/18	13:19	38.25297	-120.31534	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	559-294-6818	100744054	Unknown	12,000	Conductor	Overhead	Yes	2/25/18	13:19
1565	PG&E	2/26/18	16:33	35.53021	-118.96955	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100208194	Unknown	21,000	Conductor	Overhead	Yes	2/26/18	16:33
1566	PG&E	3/3/18	12:15	39.12128	-121.05504	Building	Urban	Structure Only	Unknown	N.A.	100095928	AT&T	0 - 750	Conductor	Overhead	Yes	3/3/18	12:15
1567	PG&E	3/5/18	16:24	34.95299	-118.90108	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Kern County FD	103235837	Unknown	12,000	Conductor	Overhead	Yes	3/5/18	16:24
1568	PG&E	3/6/18	17:57	38.28110	-120.89650	Vegetation	Rural	< 0.25 Acres	Fire Agency	530-647-5220	101238429	AT&T	12,000	Conductor	Overhead	Yes	3/6/18	17:57
1569	PG&E	3/10/18	15:22	39.27307	-122.18177	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101635717	Unknown	12,000	Lightning Arrestor	Overhead	Yes	3/10/18	15:22
1570	PG&E	3/12/18	3:26	38.95128	-122.06473	Vegetation	Rural	< 3 meters	Utility: PG&E	N.A.	103781246	Unknown	12,000	Other	Overhead	Yes	3/12/18	3:26
1571	PG&E	3/26/18	17:06	38.73038	-122.62155	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	102166450	AT&T	12,000	Conductor	Overhead	Yes	3/26/18	17:06
1572	PG&E	4/2/18	11:36	38.47995	-121.99456	Vegetation	Rural	< 0.25 Acres	Fire Agency	WINTERS FIRE DEPT	101577668	Unknown	12,000	Conductor	Overhead	Yes	4/2/18	11:36
1573	PG&E	4/3/18	14:46	37.01185	-121.61516	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	100611410	Verizon	21,000	Conductor	Overhead	Yes	4/3/18	14:46
1574	PG&E	4/12/18	14:17	34.96600	-120.42829	Other	Urban	< 3 meters	Fire Agency	santa maria FD	101871639	Verizon	0 - 750	Conductor	Overhead	Yes	4/12/18	14:17
1575	PG&E	4/16/18	20:02	36.43650	-118.89490	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	103228190	Unknown	12,000	Conductor	Overhead	Yes	4/16/18	20:02
1576	PG&E	4/23/18	20:20	37.61375	-121.36119	Vegetation	Rural	< 3 meters	Fire Agency	209-464-4650	Pole 1/9	None	115,000	Conductor	Overhead	Yes	4/23/18	20:20
1577	PG&E	4/24/18	12:00	36.38596	-119.77637	Vegetation	Rural	< 0.25 Acres	Fire Agency	559-924-2150 Jason Allen	102305550	Unknown	0 - 750	Conductor	Overhead	Yes	4/24/18	12:00
1578	PG&E	4/24/18	19:15	36.81117	-119.82598	Building	Urban	Structure Only	Fire Agency	FRESNO FIRE DEPT. 559 621 4199	100830359	Unknown	0 - 750	Conductor	Overhead	Yes	4/24/18	19:15
1579	PG&E	4/27/18	12:48	39.17166	-120.86517	Vegetation	Rural	< 0.25 Acres	Fire Agency	Incident # 9960 ph # 530-8850111	100075314	Unknown	12,000	Conductor	Overhead	Yes	4/27/18	12:48
1580	PG&E	4/29/18	11:54	36.13464	-119.54890	Vegetation	Rural	< 3 meters	Self Extinguished	N.A.	103247569	Unknown	12,000	Fuse	Overhead	Yes	4/29/18	11:54
1581	PG&E	4/30/18	14:33	36.04366	-120.49422	Vegetation	Rural	< 0.25 Acres	Fire Agency	Chris Compas 805-929-3911	101893032	Unknown	12,000	Conductor	Overhead	Yes	4/30/18	14:33
1582	PG&E	5/4/18	16:34	36.01479	-121.98685	Vegetation	Rural	< 0.25 Acres	Fire Agency	Contra Costa FD	101487755	None	0 - 750	Conductor	Overhead	No	N.A.	N.A.
1583	PG&E	5/6/18	15:02	39.13840	-122.07875	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101623905	Unknown	12,000	Conductor	Overhead	Yes	5/6/18	15:02
1584	PG&E	5/8/18	17:49	38.25480	-122.45281	Vegetation	Rural	< 3 meters	Fire Agency	Unknown	101992211	AT&T	0 - 750	Conductor	Overhead	Yes	5/8/18	17:49
1585	PG&E	5/9/18	13:47	35.40011	-118.89697	Vegetation	Rural	< 0.25 Acres	Fire Agency	Kern County FD	103924151	Unknown	12,000	Capacitor Bank	Overhead	No	N.A.	N.A.
1586	PG&E	5/9/18	14:00	38.59081	-123.34232	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CASE# 18CALNU 005865	101998286	Unknown	12,000	Conductor	Overhead	Yes	5/9/18	14:00
1587	PG&E	5/11/18	10:13	38.38700	-122.98560	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101973909	Unknown	12,000	Conductor	Overhead	Yes	5/11/18	10:13
1588	PG&E	5/11/18	12:45	38.92565	-121.24684	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100035269	AT&T	12,000	Conductor	Overhead	Yes	5/11/18	12:45
1589	PG&E	5/11/18	15:51	40.33848	-123.91367	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	100899912	Unknown	12,000	Conductor	Overhead	Yes	5/11/18	15:51
1590	PG&E	5/11/18	17:43	38.82183	-120.92953	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Douglas Ferro. cell-530-708-2715 office-530-677-6192	101388939	AT&T	21,000	Conductor	Overhead	Yes	5/11/18	17:43
1591	PG&E	5/12/18	15:50	38.65410	-121.76422	Vegetation	Rural	< 3 meters	Fire Agency	Woodland FD	101606060	None	12,000	Conductor	Overhead	Yes	5/12/18	15:50
1592	PG&E	5/13/18	0:26	38.91191	-122.06063	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	101604030	Unknown	12,000	Conductor	Overhead	Yes	5/13/18	0:26
1593	PG&E	5/13/18	11:04	37.52348	-120.32990	Building	Rural	Structure Only	Fire Agency	Unknown	Twr 13/10	None	70,000	Switch	Overhead	Yes	5/13/18	11:04
1594	PG&E	5/14/18	14:02	36.40356	-119.04133	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100240571	AT&T	12,000	Conductor	Overhead	Yes	5/14/18	14:02
1595	PG&E	5/14/18	21:10	35.23850	-119.08330	Vegetation	Rural	< 3 meters	Fire Agency	kern county FD	100164480	AT&T	21,000	Conductor	Overhead	Yes	5/14/18	21:10
1596	PG&E	5/15/18	4:22	37.44010	-121.92473	Vegetation	Rural	< 3 meters	Fire Agency	Unknown	103776990	Unknown	21,000	Conductor	Overhead	Yes	5/15/18	4:22
1597	PG&E	5/16/18	9:12	35.31063	-118.91638	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101437113	None	12,000	Conductor	Overhead	Yes	5/16/18	9:12
1598	PG&E	5/17/18	17:41	35.22350	-119.15490	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	103854888	Unknown	12,000	Conductor	Overhead	Yes	5/17/18	17:41
1599	PG&E	5/19/18	9:39	38.93260	-121.49369	Vegetation	Rural	< 3 meters	Fire Agency	EAST NICHOLOUS ? SUTTER CO.	Str. 41/319	None	115,000	Conductor	Overhead	Yes	5/19/18	9:39
1600	PG&E	5/19/18	13:58	36.47065	-121.46686	Vegetation	Rural	< 0.25 Acres	Fire Agency	Gonz FD-911	101744837	Unknown	12,000	Conductor	Overhead	Yes	5/19/18	13:58
1601	PG&E	5/19/18	19:44	40.26653	-122.27274	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	103899310	Unknown	12,000	Conductor	Overhead	Yes	5/19/18	19:44
1602	PG&E	5/19/18	21:02	36.87645	-120.21906	Vegetation	Rural	300 - 999 Acres	Fire Agency	Madera County FIRE CAPT TOM CRASS, 554-732	101089905	None	12,000	Conductor	Overhead	Yes	5/19/18	21:02
1603	PG&E	5/20/18	17:14	36.59036	-119.27522	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	100685366	Unknown	12,000	Conductor	Overhead	Yes	5/20/18	17:14
1604	PG&E	5/22/18	8:14	39.45909	-121.53220	Vegetation	Rural	< 3 meters	Fire Agency	Oroville FD	100371407	Unknown	12,000	Conductor	Overhead	Yes	5/22/18	8:14
1605	PG&E	5/22/18	15:51	36.35433	-121.74955	Vegetation	Rural	< 3 meters	Fire Agency	Unknown	101570356	None	0 - 750	Conductor	Overhead	Yes	5/22/18	15:51
1606	PG&E	5/23/18	14:03	37.36356	-120.50321	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101131307	AT&T	12,000	Conductor	Overhead	Yes	5/23/18	14:03
1607	PG&E	5/23/18	15:37	37.01972	-119.72972	Vegetation	Rural	10 - 99 Acres	Unknown	N.A.	103312862	Unknown	21,000	Conductor	Overhead	Yes	5/23/18	15:37
1608	PG&E	5/24/18	12:12	35.50789	-120.09352	Vegetation	Rural	100 - 299 Acres	Unknown	N.A.	103010228	None	12,000	Conductor	Overhead	Yes	5/24/18	12:12
1609	PG&E	5/25/18	11:38	36.71321	-119.43888	Vegetation	Rural	< 3 meters	Unknown	N.A.	100762959	Verizon	12,000	Conductor	Overhead	Yes	5/25/18	11:38
1610	PG&E	5/26/18	11:28	37.52187	-120.62784	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	101191128	Unknown	21,000	Conductor	Overhead	Yes	5/26/18	11:28
1611	PG&E	5/28/18	1:56	35.39208	-120.60812	Vegetation	Rural	< 3 meters	Fire Agency	Unknown	101849984	Unknown	0 - 750	Conductor	Overhead	Yes	5/28/18	1:56
1612	PG&E	5/28/18	6:30	40.43829	-122.30009	Building	Rural	Structure Only	Unknown	N.A.	101495757	Unknown	0 - 750	Conductor	Overhead	Yes	5/28/18	6:30
1613	PG&E	5/29/18	15:52	37.50916	-121.95447	Vegetation	Rural	< 0.25 Acres	Fire Agency	925-422-7595	101789613	N.A.	21,000	Conductor	Subsurface	Yes	5/29/18	15:52
1614	PG&E	5/30/18	13:00	38.52754	-121.82136	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	101641285	None	12,000	Conductor	Overhead	Yes	5/30/18	13:00
1615	PG&E	5/30/18	16:58	38.32472	-121.82347	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103900943	Unknown	21,000	Conductor	Overhead	Yes	5/30/18	16:58
1616	PG&E	5/31/18	6:30	38.97449	-121.61015	Vegetation	Rural	< 0.25 Acres	Fire Agency	Sutter County FD	103127037	None	12,000	Conductor	Overhead	Yes	5/31/18	6:30
1617	PG&E	5/31/18	8:50	36.16735	-119.86120	Vegetation	Rural	< 0.25 Acres	Fire Agency	Kings County. Fire took off as soon as T-Man was onsite	100688476	Unknown	12,000	Conductor	Overhead	Yes	5/31/18	8:50
1618	PG&E	5/31/18	12:28	36.77108	-119.74169	Vegetation	Urban	< 0.25 Acres	Fire Agency	Garcia	100841706	AT&T	12,000	Conductor	Overhead	Yes	5/31/18	12:28
1619	PG&E	5/31/18	14:34	35.48476	-119.04683	Vegetation	Rural	< 0.25 Acres	Fire Agency	REPORT NUMBER 1821047---- (661) 324-6551 STATION 63 RESPONDED	100114852	Unknown	12,000	Conductor	Overhead	Yes	5/31/18	14:34
1620	PG&E	6/2/18	12:02	40.45529	-122.32007	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101496970	AT&T	12,000	Conductor	Overhead	Yes	6/2/18	12:02
1621	PG&E	6/2/18	16:11	37.31560	-122.02224	Vegetation	Urban	< 0.25 Acres	Fire Agency	Santa Clara County Fire	100555119	AT&T	12,000	Conductor	Overhead	Yes	6/2/18	16:11
1622	PG&E	6/2/18	21:37	37.31096	-121.90709	Vegetation	Urban	< 3 meters	Fire Agency	San Jose FD	103781309	Unknown	12,000	Conductor	Overhead	Yes	6/2/18	21:37
1623	PG&E</																	

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
2	Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
1635	PG&E	6/5/18	13:45	38.54320	-122.72020	Vegetation	Rural	< 3 meters	Unknown	N.A.	102031673	Unknown	12,000	Conductor	Overhead	Yes	6/5/18	13:45
1636	PG&E	6/5/18	16:46	38.72446	-120.80200	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	103667302	AT&T	12,000	Conductor	Overhead	Yes	6/5/18	16:46
1637	PG&E	6/5/18	19:10	35.87673	-119.54339	Vegetation	Rural	< 0.25 Acres	Fire Agency	LT. Stewart. (559) 949-8343 dstewart@co.tulare.ca.us	100649683	Unknown	12,000	Conductor	Overhead	Yes	6/5/18	19:10
1638	PG&E	6/6/18	10:32	36.28370	-119.77342	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Kings County FD	100711710	AT&T	0 - 750	Conductor	Overhead	Yes	6/6/18	10:32
1639	PG&E	6/6/18	11:07	38.27343	-122.43845	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102005548	AT&T	12,000	Conductor	Overhead	Yes	6/6/18	11:07
1640	PG&E	6/6/18	15:00	38.79495	-121.48476	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Adrian Rogers (530) 682-7908 Fire Chief Steve Henry 6925 E Foppiano Ln Stockton Ca 95212	103815399	AT&T	12,000	Conductor	Overhead	Yes	6/6/18	15:00
1641	PG&E	6/6/18	16:28	38.08008	-121.22891	Vegetation	Rural	< 0.25 Acres	Fire Agency	209/931-3107	102105447	None	12,000	Conductor	Overhead	Yes	6/6/18	16:28
1642	PG&E	6/6/18	19:13	37.14599	-121.66763	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103790604	None	0 - 750	Conductor	Overhead	Yes	6/6/18	19:13
1643	PG&E	6/6/18	19:21	38.00119	-121.09517	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	103351400	Unknown	12,000	Conductor	Overhead	Yes	6/6/18	19:21
1644	PG&E	6/6/18	21:06	38.15100	-121.68037	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101865829	Frontier	21,000	Conductor	Overhead	Yes	6/6/18	21:06
1645	PG&E	6/8/18	17:10	35.47698	-120.65407	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101936165	Unknown	12,000	Conductor	Overhead	Yes	6/8/18	17:10
1646	PG&E	6/8/18	19:03	35.15397	-120.59403	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101852092	AT&T	12,000	Conductor	Overhead	Yes	6/8/18	19:03
1647	PG&E	6/9/18	0:46	35.07448	-120.51670	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101927520	Unknown	12,000	Conductor	Overhead	Yes	6/9/18	0:46
1648	PG&E	6/9/18	16:02	37.87853	-121.64742	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	east county fire	100497205	Unknown	21,000	Conductor	Overhead	Yes	6/9/18	16:02
1649	PG&E	6/10/18	17:19	38.41570	-122.91838	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	101978419	AT&T	12,000	Conductor	Overhead	Yes	6/10/18	17:19
1650	PG&E	6/11/18	14:20	38.89753	-121.31194	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	CAL FIRE	100042575	N.A.	12,000	Conductor	Subsurface	Yes	6/11/18	14:20
1651	PG&E	6/11/18	17:49	34.73294	-120.08068	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100151513	Unknown	0 - 750	Conductor	Overhead	Yes	6/11/18	17:49
1652	PG&E	6/11/18	19:59	38.23105	-120.79440	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	Twr 2025	None	60,000	Conductor	Overhead	Yes	6/11/18	19:59
1653	PG&E	6/12/18	8:55	35.85075	-119.89146	Vegetation	Rural	10 - 99 Acres	Fire Agency	Jason Brown 559-935-0756	100649777	None	21,000	Conductor	Overhead	Yes	6/12/18	8:55
1654	PG&E	6/12/18	12:12	38.58904	-121.51999	Vegetation	Urban	< 3 meters	Fire Agency	West Sac FD	101657851	Unknown	12,000	Conductor	Overhead	Yes	6/12/18	12:12
1655	PG&E	6/13/18	2:53	36.89639	-121.83738	Vegetation	Rural	< 3 meters	Fire Agency	Sean Murray -Phone # 831-728- 8290 and cell # 831254-1716	101699116	AT&T	21,000	Conductor	Overhead	Yes	6/13/18	2:53
1656	PG&E	6/13/18	11:18	35.29270	-120.42897	Vegetation	Rural	< 3 meters	Customer	N.A.	101884565	Unknown	12,000	Conductor	Overhead	Yes	6/13/18	11:18
1657	PG&E	6/13/18	16:27	36.63305	-119.98967	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100667215	Unknown	12,000	Conductor	Overhead	Yes	6/13/18	16:27
1658	PG&E	6/13/18	22:40	38.49014	-122.66614	Vegetation	Rural	< 0.25 Acres	Fire Agency	SRS181640125	101986547	Unknown	12,000	Conductor	Overhead	Yes	6/13/18	22:40
1659	PG&E	6/14/18	14:25	39.52464	-121.46257	Vegetation	Urban	< 0.25 Acres	Fire Agency	Mike Waters (investigator 530 538- 7888)	100426966	None	12,000	Conductor	Overhead	Yes	6/14/18	14:25
1660	PG&E	6/14/18	16:12	40.44189	-124.01973	Vegetation	Rural	< 3 meters	Utility: PG&E	N.A.	101005522	AT&T	12,000	Conductor	Overhead	Yes	6/14/18	16:12
1661	PG&E	6/15/18	2:56	37.48695	-122.42231	Vegetation	Rural	< 0.25 Acres	Utility: PG&E	N.A.	Pole 10/5	None	60,000	Conductor	Overhead	Yes	6/15/18	2:56
1662	PG&E	6/15/18	9:51	37.19859	-119.47094	Vegetation	Rural	< 0.25 Acres	Fire Agency	RANCHARIA ENGINE 4255 USFS ENG 52	101058060	Unknown	12,000	Conductor	Overhead	Yes	6/15/18	9:51
1663	PG&E	6/15/18	10:05	36.62384	-121.02214	Vegetation	Rural	< 3 meters	Customer	N.A.	101376538	AT&T	0 - 750	Conductor	Overhead	Yes	6/15/18	10:05
1664	PG&E	6/16/18	9:56	36.65588	-121.79368	Vegetation	Rural	< 3 meters	Fire Agency	Unknown	101606330	Unknown	12,000	Conductor	Overhead	Yes	6/16/18	9:56
1665	PG&E	6/16/18	13:17	36.61973	-121.84551	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Woodland FD	103905392	Unknown	12,000	Conductor	Overhead	Yes	6/16/18	13:17
1666	PG&E	6/16/18	16:28	37.07375	-120.19243	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101133603	AT&T	0 - 750	Conductor	Overhead	Yes	6/16/18	16:28
1667	PG&E	6/16/18	18:06	38.09497	-122.21014	Vegetation	Urban	< 0.25 Acres	Fire Agency	707 648-4488	102218342	AT&T	12,000	Conductor	Overhead	Yes	6/16/18	18:06
1668	PG&E	6/16/18	18:15	39.13347	-121.54364	Building	Urban	Structure Only	Fire Agency	530-743-1553	101319352	Unknown	0 - 750	Conductor	Overhead	Yes	6/16/18	18:15
1669	PG&E	6/16/18	18:46	39.33207	-121.53703	Vegetation	Rural	< 3 meters	Fire Agency	palemo	100381711	Unknown	0 - 750	Conductor	Overhead	Yes	6/16/18	18:46
1670	PG&E	6/16/18	19:37	38.75258	-121.44393	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	100102684	AT&T	0 - 750	Conductor	Overhead	Yes	6/16/18	19:37
1671	PG&E	6/16/18	19:37	36.69901	-122.02089	Vegetation	Rural	< 3 meters	Fire Agency	ESPARTO FIRE DEPT	101644179	AT&T	12,000	Conductor	Overhead	Yes	6/16/18	19:37
1672	PG&E	6/16/18	19:58	37.90696	-121.80632	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	100483910	Unknown	21,000	Conductor	Overhead	Yes	6/16/18	19:58
1673	PG&E	6/16/18	20:33	38.04936	-122.20600	Vegetation	Rural	< 0.25 Acres	Fire Agency	Contra Costa FD	101423963	Unknown	21,000	Conductor	Overhead	Yes	6/16/18	20:33
1674	PG&E	6/17/18	16:01	38.09321	-120.94500	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CATCU006927 incident #	102042425	Unknown	12,000	Conductor	Overhead	Yes	6/17/18	16:01
1675	PG&E	6/18/18	8:31	35.52701	-120.64747	Vegetation	Rural	< 3 meters	Customer	N.A.	101887037	Unknown	21,000	Conductor	Overhead	Yes	6/18/18	8:31
1676	PG&E	6/18/18	16:06	37.80534	-121.37950	Vegetation	Rural	< 0.25 Acres	Fire Agency	Stockton FD	103569107	Unknown	0 - 750	Conductor	Overhead	Yes	6/18/18	16:06
1677	PG&E	6/19/18	0:27	38.76042	-120.82237	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101388356	Unknown	12,000	Conductor	Overhead	Yes	6/19/18	0:27
1678	PG&E	6/19/18	9:43	38.53096	-121.55051	Vegetation	Rural	< 3 meters	Fire Agency	Yolo County FD	101585318	Unknown	0 - 750	Conductor	Overhead	Yes	6/19/18	9:43
1679	PG&E	6/19/18	10:17	38.59183	-120.70965	Vegetation	Rural	< 3 meters	Fire Agency	Unknown	101395943	AT&T	21,000	Conductor	Overhead	Yes	6/19/18	10:17
1680	PG&E	6/19/18	11:45	35.98510	-120.14174	Vegetation	Rural	< 3 meters	Self Extinguished	N.A.	100698130	Unknown	21,000	Conductor	Overhead	Yes	6/19/18	11:45
1681	PG&E	6/19/18	14:41	37.21581	-119.68107	Vegetation	Rural	< 0.25 Acres	Fire Agency	JOE QUINSTORFF 559-683-8008	103372829	Unknown	21,000	Conductor	Overhead	Yes	6/19/18	14:41
1682	PG&E	6/20/18	8:30	34.75611	-120.22811	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101858890	None	0 - 750	Conductor	Overhead	Yes	6/20/18	8:30
1683	PG&E	6/21/18	17:36	38.10462	-121.81453	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	Twr 21/142	None	230,000	Unknown	Overhead	Yes	6/21/18	17:36
1684	PG&E	6/21/18	17:51	38.80588	-121.19647	Vegetation	Rural	< 3 meters	Customer	N.A.	100060316	Unknown	0 - 750	Conductor	Overhead	Yes	6/21/18	17:51
1685	PG&E	6/21/18	18:58	35.12238	-120.39377	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101878933	AT&T	12,000	Conductor	Overhead	Yes	6/21/18	18:58
1686	PG&E	6/22/18	6:44	38.62704	-121.96196	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	Str. 16/230	None	60,000	Conductor	Overhead	Yes	6/22/18	6:44
1687	PG&E	6/22/18	16:28	36.45798	-119.34351	Vegetation	Rural	10 - 99 Acres	Fire Agency	MARK FLEMING @ 559 731-8674	100729160	AT&T	12,000	Conductor	Overhead	Yes	6/22/18	16:28
1688	PG&E	6/22/18	17:44	37.24846	-119.56251	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Madera County	101117749	None	0 - 750	Conductor	Overhead	Yes	6/22/18	17:44
1689	PG&E	6/22/18	18:48	40.32367	-124.29304	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	100987410	None	0 - 750	Conductor	Overhead	Yes	6/22/18	18:48
1690	PG&E	6/23/18	9:31	40.86316	-122.39624	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	RYAN MEANS 530-238-2416	101472252	AT&T	12,000	Conductor	Overhead	Yes	6/23/18	9:31
1691	PG&E	6/23/18	17:33	38.20342	-122.15688	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101663196	None	0 - 750	Transformer	Overhead	Yes	6/23/18	17:33
1692	PG&E	6/23/18	17:47	37.94275	-121.77354	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	Unknown	100483944	AT&T	21,000	Conductor	Overhead	Yes	6/23/18	17:47
1693	PG&E	6/23/18	18:12	41.04661	-124.11863	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	100976559	Unknown	12,000	Conductor	Overhead	Yes	6/23/18	18:12
1694	PG&E	6/23/18	21:05	37.20993	-121.01231	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	101231316	Unknown	0 - 750	Conductor	Overhead	Yes	6/23/18	21:05
1695	PG&E	6/24/18	13:07	38.94699	-121.09114	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100400793	Unknown	12,000	Conductor	Overhead	Yes	6/24/18	13:07
1696	PG&E	6/24/18	19:41	39.49831	-121.57777	Vegetation	Urban	< 0.25 Acres	Fire Agency	Oroville FD	100374765	Unknown	12,000	Conductor	Overhead	Yes	6/24/18	19:41
1697	PG&E	6/26/18	9:28	37.98109	-120.39076	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	101048302	AT&T	17,000	Conductor	Overhead	Yes	6/26/18	9:28
1698	PG&E	6/26/18	11:24	38.46363	-122.81611	Vegetation	Rural	<										

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
2	Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
1710	PG&E	6/29/18	15:10	38.05287	-120.93912	Vegetation	Rural	> 5000 Acres	Fire Agency	MATT GILBERT 209-419-4420	103840725	None	12,000	Conductor	Overhead	Yes	6/29/18	15:10
1711	PG&E	6/29/18	15:19	37.53435	-121.98799	Vegetation	Urban	< 5000 Acres	Fire Agency	truck 215008 B-5	100947879	AT&T	12,000	Conductor	Overhead	Yes	6/29/18	15:19
1712	PG&E	6/29/18	19:34	38.51396	-122.77475	Vegetation	Urban	< 3 meters	Customer	N.A.	102025571	Unknown	0 - 750	Conductor	Overhead	Yes	6/29/18	19:34
1713	PG&E	6/30/18	3:32	38.04392	-120.09169	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Avenal Kings County Fire Dept	100700200	Unknown	12,000	Conductor	Overhead	Yes	6/30/18	3:32
1714	PG&E	6/30/18	8:04	38.44014	-119.01318	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	Str 0/5	None	115,000	Conductor	Overhead	Yes	6/30/18	8:04
1715	PG&E	6/30/18	11:14	38.36209	-121.08092	Vegetation	Rural	< 0.25 Acres	Fire Agency	ENGINEER YUREK	100091354	AT&T	12,000	Conductor	Overhead	Yes	6/30/18	11:14
1716	PG&E	6/30/18	13:32	38.69571	-120.82483	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Ken Earle	101403798	AT&T	12,000	Conductor	Overhead	Yes	6/30/18	13:32
1717	PG&E	6/30/18	17:54	37.21614	-121.73939	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	10600855	AT&T	21,000	Conductor	Overhead	Yes	6/30/18	17:54
1718	PG&E	6/30/18	22:18	40.60430	-122.24003	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101469808	Unknown	0 - 750	Conductor	Overhead	Yes	6/30/18	22:18
1719	PG&E	6/30/18	22:36	39.11413	-121.07704	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Matt Wallen (530) 277-3312 Incident # NEU015486	100105380	AT&T	12,000	Conductor	Overhead	Yes	6/30/18	22:36
1720	PG&E	7/1/18	0:23	40.26967	-124.23862	Vegetation	Rural	< 3 meters	Fire Agency	fire chief	100986962	Unknown	12,000	Conductor	Overhead	Yes	7/1/18	0:23
1721	PG&E	7/1/18	0:45	38.88422	-120.84697	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Brian Mackwood (530)708-2711	100109003	None	21,000	Conductor	Overhead	Yes	7/1/18	0:45
1722	PG&E	7/1/18	8:13	38.41539	-121.51222	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	100430344	AT&T	12,000	Conductor	Overhead	Yes	7/1/18	8:13
1723	PG&E	7/2/18	2:26	37.70867	-121.27728	Vegetation	Rural	< 3 meters	Fire Agency	209236-8105	103921895	Unknown	17,000	Conductor	Overhead	Yes	7/2/18	2:26
1724	PG&E	7/2/18	5:12	38.60918	-122.45947	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	707-967-1467	102252558	AT&T	21,000	Conductor	Overhead	Yes	7/2/18	5:12
1725	PG&E	7/2/18	11:35	38.09951	-122.90008	Vegetation	Rural	< 3 meters	Unknown	N.A.	102146848	AT&T	12,000	Conductor	Overhead	Yes	7/2/18	11:35
1726	PG&E	7/2/18	17:15	38.660519	-119.82395	Vegetation	Rural	< 3 meters	Customer	N.A.	100753607	Unknown	12,000	Conductor	Overhead	Yes	7/2/18	17:15
1727	PG&E	7/3/18	18:02	39.71125	-121.82822	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	103387781	Unknown	12,000	Conductor	Overhead	Yes	7/3/18	18:02
1728	PG&E	7/4/18	15:26	39.55378	-123.42549	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	102196183	Verizon	12,000	Conductor	Overhead	Yes	7/4/18	15:26
1729	PG&E	7/5/18	12:45	39.77857	-121.86991	Vegetation	Urban	< 3 meters	Customer	N.A.	103350704	Unknown	0 - 750	Conductor	Overhead	Yes	7/5/18	12:45
1730	PG&E	7/6/18	17:13	38.02903	-120.52785	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103401924	Unknown	12,000	Conductor	Overhead	Yes	7/6/18	17:13
1731	PG&E	7/8/18	20:39	37.38323	-120.61507	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	103217399	Unknown	12,000	Conductor	Overhead	No	N.A.	N.A.
1732	PG&E	7/7/18	8:11	38.09380	-121.85496	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101592721	Unknown	21,000	Conductor	Overhead	Yes	7/7/18	8:11
1733	PG&E	7/7/18	9:05	38.27449	-121.66469	Vegetation	Urban	< 3 meters	Unknown	N.A.	101327124	Unknown	12,000	Conductor	Overhead	Yes	7/7/18	9:05
1734	PG&E	7/7/18	20:24	35.02115	-120.50036	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	101893417	AT&T	12,000	Conductor	Overhead	Yes	7/7/18	20:24
1735	PG&E	7/8/18	19:32	38.77362	-122.06208	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101661938	None	21,000	Conductor	Overhead	Yes	7/8/18	19:32
1736	PG&E	7/8/18	20:04	39.79149	-123.19813	Vegetation	Rural	< 3 meters	Unknown	N.A.	102182026	Verizon	12,000	Conductor	Overhead	Yes	7/8/18	20:04
1737	PG&E	7/9/18	7:27	38.07852	-120.39481	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101861366	Unknown	12,000	Conductor	Overhead	Yes	7/9/18	7:27
1738	PG&E	7/10/18	5:05	38.85410	-121.18056	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100052871	AT&T	12,000	Conductor	Overhead	Yes	7/10/18	5:05
1739	PG&E	7/10/18	6:45	37.08496	-122.07441	Vegetation	Urban	< 0.25 Acres	Fire Agency	CAL FIRE	101675262	AT&T	0 - 750	Conductor	Overhead	Yes	7/10/18	6:45
1740	PG&E	7/10/18	18:58	40.13842	-122.20849	Vegetation	Rural	< 3 meters	Unknown	N.A.	101538131	Unknown	12,000	Conductor	Overhead	Yes	7/10/18	18:58
1741	PG&E	7/11/18	2:11	37.71042	-121.47328	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	Page 7/8	None	115,000	Conductor	Overhead	Yes	7/11/18	2:11
1742	PG&E	7/11/18	10:10	37.07247	-120.94945	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	103920696	None	12,000	Conductor	Overhead	Yes	7/11/18	10:10
1743	PG&E	7/13/18	8:10	37.09974	-120.83611	Vegetation	Rural	< 3 meters	Fire Agency	Merced FD	101178812	Unknown	12,000	Capacitor Bank	Overhead	No	N.A.	N.A.
1744	PG&E	7/13/18	10:59	38.48359	-123.79238	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	102184869	AT&T	12,000	Conductor	Overhead	Yes	7/13/18	10:59
1745	PG&E	7/13/18	15:45	40.48310	-122.32250	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	103160260	Unknown	12,000	Conductor	Overhead	Yes	7/13/18	15:45
1746	PG&E	7/13/18	18:51	39.77898	-122.14092	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100421715	Unknown	12,000	Conductor	Overhead	Yes	7/13/18	18:51
1747	PG&E	7/14/18	11:34	38.40265	-122.54891	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	103141862	Verizon	12,000	Conductor	Overhead	Yes	7/14/18	11:34
1748	PG&E	7/14/18	12:40	38.57926	-122.87798	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103122744	AT&T	12,000	Conductor	Overhead	Yes	7/14/18	12:40
1749	PG&E	7/14/18	12:56	39.20931	-121.19695	Vegetation	Rural	< 0.25 Acres	Fire Agency	FIRE DEPT LEFT BEFORE UPTAINING THAT INFO	100086833	None	21,000	Conductor	Overhead	Yes	7/14/18	12:56
1750	PG&E	7/14/18	14:44	38.95242	-121.24673	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100035452	AT&T	12,000	Conductor	Overhead	Yes	7/14/18	14:44
1751	PG&E	7/14/18	15:01	37.83874	-121.01651	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	102330872	Unknown	17,000	Conductor	Overhead	Yes	7/14/18	15:01
1752	PG&E	7/14/18	15:58	35.42813	-119.05902	Vegetation	Urban	< 3 meters	Unknown	N.A.	100238826	None	12,000	Conductor	Overhead	Yes	7/14/18	15:58
1753	PG&E	7/14/18	21:38	36.33141	-121.88287	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	ASSISTED JAIMIE	101672234	Unknown	12,000	Conductor	Overhead	Yes	7/14/18	21:38
1754	PG&E	7/15/18	10:06	35.53008	-119.07180	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	100206898	Unknown	12,000	Conductor	Overhead	Yes	7/15/18	10:06
1755	PG&E	7/16/18	12:57	35.59011	-120.64335	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101904896	Unknown	21,000	Capacitor Bank	Overhead	Yes	7/16/18	12:57
1756	PG&E	7/17/18	5:59	37.93801	-122.51415	Vegetation	Rural	< 3 meters	Unknown	N.A.	102231901	Unknown	12,000	Conductor	Overhead	Yes	7/17/18	5:59
1757	PG&E	7/17/18	11:11	35.69857	-120.97769	Vegetation	Rural	10 - 99 Acres	Fire Agency	dennis byrnes 8055434244 inc # = 18ca-slu-007640	103886652	Unknown	21,000	Conductor	Overhead	Yes	7/17/18	11:11
1758	PG&E	7/17/18	11:58	37.22171	-121.67779	Vegetation	Rural	< 0.25 Acres	Fire Agency	Luis Morado state arson fire fighter	100601345	Unknown	12,000	Conductor	Overhead	Yes	7/17/18	11:58
1759	PG&E	7/17/18	15:16	39.00625	-122.87632	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102158497	Unknown	0 - 750	Conductor	Overhead	Yes	7/17/18	15:16
1760	PG&E	7/17/18	15:53	35.34975	-119.03619	Vegetation	Urban	< 3 meters	Unknown	N.A.	100244890	Yes	0 - 750	Conductor	Overhead	Yes	7/17/18	15:53
1761	PG&E	7/17/18	16:53	38.39550	-122.92120	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	101978449	AT&T	12,000	Conductor	Overhead	Yes	7/17/18	16:53
1762	PG&E	7/17/18	19:40	40.59275	-122.48956	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101477082	AT&T	12,000	Conductor	Overhead	Yes	7/17/18	19:40
1763	PG&E	7/18/18	1:14	38.36778	-120.55778	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	101247987	Unknown	12,000	Conductor	Overhead	Yes	7/18/18	1:14
1764	PG&E	7/18/18	3:46	37.12669	-121.65967	Vegetation	Urban	< 3 meters	Unknown	N.A.	103426203	None	21,000	Conductor	Overhead	Yes	7/18/18	3:46
1765	PG&E	7/18/18	7:16	35.61704	-119.19527	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	103909160	None	12,000	Conductor	Overhead	Yes	7/18/18	7:16
1766	PG&E	7/18/18	11:19	39.07137	-121.46298	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	101324059	Unknown	12,000	Conductor	Overhead	Yes	7/18/18	11:19
1767	PG&E	7/18/18	14:50	38.99819	-121.31662	Vegetation	Rural	10 - 99 Acres	Fire Agency	Fire Insp. Cris Mertens 530-277-2322	100028525	Unknown	12,000	Conductor	Overhead	Yes	7/18/18	14:50
1768	PG&E	7/19/18	0:08	36.93722	-119.45570	Vegetation	Rural	< 0.25 Acres	Fire Agency	incident # 10559	100677019	AT&T	12,000	Conductor	Overhead	Yes	7/19/18	0:08
1769	PG&E	7/19/18	5:29	40.19184	-123.53734	Vegetation	Rural	< 0.25 Acres	Fire Agency	fire captain	100939802	Unknown	12,000	Conductor	Overhead	Yes	7/19/18	5:29
1770	PG&E	7/19/18	10:44	36.22216	-119.77959	Vegetation	Rural	< 3 meters	Utility: PG&E	N.A.	103369868	Unknown	12,000	Conductor	Overhead	Yes	7/19/18	10:44
1771	PG&E	7/19/18	15:03	38.23101	-122.14948	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103919648	Unknown	12,000	Capacitor Bank	Overhead	Yes	7/19/18	15:03
1772	PG&E	7/19/18	15:52	36.61023	-119.63824	Vegetation	Rural	< 3 meters	Unknown	N.A.	100842711	Unknown	12,000	Conductor	Overhead	Yes	7/19/18	15:52
1773	PG&E	7/20/18	6:31	37.43176	-119.94411	Vegetation	Rural	< 0.25 Acres	Fire Agency	ZACH RUTHERFORD 209-966-3621	103909942	Unknown	0 - 750	Conductor	Overhead	Yes	7/20/18	6:31
1774	PG&E	7/20/18	15:36															

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
2	Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
3	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	
1786	PG&E	7/24/18	9:00	37.98384	-122.06370	Vegetation	Rural	< 3 meters	Fire Agency	Contra Costa FD	100460575	Unknown	21,000	Transformer	Overhead	Yes	7/24/18	9:00
1787	PG&E	7/24/18	13:01	37.13422	-120.14398	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	chief Vance Killion	101061631	Unknown	12,000	Conductor	Overhead	Yes	7/24/18	13:01
1788	PG&E	7/24/18	13:47	39.06057	-123.44560	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	102212216	Unknown	12,000	Conductor	Overhead	Yes	7/24/18	13:47
1789	PG&E	7/24/18	21:08	37.35270	-122.39898	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100318130	AT&T	12,000	Conductor	Overhead	Yes	7/24/18	21:08
1790	PG&E	7/25/18	0:42	39.77908	-121.61734	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	100327443	Unknown	12,000	Conductor	Overhead	Yes	7/25/18	0:42
1791	PG&E	7/25/18	12:19	37.25536	-121.00930	Vegetation	Urban	< 3 meters	Customer	N.A.	101219602	AT&T	0 - 750	Conductor	Overhead	Yes	7/25/18	12:19
1792	PG&E	7/25/18	23:16	38.40317	-121.93911	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	VACAVILLE FIRE OFF EUBANKS	101599788	Unknown	12,000	Conductor	Overhead	Yes	7/25/18	23:16
1793	PG&E	7/26/18	19:23	39.25587	-122.47487	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	JEREMIAH KARLONAS 530-473-2615	100330499	Unknown	12,000	Conductor	Overhead	Yes	7/26/18	19:23
1794	PG&E	7/26/18	20:42	40.35514	-122.34441	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	101509573	Unknown	12,000	Conductor	Overhead	Yes	7/26/18	20:42
1795	PG&E	7/27/18	23:12	37.18004	-122.02903	Vegetation	Rural	< 3 meters	Fire Agency	Jeremy Wise 408-378-4010 Incident # C182080066	100518365	Unknown	12,000	Conductor	Overhead	Yes	7/27/18	23:12
1796	PG&E	7/28/18	6:51	38.74729	-120.78658	Vegetation	Rural	< 3 meters	Fire Agency	Unknown	101418155	AT&T	21,000	Conductor	Overhead	Yes	7/28/18	6:51
1797	PG&E	7/28/18	8:47	37.88020	-122.08041	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	100493058	Yes	12,000	Conductor	Overhead	Yes	7/28/18	8:47
1798	PG&E	7/29/18	11:39	39.09685	-123.50179	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	102177329	Unknown	12,000	Conductor	Overhead	Yes	7/29/18	11:39
1799	PG&E	7/29/18	17:29	38.57772	-120.85558	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101383255	AT&T	0 - 750	Conductor	Overhead	Yes	7/29/18	17:29
1800	PG&E	7/30/18	7:49	37.73697	-122.18775	Building	Urban	Structure Only	Unknown	N.A.	103753582	Unknown	21,000	Conductor	Overhead	Yes	7/30/18	7:49
1801	PG&E	7/30/18	8:50	40.10641	-123.71382	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	100986799	Unknown	12,000	Conductor	Overhead	Yes	7/30/18	8:50
1802	PG&E	7/30/18	14:36	38.19875	-120.36382	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	NICK WEBB (209) 532-7424	103336176	Unknown	17,000	Conductor	Overhead	Yes	7/30/18	14:36
1803	PG&E	7/30/18	22:01	38.39416	-120.93401	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	101733550	Unknown	21,000	Conductor	Overhead	Yes	7/30/18	22:01
1804	PG&E	7/31/18	7:07	37.82118	-121.44998	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102065265	Unknown	12,000	Conductor	Overhead	Yes	7/31/18	7:07
1805	PG&E	7/31/18	7:57	38.95586	-122.72744	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102162351	AT&T	12,000	Conductor	Overhead	Yes	7/31/18	7:57
1806	PG&E	7/31/18	11:01	40.13320	-122.23440	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	103133510	Unknown	0 - 750	Conductor	Overhead	Yes	7/31/18	11:01
1807	PG&E	8/1/18	17:58	39.91551	-122.79896	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	102156435	Unknown	12,000	Conductor	Overhead	Yes	8/1/18	17:58
1808	PG&E	8/1/18	19:06	40.82022	-124.18345	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100985844	AT&T	12,000	Conductor	Overhead	Yes	8/1/18	19:06
1809	PG&E	8/2/18	9:48	39.47680	-121.53945	Vegetation	Rural	< 3 meters	Fire Agency	Unknown	100370637	Unknown	12,000	Conductor	Overhead	Yes	8/2/18	9:48
1810	PG&E	8/2/18	15:54	38.93240	-122.74920	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Kelsey cobb station 707-2794924 kits incident	102162100	Unknown	12,000	Conductor	Overhead	Yes	8/2/18	15:54
1811	PG&E	8/2/18	17:34	37.05025	-120.54118	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101114879	None	12,000	Conductor	Overhead	Yes	8/2/18	17:34
1812	PG&E	8/2/18	20:27	38.15130	-121.07777	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102072797	AT&T	21,000	Conductor	Overhead	Yes	8/2/18	20:27
1813	PG&E	8/3/18	0:09	38.96687	-120.05966	Vegetation	Urban	< 0.25 Acres	Fire Agency	Madera County	101225731	AT&T	0 - 750	Conductor	Overhead	Yes	8/3/18	0:09
1814	PG&E	8/3/18	9:45	40.49884	-121.83815	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	ZEIGGLER	101492431	Frontier	12,000	Conductor	Overhead	Yes	8/3/18	9:45
1815	PG&E	8/3/18	16:13	37.87650	-122.08878	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	VIC MASSENKOFF 925-941-3541 CASE # 18-7909	100491885	None	12,000	Conductor	Overhead	Yes	8/3/18	16:13
1816	PG&E	8/3/18	19:19	38.43857	-118.79685	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	102003794	AT&T	12,000	Conductor	Overhead	Yes	8/3/18	19:19
1817	PG&E	8/3/18	19:51	38.66547	-121.78432	Vegetation	Urban	< 3 meters	Fire Agency	Woodland FD	101607437	Unknown	12,000	Conductor	Overhead	Yes	8/3/18	19:51
1818	PG&E	8/4/18	6:21	37.27405	-120.63362	Vegetation	Rural	< 3 meters	Unknown	N.A.	101145547	Unknown	12,000	Conductor	Overhead	Yes	8/4/18	6:21
1819	PG&E	8/4/18	7:22	37.97561	-122.55374	Building	Urban	Structure Only	Fire Agency	ROSS VALLEY	102241252	AT&T	12,000	Conductor	Overhead	Yes	8/4/18	7:22
1820	PG&E	8/4/18	14:33	38.92620	-121.42090	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	100034761	AT&T	12,000	Conductor	Overhead	Yes	8/4/18	14:33
1821	PG&E	8/4/18	17:18	37.04721	-122.03294	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101798912	AT&T	21,000	Conductor	Overhead	Yes	8/4/18	17:18
1822	PG&E	8/5/18	13:40	37.31777	-121.85154	Vegetation	Urban	< 0.25 Acres	Fire Agency	San Jose FD	103542217	Unknown	0 - 750	Conductor	Overhead	Yes	8/5/18	13:40
1823	PG&E	8/5/18	13:56	37.40055	-119.75320	Vegetation	Rural	10 - 99 Acres	Fire Agency	JIM FORGA 209-966-3621	101017235	Unknown	12,000	Conductor	Overhead	Yes	8/5/18	13:56
1824	PG&E	8/6/18	17:27	39.33610	-121.59815	Vegetation	Rural	< 3 meters	Unknown	N.A.	100393693	Yes	12,000	Conductor	Overhead	Yes	8/6/18	17:27
1825	PG&E	8/7/18	9:47	38.65561	-121.02259	Vegetation	Urban	< 3 meters	Fire Agency	CAL FIRE	103902317	AT&T	21,000	Conductor	Overhead	Yes	8/7/18	9:47
1826	PG&E	8/7/18	10:19	38.10522	-120.49777	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101282323	Unknown	17,000	Lightning Arrestor	Overhead	Yes	8/7/18	10:19
1827	PG&E	8/7/18	15:22	36.79895	-119.76457	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	103278630	Unknown	0 - 750	Conductor	Overhead	Yes	8/7/18	15:22
1828	PG&E	8/7/18	15:46	40.44652	-122.44598	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101464611	Unknown	0 - 750	Conductor	Overhead	Yes	8/7/18	15:46
1829	PG&E	8/7/18	17:15	37.11812	-122.10927	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101670606	AT&T	12,000	Conductor	Overhead	Yes	8/7/18	17:15
1830	PG&E	8/7/18	21:03	38.21293	-120.91836	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102042811	Unknown	12,000	Conductor	Overhead	Yes	8/7/18	21:03
1831	PG&E	8/8/18	10:03	40.79333	-124.02417	Vegetation	Rural	< 0.25 Acres	Fire Agency	CHIEF	100983089	Unknown	12,000	Conductor	Overhead	Yes	8/8/18	10:03
1832	PG&E	8/8/18	16:02	36.47034	-121.71429	Vegetation	Rural	< 3 meters	Customer	N.A.	103910535	None	12,000	Conductor	Overhead	Yes	8/8/18	16:02
1833	PG&E	8/8/18	16:03	37.29739	-122.26507	Vegetation	Rural	< 3 meters	Utility: PG&E	N.A.	100307515	Unknown	12,000	Conductor	Overhead	Yes	8/8/18	16:03
1834	PG&E	8/10/18	12:54	38.79902	-120.72997	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	101386272	AT&T	12,000	Conductor	Overhead	Yes	8/10/18	12:54
1835	PG&E	8/10/18	15:39	38.20251	-122.15789	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103697205	Unknown	12,000	Conductor	Overhead	Yes	8/10/18	15:39
1836	PG&E	8/10/18	19:18	35.76524	-120.31365	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	18ca-slu-00872 dennis 805 543 4244	101876421	Unknown	21,000	Conductor	Overhead	Yes	8/10/18	19:18
1837	PG&E	8/10/18	20:18	39.20932	-121.06149	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100075517	AT&T	12,000	Conductor	Overhead	Yes	8/10/18	20:18
1838	PG&E	8/11/18	16:58	38.19525	-120.67578	Vegetation	Rural	< 0.25 Acres	Fire Agency	DON YOUNG	101250814	Unknown	12,000	Conductor	Overhead	Yes	8/11/18	16:58
1839	PG&E	8/12/18	11:42	35.63265	-119.25446	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101409652	None	12,000	Conductor	Overhead	Yes	8/12/18	11:42
1840	PG&E	8/12/18	14:46	38.64428	-120.92115	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101410516	Unknown	21,000	Conductor	Overhead	Yes	8/12/18	14:46
1841	PG&E	8/13/18	15:11	37.88318	-121.24832	Vegetation	Rural	< 3 meters	Unknown	N.A.	102137301	Unknown	12,000	Conductor	Overhead	Yes	8/13/18	15:11
1842	PG&E	8/13/18	15:33	38.70800	-120.96247	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101377799	Unknown	21,000	Conductor	Overhead	Yes	8/13/18	15:33
1843	PG&E	8/13/18	18:43	36.22648	-121.11113	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	101729151	Unknown	12,000	Conductor	Overhead	Yes	8/13/18	18:43
1844	PG&E	8/14/18	6:43	40.68604	-122.14102	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	J.L. zulliger 530-225-2420	103379843	Unknown	12,000	Conductor	Overhead	Yes	8/14/18	6:43
1845	PG&E	8/14/18	15:18	36.96557	-121.86813	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101328221	AT&T	21,000	Conductor	Overhead	Yes	8/14/18	15:18
1846	PG&E	8/14/18	15:46	38.08782	-122.60016	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103916882	Verizon	0 - 750	Conductor	Overhead	Yes	8/14/18	15:46
1847	PG&E	8/17/18	9:38	40.29968	-122.33216	Vegetation	Rural	< 0.25 Acres	Fire Agency	chief	101509747	AT&T	12,000	Conductor	Overhead	Yes	8/17/18	9:38
1848	PG&E	8/17/18	17:18	37.52578	-121.96984	Vegetation	Urban	< 3 meters	Self Extinguished	N.A.	100946234	AT&T	0 - 750	Conductor	Overhead	Yes	8/17/18	17:18
1849	PG&E	8/18/18	6:15	38.40263	-121.9634													

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Column5	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
2	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	
1862	PG&E	8/26/18	15:29	39.35990	-121.12090	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	100107472	Unknown	12,000	Conductor	Overhead	Yes	8/26/18	15:29
1863	PG&E	8/26/18	16:50	39.75851	-123.23590	Vegetation	Rural	< 0.25 Acres	Fire Agency	HOWARD FOREST	102183272	Verizon	12,000	Conductor	Overhead	Yes	8/26/18	16:50
1864	PG&E	8/27/18	5:54	36.78654	-119.52214	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100798371	Unknown	12,000	Conductor	Overhead	Yes	8/27/18	5:54
1865	PG&E	8/27/18	13:56	37.01266	-121.60258	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	103918532	Verizon	21,000	Conductor	Overhead	Yes	8/27/18	13:56
1866	PG&E	8/27/18	16:45	36.74888	-119.74714	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	100845137	Unknown	0 - 750	Conductor	Overhead	Yes	8/27/18	16:45
1867	PG&E	8/28/18	2:00	36.56454	-119.60596	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100864815	AT&T	12,000	Conductor	Overhead	Yes	8/28/18	2:00
1868	PG&E	8/28/18	12:50	40.21391	-123.59660	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	100994840	Unknown	12,000	Conductor	Overhead	Yes	8/28/18	12:50
1869	PG&E	8/28/18	16:14	39.72843	-123.19955	Vegetation	Rural	< 0.25 Acres	Fire Agency	howard forest	102174042	AT&T	12,000	Conductor	Overhead	Yes	8/28/18	16:14
1870	PG&E	8/29/18	16:19	38.77321	-121.43101	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	103918537	Unknown	12,000	Conductor	Overhead	Yes	8/29/18	16:19
1871	PG&E	8/30/18	15:38	38.25442	-122.57541	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	101990006	Unknown	12,000	Conductor	Overhead	Yes	8/30/18	15:38
1872	PG&E	8/31/18	5:07	36.78753	-119.65516	Vegetation	Rural	< 0.25 Acres	Fire Agency	CLOVIS F.D.	103281848	None	12,000	Conductor	Overhead	Yes	8/31/18	5:07
1873	PG&E	8/31/18	12:30	37.99166	-121.34775	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	103193823	Unknown	21,000	Conductor	Overhead	Yes	8/31/18	12:30
1874	PG&E	8/31/18	13:02	40.47750	-122.48470	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103918932	Unknown	12,000	Conductor	Overhead	Yes	8/31/18	13:02
1875	PG&E	8/31/18	18:04	39.57850	-123.38420	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	102196393	Unknown	12,000	Conductor	Overhead	Yes	8/31/18	18:04
1876	PG&E	8/31/18	18:09	37.05480	-122.04720	Vegetation	Urban	< 0.25 Acres	Fire Agency	CAL FIRE	101803212	Unknown	21,000	Conductor	Overhead	Yes	8/31/18	18:09
1877	PG&E	9/1/18	14:25	36.80878	-121.59157	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	Tw 35/222	None	115,000	Conductor	Overhead	Yes	9/1/18	14:25
1878	PG&E	9/2/18	15:36	37.47140	-122.42476	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Arie Delay 659-740-4636	Unknown	12,000	Capacitor Bank	Overhead	Yes	9/2/18	15:36	
1879	PG&E	9/2/18	16:11	37.26526	-121.80508	Vegetation	Urban	< 3 meters	Unknown	N.A.	103436542	Unknown	0 - 750	Conductor	Overhead	Yes	9/2/18	16:11
1880	PG&E	9/2/18	23:18	37.79415	-121.57733	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102051470	Unknown	12,000	Conductor	Overhead	Yes	9/2/18	23:18
1881	PG&E	9/3/18	12:00	38.91813	-121.54354	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	Str. 017/369	None	60,000	Conductor	Overhead	Yes	9/3/18	12:00
1882	PG&E	9/3/18	18:29	39.45473	-121.49546	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100395672	Unknown	12,000	Conductor	Overhead	Yes	9/3/18	18:29
1883	PG&E	9/5/18	11:39	38.99704	-121.54269	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	101331539	Unknown	21,000	Conductor	Overhead	Yes	9/5/18	11:39
1884	PG&E	9/5/18	16:55	37.46554	-119.90052	Vegetation	Rural	< 0.25 Acres	Fire Agency	JON BERRY 209-966-4700	101087053	Unknown	21,000	Conductor	Overhead	Yes	9/5/18	16:55
1885	PG&E	9/5/18	17:34	39.25862	-123.20168	Vegetation	Rural	< 3 meters	Fire Agency	redwood valley fire	102202457	Unknown	12,000	Conductor	Overhead	Yes	9/5/18	17:34
1886	PG&E	9/5/18	20:02	39.75452	-123.22021	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	102183324	AT&T	12,000	Conductor	Overhead	Yes	9/5/18	20:02
1887	PG&E	9/6/18	1:19	37.05981	-121.01695	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	Pole 088/386	None	70,000	Conductor	Overhead	Yes	9/6/18	1:19
1888	PG&E	9/6/18	16:19	39.09040	-120.94637	Vegetation	Rural	< 3 meters	Unknown	N.A.	100200676	Unknown	12,000	Conductor	Overhead	Yes	9/6/18	16:19
1889	PG&E	9/9/18	4:25	38.65336	-122.85384	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	Pole 13/1	None	60,000	Conductor	Overhead	Yes	9/9/18	4:25
1890	PG&E	9/10/18	7:05	35.04227	-120.56735	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101924034	Unknown	12,000	Conductor	Overhead	Yes	9/10/18	7:05
1891	PG&E	9/10/18	20:37	38.01883	-122.72246	Vegetation	Rural	100 - 299 Acres	Fire Agency	Unknown	102252760	Unknown	12,000	Conductor	Overhead	Yes	9/10/18	20:37
1892	PG&E	9/10/18	21:25	37.09844	-120.25827	Building	Rural	Structure Only	Unknown	N.A.	101129394	Unknown	12,000	Conductor	Overhead	Yes	9/10/18	21:25
1893	PG&E	9/11/18	5:23	37.37604	-119.63036	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	TROY CHEEK 209-966-3621	101023184	Unknown	12,000	Conductor	Overhead	Yes	9/11/18	5:23
1894	PG&E	9/11/18	11:19	36.42132	-120.86274	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	101928875	Unknown	12,000	Conductor	Overhead	Yes	9/11/18	11:19
1895	PG&E	9/11/18	18:51	38.39580	-121.63819	Vegetation	Rural	10 - 99 Acres	Unknown	N.A.	101586871	AT&T	12,000	Conductor	Overhead	Yes	9/11/18	18:51
1896	PG&E	9/11/18	21:44	34.85530	-119.48640	Vegetation	Rural	< 0.25 Acres	Fire Agency	Santa Barbara Co. FD	100165137	Unknown	21,000	Conductor	Overhead	Yes	9/11/18	21:44
1897	PG&E	9/12/18	19:38	38.12284	-121.81251	Building	Rural	Structure Only	Fire Agency	Solano FD	101566543	Unknown	21,000	Conductor	Overhead	Yes	9/12/18	19:38
1898	PG&E	9/13/18	9:02	40.17464	-122.24122	Vegetation	Urban	< 0.25 Acres	Fire Agency	Red Bluff FD	101541885	Unknown	0 - 750	Conductor	Overhead	Yes	9/13/18	9:02
1899	PG&E	9/14/18	9:06	40.13357	-122.20490	Vegetation	Rural	< 3 meters	Unknown	N.A.	101537662	Unknown	12,000	Capacitor Bank	Overhead	Yes	9/14/18	9:06
1900	PG&E	9/14/18	15:08	35.32890	-120.69820	Vegetation	Rural	< 0.25 Acres	Fire Agency	Sean Hernandez Cell # 805 903 3423	103400199	Unknown	12,000	Conductor	Overhead	Yes	9/14/18	15:08
1901	PG&E	9/15/18	3:47	35.44166	-119.16139	Vegetation	Rural	< 3 meters	Unknown	N.A.	103920769	Unknown	21,000	Conductor	Overhead	Yes	9/15/18	3:47
1902	PG&E	9/15/18	9:57	38.69380	-122.83201	Vegetation	Rural	< 3 meters	Customer	N.A.	102034048	AT&T	0 - 750	Conductor	Overhead	Yes	9/15/18	9:57
1903	PG&E	9/15/18	13:34	37.24642	-120.43757	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101154147	None	0 - 750	Conductor	Overhead	Yes	9/15/18	13:34
1904	PG&E	9/16/18	8:10	37.99530	-122.28336	Vegetation	Urban	< 3 meters	Unknown	N.A.	101425698	Unknown	12,000	Conductor	Overhead	Yes	9/16/18	8:10
1905	PG&E	9/16/18	8:26	35.30460	-120.63891	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	Pole 4/23A	None	70,000	Conductor	Overhead	Yes	9/16/18	8:26
1906	PG&E	9/16/18	10:22	39.46272	-123.78374	Vegetation	Rural	< 3 meters	Fire Agency	Unknown	102184303	AT&T	12,000	Conductor	Overhead	Yes	9/16/18	10:22
1907	PG&E	9/17/18	16:05	36.81454	-119.97953	Vegetation	Rural	< 0.25 Acres	Fire Agency	Fresno FD	100664916	None	12,000	Conductor	Overhead	Yes	9/17/18	16:05
1908	PG&E	9/19/18	6:04	37.53154	-120.32842	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	Pole 13/4	None	70,000	Conductor	Overhead	Yes	9/19/18	6:04
1909	PG&E	9/21/18	11:26	37.74484	-121.51356	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102064462	AT&T	12,000	Conductor	Overhead	Yes	9/21/18	11:26
1910	PG&E	9/21/18	21:10	39.02733	-122.66269	Vegetation	Rural	< 3 meters	Customer	N.A.	102147414	Unknown	12,000	Conductor	Overhead	Yes	9/21/18	21:10
1911	PG&E	9/21/18	23:02	38.64276	-122.74533	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	102218862	Unknown	12,000	Conductor	Overhead	Yes	9/21/18	23:02
1912	PG&E	9/22/18	17:56	37.01270	-120.84586	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101198814	None	12,000	Fuse	Overhead	Yes	9/22/18	17:56
1913	PG&E	9/23/18	3:18	38.41600	-121.73033	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	101587125	AT&T	12,000	Conductor	Overhead	Yes	9/23/18	3:18
1914	PG&E	9/23/18	15:57	37.33503	-121.76787	Vegetation	Urban	10 - 99 Acres	Fire Agency	San Jose FD	100567722	AT&T	21,000	Conductor	Overhead	Yes	9/23/18	15:57
1915	PG&E	9/24/18	0:35	39.81524	-121.64376	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	Pole 3/42B	None	60,000	Conductor	Overhead	Yes	9/24/18	0:35
1916	PG&E	9/24/18	12:07	37.59527	-122.01753	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	103505364	Unknown	12,000	Conductor	Overhead	Yes	9/24/18	12:07
1917	PG&E	9/24/18	17:06	37.26154	-121.93570	Vegetation	Urban	< 3 meters	Unknown	N.A.	100521762	Unknown	12,000	Conductor	Overhead	Yes	9/24/18	17:06
1918	PG&E	9/27/18	3:40	37.54733	-120.32552	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	Tw 12/2	None	70,000	Conductor	Overhead	Yes	9/27/18	3:40
1919	PG&E	9/27/18	12:43	38.51481	-122.44626	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	Tw 000/010	None	60,000	Conductor	Overhead	Yes	9/27/18	12:43
1920	PG&E	9/27/18	15:25	36.50078	-119.29129	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100779012	Unknown	0 - 750	Conductor	Overhead	Yes	9/27/18	15:25
1921	PG&E	9/27/18	17:19	36.54978	-120.38933	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	103921482	Verizon	12,000	Conductor	Overhead	Yes	9/27/18	17:19
1922	PG&E	9/28/18	4:31	36.23070	-119.09219	Vegetation	Rural	< 3 meters	Unknown	N.A.	100162524	Unknown	12,000	Conductor	Overhead	Yes	9/28/18	4:31
1923	PG&E	9/28/18	9:55	37.05639	-120.80083	Vegetation	Rural	< 3 meters	Unknown	N.A.	Pole 23/8	None	70,000	Conductor	Overhead	Yes	9/28/18	9:55
1924	PG&E	9/29/18	13:11	40.90611	-124.06250	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	100973832	Unknown	12,000	Conductor	Overhead	Yes	9/29/18	13:11
1925	PG&E	9/29/18	16:16	41.02195	-123.65500	Vegetation	Rural	< 0.25 Acres	Fire Agency	Hoopa Fire Dept	100962165	Unknown	12,000	Conductor	Overhead	Yes	9/29/18	16:16
1926	PG&E	9/30/18	14:40	39														

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
2	Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
3	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	
1944	PG&E	10/16/18	10:44	40.50968	-124.16239	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	101004106	Unknown	12,000	Conductor	Overhead	Yes	10/16/18	10:44
1945	PG&E	10/16/18	16:30	38.77543	-122.89759	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	MARK GRADEK (707) 889-4303	100962692	AT&T	12,000	Conductor	Overhead	Yes	10/16/18	16:30
1946	PG&E	10/17/18	17:41	38.03115	-121.93343	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100450321	Unknown	21,000	Conductor	Overhead	Yes	10/17/18	17:41
1947	PG&E	10/19/18	15:45	35.03947	-120.47629	Vegetation	Urban	< 3 meters	Unknown	N.A.	101893816	AT&T	0 - 750	Conductor	Overhead	Yes	10/19/18	15:45
1948	PG&E	10/20/18	8:01	35.00767	-120.49377	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101893623	Unknown	12,000	Conductor	Overhead	Yes	10/20/18	8:01
1949	PG&E	10/20/18	14:31	40.52180	-124.11374	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	Str. 003/000	None	60,000	Conductor	Overhead	Yes	10/20/18	14:31
1950	PG&E	10/21/18	0:32	35.50348	-120.60252	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101886776	Unknown	21,000	Conductor	Overhead	Yes	10/21/18	0:32
1951	PG&E	10/24/18	7:08	37.94751	-120.26713	Vegetation	Rural	< 0.25 Acres	Fire Agency	SCOTT PITTMAN 209-768-8182 TCU INCIDENT# 012528	101047865	Unknown	17,000	Conductor	Overhead	Yes	10/24/18	7:08
1952	PG&E	10/24/18	14:18	36.72648	-119.10859	Vegetation	Rural	10 - 99 Acres	Fire Agency	CHRIS CHRISTOPHERSON (559)493-4320 I.C. #18CAFKUJ015649	100691946	None	12,000	Conductor	Overhead	Yes	10/24/18	14:18
1953	PG&E	10/25/18	18:47	35.55662	-118.81679	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	GREG BLACK (661)391-7000	100203660	None	0 - 750	Conductor	Overhead	Yes	10/25/18	18:47
1954	PG&E	10/26/18	2:11	37.75530	-122.43449	Vegetation	Urban	< 3 meters	Unknown	N.A.	101838487	AT&T	0 - 750	Conductor	Overhead	Yes	10/26/18	2:11
1955	PG&E	10/26/18	20:55	40.15279	-122.36340	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAPT. ROB WAELEY 530-527-6113	101553579	Unknown	12,000	Conductor	Overhead	Yes	10/26/18	20:55
1956	PG&E	10/28/18	8:50	36.37919	-121.84544	Vegetation	Rural	< 0.25 Acres	Fire Agency	TONY (831) 625-6415	101672342	Unknown	12,000	Conductor	Overhead	Yes	10/28/18	8:50
1957	PG&E	10/29/18	19:09	39.46452	-122.24875	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100343112	None	21,000	Conductor	Overhead	Yes	10/29/18	19:09
1958	PG&E	10/30/18	15:40	37.17790	-120.63088	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101185288	Unknown	12,000	Conductor	Overhead	Yes	10/30/18	15:40
1959	PG&E	10/31/18	12:50	37.33476	-121.93699	Vegetation	Urban	< 3 meters	Fire Agency	San Jose FD	103780642	AT&T	12,000	Capacitor Bank	Overhead	Yes	10/31/18	12:50
1960	PG&E	11/1/18	20:45	38.37200	-123.05070	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	103852431	AT&T	12,000	Conductor	Overhead	Yes	11/1/18	20:45
1961	PG&E	11/7/18	15:49	37.00035	-121.98019	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	101684527	Unknown	21,000	Capacitor Bank	Overhead	Yes	11/7/18	15:49
1962	PG&E	11/9/18	11:41	34.86490	-120.34016	Vegetation	Rural	10 - 99 Acres	Unknown	N.A.	101862240	Verizon	12,000	Conductor	Overhead	Yes	11/9/18	11:41
1963	PG&E	11/8/18	13:19	38.78841	-120.15288	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101407690	AT&T	21,000	Conductor	Overhead	Yes	11/8/18	13:19
1964	PG&E	11/8/18	21:30	36.72636	-119.49865	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	103818023	Unknown	12,000	Conductor	Overhead	Yes	11/8/18	21:30
1965	PG&E	11/9/18	4:49	39.82344	-121.83816	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	100402367	AT&T	12,000	Conductor	Overhead	Yes	11/9/18	4:49
1966	PG&E	11/9/18	8:59	37.28095	-122.12144	Vegetation	Rural	26 - 9.99 Acres	Unknown	N.A.	100546562	AT&T	12,000	Conductor	Overhead	Yes	11/9/18	8:59
1967	PG&E	11/9/18	15:34	35.05121	-118.81118	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	103930710	None	12,000	Conductor	Overhead	Yes	11/9/18	15:34
1968	PG&E	11/10/18	13:31	37.04673	-121.98533	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	101671641	Unknown	21,000	Conductor	Overhead	Yes	11/10/18	13:31
1969	PG&E	11/11/18	4:18	38.43408	-122.55220	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102032588	Unknown	0 - 750	Conductor	Overhead	Yes	11/11/18	4:18
1970	PG&E	11/11/18	10:40	37.09842	-120.74163	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	103934503	Unknown	12,000	Conductor	Overhead	Yes	11/11/18	10:40
1971	PG&E	11/11/18	13:06	37.32020	-122.00234	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	103927631	AT&T	12,000	Capacitor Bank	Overhead	Yes	11/11/18	13:06
1972	PG&E	11/12/18	5:17	38.48517	-122.80465	Vegetation	Rural	< 3 meters	Unknown	N.A.	102207067	Unknown	12,000	Conductor	Overhead	Yes	11/12/18	5:17
1973	PG&E	11/12/18	14:39	36.99296	-120.03718	Vegetation	Rural	< 3 meters	Unknown	N.A.	101015260	AT&T	12,000	Conductor	Overhead	Yes	11/12/18	14:39
1974	PG&E	11/13/18	11:34	34.99420	-118.99239	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100195031	None	0 - 750	Conductor	Overhead	Yes	11/13/18	11:34
1975	PG&E	11/13/18	15:41	37.06438	-121.95780	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101680441	AT&T	0 - 750	Conductor	Overhead	Yes	11/13/18	15:41
1976	PG&E	11/15/18	6:09	38.35991	-122.36818	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102241814	AT&T	0 - 750	Conductor	Overhead	Yes	11/15/18	6:09
1977	PG&E	11/15/18	6:34	38.60816	-120.95323	Vegetation	Rural	< 0.25 Acres	Self Extinguished	N.A.	101417470	Unknown	12,000	Conductor	Overhead	Yes	11/15/18	6:34
1978	PG&E	11/16/18	17:02	38.75743	-120.90115	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101409894	AT&T	21,000	Conductor	Overhead	Yes	11/16/18	17:02
1979	PG&E	11/17/18	17:20	38.70824	-120.99266	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	104213139	Unknown	12,000	Conductor	Overhead	Yes	11/17/18	17:20
1980	PG&E	11/18/18	1:37	34.95261	-120.43642	Other	Urban	< 3 meters	Unknown	N.A.	103420365	N.A.	12,000	Transformer	Padmounted	Yes	11/18/18	1:37
1981	PG&E	11/18/18	14:31	40.79679	-124.13375	Building	Rural	Structure Only	Fire Agency	Unknown	100794898	Unknown	0 - 750	Conductor	Overhead	Yes	11/18/18	14:31
1982	PG&E	11/19/18	9:46	38.50528	-121.89559	Vegetation	Rural	< 3 meters	Unknown	N.A.	101577202	Unknown	12,000	Conductor	Overhead	Yes	11/19/18	9:46
1983	PG&E	11/20/18	13:07	35.30425	-120.80477	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101928023	Unknown	12,000	Conductor	Overhead	Yes	11/20/18	13:07
1984	PG&E	11/21/18	2:16	40.43827	-124.38470	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101005309	Frontier	12,000	Conductor	Overhead	Yes	11/21/18	2:16
1985	PG&E	11/23/18	22:14	38.26658	-122.02117	Building	Urban	Structure Only	Unknown	N.A.	101668121	AT&T	12,000	Conductor	Overhead	Yes	11/23/18	22:14
1986	PG&E	12/12/18	12:09	38.72702	-120.79470	Vegetation	Rural	< 3 meters	Unknown	N.A.	101404403	AT&T	0 - 750	Conductor	Overhead	Yes	12/12/18	12:09
1987	PG&E	12/14/18	10:32	40.43788	-123.78337	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101009136	Unknown	12,000	Conductor	Overhead	Yes	12/14/18	10:32
1988	PG&E	12/31/18	21:43	39.73802	-122.01630	Vegetation	Rural	< 3 meters	Unknown	N.A.	103801376	None	12,000	Conductor	Overhead	Yes	12/31/18	21:43
1989	PG&E	1/14/19	8:32	35.32659	-118.84319	Agriculture	3 meters - 0.25 Acres	Fire Dept	Bakersfield FD	253911104-2100007706(4113)	12,000	Line Recloser	Overhead	Yes	1/14/19	8:32		
1990	PG&E	1/16/19	0:17	38.06211	-120.19643	Vegetation	Conifer Forest	Structure Only	Cal Fire	163661701	17,000	Conductor	Overhead	Yes	1/16/19	0:17		
1991	PG&E	1/23/19	0:26	38.68016	-121.77731	Urban	1 meter - < 3 meters	Fire Dept	Woodland FD	220639836908	12,000	Conductor	Overhead	Yes	1/23/19	0:26		
1992	PG&E	2/1/19	21:40	34.86879	-120.41138	Vegetation	Urban	3 meters - 0.25 Acres	Fire Dept	Unknown	512768950741(T0541)	12,000	Conductor	Overhead	Yes	2/1/19	21:40	
1993	PG&E	2/11/19	10:55	37.24138	-121.98199	Animal Found	Urban	Structure Only	Fire Dept	Los Galos FD	315688127328	12,000	Conductor	Overhead	Yes	2/11/19	10:55	
1994	PG&E	2/23/19	11:11	35.33883	-119.02826	Vegetation	Urban	1 meter - < 3 meters	Fire Dept	Bakersfield FD	100256235	12,000	Conductor	Overhead	Yes	2/23/19	11:11	
1995	PG&E	2/26/19	12:49	36.13786	-119.88775	Urban	3 meters - 0.25 Acres	Fire Dept	Kings County FD	10069349	12,000	Transformer	Overhead	Yes	2/26/19	12:49		
1996	PG&E	3/13/19	16:08	38.89308	-122.54976	Bird Found	Herbaceous	3 meters - 0.25 Acres	Cal Fire	6FND313191607	12,000	Conductor	Overhead	Yes	3/13/19	16:08		
1997	PG&E	3/14/19	14:42	36.03674	-120.11161	Herbaceous	0.25 - 10 Acres	Fire Dept	Unknown	100701237	21,000	Pole	Overhead	Yes	3/14/19	14:42		
1998	PG&E	3/19/19	12:52	37.89560	-120.32441	-cutting, 3rd	ardwood Forest	1 meter - < 3 meters	Self Extinguished	Unknown	101045032	Unknown	17,000	Conductor	Overhead	Yes	3/19/19	12:52
1999	PG&E	4/9/19	14:07	34.63110	-119.98132	Vegetation	Wood	0.25 - 10 Acres	Fire Dept	Santa Barbara County FD	101863014	12,000	Conductor	Overhead	Yes	4/9/19	14:07	
2000	PG&E	4/9/19	17:00	36.82245	-119.82939	Agriculture	3 meters - 0.25 Acres	Fire Dept	Fresno FD	100707778	12,000	Pole	Overhead	Yes	4/9/19	17:00		
2001	PG&E	4/9/19	15:27	37.73405	-120.07761	Vegetation	Conifer Forest	3 meters - 0.25 Acres	Cal Fire	101076921	21,000	Pole	Overhead	Yes	4/9/19	15:27		
2002	PG&E	4/9/19	17:59	36.97107	-120.06700	Vegetation	Urban	1 meter - < 3 meters	Fire Dept	Madera FD	254611106	12,000	Conductor	Overhead	Yes	4/9/19	17:59	
2003	PG&E	4/10/19	22:19	36.61307	-119.66884	Urban	3 meters - 0.25 Acres	Self Extinguished	Unknown	254121108	12,000	Conductor	Overhead	Yes	4/10/19	22:19		
2004	PG&E	4/10/19	12:43	35.58036	-120.33445	Bird Found	Herbaceous	3 meters - 0.25 Acres	Cal Fire	Shandon FD	51303567640	21,000	Transformer	Overhead	Yes	4/10/19	12:43	
2005	PG&E	4/12/19	10:45	36.61443	-120.42452	Agriculture	3 meters - 0.25 Acres	Cal Fire	Unknown	253671101	12,000	Conductor	Overhead	Yes	4/12/19	10:45		
2006	PG&E	4/20/19	6:57	37.86856	-121.68427	Hardwood Wood	3 meters - 0.25 Acres	Fire Dept	East County FD	Unknown	17,000	Conductor	Overhead	No				
2007	PG&E	4/23/19	11:08	38.05945	-122.16270	Bird Found	Urban	1 meter - < 3 meters	Fire Dept	Benicia FD	7Nv0423191108	12,000	Conductor	Overhead	Yes	4/23		

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Column5	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Column11	Column12
2	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin											Date	Time
2024	PG&E	5/5/19	6:40	35.67366	-120.08727	Vehicle	Urban	10 - 100 Acres	Fire Dept	Kern County FD	252021101		12,000	Conductor	Overhead	Yes	5/5/19	6:40
2025	PG&E	5/7/19	21:33	36.45796	-119.34931		Agriculture	3 meters - 0.25 Acres	Fire Dept	Tulare County FD	7927F		12,000	Fuse	Overhead	Yes	5/7/19	21:33
2026	PG&E	5/8/19	10:23	39.38508	-122.55702		Hardwood Wood	3 meters - 0.25 Acres	Fire Dept	Colusa FD	Unknown		12,000	Conductor	Overhead	No		
2027	PG&E	5/10/19	13:00	39.27548	-121.68759	Gun Shot	Urban	0.25 - 10 Acres	Fire Dept	Sutter County FD	153771104		12,000	Conductor	Overhead	Yes	5/10/19	13:00
2028	PG&E	5/10/19	14:52	40.70400	-122.83143	Vegetation	Conifer Forests	3 meters - 0.25 Acres	Fire Dept	Lewisville FD	Keswick-Trinity 80kV Line		60,000	Conductor	Overhead	Yes	5/10/19	14:52
2029	PG&E	5/14/19	8:56	38.79891	-121.37821		Herbaceous	3 meters - 0.25 Acres	Cal Fire	California Department of Forestry	152442110		21,000	Conductor	Overhead	Yes	5/14/19	8:56
2030	PG&E	5/14/19	11:45	38.23799	-122.04330	Vegetation	Urban	3 meters - 0.25 Acres	Fire Dept	Suisun FD	Unknown		12,000	Conductor	Overhead	No		
2031	PG&E	5/14/19	16:17	36.64769	-119.80062	Vehicle	Agriculture	3 meters - 0.25 Acres	Fire Dept	Fresno County FD	417851147966		12,000	Pole	Overhead	Yes	5/14/19	16:17
2032	PG&E	5/14/19	7:17	39.50372	-121.55934		Urban	3 meters - 0.25 Acres	Unknown		22450		60,000	Pole	Overhead	Yes	5/14/19	7:17
2033	PG&E	5/14/19	18:11	38.43503	-121.95170		Urban	3 meters - 0.25 Acres	Fire Dept	Vacaville FD	103951176		12,000	Pole	Overhead	Yes	5/14/19	18:11
2034	PG&E	5/14/19	21:03	39.05535	-121.32243	Vehicle	Herbaceous	3 meters - 0.25 Acres	Fire Dept	Wheatland FD	103944282		12,000	Pole	Overhead	Yes	5/14/19	21:03
2035	PG&E	5/15/19	16:22	37.15315	-120.27768	Vehicle	Agriculture	1 meter - < 3 meters	Cal Fire		254101103		12,000	Conductor	Overhead	Yes	5/15/19	16:22
2036	PG&E	5/15/19	21:31	38.57309	-122.96032	Vegetation	ardwood Fore	1 meter - < 3 meters	Unknown		103931177		12,000	Conductor	Overhead	Yes	5/15/19	21:31
2037	PG&E	5/17/19	15:12	38.47967	-123.14858	Vegetation	Conifer Forests	1 meter - < 3 meters	Cal Fire		42811111		12,000	Conductor	Overhead	Yes	5/17/19	15:12
2038	PG&E	5/17/19	18:54	38.04763	-122.20637	Bird Found	Urban	3 meters - 0.25 Acres	Fire Dept	Crockett FD	2J0517191854		21,000	Pole	Overhead	Yes	5/17/19	18:54
2039	PG&E	5/21/19	15:50	34.86580	-120.42136	Vegetation	Urban	1 meter - < 3 meters	Fire Dept	Santa Barbara FD	182571102		12,000	Conductor	Overhead	Yes	5/21/19	15:50
2040	PG&E	5/21/19	15:50	38.01322	-121.85408		Urban	3 meters - 0.25 Acres	Cal Fire		15553		21,000	Fuse	Overhead	Yes	5/21/19	15:50
2041	PG&E	5/24/19	11:52	38.11207	-122.62141		Urban	3 meters - 0.25 Acres	Fire Dept	Novato FD	043201101		12,000	Conductor	Overhead	Yes	5/24/19	11:52
2042	PG&E	5/24/19	19:14	37.07793	-120.88102	Bird Found	Water	1 meter - < 3 meters	Cal Fire	Los Banos FD	3015781291		12,000	Transformer	Overhead	Yes	5/24/19	19:14
2043	PG&E	5/24/19	15:03	35.16961	-120.51032		Herbaceous	0.25 - 10 Acres	Cal Fire		40589503		500,000	Pole	Overhead	No		
2044	PG&E	5/25/19	18:29	37.01163	-120.12884	Vehicle	Agriculture	0.25 - 10 Acres	Cal Fire		254611104		12,000	Conductor	Overhead	Yes	5/25/19	18:29
2045	PG&E	5/25/19	20:51	38.77995	-121.51755		Agriculture	0.25 - 10 Acres	Fire Dept	Pleasant Grove FD	153761102		12,000	Conductor	Overhead	Yes	5/25/19	20:51
2046	PG&E	5/27/19	18:04	36.24951	-120.30158		Herbaceous	0.25 - 10 Acres	Cal Fire		702950		12,000	Reducer	Overhead	No		
2047	PG&E	5/28/19	12:57	37.39000	-122.01000		Urban	0.25 - 10 Acres	Fire Dept	Mountain View FD	111072		12,000	Circuit Breaker	Overhead	Yes	5/28/19	12:57
2048	PG&E	5/29/19	13:03	40.13873	-122.20877		Herbaceous	1 meter - < 3 meters	Self Extinguished		10357(TWier)		60,000	Transformer	Pad mount	Yes	5/29/19	13:03
2049	PG&E	5/29/19	16:54	37.03714	-119.52092	Vegetation	dwood Wood	10 - 100 Acres	Cal Fire		100680674		12,000	Pole	Overhead	Yes	5/29/19	16:54
2050	PG&E	5/29/19	19:13	38.56200	-119.28596	Bird Found	Agriculture	0.25 - 10 Acres	Fire Dept	Tulare County FD	470523191913		12,000	Transformer	Overhead	No		
2051	PG&E	5/29/19	20:25	39.01944	-121.06077		Hardwood Fore	3 meters - 0.25 Acres	Cal Fire		Unknown		12,000	Conductor	Overhead	No		
2052	PG&E	5/30/19	7:27	37.35452	-121.87033		Urban	3 meters - 0.25 Acres	Fire Dept	San Jose FD	K215		12,000	Other	Overhead	Yes	5/30/19	7:27
2053	PG&E	5/30/19	8:18	35.70052	-120.81038	Vehicle	Herbaceous	0.25 - 10 Acres	Cal Fire		101871463		12,000	Pole	Overhead	Yes	5/30/19	8:18
2054	PG&E	5/30/19	15:21	36.89529	-119.96271	Vehicle	Agriculture	0.25 - 10 Acres	Cal Fire		101222476		12,000	Pole	Overhead	Yes	5/30/19	15:21
2055	PG&E	5/30/19	22:25	35.53804	-119.80563		Herbaceous	10 - 100 Acres	Fire Dept	Kern County FD	100127383		12,000	Other	Overhead	Yes	5/30/19	22:25
2056	PG&E	5/31/19	13:34	34.98559	-118.90882		Agriculture	3 meters - 0.25 Acres	Unknown		100337543		12,000	Fuse	Overhead	Yes	5/31/19	13:34
2057	PG&E	5/31/19	15:25	40.44307	-121.82108		Hardwood Wood	1 meter - < 3 meters	Self Extinguished		101556319		12,000	Conductor	Overhead	Yes	5/31/19	15:25
2058	PG&E	6/1/19	6:38	38.07002	-122.12844	Vehicle	Herbaceous	3 meters - 0.25 Acres	Fire Dept	Benicia FD	103848169		12,000	Pole	Overhead	Yes	6/1/19	6:38
2059	PG&E	6/1/19	14:32	36.98709	-120.62286	Vegetation	Water	1 meter - < 3 meters	Cal Fire		254041101		12,000	Other	Overhead	Yes	6/1/19	14:32
2060	PG&E	6/3/19	6:57	35.58781	-119.01042	Bird Found	Herbaceous	1 meter - < 3 meters	Fire Dept	Kern County FD	SW1694		21,000	Switch	Overhead	No		
2061	PG&E	6/3/19	14:31	40.68224	-122.28059		Hardwood Wood	0.25 - 10 Acres	Cal Fire		101466598		12,000	Transformer	Overhead	Yes	6/3/19	14:31
2062	PG&E	6/3/19	14:47	40.44152	-122.30359		Herbaceous	1 meter - < 3 meters	Fire Dept	Anderson FD	101495589		12,000	Insulator	Overhead	No		
2063	PG&E	6/3/19	18:11	36.55796	-119.53304		Agriculture	3 10 - 100 Acres	Cal Fire		262241118		12,000	Conductor	Overhead	Yes	6/3/19	18:11
2064	PG&E	6/4/19	13:00	36.65430	-119.88219	Bird Found	Agriculture	3 meters - 0.25 Acres	Cal Fire		470604191259		12,000	Conductor	Overhead	Yes	6/4/19	13:00
2065	PG&E	6/5/19	21:01	38.55796	-121.75455		Urban	Structure Only	Fire Dept	Unknown	06204-2100957897(1105/2)		12,000	Circuit Breaker	Overhead	Yes	6/5/19	21:01
2066	PG&E	6/6/19	9:01	35.63843	-118.96873	Bird Found	Herbaceous	0.25 - 10 Acres	Fire Dept	Kern County FD	100216096		12,000	Conductor	Overhead	No		
2067	PG&E	6/6/19	20:30	38.49695	-122.64351		Barren/Other	< 1 meter	Self Extinguished		Unknown		230,000	Circuit Breaker	Overhead	Yes	6/6/19	20:30
2068	PG&E	6/7/19	9:58	38.72846	-123.35276	Vegetation	Herbaceous	0.25 - 10 Acres	Cal Fire		042861101		21,000	Conductor	Overhead	Yes	6/7/19	9:58
2069	PG&E	6/7/19	11:59	38.62952	-119.91339		Agriculture	0.25 - 10 Acres	Fire Dept	Fresno FD	417384054240		21,000	Transformer	Overhead	Yes	6/7/19	11:59
2070	PG&E	6/7/19	12:44	39.06720	-121.86930		Hardwood Wood	1 meter - < 3 meters	Self Extinguished		4391		12,000	Switch	Overhead	Yes	6/7/19	12:44
2071	PG&E	6/7/19	16:44	37.33352	-120.54241	Vegetation	Agriculture	0.25 - 10 Acres	Cal Fire		253881104		12,000	Conductor	Overhead	No		
2072	PG&E	6/8/19	9:21	39.09261	-121.54824	Vegetation	Urban	3 meters - 0.25 Acres	Fire Dept	Olivehurst FD	152901104		12,000	Conductor	Overhead	Yes	6/8/19	9:21
2073	PG&E	6/8/19	10:13	37.37307	-121.91918	Metallic Ballot	Urban	3 meters - 0.25 Acres	Fire Dept	Unknown	100566596		12,000	Pole	Overhead	Yes	6/8/19	10:13
2074	PG&E	6/8/19	14:31	34.89338	-120.31517	Metallic Ballot	Herbaceous	3 meters - 0.25 Acres	Fire Dept	Unknown	182811103		12,000	Conductor	Overhead	Yes	6/8/19	14:31
2075	PG&E	6/8/19	18:51	38.61053	-122.97318	Vegetation	Conifer Forests	3 meters - 0.25 Acres	Cal Fire		42751113		12,000	Conductor	Overhead	Yes	6/8/19	18:51
2076	PG&E	6/8/19	23:26	37.36072	-122.17084	Vegetation	Urban	1 meter - < 3 meters	Fire Dept	Santa Clara County FD	Unknown		12,000	Conductor	Overhead	No		
2077	PG&E	6/9/19	3:07	36.14280	-120.75396		Herbaceous	3 meters - 0.25 Acres	Cal Fire		38J0609190229		12,000	Conductor	Overhead	Yes	6/9/19	3:07
2078	PG&E	6/9/19	12:46	38.29660	-122.47470	Vegetation	Urban	1 meter - < 3 meters	Fire Dept	Sonoma FD	Unknown		12,000	Other	Subsurface	Yes	6/9/19	12:46
2079	PG&E	6/9/19	13:53	36.92347	-121.74605	Metallic Ballot	Urban	3 meters - 0.25 Acres	Fire Dept	Watsonville FD	83192104		21,000	Conductor	Overhead	Yes	6/9/19	13:53
2080	PG&E	6/9/19	15:23	37.86430	-122.55814		Barren/Other	3 meters - 0.25 Acres	Fire Dept	Mill Valley FD	902		12,000	Reducer	Overhead	Yes	6/9/19	15:23
2081	PG&E	6/9/19	15:34	34.89954	-120.43815		Urban	1 meter - < 3 meters	Fire Dept	Unknown	45711		12,000	Lightning Arrestor	Overhead	Yes	6/9/19	15:34
2082	PG&E	6/9/19	18:07	39.50689	-121.59854	Bird Found	Urban	1 meter - < 3 meters	Fire Dept	Oroville FD	6Fq0609191756		12,000	Transformer	Overhead	Yes	6/9/19	18:07
2083	PG&E	6/9/19	20:22	37.96314	-121.99129		Urban	1 meter - < 3 meters	Fire Dept	Contra Costa FD	Circuit 012022217		21,000	Transformer	Subsurface	Yes	6/9/19	20:22
2084	PG&E	6/10/19	11:44	37.27352	-120.63338	Vehicle	Herbaceous	3 meters - 0.25 Acres	Unknown		253611102		12,000	Conductor	Overhead	Yes	6/10/19	11:44
2085	PG&E	6/10/19	13:28	37.26977	-121.88103		Urban	1 meter - < 3 meters	Fire Dept	San Jose FD	315977228341		12,000	Transformer	Overhead	Yes	6/10/19	13:28
2086	PG&E	6/10/19	13:29	38.81371	-120.94328	Vegetation	dwood Wood	1 meter - < 3 meters	Other	Customer	153652109		21,000	Conductor	Overhead	No		
2087	PG&E	6/10/19	15:53	37.49287	-121.90856		Urban	3 meters - 0.25 Acres	Fire Dept	Fresno FD	Circuit 1d 014722109		21,000	Nice/Clamp/Connec	Subsurface	Yes	6/10/19	15:53
2088	PG&E	6/10/19	16:05	37.25953	-121.91231		Urban	1 meter - < 3 meters	Fire Dept	San Jose FD	315893027963		12,000	Transformer	Overhead	Yes	6/10/19	16:05
2089	PG&E	6/10/19	16:18	38.11068	-122.90251	Vegetation	Herbaceous	0.25 - 10 Acres	Cal Fire		42291101		12,000	Conductor	Overhead	Yes	6/10/19	16:18
2090	PG&E	6/10/19	16:34	38.82095	-120.84595	Vegetation	ardwood Fore	3 meters - 0.25 Acres</										

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
2	Utility Name	Fire Start	Column1	Location	Comments	Comments	Comments	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
2	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	
2108	PG&E	6/17/19	18:07	38.27780	-122.43844	Vegetation	Herbaceous	1 meter - < 3 meters	Fire Dept	Unknown	42721105		12,000	Conductor	Overhead	Yes	6/17/19	18:07
2109	PG&E	6/17/19	18:19	38.09840	-122.87861	Vegetation	Conifer Forest	3 meters - 0.25 Acres	Fire Dept	Marin County FD	42291101		12,000	Conductor	Overhead	Yes	6/17/19	18:19
2110	PG&E	6/17/19	23:31	36.70837	-119.76365		Urban	3 meters - 0.25 Acres	Fire Dept	Fresno County FD	1004291789		12,000	Secondary	Overhead	Yes	6/17/19	23:31
2111	PG&E	6/17/19	20:58	35.40397	-118.89504		Urban	1 meter - < 3 meters	Other	Customer	Unknown		12,000	Other	Subsurface	No		
2112	PG&E	6/18/19	8:26	36.98117	-119.87987		Urban	3 meters - 0.25 Acres	Cal Fire	Madara County FD	32181341756		12,000	Transformer	Overhead	Yes	6/18/19	8:26
2113	PG&E	6/18/19	19:38	36.68159	-122.27160		Agriculture	1 meter - < 3 meters	Fire Dept	Artois FD	100367422		21,000	Crossarm	Overhead	Yes	6/18/19	19:38
2114	PG&E	6/18/19	19:49	35.88793	-120.93167	Bird Found	Herbaceous	0.25 - 10 Acres	Cal Fire	Unknown	Unknown		12,000	Pole	Overhead	Yes	6/18/19	19:49
2115	PG&E	6/18/19	13:05	35.02322	-119.09574		Herbaceous	1 meter - < 3 meters	Self Extinguished		253411106		12,000	Other	Overhead	No		
2116	PG&E	6/19/19	9:02	37.79273	-121.28704		Urban	3 meters - 0.25 Acres	Fire Dept	Lathrop FD	102100188		17,000	Conductor	Overhead	Yes	6/19/19	9:02
2117	PG&E	6/19/19	11:44	39.86124	-121.69072	Vegetation	Conifer Forest	3 meters - 0.25 Acres	Cal Fire		100400933		12,000	Conductor	Overhead	Yes	6/19/19	11:44
2118	PG&E	6/19/19	12:15	39.40702	-122.22941	Bird Found	Urban	1 meter - < 3 meters	Fire Dept	Willows FD	69G0619191201		21,000	Conductor	Overhead	Yes	6/19/19	12:15
2119	PG&E	6/19/19	8:31	35.38335	-119.69648		Herbaceous	3 meters - 0.25 Acres	Other	Third Party Field Worker	Unknown		115,000	Jumper	Overhead	Yes	6/19/19	8:31
2120	PG&E	6/20/19	5:58	38.31575	-121.89310	Vegetation	Herbaceous	3 meters - 0.25 Acres	Fire Dept	Unknown	Unknown		21,000	Other	Overhead	No		
2121	PG&E	6/20/19	16:32	36.85145	-120.05494	Bird Found	Agriculture	1 meter - < 3 meters	Self Extinguished		57N0620191624		12,000	Transformer	Overhead	Yes	6/20/19	16:32
2122	PG&E	6/21/19	2:37	38.90256	-121.06819	Vegetation	Urban	3 meters - 0.25 Acres	Cal Fire		103957753		21,000	Pole	Overhead	Yes	6/21/19	2:37
2123	PG&E	6/21/19	10:56	39.52511	-121.68864	Bird Found	Agriculture	3 meters - 0.25 Acres	Fire Dept	Butte County FD	6F0621191046		12,000	Conductor	Underbuild	Yes	6/21/19	10:56
2124	PG&E	6/21/19	11:33	39.12880	-121.47727		Agriculture	3 meters - 0.25 Acres	Fire Dept	Linda FD	103954219		12,000	Pole	Overhead	Yes	6/21/19	11:33
2125	PG&E	6/22/19	23:30	38.01331	-121.35604		Urban	3 meters - 0.25 Acres	Fire Dept	Stockton FD	6446		21,000	Line Recloser	Overhead	Yes	6/22/19	23:30
2126	PG&E	6/23/19	12:41	37.18909	-121.78511		Herbaceous	3 meters - 0.25 Acres	Fire Dept	Unknown	83242111		21,000	Conductor	Overhead	No		
2127	PG&E	6/23/19	14:43	37.82104	-121.98876		Urban	1 meter - < 3 meters	Fire Dept	Contra Costa FD	14662107		21,000	Nice/Clamp/Conne	Overhead	Yes	6/23/19	14:43
2128	PG&E	6/24/19	9:53	37.32701	-122.07309		Herbaceous	3 meters - 0.25 Acres	Self Extinguished		Unknown		60,000	Other	Overhead	Yes	6/24/19	9:53
2129	PG&E	6/25/19	8:49	39.00423	-122.86738	Vehicle	Agriculture	1 meter - < 3 meters	Cal Fire		102144284		12,000	Pole	Overhead	Yes	6/25/19	8:49
2130	PG&E	6/25/19	16:32	36.22207	-121.07381	Bird Found	Herbaceous	100+ Acres	Cal Fire		Unknown		12,000	Conductor	Overhead	Yes	6/25/19	16:32
2131	PG&E	6/26/19	7:48	36.35851	-119.82851	Vegetation	Agriculture	1 meter - < 3 meters	Fire Dept	Unknown	252301103		12,000	Conductor	Overhead	Yes	6/26/19	7:48
2132	PG&E	6/26/19	9:29	38.18887	-121.66215		Urban	3 meters - 0.25 Acres	Fire Dept	Rio Vista FD	103951387		21,000	Pole	Overhead	Yes	6/26/19	9:29
2133	PG&E	6/26/19	13:14	40.01851	-122.41069	Vegetation	dwood Wood	3 meters - 0.25 Acres	Cal Fire		Circuit Id 103331101		12,000	Nice/Clamp/Conne	Overhead	Yes	6/26/19	13:14
2134	PG&E	6/26/19	15:22	38.51105	-122.00569	Vehicle	Agriculture	3 meters - 0.25 Acres	Fire Dept	Winters FD	103953484		12,000	Pole	Overhead	Yes	6/26/19	15:22
2135	PG&E	6/27/19	2:23	36.81983	-119.33336	Bird Found	dwood Wood	0.25 - 10 Acres	Self Extinguished		Kings River-Sanger-Reedley 115Kv At 16/089		115,000	Insulator	Overhead	Yes	6/27/19	2:23
2136	PG&E	6/28/19	13:45	36.72066	-119.86252		Agriculture	0.25 - 10 Acres	Fire Dept	Fresno FD	Circuit Id 253731112		12,000	Nice/Clamp/Conne	Overhead	Yes	6/28/19	13:45
2137	PG&E	6/29/19	11:41	37.73967	-121.42251	Metallic Ballo	Urban	3 meters - 0.25 Acres	Fire Dept	Tracy FD	162881104		12,000	Conductor	Overhead	Yes	6/29/19	11:41
2138	PG&E	6/30/19	5:22	38.98503	-121.30711	Bird Found	Herbaceous	3 meters - 0.25 Acres	Cal Fire		6Hb0630190426		12,000	Conductor	Overhead	Yes	6/30/19	5:22
2139	PG&E	6/30/19	17:30	40.52608	-122.33375		Agriculture	3 meters - 0.25 Acres	Cal Fire		374		12,000	Capacitor Bank	Overhead	Yes	6/30/19	17:30
2140	PG&E	6/30/19	18:02	37.72170	-121.52229		Urban	3 meters - 0.25 Acres	Employee		162771101		12,000	Nice/Clamp/Conne	Subsurface	Yes	6/30/19	18:02
2141	PG&E	7/1/19	2:15	38.29550	-120.83349		Shrub	0.25 - 10 Acres	Cal Fire		Unknown		12,000	Conductor	Overhead	No		
2142	PG&E	7/1/19	13:51	40.97889	-124.03658	Vehicle	Conifer Forest	0.25 - 10 Acres	Cal Fire		005004		60,000	Pole	Overhead	Yes	7/1/19	13:51
2143	PG&E	7/2/19	10:59	38.92662	-121.26029		Herbaceous	3 meters - 0.25 Acres	Self Extinguished		153701104		12,000	Conductor	Overhead	Yes	7/2/19	10:59
2144	PG&E	7/2/19	11:48	36.21459	-121.12556	Bird Found	Barren/Other	0.25 - 10 Acres	Cal Fire		Unknown		12,000	Other	Overhead	No		
2145	PG&E	7/2/19	22:51	36.33569	-121.25635		Herbaceous	3 meters - 0.25 Acres	Fire Dept	Green Field FD	3-170516		12,000	Transformer	Overhead	No		
2146	PG&E	7/4/19	16:44	39.98135	-122.22396	Bird Found	Agriculture	0.25 - 10 Acres	Cal Fire		103931102		12,000	Conductor	Overhead	Yes	7/4/19	16:44
2147	PG&E	7/5/19	1:36	37.68690	-121.0551	Vegetation	Agriculture	3 meters - 0.25 Acres	Fire Dept	Tracy FD	162471101		12,000	Conductor	Overhead	Yes	7/5/19	1:36
2148	PG&E	7/5/19	16:49	38.02390	-121.83730	Bird Found	Urban	0.25 - 10 Acres	Fire Dept	Unknown	Unknown		12,000	Conductor	Overhead	No		
2149	PG&E	7/5/19	16:02	39.08043	-122.90610	Vegetation	Urban	3 meters - 0.25 Acres	Fire Dept	Lakeport FD	43211102		12,000	Conductor	Overhead	Yes	7/5/19	16:02
2150	PG&E	7/5/19	8:15	37.97780	-121.24580	Metallic Ballo	Urban	3 meters - 0.25 Acres	Fire Dept	Stockton FD	11012		12,000	Pole	Overhead	Yes	7/5/19	8:15
2151	PG&E	7/5/19	15:10	36.77445	-119.78091		Urban	3 meters - 0.25 Acres	Fire Dept	Kings County FD	Circuit Id 253601102		12,000	Nice/Clamp/Conne	Overhead	No		
2152	PG&E	7/6/19	15:34	37.73003	-121.42693		Urban	1 meter - < 3 meters	Fire Dept	Tracy FD	317321944923		12,000	Transformer	Overhead	Yes	7/6/19	15:34
2153	PG&E	7/6/19	14:22	34.63880	-119.96954		Herbaceous	0.25 - 10 Acres	Fire Dept	Santa Barbara FD	182721104		12,000	Nice/Clamp/Conne	Overhead	Yes	7/6/19	14:22
2154	PG&E	7/7/19	19:14	38.26793	-122.01749	Metallic Ballo	Urban	1 meter - < 3 meters	Fire Dept	Fairfield FD	1105/2		12,000	Conductor	Overhead	Yes	7/7/19	19:14
2155	PG&E	7/7/19	18:23	40.38670	-122.27472	Vegetation	Urban	1 meter - < 3 meters	Fire Dept	Cottonwood FD	Unknown		12,000	Other	Overhead	Yes	7/7/19	18:23
2156	PG&E	7/7/19	16:24	38.24979	-122.03423		Urban	1 meter - < 3 meters	Fire Dept	Fairfield FD	Unknown		12,000	Other	Overhead	No		
2157	PG&E	7/10/19	14:25	36.95805	-120.10936	Bird Found	Agriculture	0.25 - 10 Acres	Cal Fire		255391102		12,000	Conductor	Overhead	Yes	7/10/19	14:25
2158	PG&E	7/11/19	15:27	39.56568	-120.66144	Vegetation	Conifer Forest	0.25 - 10 Acres	Unknown		100102596		12,000	Pole	Overhead	Yes	7/11/19	15:27
2159	PG&E	7/12/19	14:18	35.33376	-118.99106		Urban	3 meters - 0.25 Acres	Fire Dept	Bakersfield FD	253372104		21,000	Conductor	Overhead	Yes	7/12/19	14:18
2160	PG&E	7/12/19	16:40	37.85995	-120.90613		Herbaceous	< 1 meter	Self Extinguished		318851549660		17,000	Conductor	Overhead	Yes	7/12/19	16:40
2161	PG&E	7/12/19	19:38	36.80794	-119.52641	Vegetation	Agriculture	3 meters - 0.25 Acres	Cal Fire		254441106		12,000	Conductor	Overhead	Yes	7/12/19	19:38
2162	PG&E	7/13/19	13:13	34.72730	-120.43570		Shrub	0.25 - 10 Acres	Fire Dept	Santa Barbara FD	Y44		12,000	Nice/Clamp/Conne	Overhead	Yes	7/13/19	13:13
2163	PG&E	7/13/19	15:56	36.99075	-119.86805		Urban	1 meter - < 3 meters	Other	Customer	57N0713191555		12,000	Other	Overhead	Yes	7/13/19	15:56
2164	PG&E	7/13/19	12:43	37.20145	-120.32958		Agriculture	3 meters - 0.25 Acres	Fire Dept	Merced FD	320508025527		12,000	Pole	Overhead	Yes	7/13/19	12:43
2165	PG&E	7/13/19	12:04	37.39043	-120.61939		Urban	1 meter - < 3 meters	Cal Fire		253611103		12,000	Conductor	Overhead	Yes	7/13/19	12:04
2166	PG&E	7/13/19	22:16	38.06899	-121.06879	Metallic Ballo	Herbaceous	0.25 - 10 Acres	Cal Fire		Unknown		21,000	Conductor	Overhead	No		
2167	PG&E	7/15/19	7:51	38.32657	-122.56803	Vegetation	ardwood Fore	1 meter - < 3 meters	Cal Fire		42721104		12,000	Conductor	Overhead	Yes	7/15/19	7:51
2168	PG&E	7/15/19	13:50	35.60281	-119.08985	Bird Found	Agriculture	0.25 - 10 Acres	Fire Dept	Kern County FD	516762776845		12,000	Transformer	Overhead	Yes	7/15/19	13:50
2169	PG&E	7/15/19	14:12	37.99042	-121.28567		Urban	3 meters - 0.25 Acres	Fire Dept	Stockton FD	3.17741E+11		12,000	Crossarm	Overhead	Yes	7/15/19	14:12
2170	PG&E	7/15/19	16:31	37.95731	-121.22331		Urban	3 meters - 0.25 Acres	Fire Dept	Stockton FD	163211103		12,000	Conductor	Overhead	No		
2171	PG&E	7/16/19	17:31	40.16909	-122.30529	Vegetation	dwood Wood	3 meters - 0.25 Acres	Cal Fire		103541103		12,000	Conductor	Overhead	Yes	7/16/19	17:31
2172	PG&E	7/17/19	7:49	34.50656	-120.22475		Herbaceous	3 meters - 0.25 Acres	Fire Dept	Santa Barbara County FD	48X0717190747		12,000	Other	Overhead	Yes	7/17/19	7:49
2173	PG&E	7/17/19	18:00	37.28822	-122.01706		Urban	1 meter - < 3 meters	Fire Dept	Santa Clara County FD	83371114		12,000	Nice/Clamp/Conne	Overhead	Yes	7/17/19	18:00
2174	PG&E	7/18/19	12:10	3														

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
Utility Name	Fire Start	Column1	Location	Comments	Comments	Comments	Comments	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
2	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin												
2192	PG&E	7/25/19	7:39	39.17350	-123.57631	Vegetation	ardwood Fore	3 meters - 0.25 Acres	Cal Fire		Oj 2 P/Ss Of Cgd# 215532055340		12,000	Other	Overhead	Yes	7/25/19	7:39
2193	PG&E	7/25/19	15:47	37.24931	-121.88689	Vegetation	Urban	3 meters - 0.25 Acres	Fire Dept	San Jose FD	74		12,000	Other	Overhead	Yes	7/25/19	15:47
2194	PG&E	7/25/19	19:34	37.20456	-120.43663	Bird Found	Urban	1 meter - < 3 meters	Unknown		5Tf0725191902		12,000	Other	Overhead	Yes	7/25/19	19:34
2195	PG&E	7/26/19	12:03	38.80027	-120.82585	Vegetation	Urban	0.25 - 10 Acres	Cal Fire		153082106		21,000	Conductor	Overhead	Yes	7/26/19	12:03
2196	PG&E	7/26/19	18:37	38.70719	-122.04809		Agriculture	1 meter - < 3 meters	Cal Fire		101604885		21,000	Pole	Overhead	No		
2197	PG&E	7/27/19	15:30	35.48787	-120.65071	Vegetation	Urban	1 meter - < 3 meters	Fire Dept	Atascadero FD	103952454		12,000	Pole	Overhead	Yes	7/27/19	15:30
2198	PG&E	7/27/19	8:22	40.37680	-122.18728	Vegetation	Herbaceous	3 meters - 0.25 Acres	Self Extinguished		103451102		12,000	Conductor	Overhead	Yes	7/27/19	8:22
2199	PG&E	7/27/19	16:17	37.72680	-120.32455	Vegetation	Urban	0.25 - 10 Acres	Cal Fire		252811102		12,000	Conductor	Overhead	Yes	7/27/19	16:17
2200	PG&E	7/27/19	3:43	38.65571	-122.89516	Vegetation	Agriculture	3 meters - 0.25 Acres	Employee		42751113		12,000	Conductor	Overhead	Yes	7/27/19	3:43
2201	PG&E	7/27/19	4:51	37.94861	-120.46557	Vegetation	dwood Wood	3 meters - 0.25 Acres	Cal Fire		163781705		17,000	Conductor	Overhead	Yes	7/27/19	4:51
2202	PG&E	7/28/19	23:13	36.96076	-119.72804		Herbaceous	0.25 - 10 Acres	Cal Fire		255282108		21,000	Conductor	Overhead	Yes	7/28/19	23:13
2203	PG&E	7/29/19	15:11	38.51445	-122.77512		Agriculture	3 meters - 0.25 Acres	Fire Dept	Unknown	Near Meter 1009500196		12,000	Other	Overhead	Yes	7/29/19	15:11
2204	PG&E	7/30/19	0:17	38.51560	-122.82687		Herbaceous	3 meters - 0.25 Acres	Fire Dept	Windsor FD	217640530998		12,000	Transformer	Overhead	Yes	7/30/19	0:17
2205	PG&E	7/30/19	15:15	39.12067	-121.07201	Vegetation	ardwood Fore	1 meter - < 3 meters	Cal Fire		152691114		12,000	Conductor	Overhead	Yes	7/30/19	15:15
2206	PG&E	7/30/19	14:16	40.97033	-124.04355	Vehicle	Urban	3 meters - 0.25 Acres	Cal Fire		103967110	Yes	12,000	Pole	Overhead	Yes	7/30/19	14:16
2207	PG&E	7/30/19	15:24	37.45042	-121.84959		Urban	0.25 - 10 Acres	Cal Fire		82831109		12,000	Conductor	Overhead	Yes	7/30/19	15:24
2208	PG&E	7/31/19	18:34	36.31063	-121.04372	Bird Found	Herbaceous	0.25 - 10 Acres	Cal Fire		380731191818		21,000	Other	Overhead	Yes	7/31/19	18:34
2209	PG&E	8/1/19	13:28	38.57212	-120.68026	Failure/Involve	Conifer Fores	3 meters - 0.25 Acres	Cal Fire		153662102		21,000	Conductor	Overhead	Yes	8/1/19	13:28
2210	PG&E	8/2/19	3:28	38.09344	-122.19835		Herbaceous	3 meters - 0.25 Acres	Fire Dept	Vallejo FD	7Ny0802190243		12,000	Switch	Overhead	Yes	8/2/19	3:28
2211	PG&E	8/2/19	3:28	36.78632	-119.51978	Vegetation	Agriculture	3 meters - 0.25 Acres	Cal Fire		254441106		12,000	Conductor	Overhead	Yes	8/2/19	3:28
2212	PG&E	8/2/19	4:51	38.37358	-121.13945	Bird Found	Herbaceous	10 - 100 Acres	Self Extinguished		2222 Gold Hill-Bellota-Lockeford 115Kv Line		115,000	Conductor	Overhead	Yes	8/2/19	4:51
2213	PG&E	8/3/19	13:30	39.08833	-122.30917	Vegetation	dwood Wood	10 - 100 Acres	Cal Fire		7049		21,000	Conductor	Overhead	Yes	8/3/19	13:30
2214	PG&E	8/3/19	11:37	35.69091	-119.83222	Bird Found	Agriculture	10 - 100 Acres	Cal Fire		47x0803191135		12,000	Other	Overhead	Yes	8/3/19	11:37
2215	PG&E	8/5/19	11:55	38.25097	-122.58240	Bird Found	Urban	3 meters - 0.25 Acres	Cal Fire		7N0805191142		12,000	Conductor	Underbuild	Yes	8/5/19	11:55
2216	PG&E	8/5/19	22:38	37.18690	-119.79018		Hardwood Wood	3 meters - 0.25 Acres	Unknown		322068125092		21,000	Transformer	Overhead	Yes	8/5/19	22:38
2217	PG&E	8/5/19	23:32	38.28432	-122.11834	Vegetation	Agriculture	0.25 - 10 Acres	Cal Fire		43051101		12,000	Conductor	Overhead	Yes	8/5/19	23:32
2218	PG&E	8/6/19	15:47	36.57176	-122.73637	Vehicle	dwood Wood	3 meters - 0.25 Acres	Cal Fire		182222104		21,000	Conductor	Overhead	Yes	8/6/19	15:47
2219	PG&E	8/6/19	12:12	39.05055	-121.06144	Vegetation	Urban	3 meters - 0.25 Acres	Cal Fire		100107532		12,000	Insulator	Overhead	Yes	8/6/19	12:12
2220	PG&E	8/6/19	18:33	37.40304	-121.90557		Urban	3 meters - 0.25 Acres	Fire Dept	Unknown	83892108		21,000	Conductor	Overhead	Yes	8/6/19	18:33
2221	PG&E	8/7/19	7:29	37.14115	-122.32818	Vegetation	Agriculture	3 meters - 0.25 Acres	Cal Fire		24101103		12,000	Conductor	Overhead	Yes	8/7/19	7:29
2222	PG&E	8/7/19	12:55	37.14222	-120.49533	Bird Found	Agriculture	1 meter - < 3 meters	Cal Fire		5Tf0807191434		12,000	Pole	Overhead	Yes	8/7/19	12:55
2223	PG&E	8/7/19	10:42	37.28341	-120.45239		Herbaceous	3 meters - 0.25 Acres	Cal Fire		Unknown		12,000	Nice/Clamp/Connec	Overhead	No		
2224	PG&E	8/8/19	16:40	37.08368	-120.49430	Bird Found	Agriculture	1 meter - < 3 meters	Cal Fire		5Tf0808191639		12,000	Transformer	Overhead	Yes	8/8/19	16:40
2225	PG&E	8/10/19	7:26	39.01254	-121.48839	Bird Found	Agriculture	1 meter - < 3 meters	Cal Fire		6Hx0810190609		12,000	Conductor	Overhead	Yes	8/10/19	7:26
2226	PG&E	8/10/19	8:19	39.48987	-121.53393	Animal Found	Urban	3 meters - 0.25 Acres	Cal Fire		1008809971		12,000	Transformer	Overhead	Yes	8/10/19	8:19
2227	PG&E	8/10/19	17:30	35.36800	-118.96380		Urban	3 meters - 0.25 Acres	Unknown		253372106		21,000	Conductor	Overhead	Yes	8/10/19	17:30
2228	PG&E	8/10/19	22:27	35.69613	-120.69771		Barren/Other	0.25 - 10 Acres	Cal Fire		152481108		12,000	Conductor	Overhead	Yes	8/10/19	22:27
2229	PG&E	8/11/19	1:19	39.11518	-121.00104	Vegetation	Conifer Fores	3 meters - 0.25 Acres	Cal Fire		100097796		12,000	Other	Overhead	Yes	8/11/19	1:19
2230	PG&E	8/11/19	16:56	38.62433	-122.19513		Urban	0.25 - 10 Acres	Cal Fire		1010028782		12,000	Other	Overhead	No		
2231	PG&E	8/12/19	17:43	37.88338	-122.45313	Bird Found	Urban	1 meter - < 3 meters	Unknown		42011105		12,000	Switch	Overhead	Yes	8/12/19	17:43
2232	PG&E	8/12/19	17:43	37.05080	-121.58943		Herbaceous	3 meters - 0.25 Acres	Cal Fire		100612948		21,000	Conductor	Overhead	Yes	8/12/19	17:43
2233	PG&E	8/12/19	20:06	39.09524	-123.49370	Vegetation	Conifer Fores	3 meters - 0.25 Acres	Cal Fire		102177212		12,000	Conductor	Overhead	Yes	8/12/19	20:06
2234	PG&E	8/12/19	17:42	38.66183	-120.74512	Vegetation	ardwood Fore	0.25 - 10 Acres	Cal Fire		101415488_101404439		12,000	Pole	Overhead	Yes	8/12/19	17:42
2235	PG&E	8/13/19	0:55	36.95086	-119.83071		Herbaceous	0.25 - 10 Acres	Cal Fire		40239045		21,000	Capacitor Bank	Overhead	Yes	8/13/19	0:55
2236	PG&E	8/13/19	2:50	38.00044	-121.71189	h High Voltag	Urban	0.25 - 10 Acres	Fire Dept	Unknown	13652107		21,000	Conductor	Subsurface	Yes	8/13/19	2:50
2237	PG&E	8/13/19	10:30	36.61016	-121.44516		Herbaceous	3 meters - 0.25 Acres	Cal Fire		40761041		115,000	Other	Overhead	Yes	8/13/19	10:30
2238	PG&E	8/14/19	19:42	37.33672	-121.89664		Urban	3 meters - 0.25 Acres	Fire Dept	Unknown	82191104		12,000	Other	Overhead	Yes	8/14/19	19:42
2239	PG&E	8/14/19	16:35	35.27255	-120.64199	Metallic Ballco	Urban	1 meter - < 3 meters	Fire Dept	San Luis Obispo FD	101935033		12,000	Conductor	Overhead	Yes	8/14/19	16:35
2240	PG&E	8/14/19	14:04	36.97889	-120.03324		Agriculture	0.25 - 10 Acres	Cal Fire		101216303		12,000	Conductor	Overhead	Yes	8/14/19	14:04
2241	PG&E	8/14/19	10:16	35.37901	-120.42318	Vegetation	dwood Wood	< 1 meter	Cal Fire		512769068280		21,000	Conductor	Overhead	Yes	8/14/19	10:16
2242	PG&E	8/14/19	9:19	38.09095	-121.26045	Vegetation	Urban	1 meter - < 3 meters	Fire Dept	Waterloo Morada FD	102107171	Yes	21,000	Other	Overhead	Yes	8/14/19	9:19
2243	PG&E	8/14/19	7:56	39.81758	-121.90846	Animal Found	Urban	1 meter - < 3 meters	Cal Fire		102841106		12,000	Other	Overhead	No		
2244	PG&E	8/15/19	12:24	37.21655	-121.75629	Vehicle	Urban	10 - 100 Acres	Fire Dept	San Jose FD	82952107		21,000	Conductor	Overhead	Yes	8/15/19	12:24
2245	PG&E	8/15/19	12:10	36.60236	-119.45831		Urban	3 meters - 0.25 Acres	Fire Dept	Reedley FD	254531110		12,000	Conductor	Overhead	No		
2246	PG&E	8/16/19	13:20	36.58445	-119.77535	Vegetation	Agriculture	3 meters - 0.25 Acres	Cal Fire		Unknown		12,000	Pole	Overhead	Yes	8/16/19	13:20
2247	PG&E	8/16/19	8:19	40.12349	-123.87576	Vegetation	Conifer Fores	3 meters - 0.25 Acres	Self Extinguished		192221102-2101118022(5563)		12,000	Conductor	Overhead	Yes	8/16/19	8:19
2248	PG&E	8/16/19	1:37	40.29490	-121.24070	Animal Found	Urban	1 meter - < 3 meters	Cal Fire		103181102		12,000	Fuse	Overhead	Yes	8/16/19	1:37
2249	PG&E	8/16/19	10:31	39.37143	-121.32213	Vegetation	dwood Wood	0.25 - 10 Acres	Cal Fire		103191101		12,000	Conductor	Overhead	Yes	8/16/19	10:31
2250	PG&E	8/16/19	18:11	36.58406	-119.77307		Agriculture	0.25 - 10 Acres	Cal Fire		MTR#1009552365		12,000	Conductor	Overhead	No		
2251	PG&E	8/18/19	8:20	36.73295	-119.69225		Urban	3 meters - 0.25 Acres	Fire Dept	Unknown	R9547		12,000	Other	Overhead	Yes	8/18/19	8:20
2252	PG&E	8/18/19	15:46	34.87127	-120.26237		Urban	3 meters - 0.25 Acres	Fire Dept	Santa Barbara County FD	182811103		12,000	Conductor	Overhead	Yes	8/18/19	15:46
2253	PG&E	8/19/19	17:27	40.93991	-123.63221	Vegetation	Urban	3 meters - 0.25 Acres	Fire Dept	California Department of Forestry	192171101		12,000	Conductor	Overhead	Yes	8/19/19	17:27
2254	PG&E	8/20/19	9:03	41.10880	-121.50344		Agriculture	3 meters - 0.25 Acres	Cal Fire		Unknown		12,000	Conductor	Overhead	No		
2255	PG&E	8/20/19	22:04	38.22846	-121.02927		Agriculture	0.25 - 10 Acres	Cal Fire		17493		21,000	Fuse	Overhead	Yes	8/20/19	22:04
2256	PG&E	8/21/19	7:50	38.52175	-121.54946		Agriculture	0.25 - 10 Acres	Fire Dept	West Sacramento FD	63621107		12,000	Conductor	Overhead	Yes	8/21/19	7:50
2257	PG&E	8/22/19	22:23	39.13895	-121.01937	Vegetation	ardwood Fore	0.25 - 10 Acres	Cal Fire		152481106		12,000	Conductor	Overhead	Yes	8/22/19	22:23
225																		

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
2	Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
2	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	
2276	PG&E	9/3/19	6:42	39.22187	-121.44824	Urban	3 meters - 0.25 Acres	Cal Fire		152331108		12,000	Conductor	Overhead	Yes	9/3/19	6:42	
2277	PG&E	9/3/19	21:27	35.23624	-119.59706	Herbaceous	3 meters - 0.25 Acres	Fire Dept	Kern County FD	100222922		21,000	Conductor	Overhead	Yes	9/3/19	21:27	
2278	PG&E	9/4/19	11:45	35.77594	-119.71437	Gun Shot	Herbaceous	0.25 - 10 Acres	Self Extinguished	100172031		21,000	Conductor	Overhead	Yes	9/4/19	11:45	
2279	PG&E	9/5/19	13:53	36.16604	-120.25517	Agriculture	10 - 100 Acres	Cal Fire		100717742		12,000	Pole	Overhead	Yes	9/5/19	13:53	
2280	PG&E	9/5/19	23:02	37.16527	-122.20099	Vegetation	Conifer Forest	3 meters - 0.25 Acres	Cal Fire	California Department of Forestry	101670112		12,000	Fuse	Overhead	Yes	9/5/19	23:02
2281	PG&E	9/6/19	19:16	38.93397	-121.21230	Vegetation	dwood Wood	1 meter - < 3 meters	Cal Fire	153701101		12,000	Conductor	Overhead	Yes	9/6/19	19:16	
2282	PG&E	9/6/19	8:55	34.89372	-120.30097	Barren/Other	1 meter - < 3 meters	Fire Dept		0921	Santa Barbara County FD		12,000	Capacitor Bank	Overhead	Yes	9/6/19	8:55
2283	PG&E	9/6/19	12:34	40.06978	-122.23150	Herbaceous	3 meters - 0.25 Acres	Cal Fire		162			12,000	Capacitor Bank	Underbuild	No		
2284	PG&E	9/7/19	15:07	36.76042	-119.79620	Vegetation	Urban	1 meter - < 3 meters	Fire Dept	Fresno FD	100861440		12,000	Conductor	Overhead	Yes	9/7/19	15:07
2285	PG&E	9/7/19	11:42	38.89376	-121.35962	h High Voltage	Agriculture	0.25 - 10 Acres	Fire Dept	Lincoln FD	153701105-2101075312(1276)	Yes	12,000	Conductor	Overhead	Yes	9/7/19	11:42
2286	PG&E	9/7/19	16:03	37.79045	-121.23056	Vegetation	Urban	3 meters - 0.25 Acres	Fire Dept	Manteca City FD	162611706		17,000	Conductor	Overhead	Yes	9/7/19	16:03
2287	PG&E	9/7/19	17:25	39.01666	-122.91132	Vegetation	Urban	1 meter - < 3 meters	Fire Dept	Lakeport FD	Unknown		12,000	Conductor	Overhead	Yes	9/7/19	17:25
2288	PG&E	9/7/19	19:09	36.84463	-119.53908	Vegetation	Agriculture	0.25 - 10 Acres	Cal Fire	R1426		12,000	Conductor	Overhead	Yes	9/7/19	19:09	
2289	PG&E	9/8/19	16:08	39.75374	-121.91898	Bird Found	Agriculture	0.25 - 10 Acres	Fire Dept	Butte County FD	1104/2		12,000	Conductor	Overhead	Yes	9/8/19	16:08
2290	PG&E	9/8/19	12:14	35.41588	-119.04026	Urban	3 meters - 0.25 Acres	Fire Dept	Kern County FD	252721109		12,000	Conductor	Overhead	Yes	9/8/19	12:14	
2291	PG&E	9/9/19	12:38	37.71826	-122.41194	Metallic Ballo	Urban	0.25 - 10 Acres	Fire Dept	San Francisco FD	02210		12,000	Conductor	Overhead	Yes	9/9/19	12:38
2292	PG&E	9/9/19	12:35	35.69592	-120.68079	Bird Found	Herbaceous	0.25 - 10 Acres	Cal Fire	4Bk0909191234		12,000	Fuse	Overhead	Yes	9/9/19	12:35	
2293	PG&E	9/10/19	7:13	37.16527	-122.20099	Vegetation	Conifer Forest	3 meters - 0.25 Acres	Cal Fire	82841102		12,000	Conductor	Overhead	Yes	9/10/19	7:13	
2294	PG&E	9/10/19	15:03	36.43107	-119.69929	Agriculture	1 meter - < 3 meters	Fire Dept	Fresno FD	Unknown		12,000	Conductor	Overhead	Yes	9/10/19	15:03	
2295	PG&E	9/11/19	12:57	37.60934	-122.39697	Urban	3 meters - 0.25 Acres	Fire Dept	North County FD	L7R6108		12,000	Recloser	Overhead	No			
2296	PG&E	9/11/19	17:13	35.71774	-119.38384	Agriculture	1 meter - < 3 meters	Fire Dept	Kern County FD	7072		12,000	Fuse	Overhead	Yes	9/11/19	17:13	
2297	PG&E	9/11/19	18:28	35.84929	-120.06503	Bird Found	Herbaceous	100+ Acres	Cal Fire	416842619006		12,000	Transformer	Overhead	Yes	9/11/19	18:28	
2298	PG&E	9/11/19	21:03	38.31326	-120.98085	Vegetation	Herbaceous	3 meters - 0.25 Acres	Cal Fire	163341103		12,000	Conductor	Overhead	Yes	9/11/19	21:03	
2299	PG&E	9/11/19	18:56	37.99369	-122.13696	Bird Found	Wooded Wood	Other	Unknown	Unknown		115,000	Other	Overhead	Yes	9/11/19	18:56	
2300	PG&E	9/12/19	14:25	37.31437	-122.18648	Vegetation	Conifer Forest	3 meters - 0.25 Acres	Cal Fire	024131103		12,000	Conductor	Overhead	Yes	9/12/19	14:25	
2301	PG&E	9/13/19	6:30	37.33481	-121.77157	Herbaceous	3 meters - 0.25 Acres	Fire Dept	Unknown	833921101		21,000	Nice/Clamp/Connec	Overhead	Yes	9/13/19	6:30	
2302	PG&E	9/13/19	16:38	37.42558	-121.92445	Aircraft	Urban	0.25 - 10 Acres	Fire Dept	Milpitas FD	2103/2		21,000	Conductor	Overhead	Yes	9/13/19	16:38
2303	PG&E	9/13/19	15:47	37.64462	-122.11868	Urban	1 meter - < 3 meters	Fire Dept	Alameda County FD	50325		12,000	Transformer	Overhead	Yes	9/13/19	15:47	
2304	PG&E	9/13/19	20:26	40.79733	-124.19681	Vegetation	Urban	0.25 - 10 Acres	Fire Dept	Samoa FD	192451104		12,000	Conductor	Overhead	Yes	9/13/19	20:26
2305	PG&E	9/13/19	8:53	39.07537	-121.17169	Bird Found	Herbaceous	0.25 - 10 Acres	Fire Dept	Consolidated FD	Etr0913190810		12,000	Other	Overhead	Yes	9/13/19	8:53
2306	PG&E	9/13/19	10:30	36.90410	-121.40345	Bird Found	Herbaceous	3 meters - 0.25 Acres	Fire Dept	Hollister FD	9019		21,000	Conductor	Overhead	Yes	9/13/19	10:30
2307	PG&E	9/15/19	12:38	38.11940	-120.80134	Vehicle	dwood Wood	0.25 - 10 Acres	Cal Fire	103959405		12,000	Pole	Overhead	Yes	9/15/19	12:38	
2308	PG&E	9/15/19	12:58	38.10568	-122.64555	Vegetation	Urban	0.25 - 10 Acres	Fire Dept	Novato FD	103958177		12,000	Pole	Overhead	Yes	9/15/19	12:58
2309	PG&E	9/16/19	14:39	37.37624	-119.87289	Vegetation	dwood Wood	10 - 100 Acres	Cal Fire	254452102		21,000	Conductor	Overhead	Yes	9/16/19	14:39	
2310	PG&E	9/17/19	13:21	38.60177	-121.69283	Vehicle	Agriculture	3 meters - 0.25 Acres	Fire Dept	Davis FD	62041106		12,000	Conductor	Overhead	Yes	9/17/19	13:21
2311	PG&E	9/17/19	14:11	38.80655	-121.30805	Bird Found	Herbaceous	3 meters - 0.25 Acres	Unknown	Unknown		115,000	Other	Overhead	Yes	9/17/19	14:11	
2312	PG&E	9/20/19	10:58	39.98039	-122.14069	Vegetation	Urban	3 meters - 0.25 Acres	Cal Fire	Unknown		12,000	Service Conductor	Overhead	Yes	9/20/19	10:58	
2313	PG&E	9/22/19	11:45	38.60395	-121.05914	Urban	3 meters - 0.25 Acres	Cal Fire	Unknown	Unknown		21,000	Other	Pad mount	Yes	9/22/19	11:45	
2314	PG&E	9/22/19	11:34	36.02644	-121.25078	Vegetation	Herbaceous	0.25 - 10 Acres	Fire Dept	Unknown	103958188		12,000	Pole	Overhead	Yes	9/22/19	11:34
2315	PG&E	9/22/19	11:50	37.51693	-119.91594	Hardwood Wood	3 meters - 0.25 Acres	Cal Fire		103957994		21,000	Pole	Overhead	Yes	9/22/19	11:50	
2316	PG&E	9/23/19	16:04	37.87988	-122.07887	Animal Found	Urban	3 meters - 0.25 Acres	Cal Fire	11055/2		12,000	Pothole	Overhead	Yes	9/23/19	16:04	
2317	PG&E	9/23/19	16:39	38.62689	-121.71094	Agriculture	0.25 - 10 Acres	Fire Dept	Woodland FD	62041106		12,000	Conductor	Overhead	No			
2318	PG&E	9/23/19	19:13	38.43157	-121.91546	Bird Found	Urban	3 meters - 0.25 Acres	Fire Dept	Dixon FD	6P0K923191913		12,000	Conductor	Overhead	Yes	9/23/19	19:13
2319	PG&E	9/24/19	13:13	38.49116	-122.47968	Bird Found	Urban	3 meters - 0.25 Acres	Fire Dept	Saint Helena FD	Silverado 2103		21,000	Crossarm	Overhead	Yes	9/24/19	13:13
2320	PG&E	9/24/19	13:59	35.13143	-119.46165	Urban	1 meter - < 3 meters	Fire Dept	Kern County FD	252081108		12,000	Conductor	Overhead	Yes	9/24/19	13:59	
2321	PG&E	9/25/19	9:45	38.79513	-121.47560	Agriculture	3 meters - 0.25 Acres	Cal Fire		Fuses At C943		12,000	Fuse	Overhead	No			
2322	PG&E	9/26/19	11:12	38.58950	-121.69804	Agriculture	3 meters - 0.25 Acres	Fire Dept	Woodland FD	Cutouts And Jumpers At 9127		12,000	Conductor	Overhead	Yes	9/26/19	11:12	
2323	PG&E	9/26/19	13:47	38.11225	-122.22145	Vegetation	Urban	0.25 - 10 Acres	Fire Dept	Vallejo FD	Unknown		12,000	Secondary	Overhead	Yes	9/26/19	13:47
2324	PG&E	9/26/19	14:12	36.95171	-121.82779	Vegetation	Shrub	1 meter - < 3 meters	Cal Fire	2287		21,000	Conductor	Overhead	Yes	9/26/19	14:12	
2325	PG&E	9/26/19	17:54	38.08763	-121.52662	Urban	0.25 - 10 Acres	Fire Dept	Unknown	103958238		21,000	Pole	Overhead	Yes	9/26/19	17:54	
2326	PG&E	9/27/19	10:30	36.53362	-121.14640	Vegetation	Barren/Other	0.25 - 10 Acres	Cal Fire	182492105		21,000	Conductor	Overhead	Yes	9/27/19	10:30	
2327	PG&E	9/27/19	14:25	38.48451	-121.72288	Vehicle	Agriculture	3 meters - 0.25 Acres	Fire Dept	Unknown	103959408		12,000	Pole	Overhead	Yes	9/27/19	14:25
2328	PG&E	9/28/19	13:16	37.25534	-119.50572	Hardwood Wood	3 meters - 0.25 Acres	Cal Fire		252531103		12,000	Conductor	Overhead	Yes	9/28/19	13:16	
2329	PG&E	9/28/19	16:18	38.23003	-122.45929	Urban	0.25 - 10 Acres	Cal Fire		103958771		12,000	Pole	Overhead	Yes	9/28/19	16:18	
2330	PG&E	9/28/19	19:24	38.61346	-121.70832	Herbaceous	100+ Acres	Cal Fire		Unknown		12,000	Conductor	Overhead	Yes	9/28/19	19:24	
2331	PG&E	9/29/19	13:30	39.55135	-121.81040	Agriculture	0.25 - 10 Acres	Cal Fire		102171101		12,000	Conductor	Overhead	Yes	9/29/19	13:30	
2332	PG&E	9/29/19	15:04	36.23811	-120.39582	Herbaceous	0.25 - 10 Acres	Cal Fire		Coalinga FD	9000		12,000	Conductor	Overhead	Yes	9/29/19	15:04
2333	PG&E	9/29/19	20:06	37.44482	-121.89638	Metallic Ballo	Urban	0.25 - 10 Acres	Cal Fire	8015		12,000	Insulator	Overhead	Yes	9/29/19	20:06	
2334	PG&E	9/29/19	20:29	36.29940	-119.76942	Urban	3 meters - 0.25 Acres	Fire Dept	Lemoore FD	253601105		12,000	Conductor	Overhead	Yes	9/29/19	20:29	
2335	PG&E	9/29/19	22:06	37.06417	-119.97695	Agriculture	3 meters - 0.25 Acres	Cal Fire	Madera FD	321533520550		12,000	Transformer	Overhead	Yes	9/29/19	22:06	
2336	PG&E	9/30/19	14:29	34.61392	-120.17995	h High Voltage	Agriculture	0.25 - 10 Acres	Cal Fire	183041102		12,000	Conductor	Overhead	Yes	9/30/19	14:29	
2337	PG&E	10/2/19	17:17	38.43059	-122.81100	Herbaceous	0.25 - 10 Acres	Fire Dept	Unknown	7N1002191710		12,000	Conductor	Overhead	Yes	10/2/19	17:17	
2338	PG&E	10/2/19	19:15	36.99541	-119.99999	Vehicle	Urban	1 meter - < 3 meters	Cal Fire	321463218071		12,000	Transformer	Overhead	Yes	10/2/19	19:15	
2339	PG&E	10/3/19	16:28	37.19779	-120.01431	Herbaceous	10 - 100 Acres	Cal Fire		101024245		12,000	Insulator	Overhead	No			
2340	PG&E	10/4/19	19:07	40.49644	-122.04478	Hardwood Wood	0.25 - 10 Acres	Cal Fire		Unknown		12,000	Other	Overhead	Yes	10/4/19	19:07	
2341	PG&E	10/5/19	5:48	36.20845	-119.00683	Agriculture	3 meters - 0.25 Acres	Fire Dept	Kern County FD	3310		12,000	Other	Overhead	Yes	10/5/19	5:48	
2342	PG&E	10/5/19	16:46	34.86955	-120.24717	Vegetation	Urban	0.25 - 10 Acres	Cal Fire	182811103		12,000	Conductor	Overhead	Yes	10/5/19	16:46	
2343																		

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
2	Utility Name	Fire Start	Column1	Column2	Column3	Column4	Column5	Column6	Column7	Column8	Column9	Column10	Column11	Column12	Column13	Column14	Column15	Column16
	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	
2360	PG&E	10/20/19	12:11	35.37639	-118.94935	Metallic Ballco	Urban	1 meter - < 3 meters	Fire Dept	Unknown		12,000	Fuse	Overhead	Yes	10/20/19	12:11	
2361	PG&E	10/20/19	14:23	34.88738	-120.38317		Barren/Other	34 meters - 0.25 Acres	Fire Dept	Unknown		12,000	Fuse	Overhead	Yes	10/20/19	14:23	
2362	PG&E	10/20/19	17:09	37.15852	-122.13390		Conifer Fores	1 meter - < 3 meters	Employee	Unknown		12,000	Conductor	Overhead	No			
2363	PG&E	10/22/19	15:06	36.78650	-119.55979		Urban	3 meters - 0.25 Acres	Fire Dept	Fresno County FD		12,000	Nice/Clamp/Connec	Overhead	Yes	10/22/19	15:06	
2364	PG&E	10/22/19	14:44	35.73360	-119.68968		Bird Found	Urban	0.25 - 10 Acres	Fire Dept	Unknown	21,000	Pole	Overhead	Yes	10/22/19	14:44	
2365	PG&E	10/23/19	21:27	38.76596	-122.76725		Herbaceous	100+ Acres	Cal Fire	001/006		230,000	Under Investigation	Overhead	Yes	10/23/19	21:19	
2366	PG&E	10/23/19	20:54	39.09484	-121.95173		Vegetation	Agriculture	3 meters - 0.25 Acres	Fire Dept	Sacramento FD	12,000	Conductor	Overhead	Yes	10/23/19	20:54	
2367	PG&E	10/24/19	11:44	37.97542	-122.32195		Urban	3 meters - 0.25 Acres	Fire Dept	Richmond FD		12,000	Conductor	Overhead	Yes	10/24/19	11:44	
2368	PG&E	10/24/19	7:38	36.93163	-121.47590		Vehicle	Barren/Other	3 meters - 0.25 Acres	Fire Dept	Hollister FD	21,000	Pole	Overhead	Yes	10/24/19	7:38	
2369	PG&E	10/24/19	5:44	38.32303	-122.47585		Vegetation	Urban	3 meters - 0.25 Acres	Cal Fire		12,000	Pole	Overhead	Yes	10/24/19	5:44	
2370	PG&E	10/25/19	13:18	38.21427	-121.97036		Herbaceous	0.25 - 10 Acres	Fire Dept	Suisun FD		21,000	Pole	Overhead	No			
2371	PG&E	10/25/19	11:37	35.32100	-119.34134		Agriculture	0.25 - 10 Acres	Fire Dept	Kern County FD		12,000	Pole	Overhead	Yes	10/25/19	11:37	
2372	PG&E	10/26/19	23:27	40.16738	-122.24674		Urban	3 meters - 0.25 Acres	Fire Dept	Red Bluff FD		12,000	Transformer	Overhead	Yes	10/26/19	23:27	
2373	PG&E	10/26/19	4:26	36.48918	-119.79089		Vehicle	Agriculture	3 meters - 0.25 Acres	Fire Dept	Unknown	10,9960407	Pole	Overhead	Yes	10/26/19	4:26	
2374	PG&E	10/27/19	13:30	37.89973	-122.09080		Urban	0.25 - 10 Acres	Fire Dept	Contra Costa FD		12,000	Pole	Overhead	Yes	10/27/19	13:30	
2375	PG&E	10/27/19	14:55	37.43447	-121.91358		Urban	0.25 - 10 Acres	Fire Dept	Unknown		21,000	Conductor	Overhead	Yes	10/27/19	14:55	
2376	PG&E	10/27/19	14:55	37.53556	-121.95156		Vegetation	Urban	3 meters - 0.25 Acres	Fire Dept	Unknown	12,000	Conductor	Overhead	Yes	10/27/19	14:55	
2377	PG&E	10/27/19	14:34	38.77719	-121.68826		Vegetation	Urban	0.25 - 10 Acres	Fire Dept	Knights Landing FD	12,000	Conductor	Overhead	Yes	10/27/19	14:34	
2378	PG&E	10/27/19	17:12	37.31150	-121.99959		Vegetation	Urban	1 meter - < 3 meters	Fire Dept	Santa Clara County FD	12,000	Transformer	Overhead	Yes	10/27/19	17:12	
2379	PG&E	10/27/19	15:38	37.89095	-122.09406		Urban	3 meters - 0.25 Acres	Fire Dept	Contra Costa County FD		12,000	Conductor	Overhead	No			
2380	PG&E	10/27/19	15:28	36.78502	-121.65088		Vegetation	dwood Wood	3 meters - 0.25 Acres	Cal Fire		12,000	Conductor	Overhead	Yes	10/27/19	15:28	
2381	PG&E	10/27/19	16:15	37.38066	-121.90166		Metallic Ballco	Urban	3 meters - 0.25 Acres	Fire Dept	Unknown	21,000	Conductor	Overhead	Yes	10/27/19	16:15	
2382	PG&E	10/27/19	15:01	37.93835	-121.24690		Vegetation	Urban	1 meter - < 3 meters	Fire Dept	Stockton FD	12,000	Conductor	Overhead	Yes	10/27/19	15:01	
2383	PG&E	10/27/19	14:41	36.99098	-120.62303		Vegetation	Urban	3 meters - 0.25 Acres	Fire Dept	Merced County FD	12,000	Conductor	Overhead	Yes	10/27/19	14:41	
2384	PG&E	10/27/19	14:48	37.27668	-121.81465		Vegetation	Urban	0.25 - 10 Acres	Fire Dept	Unknown	21,000	Conductor	Overhead	Yes	10/27/19	14:48	
2385	PG&E	10/27/19	13:32	37.96663	-121.34618		Urban	1 meter - < 3 meters	Fire Dept	Stockton FD		12,000	Conductor	Overhead	Yes	10/27/19	13:32	
2386	PG&E	10/27/19	11:01	37.59733	-122.06156		Vegetation	Urban	3 meters - 0.25 Acres	Self Extinguished		12,000	Other	Overhead	Yes	10/27/19	11:01	
2387	PG&E	10/27/19	9:44	36.98802	-121.93952		Urban	3 meters - 0.25 Acres	Fire Dept	Unknown		21,000	Conductor	Overhead	Yes	10/27/19	9:44	
2388	PG&E	10/27/19	6:34	38.74670	-122.14920		Agriculture	3 meters - 0.25 Acres	Cal Fire	Esparto FD		21,000	Conductor	Overhead	Yes	10/27/19	6:34	
2389	PG&E	10/27/19	7:27	37.99324	-121.64123		Urban	10 - 100 Acres	Cal Fire	Contra Costa County FD		21,000	Line Recloser	Overhead	Yes	10/27/19	7:27	
2390	PG&E	10/27/19	14:56	38.15628	-121.97610		Urban	100+ Acres	Fire Dept	Suisun FD		12,000	Conductor	Overhead	No			
2391	PG&E	10/27/19	5:38	39.19675	-121.93273		Vegetation	dwood Wood	3 meters - 0.25 Acres	Fire Dept	Unknown	12,000	Conductor	Overhead	No			
2392	PG&E	10/27/19	3:16	39.56031	-122.10678		Vegetation	Agriculture	0.25 - 10 Acres	Self Extinguished		12,000	Pole	Overhead	Yes	10/27/19	3:16	
2393	PG&E	10/27/19	1:42	39.17368	-122.13344		Urban	10 - 100 Acres	Fire Dept	Williams FD		12,000	Pole	Overhead	Yes	10/27/19	1:42	
2394	PG&E	10/27/19	2:39	38.16658	-121.59678		Urban	0.25 - 10 Acres	Fire Dept	Unknown		21,000	Other	Overhead	Yes	10/27/19	2:39	
2395	PG&E	10/27/19	2:14	39.52676	-122.36420		Vegetation	Herbaceous	10 - 100 Acres	Cal Fire		21,000	Pole	Overhead	Yes	10/27/19	2:14	
2396	PG&E	10/27/19	5:35	38.27622	-122.46142		Urban	0.25 - 10 Acres	Cal Fire	Unknown		12,000	Conductor	Overhead	No			
2397	PG&E	10/28/19	17:48	37.03095	-121.77882		Vegetation	dwood Wood	0.25 - 10 Acres	Cal Fire		21,000	Conductor	Overhead	Yes	10/28/19	17:48	
2398	PG&E	10/28/19	18:46	38.56463	-122.46418		Vegetation	Conifer Fores	1 meter - < 3 meters	Cal Fire		21,000	Conductor	Overhead	Yes	10/28/19	18:46	
2399	PG&E	10/28/19	7:09	37.98893	-121.52118		Herbaceous	0.25 - 10 Acres	Fire Dept	Livermore FD		12,000	Fuse	Underbuild	Yes	10/28/19	7:09	
2400	PG&E	10/28/19	16:54	38.65597	-121.71865		Agriculture	0.25 - 10 Acres	Fire Dept	Sutter County FD		12,000	Conductor	Overhead	No			
2401	PG&E	10/28/19	13:00	39.32079	-121.12726		Vegetation	Conifer Fores	1 meter - < 3 meters	Cal Fire		12,000	Transformer	Overbuild	Yes	10/28/19	13:00	
2402	PG&E	10/28/19	11:34	38.21147	-121.35467		Vegetation	ardwood Fore	10 - 100 Acres	Fire Dept	Woodbridge FD	12,000	Conductor	Overhead	Yes	10/28/19	11:34	
2403	PG&E	10/29/19	20:40	37.26893	-122.01755		Vegetation	Urban	3 meters - 0.25 Acres	Cal Fire		12,000	Cable	Overhead	Yes	10/29/19	20:40	
2404	PG&E	10/29/19	12:57	34.62034	-120.10973		Animal Found	Herbaceous	3 meters - 0.25 Acres	Fire Dept	Unknown	12,000	Other	Overhead	Yes	10/29/19	12:57	
2405	PG&E	10/29/19	3:29	37.03745	-121.52075		Animal Found	dwood Wood	0.25 - 10 Acres	Cal Fire		21,000	Fuse	Overhead	Yes	10/29/19	3:29	
2406	PG&E	10/30/19	12:03	35.42390	-119.01930		Urban	3 meters - 0.25 Acres	Fire Dept	Unknown		12,000	Conductor	Overhead	Yes	10/30/19	12:03	
2407	PG&E	10/30/19	14:29	35.39391	-118.99500		Vegetation	Urban	3 meters - 0.25 Acres	Fire Dept	Unknown	12,000	Secondary	Overhead	Yes	10/30/19	14:29	
2408	PG&E	10/30/19	8:47	38.36119	-121.99945		Vegetation	Urban	3 meters - 0.25 Acres	Fire Dept	Vacaville FD	12,000	Conductor	Overhead	Yes	10/30/19	8:47	
2409	PG&E	10/30/19	13:32	38.47922	-122.03024		Vegetation	Herbaceous	0.25 - 10 Acres	Cal Fire		12,000	Conductor	Overhead	No			
2410	PG&E	10/30/19	10:02	35.41848	-119.05195		Urban	3 meters - 0.25 Acres	Fire Dept	Kern County FD		12,000	Conductor	Overhead	No			
2411	PG&E	10/31/19	21:21	39.66100	-120.62640		Vegetation	ardwood Fore	1 meter - < 3 meters	Fire Dept	Sierra County FD	12,000	Conductor	Overhead	Yes	10/31/19	21:21	
2412	PG&E	10/31/19	17:23	38.04583	-122.19051		Herbaceous	1 meter - < 3 meters	Fire Dept	Crockett FD		21,000	Conductor	Overhead	Yes	10/31/19	17:23	
2413	PG&E	10/31/19	16:09	38.38449	-122.18928		Vegetation	Agriculture	0.25 - 10 Acres	Cal Fire		12,000	Conductor	Overhead	No			
2414	PG&E	10/31/19	14:57	37.36761	-122.13347		Vegetation	dwood Wood	1 meter - < 3 meters	Fire Dept	Santa Clara County FD	12,000	Conductor	Overhead	Yes	10/31/19	14:57	
2415	PG&E	11/1/19	11:33	38.58012	-122.57785		Vegetation	Urban	0.25 - 10 Acres	Cal Fire		12,000	Conductor	Overhead	Yes	11/1/19	11:33	
2416	PG&E	11/1/19	22:43	34.72591	-120.42880		Herbaceous	3 meters - 0.25 Acres	Fire Dept	Unknown		12,000	Transformer	Overhead	No			
2417	PG&E	11/1/19	11:57	37.65300	-121.66710		Animal Found	Herbaceous	1 meter - < 3 meters	Self Extinguished		12,000	Transformer	Overhead	Yes	11/1/19	11:57	
2418	PG&E	11/3/19	22:01	37.65836	-122.04361		Hardwood Wood	3 meters - 0.25 Acres	Fire Dept	Hayward FD		12,000	Conductor	Overhead	Yes	11/3/19	22:01	
2419	PG&E	11/3/19	18:26	36.23229	-121.76219		Vegetation	ardwood Fore	0.25 - 10 Acres	Cal Fire		12,000	Conductor	Overhead	Yes	11/3/19	18:26	
2420	PG&E	11/4/19	9:48	38.68005	-122.05593		Metallic Ballco	Agriculture	3 meters - 0.25 Acres	Cal Fire	Esparto FD	21,000	Conductor	Overhead	No			
2421	PG&E	11/4/19	23:32	34.66190	-120.08520		Herbaceous	3 meters - 0.25 Acres	Fire Dept	Unknown		12,000	Conductor	Overhead	Yes	11/4/19	23:32	
2422	PG&E	11/5/19	15:53	35.70669	-120.70589		Bird Found	Herbaceous	0.25 - 10 Acres	Cal Fire		12,000	Conductor	Overhead	Yes	11/5/19	15:53	
2423	PG&E	11/6/19	18:13	36.01441	-120.12968		Bird Found	Urban	1 meter - < 3 meters	Self Extinguished		21,000	Conductor	Overhead	Yes	11/6/19	18:13	
2424	PG&E	11/7/19	10:48	37.29477	-120.81042		Agriculture	1 meter - < 3 meters	Cal Fire			12,000	Lightning Arrestor	Overhead	Yes	11/7/19	10:48	
2425	PG&E	11/8/19	7:22	37.97852	-122.30865		Urban	0.25 - 10 Acres	Fire Dept	Richmond FD		12,000	Conductor	Overhead	Yes	11/8/19	7:22	
2426	PG&E	11/9/19	22:02	37.28041	-121.90419		Vegetation	Urban	3 meters - 0.25 Acres	Fire Dept	San Jose FD	12,000	Conductor	Overhead	Yes	11/9/19	22:02	
2427	PG&E	11/10/19	9:47	35.07871	-120.49745		Herbaceous	1 meter - < 3 meters	Cal Fire			12,000	Conductor	Overhead	Yes	11/10/19	9:47	
2428	PG&E	11/11/19	6:52	36.68217	-119.18056		Herbaceous	3 meters - 0.25 Acres	Cal Fire			12,000	Other	Overhead	Yes	11/11/19	6:52	
2429	PG&E	11/11/19	9:46	37.87824	-120.45959		Vehicle	Urban	3 meters - 0.25 Acres	Cal Fire		17,000	Other	Overhead	Yes	11/11/19	9:46	
2430	PG&E	11/13/19	15:43	35.31798	-119.16612		Agriculture	1 meter - < 3 meters	Fire Dept									

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
1	Utility Name	Fire Start	Column1	Location	Column2	Column3	Column4	Fire	Column5	Column6	Column7	Column8	Column9	Column10	Column11	Outage	Column11	Column12
2		Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time
2444	PG&E	11/27/19	15:39	40.65793	-122.42110	Hardwood Wood		1 meter - < 3 meters	Cal Fire		103521102-2101107406(2413)		12,000	Fuse	Overhead	Yes	11/27/19	15:39
2445	PG&E	11/27/19	6:37	37.27172	-122.30779	Vegetation	Conifer Fores	3 meters - 0.25 Acres	Cal Fire		24101103		12,000	Conductor	Overhead	Yes	11/27/19	6:37
2446	PG&E	11/29/19	20:18	39.85033	-121.63120		Shrub	1 meter - < 3 meters	Unknown		40700248, 42578814, 42578813		60,000	Pole	Overhead	Yes	11/29/19	20:18
2447	PG&E	12/12/19	13:44	37.92758	-121.43156		Urban	1 meter - < 3 meters	Employee		317315152121		12,000	Transformer	Overhead	Yes	12/12/19	13:44
2448	PG&E	12/17/19	13:44	36.32336	-121.21168		Herbaceous	3 meters - 0.25 Acres	Cal Fire		103827940		21,000	Transformer	Overhead	Yes	12/17/19	13:44
2449	PG&E	12/18/19	5:25	38.28169	-120.51701	Vegetation	Herbaceous	0.25 - 10 Acres	Cal Fire		101273893		12,000	Pole	Overhead	Yes	12/18/19	5:25
2450	PG&E	12/23/19	22:49	36.96023	-122.04969	Failure/Involve	Urban	1 meter - < 3 meters	Fire Dept	Santa Cruz FD	103822060		4,000	Pole	Underbuild	Yes	12/23/19	22:49
2451	PG&E	12/25/19	0:58	36.64377	-121.79940	Hardwood Wood		1 meter - < 3 meters	Unknown		101784201		21,000	Conductor	Overhead	Yes	12/25/19	0:58

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
3	PG&E	6/10/14	15:14	Contact From Object	N.A.	Other	Electric Facility	Human Error	Conveyor belt contact
4	PG&E	6/12/14	6:30	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
5	PG&E	6/13/14	9:19	Contact From Object	N.A.	Vehicle	Pole	Human Error	
6	PG&E	6/14/14	8:47	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
7	PG&E	6/14/14	11:01	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
8	PG&E	6/15/14	9:47	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
9	PG&E	6/15/14	17:28	Wire-Wire Contact	N.A.	N.A.	N.A.	Weather	
10	PG&E	6/15/14	20:55	Contact From Object	N.A.	Vehicle	Pole	Human Error	
11	PG&E	6/16/14	15:37	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
12	PG&E	6/17/14	13:49	Contact From Object	N.A.	Vehicle	Pole	Human Error	
13	PG&E	6/17/14	14:50	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
14	PG&E	6/17/14	16:47	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
15	PG&E	6/17/14	21:24	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
16	PG&E	6/18/14	10:01	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
17	PG&E	6/18/14	18:29	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
18	PG&E	6/19/14	16:32	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	service conductor
19	PG&E	6/19/14	18:54	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
20	PG&E	6/20/14	9:47	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
21	PG&E	6/20/14	12:00	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
22	PG&E	6/20/14	14:15	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
23	PG&E	6/21/14	6:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
24	PG&E	6/21/14	14:36	Contact From Object	N.A.	Vehicle	Pole	Human Error	
25	PG&E	6/22/14	8:19	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
26	PG&E	6/23/14	8:04	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
27	PG&E	6/23/14	17:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
28	PG&E	6/24/14	7:11	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
29	PG&E	6/24/14	7:48	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	dumpster burned
30	PG&E	6/24/14	14:31	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
31	PG&E	6/24/14	16:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
32	PG&E	6/24/14	17:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
33	PG&E	6/25/14	1:36	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
34	PG&E	6/25/14	8:51	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
35	PG&E	6/25/14	8:53	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
36	PG&E	6/25/14	21:47	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
37	PG&E	6/26/14	0:15	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
38	PG&E	6/28/14	23:04	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
39	PG&E	6/29/14	7:59	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
40	PG&E	6/29/14	8:23	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
41	PG&E	6/29/14	19:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
42	PG&E	6/30/14	14:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
43	PG&E	6/30/14	18:25	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
44	PG&E	6/30/14	20:02	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
45	PG&E	7/1/14	3:46	Contact From Object	N.A.	Vehicle	Pole	Human Error	
46	PG&E	7/1/14	6:43	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
47	PG&E	7/1/14	9:45	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
48	PG&E	7/1/14	14:36	Contact From Object	N.A.	Vehicle	Communication Facility	Human Error	
49	PG&E	7/1/14	18:43	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
50	PG&E	7/2/14	13:17	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
51	PG&E	7/2/14	14:29	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	Third-party caused
52	PG&E	7/2/14	17:17	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
53	PG&E	7/3/14	11:37	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
54	PG&E	7/3/14	19:22	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
55	PG&E	7/3/14	20:28	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
56	PG&E	7/4/14	1:40	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
57	PG&E	7/4/14	6:52	Unknown	N.A.	N.A.	N.A.	Unknown	
58	PG&E	7/5/14	3:30	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
59	PG&E	7/5/14	5:33	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	debris burned
60	PG&E	7/5/14	10:09	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
61	PG&E	7/5/14	23:17	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
62	PG&E	7/6/14	17:00	Unknown	N.A.	N.A.	N.A.	Unknown	
63	PG&E	7/6/14	19:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
64	PG&E	7/7/14	20:43	Contact From Object	N.A.	Other	Electric Facility	Human Error	suspect large crane
65	PG&E	7/7/14	23:49	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
66	PG&E	7/8/14	11:07	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
67	PG&E	7/8/14	11:41	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
68	PG&E	7/8/14	12:34	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
69	PG&E	7/8/14	22:39	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
70	PG&E	7/9/14	14:42	Unknown	N.A.	N.A.	N.A.	Unknown	
71	PG&E	7/10/14	14:37	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
72	PG&E	7/11/14	1:42	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
73	PG&E	7/11/14	14:07	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
74	PG&E	7/11/14	15:15	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
75	PG&E	7/11/14	21:56	Contact From Object	N.A.	Vehicle	Pole	Human Error	
76	PG&E	7/12/14	16:25	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
77	PG&E	7/12/14	19:52	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
78	PG&E	7/13/14	18:42	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
79	PG&E	7/14/14	9:36	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
80	PG&E	7/14/14	16:41	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
81	PG&E	7/15/14	9:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
82	PG&E	7/15/14	16:32	Unknown	N.A.	N.A.	N.A.	Unknown	
83	PG&E	7/16/14	1:29	Unknown	N.A.	N.A.	N.A.	Unknown	
84	PG&E	7/17/14	13:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
85	PG&E	7/17/14	15:14	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
86	PG&E	7/17/14	17:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
87	PG&E	7/20/14	3:07	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	play structure burned
88	PG&E	7/20/14	12:23	Contact From Object	N.A.	Other	Electric Facility	Unknown	lightning strike
89	PG&E	7/20/14	12:44	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
90	PG&E	7/21/14	9:57	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
91	PG&E	7/22/14	14:53	Unknown	N.A.	N.A.	N.A.	Unknown	
92	PG&E	7/22/14	20:09	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
93	PG&E	7/23/14	12:16	Contact From Object	N.A.	Vehicle	Pole	Human Error	vehicle burned
94	PG&E	7/24/14	1:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
95	PG&E	7/24/14	10:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
96	PG&E	7/24/14	11:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
97	PG&E	7/24/14	15:26	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
98	PG&E	7/24/14	15:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
99	PG&E	7/24/14	19:28	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
100	PG&E	7/25/14	12:16	Unknown	N.A.	N.A.	N.A.	Unknown	
101	PG&E	7/26/14	5:02	Unknown	N.A.	N.A.	N.A.	Unknown	
102	PG&E	7/26/14	15:26	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
103	PG&E	7/27/14	4:17	Contact From Object	N.A.	Vehicle	Pole	Human Error	car / garage burned
104	PG&E	7/27/14	6:54	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
105	PG&E	7/27/14	16:30	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
106	PG&E	7/27/14	17:40	Other	N.A.	N.A.	N.A.	Outside Force	woodpecker damage
107	PG&E	7/28/14	0:46	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	shack burned
108	PG&E	7/28/14	16:00	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
109	PG&E	7/28/14	19:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
110	PG&E	7/30/14	4:36	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
111	PG&E	7/30/14	10:42	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
112	PG&E	7/30/14	17:35	Equipment/ Facility Failure	Voltage Regulator	N.A.	N.A.	Unknown	
113	PG&E	7/31/14	12:41	Contact From Object	N.A.	Vehicle	Pole	Human Error	
114	PG&E	7/31/14	15:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
115	PG&E	7/31/14	22:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
116	PG&E	8/1/14	16:17	Unknown	N.A.	N.A.	N.A.	Unknown	
117	PG&E	8/2/14	0:04	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
118	PG&E	8/2/14	10:38	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
119	PG&E	8/3/14	16:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
120	PG&E	8/4/14	4:18	Contact From Object	N.A.	Vehicle	Communication Facility	Human Error	
121	PG&E	8/5/14	0:08	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
122	PG&E	8/5/14	2:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
123	PG&E	8/5/14	12:03	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
124	PG&E	8/5/14	14:50	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
125	PG&E	8/5/14	16:13	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
126	PG&E	8/5/14	17:12	Unknown	N.A.	N.A.	N.A.	Unknown	
127	PG&E	8/5/14	21:41	Unknown	N.A.	N.A.	N.A.	Unknown	
128	PG&E	8/8/14	18:17	Contact From Object	N.A.	Vehicle	Pole	Human Error	
129	PG&E	8/9/14	2:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
130	PG&E	8/9/14	15:36	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
131	PG&E	8/11/14	9:23	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
132	PG&E	8/11/14	14:35	Contact From Object	N.A.	Other	Electric Facility	Weather	lightning strike
133	PG&E	8/12/14	8:58	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
134	PG&E	8/12/14	9:42	Contact From Object	N.A.	Vehicle	Pole	Human Error	vehicle burned
135	PG&E	8/12/14	15:38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
136	PG&E	8/14/14	10:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
137	PG&E	8/14/14	14:57	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
138	PG&E	8/15/14	11:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
139	PG&E	8/16/14	7:30	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
140	PG&E	8/17/14	7:27	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
141	PG&E	8/17/14	17:33	Contact From Object	N.A.	Vehicle	Pole	Human Error	vehicle burned
142	PG&E	8/19/14	3:06	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	vehicle burned
143	PG&E	8/19/14	21:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
144	PG&E	8/20/14	14:22	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
145	PG&E	8/20/14	16:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
146	PG&E	8/21/14	0:00	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
147	PG&E	8/23/14	8:36	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
148	PG&E	8/24/14	11:08	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
149	PG&E	8/27/14	6:51	Contact From Object	N.A.	Vehicle	Pole	Human Error	
150	PG&E	8/27/14	15:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
151	PG&E	8/28/14	0:00	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
152	PG&E	8/28/14	13:51	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
153	PG&E	8/29/14	19:21	Contact From Object	N.A.	Vehicle	Pole	Human Error	
154	PG&E	8/30/14	12:08	Unknown	N.A.	N.A.	N.A.	Unknown	
155	PG&E	8/30/14	15:40	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
156	PG&E	8/30/14	18:34	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
157	PG&E	8/31/14	2:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
158	PG&E	9/1/14	15:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
159	PG&E	9/2/14	3:49	Contamination	N.A.	N.A.	N.A.	Weather	
160	PG&E	9/3/14	7:05	Unknown	N.A.	N.A.	N.A.	Unknown	
161	PG&E	9/3/14	13:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
162	PG&E	9/4/14	0:34	Contact From Object	N.A.	Vehicle	Pole	Human Error	
163	PG&E	9/6/14	16:42	Unknown	N.A.	N.A.	N.A.	Unknown	
164	PG&E	9/7/14	6:33	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
165	PG&E	9/9/14	9:54	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
166	PG&E	9/10/14	0:00	Unknown	N.A.	N.A.	N.A.	Unknown	
167	PG&E	9/11/14	11:39	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
168	PG&E	9/12/14	5:20	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
169	PG&E	9/13/14	17:25	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
170	PG&E	9/14/14	14:47	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
171	PG&E	9/15/14	19:22	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
172	PG&E	9/16/14	12:56	Contact From Object	N.A.	Vehicle	Communication Facility	Human Error	
173	PG&E	9/17/14	8:36	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
174	PG&E	9/17/14	11:49	Contact From Object	N.A.	Vehicle	Pole	Human Error	
175	PG&E	9/17/14	14:47	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
176	PG&E	9/18/14	13:00	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
177	PG&E	9/19/14	8:44	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
178	PG&E	9/20/14	0:00	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
179	PG&E	9/20/14	7:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
180	PG&E	9/21/14	4:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
181	PG&E	9/23/14	10:05	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
182	PG&E	9/23/14	10:53	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
183	PG&E	9/25/14	2:58	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
184	PG&E	9/25/14	20:27	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
185	PG&E	9/27/14	14:03	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
186	PG&E	9/27/14	17:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
187	PG&E	9/29/14	14:26	Contact From Object	N.A.	Vehicle	Pole	Human Error	
188	PG&E	9/30/14	11:41	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
189	PG&E	9/30/14	14:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
190	PG&E	10/1/14	12:02	Unknown	N.A.	N.A.	N.A.	Unknown	
191	PG&E	10/1/14	12:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
192	PG&E	10/1/14	13:24	Contact From Object	N.A.	Vehicle	Communication Facility	Human Error	
193	PG&E	10/1/14	15:04	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
194	PG&E	10/4/14	18:09	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
195	PG&E	10/4/14	17:00	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
196	PG&E	10/5/14	10:12	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
197	PG&E	10/5/14	22:32	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
198	PG&E	10/6/14	8:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
199	PG&E	10/7/14	11:35	Contact From Object	N.A.	Other	Electric Facility	Human Error	Third-party dig-in
200	PG&E	10/8/14	14:21	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
201	PG&E	10/9/14	8:25	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	roof burned
202	PG&E	10/9/14	19:10	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
203	PG&E	10/10/14	14:41	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
204	PG&E	10/11/14	10:19	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
205	PG&E	10/12/14	10:59	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	roof burned
206	PG&E	10/12/14	12:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
207	PG&E	10/12/14	16:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
208	PG&E	10/13/14	9:19	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
209	PG&E	10/14/14	7:33	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gun-shot
210	PG&E	10/14/14	11:04	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
211	PG&E	10/14/14	14:32	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
212	PG&E	10/16/14	16:26	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
213	PG&E	10/17/14	13:41	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
214	PG&E	10/20/14	1:23	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
215	PG&E	10/20/14	13:30	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
216	PG&E	10/21/14	2:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
217	PG&E	10/22/14	16:45	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
218	PG&E	10/22/14	20:51	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown	
219	PG&E	10/23/14	12:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
220	PG&E	10/25/14	3:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
221	PG&E	10/25/14	10:52	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
222	PG&E	10/25/14	14:35	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
223	PG&E	10/25/14	14:45	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
224	PG&E	10/26/14	22:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
225	PG&E	10/27/14	6:34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
226	PG&E	10/28/14	12:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
227	PG&E	10/28/14	16:34	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
228	PG&E	10/29/14	13:22	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
229	PG&E	11/1/14	9:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
230	PG&E	11/1/14	20:52	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
231	PG&E	11/5/14	8:34	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
232	PG&E	11/6/14	10:42	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
233	PG&E	11/6/14	14:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
234	PG&E	11/7/14	6:12	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
235	PG&E	11/8/14	15:02	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
236	PG&E	11/9/14	6:34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
237	PG&E	11/14/14	12:37	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	
238	PG&E	11/16/14	5:29	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
239	PG&E	11/16/14	17:55	Contact From Object	N.A.	Other	Electric Facility	Human Error	Soccer ball?
240	PG&E	11/17/14	17:15	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
241	PG&E	11/18/14	14:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
242	PG&E	11/22/14	6:29	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
243	PG&E	11/23/14	5:45	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
244	PG&E	11/24/14	15:29	Unknown	N.A.	N.A.	N.A.	Unknown	
245	PG&E	11/28/14	1:17	Unknown	N.A.	N.A.	N.A.	Unknown	
246	PG&E	11/29/14	14:21	Unknown	N.A.	N.A.	N.A.	Unknown	roof burned
247	PG&E	12/8/14	9:51	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
248	PG&E	12/8/14	18:33	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
249	PG&E	12/12/14	4:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
250	PG&E	12/12/14	22:15	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
251	PG&E	12/14/14	4:52	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	vehicle burned
252	PG&E	12/19/14	13:50	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
253	PG&E	12/25/14	10:50	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
254	PG&E	12/29/14	11:58	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	mobile home burned

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
255	PG&E	12/30/14	9:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
256	PG&E	12/30/14	15:53	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	vehicle burned
257	PG&E	01/08/15	15:18	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	
258	PG&E	01/10/15	13:07	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
259	PG&E	01/16/15	7:07	Unknown	N.A.	N.A.	N.A.	Unknown	
260	PG&E	01/28/15	3:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
261	PG&E	02/06/15	6:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
262	PG&E	02/06/15	14:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
263	PG&E	02/07/15	15:13	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
264	PG&E	02/07/15	18:38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
265	PG&E	02/13/15	16:01	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
266	PG&E	02/16/15	11:08	Contact From Object	N.A.	Vehicle	Pole	Human Error	
267	PG&E	02/17/15	16:46	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
268	PG&E	02/22/15	14:20	Contact From Object	N.A.	Vehicle	Pole	Human Error	
269	PG&E	02/23/15	2:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
270	PG&E	02/23/15	13:25	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
271	PG&E	02/25/15	2:34	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
272	PG&E	02/25/15	16:42	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
273	PG&E	03/04/15	18:44	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
274	PG&E	03/07/15	13:35	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
275	PG&E	03/09/15	9:36	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
276	PG&E	03/14/15	2:30	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
277	PG&E	03/14/15	14:17	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
278	PG&E	03/14/15	22:09	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
279	PG&E	03/15/15	3:26	Unknown	N.A.	N.A.	N.A.	Unknown	
280	PG&E	03/15/15	3:38	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
281	PG&E	03/15/15	22:47	Contact From Object	N.A.	Vehicle	Pole	Human Error	
282	PG&E	03/19/15	20:11	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
283	PG&E	03/21/15	10:46	Contact From Object	N.A.	Vehicle	Pole	Human Error	
284	PG&E	03/21/15	11:03	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
285	PG&E	03/31/15	13:33	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
286	PG&E	04/02/15	9:44	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
287	PG&E	04/04/15	16:49	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	Booster
288	PG&E	04/11/15	17:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
289	PG&E	04/12/15	12:35	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
290	PG&E	04/14/15	11:09	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
291	PG&E	04/14/15	12:35	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
292	PG&E	04/15/15	12:35	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
293	PG&E	04/16/15	17:35	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
294	PG&E	04/17/15	14:34	Other	N.A.	N.A.	N.A.	Unknown	bird nest caught fire
295	PG&E	04/18/15	3:07	Contact From Object	N.A.	Vehicle	Pole	Human Error	
296	PG&E	04/19/15	9:18	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
297	PG&E	04/19/15	13:01	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
298	PG&E	04/20/15	18:18	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
299	PG&E	04/21/15	17:01	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
300	PG&E	04/24/15	6:06	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
301	PG&E	04/24/15	17:47	Unknown	N.A.	N.A.	N.A.	Unknown	
302	PG&E	04/26/15	16:50	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
303	PG&E	04/27/15	12:54	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
304	PG&E	04/28/15	13:57	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
305	PG&E	04/28/15	14:20	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
306	PG&E	04/30/15	0:26	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
307	PG&E	05/02/15	16:51	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
308	PG&E	05/02/15	17:30	Contact From Object	N.A.	Other	Electric Facility	Human Error	Sky diver hit line
309	PG&E	05/06/15	17:17	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	Booster
310	PG&E	05/06/15	23:10	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
311	PG&E	05/07/15	8:06	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
312	PG&E	05/08/15	5:55	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
313	PG&E	05/09/15	13:10	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
314	PG&E	05/09/15	21:37	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
315	PG&E	05/10/15	15:03	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
316	PG&E	05/10/15	16:07	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
317	PG&E	05/11/15	7:19	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
318	PG&E	05/11/15	16:07	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
319	PG&E	05/11/15	16:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
320	PG&E	05/12/15	23:57	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
321	PG&E	05/13/15	21:57	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
322	PG&E	05/14/15	11:03	Contact From Object	N.A.	Vehicle	Pole	Human Error	
323	PG&E	05/17/15	23:41	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
324	PG&E	05/19/15	13:31	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown	
325	PG&E	05/21/15	6:02	Unknown	N.A.	N.A.	N.A.	Unknown	
326	PG&E	05/21/15	9:23	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
327	PG&E	05/24/15	10:59	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
328	PG&E	05/25/15	2:42	Unknown	N.A.	N.A.	N.A.	Unknown	
329	PG&E	05/26/15	5:44	Other	N.A.	N.A.	N.A.	Other	Crow's nest caught fire
330	PG&E	05/27/15	1:02	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	UG cable
331	PG&E	05/27/15	21:44	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
332	PG&E	05/28/15	17:09	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
333	PG&E	05/29/15	11:31	Contact From Object	N.A.	Vehicle	Pole	Human Error	
334	PG&E	05/30/15	9:06	Contact From Object	N.A.	Other	Electric Facility	Human Error	helicopter hit line
335	PG&E	05/30/15	11:04	Contact From Object	N.A.	Vehicle	Pole	Human Error	
336	PG&E	05/30/15	12:52	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
337	PG&E	05/30/15	17:35	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
338	PG&E	05/31/15	0:23	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
339	PG&E	05/31/15	7:07	Unknown	N.A.	N.A.	N.A.	Unknown	
340	PG&E	05/31/15	9:27	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
341	PG&E	05/31/15	11:31	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
342	PG&E	05/31/15	11:55	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
343	PG&E	06/03/15	9:33	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
344	PG&E	06/03/15	13:44	Contact From Object	N.A.	Vehicle	Pole	Human Error	
345	PG&E	06/03/15	13:39	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
346	PG&E	06/04/15	13:17	Contact From Object	N.A.	Vehicle	Pole	Human Error	
347	PG&E	06/04/15	15:44	Contact From Object	N.A.	Vehicle	Pole	Human Error	
348	PG&E	06/04/15	18:38	Unknown	N.A.	N.A.	N.A.	Unknown	
349	PG&E	06/04/15	20:00	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
350	PG&E	06/05/15	1:25	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
351	PG&E	06/05/15	9:58	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	tie wire
352	PG&E	06/05/15	14:40	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
353	PG&E	06/05/15	15:15	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
354	PG&E	06/05/15	22:13	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
355	PG&E	06/06/15	11:24	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
356	PG&E	06/06/15	12:00	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
357	PG&E	06/06/15	15:38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
358	PG&E	06/06/15	21:17	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
359	PG&E	06/07/15	5:05	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
360	PG&E	06/07/15	14:53	Unknown	N.A.	N.A.	N.A.	Unknown	
361	PG&E	06/07/15	17:48	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gun-shot conductor
362	PG&E	06/08/15	14:18	Contact From Object	N.A.	Vehicle	Pole	Human Error	
363	PG&E	06/08/15	16:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
364	PG&E	06/08/15	16:15	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
365	PG&E	06/08/15	17:38	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
366	PG&E	06/08/15	18:32	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
367	PG&E	06/09/15	1:19	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
368	PG&E	06/09/15	11:51	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
369	PG&E	06/09/15	13:10	Contact From Object	N.A.	Vehicle	Pole	Human Error	
370	PG&E	06/09/15	15:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
371	PG&E	06/09/15	16:20	Unknown	N.A.	N.A.	N.A.	Unknown	
372	PG&E	06/09/15	21:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
373	PG&E	06/10/15	12:00	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
374	PG&E	06/10/15	17:02	Unknown	N.A.	N.A.	N.A.	Unknown	
375	PG&E	06/10/15	21:43	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
376	PG&E	06/11/15	18:32	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown	
377	PG&E	06/12/15	9:04	Contact From Object	N.A.	Other	Electric Facility	Human Error	crop duster hit line
378	PG&E	06/12/15	9:24	Unknown	N.A.	N.A.	N.A.	Unknown	
379	PG&E	06/12/15	10:49	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
380	PG&E	06/12/15	13:07	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
381	PG&E	06/12/15	16:01	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
382	PG&E	06/12/15	23:32	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
383	PG&E	06/13/15	12:50	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
384	PG&E	06/14/15	12:19	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
385	PG&E	06/14/15	13:50	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
386	PG&E	06/15/15	15:35	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
387	PG&E	06/16/15	10:40	Contact From Object	N.A.	Other	Electric Facility	Unknown	bird-dropped material
388	PG&E	06/16/15	11:27	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
389	PG&E	06/17/15	10:32	Contact From Object	N.A.	Vehicle	Pole	Human Error	
390	PG&E	06/17/15	15:49	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
391	PG&E	06/17/15	18:35	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
392	PG&E	06/19/15	12:14	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
393	PG&E	06/19/15	20:09	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
394	PG&E	06/20/15	1:28	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
395	PG&E	06/21/15	1:32	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
396	PG&E	06/21/15	3:17	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	Potential transformer
397	PG&E	06/21/15	12:07	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
398	PG&E	06/21/15	12:10	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
399	PG&E	06/21/15	12:31	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
400	PG&E	06/21/15	12:46	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
401	PG&E	06/21/15	13:31	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
402	PG&E	06/22/15	11:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
403	PG&E	06/22/15	18:56	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
404	PG&E	06/23/15	15:23	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
405	PG&E	06/23/15	19:06	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
406	PG&E	06/23/15	20:34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
407	PG&E	06/23/15	20:57	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
408	PG&E	06/24/15	19:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
409	PG&E	06/25/15	8:43	Contact From Object	N.A.	Vehicle	Pole	Human Error	
410	PG&E	06/25/15	11:22	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
411	PG&E	06/25/15	18:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
412	PG&E	06/25/15	18:29	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
413	PG&E	06/25/15	19:44	Equipment/ Facility Failure	Voltage Regulator	N.A.	N.A.	Unknown	
414	PG&E	06/26/15	2:51	Unknown	N.A.	N.A.	N.A.	Unknown	
415	PG&E	06/26/15	17:20	Unknown	N.A.	N.A.	N.A.	Unknown	
416	PG&E	06/27/15	12:48	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
417	PG&E	06/27/15	18:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
418	PG&E	06/27/15	21:15	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
419	PG&E	06/27/15	22:28	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
420	PG&E	06/28/15	2:50	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
421	PG&E	06/28/15	2:54	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
422	PG&E	06/28/15	14:39	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
423	PG&E	06/28/15	14:47	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
424	PG&E	06/28/15	17:15	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
425	PG&E	06/28/15	20:40	Contact From Object	N.A.	Vehicle	Pole	Human Error	
426	PG&E	06/28/15	21:07	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
427	PG&E	06/29/15	1:06	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
428	PG&E	06/29/15	6:26	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
429	PG&E	06/29/15	7:43	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
430	PG&E	06/29/15	18:45	Contact From Object	N.A.	Vehicle	Pole	Human Error	
431	PG&E	06/30/15	0:05	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
432	PG&E	06/30/15	5:40	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
433	PG&E	06/30/15	17:54	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
434	PG&E	06/30/15	18:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
435	PG&E	07/01/15	9:17	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
436	PG&E	07/01/15	12:57	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
437	PG&E	07/02/15	12:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
438	PG&E	07/02/15	14:06	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
439	PG&E	07/02/15	22:52	Contamination	N.A.	N.A.	N.A.	Unknown	
440	PG&E	07/03/15	3:23	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
441	PG&E	07/03/15	12:12	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
442	PG&E	07/03/15	19:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
443	PG&E	07/04/15	1:14	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	Booster
444	PG&E	07/04/15	7:37	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
445	PG&E	07/04/15	14:14	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
446	PG&E	07/05/15	9:42	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
447	PG&E	07/05/15	21:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
448	PG&E	07/07/15	3:02	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
449	PG&E	07/07/15	5:52	Contact From Object	N.A.	Vehicle	Pole	Human Error	
450	PG&E	07/07/15	10:42	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
451	PG&E	07/07/15	15:27	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
452	PG&E	07/07/15	22:02	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
453	PG&E	07/08/15	11:23	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
454	PG&E	07/11/15	8:57	Equipment/ Facility Failure	Guy/Span Wire	N.A.	N.A.	Unknown	
455	PG&E	07/11/15	15:38	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
456	PG&E	07/12/15	1:32	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
457	PG&E	07/12/15	15:27	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
458	PG&E	07/12/15	17:04	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	Jumper
459	PG&E	07/12/15	19:47	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
460	PG&E	07/13/15	14:16	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
461	PG&E	07/13/15	17:04	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
462	PG&E	07/14/15	12:37	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
463	PG&E	07/14/15	17:25	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
464	PG&E	07/14/15	20:38	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
465	PG&E	07/15/15	9:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
466	PG&E	07/15/15	19:14	Contact From Object	N.A.	Vehicle	Pole	Human Error	
467	PG&E	07/16/15	19:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
468	PG&E	07/16/15	19:27	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
469	PG&E	07/17/15	0:20	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
470	PG&E	07/17/15	0:53	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
471	PG&E	07/17/15	17:18	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
472	PG&E	07/18/15	17:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
473	PG&E	07/18/15	18:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
474	PG&E	07/19/15	9:44	Contact From Object	N.A.	Other	Electric Facility	Weather	lightning strike
475	PG&E	07/19/15	19:36	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
476	PG&E	07/20/15	15:15	Unknown	N.A.	N.A.	N.A.	Unknown	
477	PG&E	07/21/15	8:44	Unknown	N.A.	N.A.	N.A.	Unknown	
478	PG&E	07/21/15	10:46	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
479	PG&E	07/22/15	11:03	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
480	PG&E	07/22/15	14:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
481	PG&E	07/23/15	13:14	Contact From Object	N.A.	Vehicle	Pole	Human Error	
482	PG&E	07/23/15	20:04	Unknown	N.A.	N.A.	N.A.	Unknown	
483	PG&E	07/24/15	4:10	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
484	PG&E	07/24/15	14:30	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
485	PG&E	07/25/15	14:52	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
486	PG&E	07/25/15	19:34	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
487	PG&E	07/26/15	12:25	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
488	PG&E	07/27/15	9:41	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
489	PG&E	07/27/15	13:07	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
490	PG&E	07/27/15	15:33	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
491	PG&E	07/27/15	15:57	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	Booster
492	PG&E	07/28/15	12:15	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
493	PG&E	07/28/15	12:19	Contact From Object	N.A.	Vehicle	Pole	Human Error	
494	PG&E	07/28/15	12:32	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
495	PG&E	07/29/15	13:30	Contact From Object	N.A.	Other	Electric Facility	Human Error	hit by boom of bucket t
496	PG&E	07/29/15	23:34	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
497	PG&E	07/30/15	14:26	Unknown	N.A.	N.A.	N.A.	Unknown	
498	PG&E	07/30/15	14:55	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
499	PG&E	07/30/15	15:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
500	PG&E	07/30/15	17:38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
501	PG&E	07/30/15	17:56	Contact From Object	N.A.	Other	Electric Facility	Unknown	osprey nest
502	PG&E	07/30/15	19:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
503	PG&E	07/31/15	15:57	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
504	PG&E	07/31/15	19:36	Unknown	N.A.	N.A.	N.A.	Unknown	
505	PG&E	07/31/15	22:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
506	PG&E	08/01/15	7:15	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
507	PG&E	08/01/15	14:30	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
508	PG&E	08/02/15	8:08	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
509	PG&E	08/02/15	13:48	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
510	PG&E	08/02/15	16:24	Unknown	N.A.	N.A.	N.A.	Unknown	
511	PG&E	08/03/15	0:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
512	PG&E	08/03/15	17:53	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
513	PG&E	08/04/15	16:05	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
514	PG&E	08/04/15	17:57	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
515	PG&E	08/05/15	15:13	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
516	PG&E	08/06/15	12:10	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
517	PG&E	08/06/15	16:18	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
518	PG&E	08/07/15	6:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
519	PG&E	08/07/15	6:32	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
520	PG&E	08/07/15	16:59	Contact From Object	N.A.	Vehicle	Pole	Human Error	
521	PG&E	08/08/15	7:42	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
522	PG&E	08/08/15	16:03	Contact From Object	N.A.	Vehicle	Pole	Human Error	
523	PG&E	08/10/15	11:30	Contact From Object	N.A.	Other	Electric Facility	Human Error	third-party cut into riser
524	PG&E	08/10/15	12:41	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
525	PG&E	08/10/15	21:58	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
526	PG&E	08/11/15	4:26	Contact From Object	N.A.	Vehicle	Pole	Human Error	
527	PG&E	08/12/15	17:38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
528	PG&E	08/13/15	3:46	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
529	PG&E	08/13/15	3:57	Contact From Object	N.A.	Vehicle	Pole	Human Error	
530	PG&E	08/13/15	23:55	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
531	PG&E	08/14/15	10:22	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
532	PG&E	08/14/15	15:09	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
533	PG&E	08/14/15	17:44	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
534	PG&E	08/15/15	12:26	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
535	PG&E	08/15/15	13:41	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
536	PG&E	08/16/15	7:35	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
537	PG&E	08/16/15	12:04	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
538	PG&E	08/16/15	20:59	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
539	PG&E	08/17/15	8:37	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
540	PG&E	08/17/15	14:29	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
541	PG&E	08/17/15	17:33	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
542	PG&E	08/17/15	20:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
543	PG&E	08/18/15	8:03	Unknown	N.A.	N.A.	N.A.	Unknown	
544	PG&E	08/18/15	20:36	Contact From Object	N.A.	Vehicle	Pole	Human Error	
545	PG&E	08/19/15	0:07	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
546	PG&E	08/19/15	2:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
547	PG&E	08/19/15	6:20	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
548	PG&E	08/19/15	13:42	Contact From Object	N.A.	Vehicle	Pole	Human Error	
549	PG&E	08/20/15	14:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
550	PG&E	08/21/15	13:54	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
551	PG&E	08/22/15	20:38	Contact From Object	N.A.	Vegetation	Communication Facility	Unknown	tree hit phone lines
552	PG&E	08/23/15	14:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
553	PG&E	08/23/15	14:15	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
554	PG&E	08/24/15	22:48	Unknown	N.A.	N.A.	N.A.	Unknown	
555	PG&E	08/25/15	9:12	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
556	PG&E	08/25/15	14:01	Unknown	N.A.	N.A.	N.A.	Unknown	
557	PG&E	08/26/15	12:04	Unknown	N.A.	N.A.	N.A.	Unknown	
558	PG&E	08/26/15	15:36	Contact From Object	N.A.	Vehicle	Pole	Human Error	
559	PG&E	08/26/15	23:49	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
560	PG&E	08/27/15	3:30	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
561	PG&E	08/27/15	18:00	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown	
562	PG&E	08/28/15	3:14	Contact From Object	N.A.	Vehicle	Pole	Human Error	
563	PG&E	08/28/15	7:08	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
564	PG&E	08/28/15	11:48	Unknown	N.A.	N.A.	N.A.	Unknown	
565	PG&E	08/28/15	12:02	Unknown	N.A.	N.A.	N.A.	Unknown	
566	PG&E	08/28/15	21:45	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	pole cut with chainsaw
567	PG&E	08/28/15	22:05	Contact From Object	N.A.	Vehicle	Pole	Human Error	
568	PG&E	08/29/15	3:30	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
569	PG&E	08/30/15	17:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
570	PG&E	08/31/15	14:28	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
571	PG&E	08/31/15	16:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
572	PG&E	08/31/15	20:19	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
573	PG&E	09/01/15	1:29	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
574	PG&E	09/01/15	10:34	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gun-shot conductor
575	PG&E	09/01/15	18:48	Contact From Object	N.A.	Vehicle	Pole	Human Error	
576	PG&E	09/01/15	22:15	Contact From Object	N.A.	Vehicle	Pole	Human Error	
577	PG&E	09/02/15	19:07	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gun-shot conductor
578	PG&E	09/03/15	19:51	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
579	PG&E	09/04/15	7:49	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
580	PG&E	09/04/15	8:47	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
581	PG&E	09/05/15	5:36	Unknown	N.A.	N.A.	N.A.	Unknown	
582	PG&E	09/05/15	16:47	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
583	PG&E	09/06/15	13:37	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
584	PG&E	09/06/15	19:27	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
585	PG&E	09/06/15	19:40	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
586	PG&E	09/07/15	0:05	Contact From Object	N.A.	Vehicle	Pole	Human Error	
587	PG&E	09/08/15	8:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
588	PG&E	09/09/15	6:44	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
589	PG&E	09/09/15	10:47	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
590	PG&E	09/10/15	5:42	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
591	PG&E	09/10/15	16:24	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
592	PG&E	09/10/15	18:39	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
593	PG&E	09/11/15	6:38	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
594	PG&E	09/11/15	8:15	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
595	PG&E	09/11/15	17:28	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
596	PG&E	09/12/15	9:51	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
597	PG&E	09/12/15	11:09	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
598	PG&E	09/12/15	11:36	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
599	PG&E	09/13/15	8:48	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
600	PG&E	09/13/15	18:24	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
601	PG&E	09/15/15	22:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
602	PG&E	09/16/15	0:18	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
603	PG&E	09/18/15	16:23	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
604	PG&E	09/18/15	17:05	Contact From Object	N.A.	Vehicle	Pole	Human Error	
605	PG&E	09/19/15	9:51	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
606	PG&E	09/20/15	18:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
607	PG&E	09/21/15	4:06	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
608	PG&E	09/21/15	14:23	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
609	PG&E	09/21/15	16:33	Contact From Object	N.A.	Balloons	Electric Facility	Unknown	
610	PG&E	09/22/15	0:44	Contact From Object	N.A.	Vehicle	Pole	Human Error	
611	PG&E	09/22/15	15:55	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
612	PG&E	09/22/15	20:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
613	PG&E	09/24/15	1:40	Contact From Object	N.A.	Vehicle	Pole	Human Error	
614	PG&E	09/24/15	3:58	Unknown	N.A.	N.A.	N.A.	Unknown	
615	PG&E	09/24/15	4:30	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
616	PG&E	09/24/15	13:56	Contact From Object	N.A.	Vehicle	Pole	Human Error	
617	PG&E	09/25/15	13:31	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gun-shot conductor
618	PG&E	09/25/15	17:28	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
619	PG&E	09/26/15	14:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
620	PG&E	09/28/15	4:42	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
621	PG&E	09/28/15	9:42	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
622	PG&E	09/28/15	18:10	Contact From Object	N.A.	Vehicle	Pole	Human Error	
623	PG&E	09/29/15	2:52	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
624	PG&E	09/29/15	19:05	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gun-shot conductor
625	PG&E	09/29/15	19:46	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
626	PG&E	09/30/15	16:41	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
627	PG&E	09/30/15	17:25	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
628	PG&E	09/30/15	19:38	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
629	PG&E	10/01/15	2:43	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
630	PG&E	10/01/15	11:28	Contamination	N.A.	N.A.	N.A.	Unknown	
631	PG&E	10/01/15	13:13	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
632	PG&E	10/02/15	19:16	Contact From Object	N.A.	Other	Electric Facility	Human Error	Kite on line
633	PG&E	10/03/15	7:27	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
634	PG&E	10/03/15	21:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
635	PG&E	10/03/15	22:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
636	PG&E	10/04/15	1:03	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
637	PG&E	10/04/15	1:32	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
638	PG&E	10/04/15	8:26	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
639	PG&E	10/04/15	14:35	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
640	PG&E	10/04/15	17:42	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
641	PG&E	10/06/15	18:48	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
642	PG&E	10/07/15	15:03	Contact From Object	N.A.	Vehicle	Pole	Human Error	
643	PG&E	10/08/15	13:47	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
644	PG&E	10/09/15	6:32	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
645	PG&E	10/09/15	19:03	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
646	PG&E	10/09/15	22:16	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
647	PG&E	10/10/15	0:20	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
648	PG&E	10/12/15	9:13	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
649	PG&E	10/12/15	15:16	Contact From Object	N.A.	Vehicle	Pole	Human Error	
650	PG&E	10/12/15	17:25	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
651	PG&E	10/13/15	14:38	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
652	PG&E	10/13/15	18:32	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
653	PG&E	10/14/15	14:17	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
654	PG&E	10/15/15	18:51	Contact From Object	N.A.	Other	Electric Facility	Weather	lightning strike
655	PG&E	10/16/15	9:43	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
656	PG&E	10/17/15	7:04	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
657	PG&E	10/18/15	20:06	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
658	PG&E	10/20/15	5:59	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
659	PG&E	10/25/15	5:50	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
660	PG&E	10/27/15	16:15	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
661	PG&E	10/27/15	19:27	Unknown	N.A.	N.A.	N.A.	Unknown	
662	PG&E	10/28/15	1:05	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
663	PG&E	10/30/15	4:29	Contact From Object	N.A.	Vehicle	Pole	Human Error	
664	PG&E	10/30/15	17:13	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
665	PG&E	10/31/15	7:45	Contact From Object	N.A.	Vehicle	Pole	Human Error	
666	PG&E	10/31/15	19:11	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
667	PG&E	11/01/15	4:22	Contact From Object	N.A.	Vehicle	Pole	Human Error	
668	PG&E	11/02/15	9:53	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
669	PG&E	11/04/15	17:30	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
670	PG&E	11/04/15	19:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
671	PG&E	11/05/15	10:39	Contact From Object	N.A.	Vehicle	Pole	Human Error	
672	PG&E	11/05/15	12:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
673	PG&E	11/07/15	1:15	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
674	PG&E	11/07/15	10:16	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
675	PG&E	11/09/15	5:55	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
676	PG&E	11/13/15	12:03	Contact From Object	N.A.	Vehicle	Pole	Human Error	
677	PG&E	11/15/15	13:47	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
678	PG&E	11/15/15	16:30	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
679	PG&E	11/21/15	10:36	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
680	PG&E	11/26/15	15:32	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
681	PG&E	12/01/15	9:26	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
682	PG&E	12/01/15	12:03	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
683	PG&E	12/02/15	9:40	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
684	PG&E	12/03/15	9:12	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
685	PG&E	12/03/15	12:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
686	PG&E	12/08/15	12:41	Contact From Object	N.A.	Other	Electric Facility	Human Error	AT&T work error
687	PG&E	12/10/15	11:19	Contact From Object	N.A.	Vehicle	Pole	Human Error	
688	PG&E	12/11/15	7:27	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
689	PG&E	12/22/15	2:44	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
690	PG&E	12/28/15	19:29	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
691	PG&E	12/31/15	19:12	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
692	PG&E	1/21/16	21:32	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
693	PG&E	1/23/16	15:41	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
694	PG&E	2/2/16	6:01	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
695	PG&E	2/5/16	20:50	Contact From Object	N.A.	Vehicle	Pole	Human Error	
696	PG&E	2/8/16	3:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
697	PG&E	2/11/16	21:16	Contact From Object	N.A.	Other	Electric Facility	Unknown	lightning strike
698	PG&E	2/26/16	15:40	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
699	PG&E	3/28/16	12:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
700	PG&E	4/1/16	4:25	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
701	PG&E	4/2/16	3:48	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
702	PG&E	4/2/16	7:06	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
703	PG&E	4/3/16	6:54	Contact From Object	N.A.	Vehicle	Pole	Human Error	
704	PG&E	4/3/16	12:01	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
705	PG&E	4/4/16	0:08	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
706	PG&E	4/7/16	17:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
707	PG&E	4/8/16	13:14	Contact From Object	N.A.	Vehicle	Pole	Human Error	
708	PG&E	4/13/16	19:28	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
709	PG&E	4/14/16	14:16	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
710	PG&E	4/18/16	18:14	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
711	PG&E	4/20/16	16:39	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
712	PG&E	4/21/16	3:20	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
713	PG&E	4/21/16	9:25	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
714	PG&E	4/22/16	17:10	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
715	PG&E	4/22/16	22:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
716	PG&E	4/23/16	18:32	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
717	PG&E	4/24/16	11:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
718	PG&E	4/25/16	12:34	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
719	PG&E	4/25/16	14:50	Other	N.A.	N.A.	N.A.	Human Error	
720	PG&E	4/27/16	14:02	Contact From Object	N.A.	Other	Electric Facility	Unknown	bird nest
721	PG&E	4/30/16	17:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
722	PG&E	4/30/16	16:40	Unknown	N.A.	N.A.	N.A.	Unknown	
723	PG&E	4/30/16	13:41	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
724	PG&E	5/2/16	10:05	Contact From Object	N.A.	Other	Electric Facility	Unknown	bird dropped snake
725	PG&E	5/9/16	17:05	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
726	PG&E	5/11/16	12:15	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
727	PG&E	5/12/16	10:47	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
728	PG&E	5/12/16	13:35	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
729	PG&E	5/12/16	20:15	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
730	PG&E	5/14/16	15:06	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
731	PG&E	5/14/16	22:06	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown	
732	PG&E	5/15/16	15:54	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
733	PG&E	5/16/16	8:59	Contact From Object	N.A.	Vehicle	Pole	Human Error	
734	PG&E	5/16/16	11:34	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	
735	PG&E	5/17/16	10:01	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
736	PG&E	5/17/16	16:03	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
737	PG&E	5/18/16	18:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
738	PG&E	5/18/16	15:45	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
739	PG&E	5/18/16	20:04	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
740	PG&E	5/19/16	1:42	Contact From Object	N.A.	Vehicle	Pole	Human Error	
741	PG&E	5/19/16	18:33	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
742	PG&E	5/19/16	18:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
743	PG&E	5/20/16	15:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
744	PG&E	5/20/16	18:54	Unknown	N.A.	N.A.	N.A.	Unknown	
745	PG&E	5/20/16	20:43	Other	N.A.	N.A.	N.A.	Unknown	
746	PG&E	5/21/16	17:44	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
747	PG&E	5/23/16	12:52	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
748	PG&E	5/23/16	16:08	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
749	PG&E	5/24/16	12:36	Contact From Object	N.A.	Vehicle	Pole	Human Error	
750	PG&E	5/26/16	17:42	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
751	PG&E	5/27/16	3:01	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
752	PG&E	5/28/16	15:53	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
753	PG&E	5/29/16	14:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
754	PG&E	5/29/16	18:28	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
755	PG&E	5/30/16	20:37	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
756	PG&E	5/31/16	4:02	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
757	PG&E	5/31/16	8:24	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
758	PG&E	5/31/16	9:51	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
759	PG&E	5/31/16	10:20	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
760	PG&E	6/1/16	14:00	Contact From Object	N.A.	Other	Electric Facility	Unknown	third-party caused
761	PG&E	6/1/16	22:31	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
762	PG&E	6/2/16	14:23	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
763	PG&E	6/2/16	14:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
764	PG&E	6/2/16	15:15	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
765	PG&E	6/2/16	16:58	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
766	PG&E	6/3/16	12:16	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
767	PG&E	6/3/16	16:45	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
768	PG&E	6/3/16	18:43	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
769	PG&E	6/3/16	20:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
770	PG&E	6/4/16	22:15	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
771	PG&E	6/4/16	15:11	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
772	PG&E	6/4/16	15:51	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
773	PG&E	6/4/16	20:38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
774	PG&E	6/5/16	16:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
775	PG&E	6/5/16	10:06	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
776	PG&E	6/5/16	15:44	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
777	PG&E	6/6/16	19:48	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
778	PG&E	6/7/16	13:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
779	PG&E	6/7/16	18:19	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
780	PG&E	6/7/16	19:40	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
781	PG&E	6/7/16	0:45	Contact From Object	N.A.	Vehicle	Pole	Human Error	
782	PG&E	6/7/16	9:12	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
783	PG&E	6/8/16	11:20	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
784	PG&E	6/8/16	0:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
785	PG&E	6/8/16	16:50	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	
786	PG&E	6/9/16	14:26	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
787	PG&E	6/9/16	10:52	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
788	PG&E	6/9/16	23:39	Contact From Object	N.A.	Vehicle	Pole	Human Error	
789	PG&E	6/10/16	8:25	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
790	PG&E	6/10/16	15:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
791	PG&E	6/10/16	15:57	Contact From Object	N.A.	Vehicle	Pole	Human Error	
792	PG&E	6/11/16	19:45	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
793	PG&E	6/12/16	8:01	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
794	PG&E	6/12/16	10:22	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
795	PG&E	6/12/16	11:52	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
796	PG&E	6/12/16	13:10	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
797	PG&E	6/12/16	13:14	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
798	PG&E	6/12/16	1:45	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
799	PG&E	6/12/16	19:19	Contact From Object	N.A.	Vehicle	Pole	Human Error	
800	PG&E	6/12/16	20:00	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
801	PG&E	6/13/16	5:51	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
802	PG&E	6/15/16	14:40	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
803	PG&E	6/15/16	13:09	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
804	PG&E	6/15/16	13:44	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
805	PG&E	6/16/16	17:41	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
806	PG&E	6/16/16	7:22	Contact From Object	N.A.	Vehicle	Pole	Human Error	
807	PG&E	6/16/16	13:07	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
808	PG&E	6/17/16	11:17	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
809	PG&E	6/19/16	12:07	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
810	PG&E	6/19/16	17:19	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
811	PG&E	6/19/16	15:50	Contact From Object	N.A.	Vehicle	Pole	Human Error	
812	PG&E	6/20/16	13:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
813	PG&E	6/20/16	16:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
814	PG&E	6/21/16	20:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
815	PG&E	6/21/16	10:09	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
816	PG&E	6/21/16	16:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
817	PG&E	6/21/16	18:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
818	PG&E	6/22/16	19:13	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
819	PG&E	6/23/16	10:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
820	PG&E	6/23/16	19:19	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
821	PG&E	6/23/16	21:33	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
822	PG&E	6/24/16	3:07	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
823	PG&E	6/24/16	14:38	Unknown	N.A.	N.A.	N.A.	Unknown	
824	PG&E	6/25/16	17:07	Contact From Object	N.A.	Vehicle	Pole	Human Error	
825	PG&E	6/26/16	16:38	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
826	PG&E	6/26/16	16:50	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gunshot
827	PG&E	6/26/16	17:59	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
828	PG&E	6/26/16	11:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
829	PG&E	6/27/16	11:12	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
830	PG&E	6/28/16	11:40	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
831	PG&E	6/28/16	13:36	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
832	PG&E	6/28/16	9:11	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
833	PG&E	6/29/16	12:55	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
834	PG&E	6/30/16	0:03	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
835	PG&E	6/30/16	17:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
836	PG&E	6/30/16	14:20	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
837	PG&E	7/1/16	22:03	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
838	PG&E	7/2/16	4:05	Contact From Object	N.A.	Vehicle	Pole	Human Error	
839	PG&E	7/3/16	15:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
840	PG&E	7/4/16	7:43	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
841	PG&E	7/5/16	8:35	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
842	PG&E	7/5/16	10:36	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
843	PG&E	7/7/16	10:56	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
844	PG&E	7/8/16	10:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
845	PG&E	7/8/16	15:13	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
846	PG&E	7/9/16	10:05	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
847	PG&E	7/9/16	14:57	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
848	PG&E	7/9/16	15:42	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
849	PG&E	7/9/16	19:22	Unknown	N.A.	N.A.	N.A.	Unknown	
850	PG&E	7/12/16	14:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
851	PG&E	7/13/16	10:20	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
852	PG&E	7/14/16	13:44	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
853	PG&E	7/15/16	5:19	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
854	PG&E	7/15/16	14:09	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
855	PG&E	7/15/16	14:26	Contact From Object	N.A.	Vehicle	Pole	Human Error	
856	PG&E	7/15/16	17:09	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
857	PG&E	7/16/16	0:58	Equipment/ Facility Failure	Voltage Regulator	N.A.	N.A.	Unknown	
858	PG&E	7/16/16	8:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
859	PG&E	7/16/16	20:26	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
860	PG&E	7/18/16	7:39	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
861	PG&E	7/18/16	9:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
862	PG&E	7/18/16	15:56	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
863	PG&E	7/18/16	17:14	Equipment/ Facility Failure	Sectionalizer	N.A.	N.A.	Unknown	
864	PG&E	7/19/16	1:53	Equipment/ Facility Failure	Recloser	N.A.	N.A.	Unknown	
865	PG&E	7/19/16	14:41	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
866	PG&E	7/20/16	6:25	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
867	PG&E	7/20/16	19:15	Contact From Object	N.A.	Vehicle	Pole	Human Error	
868	PG&E	7/21/16	13:10	Contact From Object	N.A.	Vehicle	Pole	Human Error	
869	PG&E	7/21/16	13:30	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
870	PG&E	7/21/16	17:38	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
871	PG&E	7/21/16	18:20	Equipment/ Facility Failure	Recloser	N.A.	N.A.	Unknown	
872	PG&E	7/21/16	21:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
873	PG&E	7/22/16	4:46	Unknown	N.A.	N.A.	N.A.	Unknown	
874	PG&E	7/22/16	14:11	Contact From Object	N.A.	Vehicle	Pole	Human Error	
875	PG&E	7/23/16	12:45	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
876	PG&E	7/23/16	16:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
877	PG&E	7/23/16	19:12	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
878	PG&E	7/24/16	16:24	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
879	PG&E	7/25/16	10:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
880	PG&E	7/25/16	15:32	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
881	PG&E	7/27/16	15:29	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
882	PG&E	7/27/16	11:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
883	PG&E	7/27/16	15:04	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
884	PG&E	7/27/16	17:05	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
885	PG&E	7/28/16	2:41	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
886	PG&E	7/28/16	8:12	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
887	PG&E	7/28/16	12:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
888	PG&E	7/28/16	13:19	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
889	PG&E	7/28/16	14:07	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
890	PG&E	7/28/16	14:24	Equipment/ Facility Failure	Guy/Span Wire	N.A.	N.A.	Unknown	
891	PG&E	7/28/16	16:16	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
892	PG&E	7/29/16	18:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
893	PG&E	7/29/16	1:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
894	PG&E	7/29/16	15:47	Unknown	N.A.	N.A.	N.A.	Unknown	
895	PG&E	7/29/16	18:50	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
896	PG&E	7/30/16	11:04	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
897	PG&E	7/31/16	12:11	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
898	PG&E	8/1/16	12:50	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
899	PG&E	8/1/16	16:47	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
900	PG&E	8/1/16	18:29	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
901	PG&E	8/2/16	6:52	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
902	PG&E	8/2/16	16:15	Contact From Object	N.A.	Vehicle	Pole	Human Error	
903	PG&E	8/3/16	4:38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
904	PG&E	8/3/16	12:41	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
905	PG&E	8/3/16	19:41	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
906	PG&E	8/4/16	12:19	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
907	PG&E	8/5/16	12:40	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
908	PG&E	8/5/16	12:42	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
909	PG&E	8/5/16	14:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
910	PG&E	8/5/16	20:44	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
911	PG&E	8/6/16	18:53	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
912	PG&E	8/7/16	14:20	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
913	PG&E	8/7/16	21:42	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
914	PG&E	8/8/16	15:44	Unknown	N.A.	N.A.	N.A.	Unknown	
915	PG&E	8/9/16	10:18	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
916	PG&E	8/9/16	14:06	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
917	PG&E	8/9/16	19:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
918	PG&E	8/10/16	17:59	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
919	PG&E	8/10/16	8:36	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
920	PG&E	8/10/16	15:26	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
921	PG&E	8/11/16	4:10	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
922	PG&E	8/11/16	19:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
923	PG&E	8/11/16	21:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
924	PG&E	8/12/16	10:08	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
925	PG&E	8/13/16	14:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
926	PG&E	8/13/16	14:00	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
927	PG&E	8/14/16	22:50	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
928	PG&E	8/15/16	0:11	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
929	PG&E	8/15/16	11:29	Equipment/ Facility Failure	Recloser	N.A.	N.A.	Unknown	
930	PG&E	8/15/16	15:43	Contact From Object	N.A.	Vehicle	Pole	Human Error	
931	PG&E	8/16/16	13:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
932	PG&E	8/16/16	22:17	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
933	PG&E	8/17/16	9:41	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
934	PG&E	8/17/16	12:23	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
935	PG&E	8/17/16	14:02	Contact From Object	N.A.	Vehicle	Pole	Human Error	
936	PG&E	8/17/16	18:37	Contact From Object	N.A.	Vehicle	Pole	Human Error	
937	PG&E	8/18/16	15:22	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
938	PG&E	8/18/16	18:12	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
939	PG&E	8/18/16	18:36	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
940	PG&E	8/19/16	16:23	Contact From Object	N.A.	Vehicle	Pole	Human Error	
941	PG&E	8/20/16	18:51	Contact From Object	N.A.	Vehicle	Pole	Human Error	
942	PG&E	8/21/16	13:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
943	PG&E	8/22/16	16:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
944	PG&E	8/23/16	16:03	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
945	PG&E	8/24/16	12:11	Contact From Object	N.A.	Vehicle	Pole	Human Error	
946	PG&E	8/24/16	14:19	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
947	PG&E	8/25/16	12:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
948	PG&E	8/25/16	11:31	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
949	PG&E	8/27/16	5:37	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
950	PG&E	8/27/16	19:33	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
951	PG&E	8/28/16	16:49	Contact From Object	N.A.	Vehicle	Pole	Human Error	
952	PG&E	8/29/16	16:25	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	
953	PG&E	8/30/16	16:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
954	PG&E	8/30/16	16:14	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
955	PG&E	8/30/16	19:27	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
956	PG&E	8/31/16	11:17	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
957	PG&E	8/31/16	14:52	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
958	PG&E	8/31/16	19:43	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
959	PG&E	9/1/16	9:30	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
960	PG&E	9/1/16	13:08	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
961	PG&E	9/2/16	12:42	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
962	PG&E	9/2/16	13:50	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
963	PG&E	9/3/16	20:12	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
964	PG&E	9/3/16	20:58	Contact From Object	N.A.	Vehicle	Pole	Human Error	
965	PG&E	9/5/16	8:26	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
966	PG&E	9/7/16	19:37	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
967	PG&E	9/7/16	9:56	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
968	PG&E	9/8/16	14:39	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
969	PG&E	9/8/16	22:04	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
970	PG&E	9/9/16	10:57	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
971	PG&E	9/9/16	13:22	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
972	PG&E	9/9/16	15:25	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
973	PG&E	9/10/16	2:09	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
974	PG&E	9/11/16	21:24	Unknown	N.A.	N.A.	N.A.	Unknown	
975	PG&E	9/12/16	4:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
976	PG&E	9/12/16	12:38	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
977	PG&E	9/12/16	18:47	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
978	PG&E	9/12/16	20:42	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
979	PG&E	9/12/16	15:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
980	PG&E	9/13/16	10:26	Unknown	N.A.	N.A.	N.A.	Unknown	
981	PG&E	9/13/16	10:45	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
982	PG&E	9/14/16	21:16	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gunshot
983	PG&E	9/14/16	23:25	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
984	PG&E	9/15/16	15:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
985	PG&E	9/16/16	20:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
986	PG&E	9/17/16	10:03	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
987	PG&E	9/17/16	17:47	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
988	PG&E	9/18/16	14:33	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
989	PG&E	9/19/16	14:09	Unknown	N.A.	N.A.	N.A.	Unknown	
990	PG&E	9/19/16	22:10	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
991	PG&E	9/19/16	8:51	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
992	PG&E	9/20/16	8:25	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
993	PG&E	9/21/16	10:01	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
994	PG&E	9/21/16	19:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
995	PG&E	9/21/16	21:00	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
996	PG&E	9/21/16	6:36	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
997	PG&E	9/22/16	8:27	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
998	PG&E	9/22/16	13:53	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
999	PG&E	9/22/16	11:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1000	PG&E	9/23/16	15:13	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1001	PG&E	9/23/16	15:23	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
1002	PG&E	9/24/16	14:32	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1003	PG&E	9/25/16	12:13	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1004	PG&E	9/25/16	16:29	Contact From Object	N.A.	Vehicle	Pole	Human Error	
1005	PG&E	9/25/16	19:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1006	PG&E	9/25/16	10:35	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1007	PG&E	9/26/16	10:40	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1008	PG&E	9/27/16	12:28	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1009	PG&E	9/28/16	5:30	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1010	PG&E	9/28/16	14:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
1011	PG&E	9/28/16	16:21	Contact From Object	N.A.	Vehicle	Pole	Human Error	
1012	PG&E	9/29/16	11:17	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1013	PG&E	10/1/16	15:19	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
1014	PG&E	10/2/16	15:51	Contamination	N.A.	N.A.	N.A.	Unknown	
1015	PG&E	10/2/16	18:41	Other	N.A.	N.A.	N.A.	Weather	lightning strike
1016	PG&E	10/3/16	18:23	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1017	PG&E	10/4/16	2:04	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1018	PG&E	10/4/16	12:50	Contact From Object	N.A.	Vehicle	Pole	Human Error	
1019	PG&E	10/5/16	16:23	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
1020	PG&E	10/6/16	22:06	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1021	PG&E	10/7/16	8:17	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1022	PG&E	10/8/16	6:52	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1023	PG&E	10/8/16	15:04	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1024	PG&E	10/8/16	16:31	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1025	PG&E	10/9/16	7:43	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1026	PG&E	10/9/16	18:52	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1027	PG&E	10/9/16	22:47	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1028	PG&E	10/10/16	10:06	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1029	PG&E	10/11/16	11:30	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1030	PG&E	10/11/16	23:16	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	
1031	PG&E	10/13/16	23:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1032	PG&E	10/13/16	23:52	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
1033	PG&E	10/14/16	1:32	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1034	PG&E	10/14/16	4:32	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1035	PG&E	10/14/16	10:24	Contamination	N.A.	N.A.	N.A.	Unknown	
1036	PG&E	10/14/16	10:36	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1037	PG&E	10/14/16	11:00	Contamination	N.A.	N.A.	N.A.	Unknown	
1038	PG&E	10/14/16	19:44	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1039	PG&E	10/15/16	15:34	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1040	PG&E	10/18/16	10:50	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1041	PG&E	10/18/16	16:20	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
1042	PG&E	10/19/16	10:42	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1043	PG&E	10/23/16	10:54	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1044	PG&E	10/23/16	14:16	Contact From Object	N.A.	Vehicle	Pole	Human Error	
1045	PG&E	10/23/16	18:10	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1046	PG&E	10/26/16	10:16	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1047	PG&E	10/31/16	17:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1048	PG&E	11/9/16	9:06	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
1049	PG&E	11/14/16	3:25	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1050	PG&E	11/14/16	13:15	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1051	PG&E	11/15/16	17:27	Contact From Object	N.A.	Vehicle	Pole	Human Error	
1052	PG&E	11/20/16	11:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1053	PG&E	11/26/16	12:10	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1054	PG&E	01/01/17	15:57	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1055	PG&E	01/10/17	15:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1056	PG&E	01/18/17	15:34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1057	PG&E	01/29/17	09:45	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1058	PG&E	02/03/17	10:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1059	PG&E	02/07/17	04:50	Other	N.A.	N.A.	N.A.	Unknown	
1060	PG&E	03/16/17	12:43	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1061	PG&E	03/17/17	09:37	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1062	PG&E	03/19/17	17:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1063	PG&E	03/23/17	07:04	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1064	PG&E	03/28/17	12:15	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1065	PG&E	04/01/17	14:54	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1066	PG&E	04/04/17	13:29	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1067	PG&E	04/04/17	14:54	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1068	PG&E	04/10/17	16:35	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1069	PG&E	04/13/17	14:21	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1070	PG&E	04/16/17	15:14	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1071	PG&E	04/20/17	20:14	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1072	PG&E	04/23/17	7:10	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1073	PG&E	04/24/17	11:52	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	tie wire
1074	PG&E	04/25/17	12:38	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1075	PG&E	04/25/17	18:26	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1076	PG&E	04/26/17	15:55	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
1077	PG&E	04/28/17	5:55	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1078	PG&E	04/28/17	14:35	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1079	PG&E	04/28/17	15:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1080	PG&E	04/28/17	15:07	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1081	PG&E	04/30/17	9:32	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1082	PG&E	05/01/17	14:20	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
1083	PG&E	05/03/17	10:04	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1084	PG&E	05/03/17	12:51	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1085	PG&E	05/04/17	16:19	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1086	PG&E	05/05/17	15:52	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
1087	PG&E	05/06/17	1:56	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1088	PG&E	05/06/17	11:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1089	PG&E	05/06/17	12:43	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1090	PG&E	05/06/17	15:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1091	PG&E	05/06/17	23:46	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1092	PG&E	05/09/17	11:15	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1093	PG&E	05/09/17	15:57	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1094	PG&E	05/09/17	18:26	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1095	PG&E	05/12/17	15:16	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1096	PG&E	05/13/17	21:49	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1097	PG&E	05/14/17	11:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1098	PG&E	05/14/17	16:09	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1099	PG&E	05/15/17	3:05	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1100	PG&E	05/15/17	13:05	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1101	PG&E	05/15/17	16:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1102	PG&E	05/15/17	20:57	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1103	PG&E	05/16/17	17:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1104	PG&E	05/17/17	14:49	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	Transformer fuse
1105	PG&E	05/17/17	15:13	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1106	PG&E	05/19/17	9:37	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	secondary riser
1107	PG&E	05/19/17	10:52	Contamination	N.A.	N.A.	N.A.	Unknown	
1108	PG&E	05/20/17	12:20	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	secondary riser
1109	PG&E	05/21/17	11:36	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1110	PG&E	05/21/17	22:47	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1111	PG&E	05/22/17	5:39	Equipment/ Facility Failure	Voltage Regulator	N.A.	N.A.	Unknown	
1112	PG&E	05/22/17	17:52	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1113	PG&E	05/24/17	16:24	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1114	PG&E	05/25/17	11:09	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1115	PG&E	05/25/17	15:05	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1116	PG&E	05/25/17	16:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1117	PG&E	05/29/17	18:29	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1118	PG&E	05/30/17	11:40	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1119	PG&E	05/31/17	2:06	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1120	PG&E	05/31/17	5:24	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1121	PG&E	06/01/17	9:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1122	PG&E	06/01/17	21:35	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1123	PG&E	06/01/17	22:44	Equipment/ Facility Failure	Lightning Arreslor	N.A.	N.A.	Unknown	
1124	PG&E	06/03/17	13:26	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1125	PG&E	06/03/17	20:52	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1126	PG&E	06/04/17	00:08	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1127	PG&E	06/04/17	13:12	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1128	PG&E	06/05/17	0:52	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1129	PG&E	06/05/17	7:56	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1130	PG&E	06/05/17	17:12	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1131	PG&E	06/06/17	9:15	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1132	PG&E	06/06/17	09:48	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1133	PG&E	06/06/17	13:39	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1134	PG&E	06/07/17	13:25	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1135	PG&E	06/07/17	10:13	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1136	PG&E	06/08/17	5:33	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1137	PG&E	06/08/17	0:26	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1138	PG&E	06/08/17	15:08	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1139	PG&E	06/09/17	10:40	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1140	PG&E	06/09/17	13:27	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1141	PG&E	06/09/17	17:20	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1142	PG&E	06/10/17	07:37	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1143	PG&E	06/12/17	15:28	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1144	PG&E	06/12/17	18:04	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
1145	PG&E	06/13/17	14:30	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1146	PG&E	06/14/17	22:23	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1147	PG&E	06/15/17	2:58	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	power theft
1148	PG&E	06/15/17	5:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1149	PG&E	06/15/17	7:39	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1150	PG&E	06/15/17	15:01	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1151	PG&E	06/15/17	16:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1152	PG&E	06/15/17	17:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1153	PG&E	06/16/17	13:50	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1154	PG&E	06/16/17	14:22	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1155	PG&E	06/16/17	16:17	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1156	PG&E	06/16/17	17:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1157	PG&E	06/16/17	19:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1158	PG&E	06/16/17	22:30	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1159	PG&E	06/17/17	02:53	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1160	PG&E	06/17/17	15:49	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1161	PG&E	06/18/17	23:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1162	PG&E	06/18/17	12:22	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1163	PG&E	06/18/17	13:10	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1164	PG&E	06/18/17	18:09	Equipment/ Facility Failure	Guy/Span Wire	N.A.	N.A.	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
1165	PG&E	06/18/17	20:16	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
1166	PG&E	06/18/17	21:07	Contact From Object	N.A.	Vehicle	Pole	Unknown	third-party caused
1167	PG&E	06/18/17	22:12	Equipment/ Facility Failure	Voltage Regulator	N.A.	N.A.	Unknown	
1168	PG&E	06/18/17	23:12	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1169	PG&E	06/18/17	23:31	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1170	PG&E	06/19/17	01:23	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1171	PG&E	06/19/17	13:51	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1172	PG&E	06/19/17	16:18	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1173	PG&E	06/19/17	16:26	Equipment/ Facility Failure	Recloser	N.A.	N.A.	Unknown	
1174	PG&E	06/19/17	17:31	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1175	PG&E	06/19/17	18:00	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
1176	PG&E	06/19/17	20:22	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1177	PG&E	06/20/17	00:49	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1178	PG&E	06/20/17	09:12	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1179	PG&E	06/20/17	10:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1180	PG&E	06/20/17	13:37	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1181	PG&E	06/20/17	15:17	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1182	PG&E	06/20/17	11:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1183	PG&E	06/20/17	18:32	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1184	PG&E	06/20/17	20:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1185	PG&E	06/20/17	23:16	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1186	PG&E	06/21/17	08:41	Contact From Object	N.A.	Other	Electric Facility	Human Error	helicopter
1187	PG&E	06/21/17	14:23	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1188	PG&E	06/22/17	9:36	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1189	PG&E	06/22/17	16:30	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1190	PG&E	06/22/17	18:07	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
1191	PG&E	06/22/17	19:29	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1192	PG&E	06/23/17	13:00	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	power theft
1193	PG&E	06/23/17	20:09	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	Booster bank
1194	PG&E	06/23/17	19:23	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1195	PG&E	06/24/17	10:31	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1196	PG&E	06/24/17	14:51	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1197	PG&E	06/24/17	22:27	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1198	PG&E	06/25/17	18:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1199	PG&E	06/25/17	0:23	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1200	PG&E	06/25/17	6:02	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1201	PG&E	06/25/17	15:37	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1202	PG&E	06/25/17	22:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1203	PG&E	06/26/17	8:18	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1204	PG&E	06/26/17	14:28	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1205	PG&E	06/27/17	3:23	Other	N.A.	N.A.	N.A.	Unknown	
1206	PG&E	06/27/17	17:47	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1207	PG&E	06/28/17	09:57	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1208	PG&E	06/28/17	13:09	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1209	PG&E	06/29/17	18:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1210	PG&E	06/29/17	21:55	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1211	PG&E	06/30/17	10:24	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1212	PG&E	06/30/17	01:20	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1213	PG&E	06/30/17	23:54	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1214	PG&E	07/01/17	12:02	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1215	PG&E	07/01/17	3:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1216	PG&E	07/01/17	3:12	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1217	PG&E	07/01/17	10:41	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1218	PG&E	07/02/17	13:28	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1219	PG&E	07/02/17	3:49	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	Third-party caused
1220	PG&E	07/03/17	20:26	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1221	PG&E	07/04/17	13:56	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1222	PG&E	07/04/17	16:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1223	PG&E	07/04/17	20:16	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1224	PG&E	07/05/17	3:25	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1225	PG&E	07/05/17	11:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1226	PG&E	07/05/17	20:54	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1227	PG&E	07/06/17	15:18	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
1228	PG&E	07/06/17	14:02	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	Third-party caused
1229	PG&E	07/06/17	20:07	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1230	PG&E	07/06/17	23:30	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1231	PG&E	07/07/17	15:09	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1232	PG&E	07/07/17	14:31	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	PG&E contractor
1233	PG&E	07/08/17	4:03	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1234	PG&E	07/08/17	15:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1235	PG&E	07/08/17	18:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1236	PG&E	07/08/17	18:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1237	PG&E	07/09/17	7:07	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1238	PG&E	07/09/17	11:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1239	PG&E	07/10/17	09:07	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1240	PG&E	07/10/17	12:32	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1241	PG&E	07/10/17	16:39	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1242	PG&E	07/10/17	17:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1243	PG&E	07/11/17	8:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1244	PG&E	07/11/17	11:53	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
1245	PG&E	07/11/17	13:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
1246	PG&E	07/11/17	22:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1247	PG&E	07/12/17	16:04	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1248	PG&E	07/12/17	05:51	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1249	PG&E	07/12/17	10:48	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1250	PG&E	07/12/17	15:09	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1251	PG&E	07/12/17	20:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1252	PG&E	07/13/17	5:13	Contact From Object	N.A.	Other	Electric Facility	Other	bird material
1253	PG&E	07/13/17	07:43	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1254	PG&E	07/13/17	19:29	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1255	PG&E	07/14/17	17:54	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1256	PG&E	07/15/17	14:34	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1257	PG&E	07/15/17	14:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1258	PG&E	07/15/17	20:16	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1259	PG&E	07/15/17	21:01	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1260	PG&E	07/16/17	10:39	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1261	PG&E	07/16/17	11:59	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1262	PG&E	07/16/17	12:10	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1263	PG&E	07/16/17	17:07	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1264	PG&E	07/17/17	07:39	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1265	PG&E	07/17/17	10:00	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1266	PG&E	07/17/17	18:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1267	PG&E	07/18/17	11:30	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1268	PG&E	07/18/17	21:40	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1269	PG&E	07/18/17	07:39	Other	N.A.	N.A.	N.A.	Unknown	
1270	PG&E	07/18/17	11:45	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1271	PG&E	07/19/17	5:52	Contact From Object	N.A.	Other	Electric Facility	Unknown	
1272	PG&E	07/19/17	09:33	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1273	PG&E	07/19/17	17:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1274	PG&E	07/20/17	20:57	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
1275	PG&E	07/20/17	01:46	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
1276	PG&E	07/20/17	04:27	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1277	PG&E	07/20/17	13:45	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1278	PG&E	07/20/17	17:00	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1279	PG&E	07/21/17	13:27	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1280	PG&E	07/21/17	20:26	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1281	PG&E	07/22/17	12:25	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
1282	PG&E	07/22/17	14:38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1283	PG&E	07/22/17	16:01	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
1284	PG&E	07/23/17	09:22	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1285	PG&E	07/23/17	16:32	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1286	PG&E	07/23/17	18:25	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1287	PG&E	07/23/17	19:41	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1288	PG&E	07/24/17	14:01	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1289	PG&E	07/24/17	16:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1290	PG&E	07/24/17	19:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1291	PG&E	07/24/17	21:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1292	PG&E	07/25/17	15:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1293	PG&E	07/25/17	19:12	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1294	PG&E	07/26/17	06:55	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1295	PG&E	07/28/17	14:02	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1296	PG&E	07/28/17	16:57	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1297	PG&E	07/28/17	19:20	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1298	PG&E	07/29/17	13:18	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1299	PG&E	07/29/17	13:28	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1300	PG&E	07/29/17	14:52	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1301	PG&E	07/29/17	17:56	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1302	PG&E	07/29/17	18:08	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1303	PG&E	07/29/17	20:45	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	Third-party caused
1304	PG&E	07/30/17	09:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1305	PG&E	07/31/17	12:58	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1306	PG&E	07/31/17	14:10	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1307	PG&E	07/31/17	14:41	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1308	PG&E	08/01/17	12:23	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1309	PG&E	08/02/17	9:42	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1310	PG&E	08/02/17	5:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1311	PG&E	08/02/17	8:58	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1312	PG&E	08/02/17	17:04	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1313	PG&E	08/02/17	18:16	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1314	PG&E	08/03/17	10:53	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1315	PG&E	08/03/17	11:16	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1316	PG&E	08/03/17	22:44	Unknown	N.A.	N.A.	N.A.	Unknown	
1317	PG&E	08/04/17	09:54	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1318	PG&E	08/04/17	18:14	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1319	PG&E	08/05/17	08:33	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
1320	PG&E	08/05/17	18:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1321	PG&E	08/05/17	18:09	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1322	PG&E	08/05/17	19:21	Equipment/ Facility Failure	Recloser	N.A.	N.A.	Unknown	
1323	PG&E	08/06/17	11:38	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1324	PG&E	08/06/17	18:21	Contact From Object	N.A.	Other	Electric Facility	Weather	lightning strike
1325	PG&E	08/08/17	13:46	Contact From Object	N.A.	Other	Electric Facility	Human Error	
1326	PG&E	08/08/17	0:36	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1327	PG&E	08/08/17	4:10	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1328	PG&E	08/08/17	11:27	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1329	PG&E	08/08/17	20:35	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1330	PG&E	08/09/17	11:29	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1331	PG&E	08/11/17	07:55	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1332	PG&E	08/12/17	09:08	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	wire cut
1333	PG&E	08/13/17	13:11	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1334	PG&E	08/14/17	6:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1335	PG&E	08/14/17	23:52	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1336	PG&E	08/14/17	07:56	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1337	PG&E	08/15/17	19:28	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1338	PG&E	08/16/17	20:24	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1339	PG&E	08/17/17	2:33	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	pole cut down
1340	PG&E	08/17/17	15:15	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1341	PG&E	08/18/17	17:09	Other	N.A.	N.A.	N.A.	Human Error	CIP contractor
1342	PG&E	08/19/17	11:31	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1343	PG&E	08/19/17	21:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1344	PG&E	08/20/17	11:38	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1345	PG&E	08/21/17	15:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1346	PG&E	08/21/17	19:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1347	PG&E	08/22/17	14:17	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1348	PG&E	08/24/17	6:32	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1349	PG&E	08/25/17	9:47	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1350	PG&E	08/26/17	7:10	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	Third-party caused
1351	PG&E	08/26/17	20:39	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1352	PG&E	08/26/17	20:53	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1353	PG&E	08/27/17	18:11	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1354	PG&E	08/27/17	20:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1355	PG&E	08/27/17	22:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1356	PG&E	08/28/17	6:32	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1357	PG&E	08/28/17	8:36	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1358	PG&E	08/28/17	9:14	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1359	PG&E	08/28/17	10:07	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
1360	PG&E	08/28/17	13:55	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1361	PG&E	08/28/17	14:06	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1362	PG&E	08/28/17	14:23	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1363	PG&E	08/28/17	14:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1364	PG&E	08/28/17	23:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1365	PG&E	08/29/17	6:08	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1366	PG&E	08/29/17	10:27	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1367	PG&E	08/29/17	10:40	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1368	PG&E	08/29/17	12:49	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	PG&E contractor
1369	PG&E	08/29/17	15:54	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1370	PG&E	08/30/17	16:17	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1371	PG&E	08/30/17	18:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1372	PG&E	08/30/17	22:37	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1373	PG&E	08/30/17	22:39	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1374	PG&E	08/31/17	6:42	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1375	PG&E	08/31/17	11:33	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1376	PG&E	08/31/17	11:51	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1377	PG&E	08/31/17	21:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1378	PG&E	08/31/17	22:50	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1379	PG&E	09/01/17	6:09	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1380	PG&E	09/01/17	8:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1381	PG&E	09/01/17	12:07	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
1382	PG&E	09/01/17	12:52	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1383	PG&E	09/01/17	12:59	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1384	PG&E	09/01/17	17:48	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1385	PG&E	09/01/17	18:42	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1386	PG&E	09/02/17	12:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1387	PG&E	09/02/17	16:18	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1388	PG&E	09/02/17	18:00	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1389	PG&E	09/03/17	7:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1390	PG&E	09/03/17	12:52	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1391	PG&E	09/03/17	17:52	Contact From Object	N.A.	Other	Electric Facility	Weather	lightning strike
1392	PG&E	09/03/17	22:57	Contact Between Third Party Facility	N.A.	N.A.	N.A.	Weather	
1393	PG&E	09/04/17	0:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1394	PG&E	09/04/17	3:29	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1395	PG&E	09/04/17	6:43	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1396	PG&E	09/05/17	1:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1397	PG&E	09/05/17	6:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1398	PG&E	09/05/17	7:20	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
1399	PG&E	09/05/17	13:51	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1400	PG&E	09/05/17	17:51	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1401	PG&E	09/06/17	19:26	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
1402	PG&E	09/06/17	20:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1403	PG&E	09/08/17	4:47	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1404	PG&E	09/08/17	17:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1405	PG&E	09/08/17	21:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1406	PG&E	09/09/17	18:36	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1407	PG&E	09/10/17	1:22	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1408	PG&E	09/10/17	16:30	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1409	PG&E	09/11/17	7:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1410	PG&E	09/11/17	8:50	Contact From Object	N.A.	Other	Electric Facility	Weather	lightning strike
1411	PG&E	09/11/17	23:50	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1412	PG&E	09/12/17	9:24	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1413	PG&E	09/12/17	17:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1414	PG&E	09/14/17	11:02	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown	
1415	PG&E	09/14/17	12:09	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1416	PG&E	09/14/17	14:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1417	PG&E	09/15/17	14:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1418	PG&E	09/17/17	15:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1419	PG&E	09/17/17	17:38	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1420	PG&E	09/18/17	13:01	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1421	PG&E	09/18/17	15:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1422	PG&E	09/18/17	18:01	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1423	PG&E	09/18/17	19:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1424	PG&E	09/18/17	23:50	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1425	PG&E	09/19/17	19:13	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
1426	PG&E	09/20/17	2:06	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1427	PG&E	09/20/17	8:41	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
1428	PG&E	09/21/17	8:39	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1429	PG&E	09/22/17	14:28	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1430	PG&E	09/23/17	9:16	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1431	PG&E	09/23/17	14:17	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
1432	PG&E	09/24/17	2:13	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1433	PG&E	09/24/17	7:54	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1434	PG&E	09/24/17	16:42	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1435	PG&E	09/25/17	19:49	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1436	PG&E	09/26/17	17:44	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1437	PG&E	09/27/17	9:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1438	PG&E	09/27/17	12:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1439	PG&E	09/27/17	19:06	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1440	PG&E	09/28/17	18:28	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	Third-party caused
1441	PG&E	09/29/17	2:01	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1442	PG&E	09/30/17	15:08	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	Third-party caused
1443	PG&E	10/01/17	7:24	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1444	PG&E	10/01/17	16:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1445	PG&E	10/01/17	23:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1446	PG&E	10/02/17	2:55	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1447	PG&E	10/02/17	7:07	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1448	PG&E	10/02/17	12:22	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1449	PG&E	10/02/17	14:56	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1450	PG&E	10/02/17	16:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1451	PG&E	10/02/17	17:30	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1452	PG&E	10/03/17	17:48	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1453	PG&E	10/04/17	12:20	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1454	PG&E	10/04/17	23:42	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1455	PG&E	10/05/17	0:20	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown	
1456	PG&E	10/05/17	10:57	Contact From Object	N.A.	Other	Electric Facility	Other	bird's Nest
1457	PG&E	10/06/17	7:24	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
1458	PG&E	10/06/17	12:03	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1459	PG&E	10/06/17	16:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1460	PG&E	10/07/17	10:11	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1461	PG&E	10/08/17	5:11	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1462	PG&E	10/08/17	16:41	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1463	PG&E	10/08/17	16:43	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1464	PG&E	10/08/17	17:39	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1465	PG&E	10/08/17	19:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1466	PG&E	10/08/17	19:44	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1467	PG&E	10/08/17	20:35	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1468	PG&E	10/08/17	21:10	Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
1469	PG&E	10/08/17	21:46	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1470	PG&E	10/08/17	22:19	Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
1471	PG&E	10/08/17	22:30	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1472	PG&E	10/08/17	22:44	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1473	PG&E	10/08/17	22:58	Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
1474	PG&E	10/08/17	23:51	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
1475	PG&E	10/09/17	1:02	Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
1476	PG&E	10/09/17	1:13	Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
1477	PG&E	10/09/17	1:25	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1478	PG&E	10/09/17	1:29	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1479	PG&E	10/09/17	1:45	Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
1480	PG&E	10/09/17	2:27	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1481	PG&E	10/09/17	4:36	Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
1482	PG&E	10/09/17	12:05	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
1483	PG&E	10/10/17	13:36	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1484	PG&E	10/10/17	16:17	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1485	PG&E	10/10/17	16:29	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1486	PG&E	10/11/17	11:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1487	PG&E	10/11/17	16:41	Unknown	N.A.	N.A.	N.A.	Unknown	
1488	PG&E	10/13/17	8:30	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1489	PG&E	10/13/17	10:27	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1490	PG&E	10/13/17	19:15	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1491	PG&E	10/13/17	22:19	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1492	PG&E	10/14/17	8:37	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1493	PG&E	10/14/17	14:43	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1494	PG&E	10/15/17	13:15	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1495	PG&E	10/16/17	12:10	Contact From Object	N.A.	Vehicle	Communication Facility	Human Error	
1496	PG&E	10/16/17	12:20	Contact From Object	N.A.	Vehicle	Communication Facility	Human Error	
1497	PG&E	10/16/17	12:26	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1498	PG&E	10/17/17	18:22	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1499	PG&E	10/18/17	13:58	Contact From Object	N.A.	Vehicle	N.A.	Human Error	
1500	PG&E	10/20/17	5:59	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1501	PG&E	10/20/17	6:18	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1502	PG&E	10/20/17	9:06	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
1503	PG&E	10/20/17	13:43	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1504	PG&E	10/20/17	13:45	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1505	PG&E	10/20/17	14:00	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1506	PG&E	10/21/17	15:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1507	PG&E	10/21/17	16:05	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	Third-party caused
1508	PG&E	10/23/17	19:34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1509	PG&E	10/23/17	21:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1510	PG&E	10/24/17	15:23	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1511	PG&E	10/26/17	10:53	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1512	PG&E	10/28/17	15:26	Contact From Object	N.A.	Vehicle	Communication Facility	Human Error	
1513	PG&E	10/28/17	20:08	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1514	PG&E	10/31/17	18:56	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	Third-party caused
1515	PG&E	10/31/17	21:02	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1516	PG&E	11/06/17	9:59	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1517	PG&E	11/06/17	15:06	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1518	PG&E	11/08/17	07:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1519	PG&E	11/08/17	14:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1520	PG&E	11/11/17	11:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1521	PG&E	11/12/17	19:44	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1522	PG&E	11/14/17	07:43	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1523	PG&E	11/17/17	09:53	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1524	PG&E	11/20/17	08:32	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1525	PG&E	11/20/17	20:05	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1526	PG&E	11/21/17	11:55	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1527	PG&E	11/22/17	13:44	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1528	PG&E	11/23/17	16:29	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1529	PG&E	11/24/17	10:33	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1530	PG&E	11/25/17	6:29	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1531	PG&E	11/26/17	10:10	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
1532	PG&E	11/27/17	06:23	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1533	PG&E	11/27/17	11:11	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1534	PG&E	11/28/17	15:49	Equipment/ Facility Failure	Voltage Regulator	N.A.	N.A.	Unknown	
1535	PG&E	11/29/17	17:34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1536	PG&E	12/07/17	12:25	Unknown	N.A.	N.A.	N.A.	Unknown	
1537	PG&E	12/12/17	4:40	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1538	PG&E	12/13/17	12:13	Equipment/ Facility Failure	Recloser	N.A.	N.A.	Unknown	
1539	PG&E	12/14/17	1:33	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1540	PG&E	12/14/17	17:16	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1541	PG&E	12/16/17	7:01	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1542	PG&E	12/16/17	11:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1543	PG&E	12/16/17	13:39	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1544	PG&E	12/16/17	16:03	Other	N.A.	N.A.	N.A.	Unknown	
1545	PG&E	12/19/17	7:05	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1546	PG&E	12/19/17	16:55	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1547	PG&E	12/19/17	19:45	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1548	PG&E	12/20/17	07:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1549	PG&E	12/20/17	14:03	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1550	PG&E	12/20/17	16:04	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1551	PG&E	12/22/17	14:38	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown	
1552	PG&E	12/24/17	6:41	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1553	PG&E	12/24/17	03:53	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	Third-party caused
1554	PG&E	12/29/17	16:31	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1555	PG&E	1/1/18	1:35	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gun-shot conductor
1556	PG&E	1/1/18	16:00	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1557	PG&E	1/13/18	18:34	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	Marker ball
1558	PG&E	1/16/18	14:25	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1559	PG&E	2/1/18	17:41	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
1560	PG&E	2/7/18	5:44	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1561	PG&E	2/7/18	9:16	Contact From Object	N.A.	Other	Electric Facility	Human Error	third-party caused
1562	PG&E	2/9/18	18:56	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1563	PG&E	2/12/18	20:20	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1564	PG&E	2/25/18	13:19	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1565	PG&E	2/26/18	16:33	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1566	PG&E	3/3/18	12:15	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1567	PG&E	3/5/18	16:24	Unknown	N.A.	N.A.	N.A.	Unknown	
1568	PG&E	3/6/18	17:57	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1569	PG&E	3/10/18	15:22	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
1570	PG&E	3/12/18	3:26	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1571	PG&E	3/26/18	17:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1572	PG&E	4/2/18	11:36	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1573	PG&E	4/3/18	14:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1574	PG&E	4/12/18	14:17	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1575	PG&E	4/16/18	20:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1576	PG&E	4/23/18	20:20	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
1577	PG&E	4/24/18	12:00	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1578	PG&E	4/24/18	19:15	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1579	PG&E	4/27/18	12:48	Unknown	N.A.	N.A.	N.A.	Unknown	
1580	PG&E	4/29/18	11:54	Contact from Object	N.A.	Other	Electric Facility	Other	bird's nest
1581	PG&E	4/30/18	14:33	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1582	PG&E	5/4/18	16:34	Unknown	N.A.	N.A.	N.A.	Unknown	
1583	PG&E	5/6/18	15:02	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1584	PG&E	5/8/18	17:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1585	PG&E	5/9/18	13:47	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1586	PG&E	5/9/18	14:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1587	PG&E	5/11/18	10:13	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1588	PG&E	5/11/18	12:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1589	PG&E	5/11/18	15:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1590	PG&E	5/11/18	17:43	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1591	PG&E	5/12/18	15:50	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1592	PG&E	5/13/18	0:26	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1593	PG&E	5/13/18	11:04	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
1594	PG&E	5/14/18	14:02	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1595	PG&E	5/14/18	21:10	Unknown	N.A.	N.A.	N.A.	Unknown	
1596	PG&E	5/15/18	4:22	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1597	PG&E	5/16/18	9:12	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1598	PG&E	5/17/18	17:41	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1599	PG&E	5/19/18	9:39	Contact From Object	N.A.	Other	Electric Facility	Human Error	aircraft
1600	PG&E	5/19/18	13:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1601	PG&E	5/19/18	19:44	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1602	PG&E	5/19/18	21:02	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1603	PG&E	5/20/18	17:14	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gun-shot conductor
1604	PG&E	5/22/18	8:14	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1605	PG&E	5/22/18	15:51	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1606	PG&E	5/23/18	14:03	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1607	PG&E	5/23/18	15:37	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1608	PG&E	5/24/18	12:12	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1609	PG&E	5/25/18	11:38	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1610	PG&E	5/26/18	11:28	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1611	PG&E	5/28/18	1:56	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1612	PG&E	5/28/18	6:30	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1613	PG&E	5/29/18	15:52	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1614	PG&E	5/30/18	13:00	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1615	PG&E	5/30/18	16:58	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1616	PG&E	5/31/18	6:30	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1617	PG&E	5/31/18	8:50	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1618	PG&E	5/31/18	12:28	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1619	PG&E	5/31/18	14:34	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1620	PG&E	6/2/18	12:02	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1621	PG&E	6/2/18	16:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1622	PG&E	6/2/18	21:37	Unknown	N.A.	N.A.	N.A.	Unknown	
1623	PG&E	6/3/18	8:39	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1624	PG&E	6/3/18	15:01	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1625	PG&E	6/3/18	15:08	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1626	PG&E	6/4/18	9:25	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1627	PG&E	6/4/18	13:18	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1628	PG&E	6/4/18	14:31	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1629	PG&E	6/4/18	14:45	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1630	PG&E	6/4/18	17:38	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1631	PG&E	6/4/18	17:38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1632	PG&E	6/4/18	21:42	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1633	PG&E	6/5/18	10:13	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1634	PG&E	6/5/18	11:46	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
1635	PG&E	6/5/18	13:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1636	PG&E	6/5/18	16:46	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1637	PG&E	6/5/18	19:10	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gun-shot conductor
1638	PG&E	6/6/18	10:32	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1639	PG&E	6/6/18	11:07	Wire-Wire Contact	N.A.	N.A.	N.A.	Human Error	Work error
1640	PG&E	6/6/18	15:00	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1641	PG&E	6/6/18	16:28	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1642	PG&E	6/6/18	19:13	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1643	PG&E	6/6/18	19:21	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1644	PG&E	6/6/18	21:06	Unknown	N.A.	N.A.	N.A.	Unknown	
1645	PG&E	6/8/18	17:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1646	PG&E	6/8/18	19:03	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1647	PG&E	6/9/18	0:46	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1648	PG&E	6/9/18	16:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1649	PG&E	6/10/18	17:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1650	PG&E	6/11/18	14:20	Contact From Object	N.A.	Other	Electric Facility	Human Error	third-party dig in
1651	PG&E	6/11/18	17:49	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1652	PG&E	6/11/18	19:59	Contamination	N.A.	N.A.	N.A.	Unknown	
1653	PG&E	6/12/18	8:55	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1654	PG&E	6/12/18	12:12	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1655	PG&E	6/13/18	2:53	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1656	PG&E	6/13/18	11:18	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1657	PG&E	6/13/18	16:27	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1658	PG&E	6/13/18	22:40	Equipment/ Facility Failure	Voltage Regulator	N.A.	N.A.	Unknown	
1659	PG&E	6/14/18	14:25	Contact From Object	N.A.	Other	Electric Facility	Human Error	bucket truck
1660	PG&E	6/14/18	16:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1661	PG&E	6/15/18	2:56	Contamination	N.A.	N.A.	N.A.	Unknown	
1662	PG&E	6/15/18	9:51	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
1663	PG&E	6/15/18	10:05	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1664	PG&E	6/16/18	9:56	Contact From Object	N.A.	Other	Electric Facility	Unknown	bird's nest
1665	PG&E	6/16/18	13:17	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1666	PG&E	6/16/18	16:28	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gun-shot conductor
1667	PG&E	6/16/18	18:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1668	PG&E	6/16/18	18:15	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1669	PG&E	6/16/18	18:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1670	PG&E	6/16/18	19:37	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1671	PG&E	6/16/18	19:37	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1672	PG&E	6/16/18	19:58	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1673	PG&E	6/16/18	20:33	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
1674	PG&E	6/17/18	16:01	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1675	PG&E	6/18/18	8:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1676	PG&E	6/18/18	16:06	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1677	PG&E	6/19/18	0:27	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1678	PG&E	6/19/18	9:43	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1679	PG&E	6/19/18	10:17	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
1680	PG&E	6/19/18	11:45	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1681	PG&E	6/19/18	14:41	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1682	PG&E	6/20/18	8:30	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1683	PG&E	6/21/18	17:36	Unknown	N.A.	N.A.	N.A.	Unknown	
1684	PG&E	6/21/18	17:51	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1685	PG&E	6/21/18	18:58	Unknown	N.A.	N.A.	N.A.	Unknown	
1686	PG&E	6/22/18	6:44	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1687	PG&E	6/22/18	16:28	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1688	PG&E	6/22/18	17:44	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1689	PG&E	6/22/18	18:48	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1690	PG&E	6/23/18	9:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1691	PG&E	6/23/18	17:33	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1692	PG&E	6/23/18	17:47	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1693	PG&E	6/23/18	18:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1694	PG&E	6/23/18	21:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1695	PG&E	6/24/18	13:07	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1696	PG&E	6/24/18	19:41	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
1697	PG&E	6/26/18	9:28	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1698	PG&E	6/26/18	11:24	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1699	PG&E	6/26/18	13:58	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	elbow
1700	PG&E	6/26/18	15:53	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1701	PG&E	6/27/18	17:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1702	PG&E	6/27/18	18:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1703	PG&E	6/27/18	21:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1704	PG&E	6/28/18	12:27	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1705	PG&E	6/28/18	18:38	Unknown	N.A.	N.A.	N.A.	Unknown	
1706	PG&E	6/28/18	19:41	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1707	PG&E	6/29/18	3:50	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1708	PG&E	6/29/18	11:30	Equipment/ Facility Failure	capacitor bank	N.A.	N.A.	Unknown	
1709	PG&E	6/29/18	13:18	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
1710	PG&E	6/29/18	15:10	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1711	PG&E	6/29/18	15:19	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1712	PG&E	6/29/18	19:34	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1713	PG&E	6/30/18	3:32	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1714	PG&E	6/30/18	8:04	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1715	PG&E	6/30/18	11:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1716	PG&E	6/30/18	13:32	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1717	PG&E	6/30/18	17:54	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1718	PG&E	6/30/18	22:18	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1719	PG&E	6/30/18	22:36	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1720	PG&E	7/1/18	0:23	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1721	PG&E	7/1/18	0:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1722	PG&E	7/1/18	8:13	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1723	PG&E	7/2/18	2:26	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1724	PG&E	7/2/18	5:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1725	PG&E	7/2/18	11:35	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1726	PG&E	7/2/18	17:15	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1727	PG&E	7/3/18	18:02	Unknown	N.A.	N.A.	N.A.	Unknown	
1728	PG&E	7/4/18	15:26	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1729	PG&E	7/5/18	12:45	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1730	PG&E	7/6/18	17:13	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1731	PG&E	7/6/18	20:39	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1732	PG&E	7/7/18	8:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1733	PG&E	7/7/18	9:05	Contact From Object	N.A.	Other	Electric Facility	Human Error	third-party caused
1734	PG&E	7/7/18	20:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1735	PG&E	7/8/18	19:32	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1736	PG&E	7/8/18	20:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1737	PG&E	7/9/18	7:27	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1738	PG&E	7/10/18	5:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1739	PG&E	7/10/18	6:45	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1740	PG&E	7/10/18	18:58	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1741	PG&E	7/11/18	2:11	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1742	PG&E	7/11/18	10:10	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1743	PG&E	7/13/18	8:10	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1744	PG&E	7/13/18	10:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1745	PG&E	7/13/18	15:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1746	PG&E	7/13/18	18:51	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1747	PG&E	7/14/18	11:34	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1748	PG&E	7/14/18	12:40	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1749	PG&E	7/14/18	12:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1750	PG&E	7/14/18	14:44	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1751	PG&E	7/14/18	15:01	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1752	PG&E	7/14/18	15:58	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1753	PG&E	7/14/18	21:38	Contact From Object	N.A.	Animal	Pole	Other	bull rubbing pole
1754	PG&E	7/15/18	10:06	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1755	PG&E	7/16/18	12:57	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1756	PG&E	7/17/18	5:59	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1757	PG&E	7/17/18	11:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1758	PG&E	7/17/18	11:58	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1759	PG&E	7/17/18	15:16	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1760	PG&E	7/17/18	15:53	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1761	PG&E	7/17/18	16:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1762	PG&E	7/17/18	19:40	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1763	PG&E	7/18/18	1:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1764	PG&E	7/18/18	3:46	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1765	PG&E	7/18/18	7:16	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1766	PG&E	7/18/18	11:19	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1767	PG&E	7/18/18	14:50	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1768	PG&E	7/19/18	0:08	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1769	PG&E	7/19/18	5:29	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1770	PG&E	7/19/18	10:44	Equipment/ Facility Failure	Voltage Regulator	N.A.	N.A.	Unknown	
1771	PG&E	7/19/18	15:03	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1772	PG&E	7/19/18	15:52	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1773	PG&E	7/20/18	6:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1774	PG&E	7/20/18	15:36	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1775	PG&E	7/20/18	22:44	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1776	PG&E	7/21/18	0:23	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1777	PG&E	7/21/18	14:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1778	PG&E	7/21/18	16:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1779	PG&E	7/21/18	17:03	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1780	PG&E	7/21/18	21:03	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1781	PG&E	7/23/18	3:36	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1782	PG&E	7/23/18	8:46	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1783	PG&E	7/23/18	15:11	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1784	PG&E	7/23/18	17:27	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1785	PG&E	7/23/18	20:35	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
1786	PG&E	7/24/18	9:00	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1787	PG&E	7/24/18	13:01	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1788	PG&E	7/24/18	13:47	Unknown	N.A.	N.A.	N.A.	Unknown	
1789	PG&E	7/24/18	21:08	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1790	PG&E	7/25/18	0:42	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1791	PG&E	7/25/18	12:19	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
1792	PG&E	7/25/18	23:16	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1793	PG&E	7/26/18	19:23	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1794	PG&E	7/26/18	20:42	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1795	PG&E	7/27/18	23:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1796	PG&E	7/28/18	6:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1797	PG&E	7/28/18	8:47	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1798	PG&E	7/29/18	11:39	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1799	PG&E	7/29/18	17:29	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1800	PG&E	7/30/18	7:49	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
1801	PG&E	7/30/18	8:50	Equipment/ Facility Failure	crossarm	N.A.	N.A.	Unknown	
1802	PG&E	7/30/18	14:36	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	PG&E contractor
1803	PG&E	7/30/18	22:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1804	PG&E	7/31/18	7:07	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1805	PG&E	7/31/18	7:57	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1806	PG&E	7/31/18	11:01	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1807	PG&E	8/1/18	17:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1808	PG&E	8/1/18	19:06	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1809	PG&E	8/2/18	9:48	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1810	PG&E	8/2/18	15:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1811	PG&E	8/2/18	17:34	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gun-shot conductor
1812	PG&E	8/2/18	20:27	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1813	PG&E	8/3/18	0:09	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1814	PG&E	8/3/18	9:45	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1815	PG&E	8/3/18	16:13	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1816	PG&E	8/3/18	19:19	Contact From Object	N.A.	Other	Electric Facility	Human Error	helicopter
1817	PG&E	8/3/18	19:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1818	PG&E	8/4/18	6:21	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1819	PG&E	8/4/18	7:22	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1820	PG&E	8/4/18	14:33	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1821	PG&E	8/4/18	17:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1822	PG&E	8/5/18	13:40	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
1823	PG&E	8/5/18	13:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1824	PG&E	8/6/18	17:27	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1825	PG&E	8/7/18	9:47	Unknown	N.A.	N.A.	N.A.	Unknown	
1826	PG&E	8/7/18	10:19	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1827	PG&E	8/7/18	15:22	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	PG&E contractor
1828	PG&E	8/7/18	15:46	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1829	PG&E	8/7/18	17:15	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1830	PG&E	8/7/18	21:03	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1831	PG&E	8/8/18	10:03	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
1832	PG&E	8/8/18	16:02	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1833	PG&E	8/8/18	16:03	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1834	PG&E	8/10/18	12:54	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1835	PG&E	8/10/18	15:39	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1836	PG&E	8/10/18	19:18	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1837	PG&E	8/10/18	20:18	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1838	PG&E	8/11/18	16:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1839	PG&E	8/12/18	11:42	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1840	PG&E	8/12/18	14:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1841	PG&E	8/13/18	15:11	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1842	PG&E	8/13/18	15:33	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1843	PG&E	8/13/18	18:43	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1844	PG&E	8/14/18	6:43	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1845	PG&E	8/14/18	15:18	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1846	PG&E	8/14/18	15:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1847	PG&E	8/17/18	9:38	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1848	PG&E	8/17/18	17:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1849	PG&E	8/18/18	6:15	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1850	PG&E	8/20/18	5:26	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1851	PG&E	8/20/18	9:34	Contact From Object	N.A.	Other	Electric Facility	Human Error	PG&E contractor
1852	PG&E	8/20/18	10:06	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
1853	PG&E	8/21/18	0:23	Unknown	N.A.	N.A.	N.A.	Unknown	
1854	PG&E	8/21/18	17:33	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1855	PG&E	8/22/18	17:24	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	dampeners
1856	PG&E	8/22/18	21:56	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1857	PG&E	8/23/18	14:23	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1858	PG&E	8/23/18	16:06	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1859	PG&E	8/24/18	1:38	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1860	PG&E	8/24/18	5:03	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1861	PG&E	8/25/18	17:15	Contact From Object	N.A.	Animal	Electric Facility	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
1862	PG&E	8/26/18	15:29	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1863	PG&E	8/26/18	16:50	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1864	PG&E	8/27/18	5:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1865	PG&E	8/27/18	13:56	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1866	PG&E	8/27/18	16:45	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1867	PG&E	8/28/18	2:00	Unknown	N.A.	N.A.	N.A.	Unknown	
1868	PG&E	8/28/18	12:50	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1869	PG&E	8/28/18	16:14	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1870	PG&E	8/29/18	16:19	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1871	PG&E	8/30/18	15:38	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1872	PG&E	8/31/18	5:07	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1873	PG&E	8/31/18	12:30	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1874	PG&E	8/31/18	13:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1875	PG&E	8/31/18	18:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1876	PG&E	8/31/18	18:09	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1877	PG&E	9/1/18	14:25	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1878	PG&E	9/2/18	15:36	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1879	PG&E	9/2/18	16:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1880	PG&E	9/2/18	23:18	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1881	PG&E	9/3/18	12:00	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1882	PG&E	9/3/18	18:29	Unknown	N.A.	N.A.	N.A.	Unknown	
1883	PG&E	9/5/18	11:39	Contact From Object	N.A.	Other	Electric Facility	Human Error	third-party caused
1884	PG&E	9/5/18	16:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1885	PG&E	9/5/18	17:34	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1886	PG&E	9/5/18	20:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1887	PG&E	9/6/18	1:19	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1888	PG&E	9/6/18	16:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1889	PG&E	9/9/18	4:25	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1890	PG&E	9/10/18	7:05	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1891	PG&E	9/10/18	20:37	Unknown	N.A.	N.A.	N.A.	Unknown	
1892	PG&E	9/10/18	21:25	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1893	PG&E	9/11/18	5:23	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1894	PG&E	9/11/18	11:19	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1895	PG&E	9/11/18	18:51	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1896	PG&E	9/11/18	21:44	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1897	PG&E	9/12/18	19:38	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1898	PG&E	9/13/18	9:02	Unknown	N.A.	N.A.	N.A.	Unknown	
1899	PG&E	9/14/18	9:06	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1900	PG&E	9/14/18	15:08	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1901	PG&E	9/15/18	3:47	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1902	PG&E	9/15/18	9:57	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1903	PG&E	9/15/18	13:34	Unknown	N.A.	N.A.	N.A.	Unknown	
1904	PG&E	9/16/18	8:10	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1905	PG&E	9/16/18	8:26	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gun-shot conductor
1906	PG&E	9/16/18	10:22	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1907	PG&E	9/17/18	16:05	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1908	PG&E	9/19/18	6:04	Contact From Object	N.A.	Other	Electric Facility	Unknown	guano
1909	PG&E	9/21/18	11:26	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1910	PG&E	9/21/18	21:10	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1911	PG&E	9/21/18	23:02	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1912	PG&E	9/22/18	17:56	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1913	PG&E	9/23/18	3:18	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1914	PG&E	9/23/18	15:57	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1915	PG&E	9/24/18	0:35	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1916	PG&E	9/24/18	12:07	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1917	PG&E	9/24/18	17:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1918	PG&E	9/27/18	3:40	Contact From Object	N.A.	Other	Electric Facility	Unknown	guano
1919	PG&E	9/27/18	12:43	Contact From Object	N.A.	Other	Electric Facility	Human Error	helicopter
1920	PG&E	9/27/18	15:25	Contact From Object	N.A.	Other	Pole	Human Error	third-party caused
1921	PG&E	9/27/18	17:19	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1922	PG&E	9/28/18	4:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1923	PG&E	9/28/18	9:55	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1924	PG&E	9/29/18	13:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1925	PG&E	9/29/18	16:16	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
1926	PG&E	9/30/18	14:40	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1927	PG&E	10/1/18	15:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1928	PG&E	10/3/18	16:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1929	PG&E	10/6/18	14:56	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1930	PG&E	10/6/18	17:29	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1931	PG&E	10/7/18	1:44	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1932	PG&E	10/7/18	8:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1933	PG&E	10/7/18	8:48	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1934	PG&E	10/7/18	17:48	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1935	PG&E	10/8/18	11:03	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1936	PG&E	10/10/18	13:24	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1937	PG&E	10/11/18	10:40	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1938	PG&E	10/11/18	12:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1939	PG&E	10/11/18	22:39	Unknown	N.A.	N.A.	N.A.	Unknown	
1940	PG&E	10/14/18	11:40	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1941	PG&E	10/14/18	19:39	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1942	PG&E	10/14/18	20:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1943	PG&E	10/15/18	3:23	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
1944	PG&E	10/16/18	10:44	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1945	PG&E	10/16/18	16:30	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1946	PG&E	10/17/18	17:41	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1947	PG&E	10/19/18	15:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1948	PG&E	10/20/18	8:01	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1949	PG&E	10/20/18	14:31	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1950	PG&E	10/21/18	0:32	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1951	PG&E	10/24/18	7:08	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1952	PG&E	10/24/18	14:18	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gun-shot conductor
1953	PG&E	10/25/18	18:47	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1954	PG&E	10/26/18	2:11	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1955	PG&E	10/26/18	20:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1956	PG&E	10/28/18	8:50	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1957	PG&E	10/29/18	19:09	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1958	PG&E	10/30/18	15:40	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1959	PG&E	10/31/18	12:50	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1960	PG&E	11/1/18	20:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1961	PG&E	11/7/18	15:49	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1962	PG&E	11/8/18	11:41	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1963	PG&E	11/8/18	13:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1964	PG&E	11/8/18	21:30	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1965	PG&E	11/9/18	4:49	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1966	PG&E	11/9/18	8:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1967	PG&E	11/9/18	15:34	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1968	PG&E	11/10/18	13:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1969	PG&E	11/11/18	4:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1970	PG&E	11/11/18	10:40	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1971	PG&E	11/11/18	13:06	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1972	PG&E	11/12/18	5:17	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1973	PG&E	11/12/18	14:39	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1974	PG&E	11/13/18	11:34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1975	PG&E	11/13/18	15:41	Other	N.A.	N.A.	N.A.	Human Error	Grow house
1976	PG&E	11/15/18	6:09	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1977	PG&E	11/15/18	6:34	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1978	PG&E	11/16/18	17:02	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1979	PG&E	11/17/18	17:20	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1980	PG&E	11/18/18	1:37	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1981	PG&E	11/18/18	14:31	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
1982	PG&E	11/19/18	9:46	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1983	PG&E	11/20/18	13:07	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1984	PG&E	11/21/18	2:16	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gun-shot conductor
1985	PG&E	11/23/18	22:14	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1986	PG&E	12/12/18	12:09	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1987	PG&E	12/14/18	10:32	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1988	PG&E	12/31/18	21:43	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1989	PG&E	1/14/19	8:32	Equipment - PG&E	Line Recloser				
1990	PG&E	1/16/19	0:17	Vegetation		Veg. contact	Electric Facility		
1991	PG&E	1/23/19	0:26	Equipment - PG&E	Conductor				
1992	PG&E	2/1/19	21:40	Vegetation		Veg. contact	Electric Facility		
1993	PG&E	2/11/19	10:55	Contact - Animal - Other				Animal Contact	
1994	PG&E	2/23/19	11:11	Vegetation		Veg. contact	Electric Facility		
1995	PG&E	2/26/19	12:49	Equipment - PG&E	Transformer				
1996	PG&E	3/13/19	16:08	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
1997	PG&E	3/14/19	14:42	Equipment - PG&E	Pole				
1998	PG&E	3/19/19	12:52	Contact - 3rd Party		Contact from Object - O	Electric Facility	Human Error	
1999	PG&E	4/9/19	14:07	Vegetation		Veg. contact	Electric Facility		
2000	PG&E	4/9/19	17:00	Weather - High Wind				High Winds	
2001	PG&E	4/9/19	15:27	Vegetation		Veg. contact	Pole		
2002	PG&E	4/9/19	17:59	Vegetation		Veg. contact	Electric Facility		
2003	PG&E	4/10/19	22:19	Weather - High Wind				High Winds	
2004	PG&E	4/10/19	12:43	Contact - Animal - Other		Animal contact	Electric Facility	Animal Contact	
2005	PG&E	4/12/19	10:45	Contact - 3rd Party		Contact from Object - O	Electric Facility	Human Error	
2006	PG&E	4/20/19	6:57	Equipment - PG&E	Conductor				
2007	PG&E	4/23/19	11:08	Contact - 3rd Party		Vehicle contact	Electric Facility	Human Error	
2008	PG&E	4/24/19	18:01	Contact - Animal - Other		Animal contact		Animal Contact	
2009	PG&E	4/24/19	11:59	Equipment - PG&E	Conductor				
2010	PG&E	4/25/19	12:18	Equipment - PG&E	Capacitor Bank				
2011	PG&E	4/25/19	12:40	Contact - 3rd Party		Vehicle contact	Electric Facility	Human Error	
2012	PG&E	4/26/19	3:26	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2013	PG&E	4/26/19	16:53	Vegetation		Veg. contact	Electric Facility		
2014	PG&E	4/28/19	12:36	Equipment - PG&E	Conductor				
2015	PG&E	4/29/19	8:53	Contact - Animal - Other		Animal contact	Electric Facility	Animal Contact	
2016	PG&E	4/29/19	18:07	Equipment - PG&E	Conductor				
2017	PG&E	5/1/19	17:51	Contact - 3rd Party		Other	Electric Facility	Human Error	
2018	PG&E	5/3/19	13:47	Contact - 3rd Party		Vehicle contact	Electric Facility	Human Error	
2019	PG&E	5/3/19	15:45	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2020	PG&E	5/3/19	19:11	Equipment - PG&E					
2021	PG&E	5/3/19	21:28	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2022	PG&E	5/4/19	17:48	Contact - Animal - Other		Animal contact	Pole	Animal Contact	
2023	PG&E	5/4/19	23:19	Contact - 3rd Party		Contact from Object - O	Electric Facility	Human Error	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column13	Field Observations	Column13	Column14	Column15	Column16	Notes
2	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor		
2024	PG&E	5/5/19	6:40	Contact - 3rd Party		Vehicle contact	Electric Facility	Human Error	
2025	PG&E	5/7/19	21:33	Equipment - PG&E	Fuse				
2026	PG&E	5/8/19	10:23	Equipment - PG&E	Conductor				
2027	PG&E	5/10/19	13:00	Contact - 3rd Party		Contact from Object - O	Electric Facility	Human Error	
2028	PG&E	5/10/19	14:52	Vegetation		Contact from Object - O	Electric Facility		
2029	PG&E	5/14/19	8:56	Equipment - PG&E	Conductor				
2030	PG&E	5/14/19	11:55	Vegetation		Veg. contact	Electric Facility		
2031	PG&E	5/14/19	16:17	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2032	PG&E	5/14/19	7:17	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2033	PG&E	5/14/19	18:11	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2034	PG&E	5/14/19	21:03	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2035	PG&E	5/15/19	16:22	Contact - 3rd Party		Vehicle contact	Electric Facility	Human Error	
2036	PG&E	5/15/19	21:31	Vegetation		Veg. contact	Electric Facility		
2037	PG&E	5/17/19	15:12	Vegetation		Veg. contact	Electric Facility		
2038	PG&E	5/17/19	18:54	Contact - Animal - Bird		Animal contact	Pole	Animal Contact	
2039	PG&E	5/21/19	15:50	Vegetation		Veg. contact	Electric Facility		
2040	PG&E	5/21/19	15:50	Equipment - PG&E					
2041	PG&E	5/24/19	11:52	Contact - Customer (Equip/Structure/Veg)		Veg. contact	Electric Facility		
2042	PG&E	5/24/19	19:14	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2043	PG&E	5/24/19	15:03	Equipment - PG&E					
2044	PG&E	5/25/19	18:29	Contact - 3rd Party		Vehicle contact	Electric Facility	Human Error	
2045	PG&E	5/25/19	20:51	Equipment - PG&E	Conductor				
2046	PG&E	5/27/19	18:04	Equipment - PG&E	Recloser				
2047	PG&E	5/28/19	12:57	Weather - High Wind				High Winds	
2048	PG&E	5/29/19	13:03	Equipment - PG&E	Transformer				
2049	PG&E	5/29/19	16:54	Vegetation		Veg. contact	Pole		
2050	PG&E	5/29/19	19:13	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2051	PG&E	5/29/19	20:25	Equipment - PG&E	Conductor				
2052	PG&E	5/30/19	7:27	Equipment - PG&E	Other				
2053	PG&E	5/30/19	8:18	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2054	PG&E	5/30/19	15:21	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2055	PG&E	5/30/19	22:25	Equipment - PG&E	Other				
2056	PG&E	5/31/19	13:34	Equipment - PG&E	Fuse				
2057	PG&E	5/31/19	15:25	Equipment - PG&E	Conductor				
2058	PG&E	6/1/19	6:38	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2059	PG&E	6/1/19	14:32	Vegetation		Veg. contact	Electric Facility		
2060	PG&E	6/3/19	6:57	Contact - Animal - Other		Animal contact	Electric Facility	Animal Contact	
2061	PG&E	6/3/19	14:31	Equipment - Overloaded	Transformer				
2062	PG&E	6/3/19	14:47	Equipment - PG&E					
2063	PG&E	6/3/19	18:11	Equipment - PG&E					
2064	PG&E	6/4/19	13:00	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2065	PG&E	6/5/19	21:01	Equipment - PG&E	Circuit Breaker				
2066	PG&E	6/6/19	9:01	Contact - Animal - Other		Animal contact		Animal Contact	
2067	PG&E	6/6/19	20:30	Contact - 3rd Party		Contact from Object - Other		Human Error	
2068	PG&E	6/7/19	9:58	Vegetation		Veg. contact	Electric Facility		
2069	PG&E	6/7/19	11:59	Equipment - PG&E	Transformer				
2070	PG&E	6/7/19	12:44	Equipment - PG&E	Switch				
2071	PG&E	6/7/19	16:44	Vegetation		Veg. contact	Electric Facility		
2072	PG&E	6/8/19	9:21	Vegetation		Veg. contact	Electric Facility		
2073	PG&E	6/8/19	10:13	Contact - 3rd Party		Balloon contact	Pole	Human Error	
2074	PG&E	6/8/19	14:31	Contact - 3rd Party		Balloon contact	Electric Facility	Human Error	
2075	PG&E	6/8/19	18:51	Vegetation		Veg. contact	Electric Facility		
2076	PG&E	6/8/19	23:26	Vegetation	Conductor	Veg. contact	Electric Facility		
2077	PG&E	6/9/19	3:07	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2078	PG&E	6/9/19	12:46	Vegetation		Veg. contact	Electric Facility		
2079	PG&E	6/9/19	13:53	Contact - 3rd Party		Balloon contact	Electric Facility	Human Error	
2080	PG&E	6/9/19	15:23	Equipment - PG&E	Recloser				
2081	PG&E	6/9/19	15:34	Equipment - PG&E	Lightning Arrestor				
2082	PG&E	6/9/19	18:07	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2083	PG&E	6/9/19	20:22	Equipment - PG&E	Transformer				
2084	PG&E	6/10/19	11:44	Contact - 3rd Party		Vehicle contact	Electric Facility	Human Error	
2085	PG&E	6/10/19	13:28	Equipment - PG&E	Transformer				
2086	PG&E	6/10/19	13:29	Vegetation		Veg. contact	Electric Facility		
2087	PG&E	6/10/19	15:53	Equipment - PG&E	Splice/Clamp/Connector				
2088	PG&E	6/10/19	16:05	Equipment - PG&E	Transformer				
2089	PG&E	6/10/19	16:18	Vegetation		Veg. contact	Electric Facility		
2090	PG&E	6/10/19	16:34	Vegetation		Veg. contact	Electric Facility		
2091	PG&E	6/10/19	18:52	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2092	PG&E	6/11/19	3:40	Equipment - PG&E					
2093	PG&E	6/11/19	8:49	Vegetation		Veg. contact	Electric Facility		
2094	PG&E	6/11/19	12:41	Vegetation		Veg. contact	Electric Facility		
2095	PG&E	6/11/19	15:41	Equipment - PG&E	Transformer				
2096	PG&E	6/11/19	16:31	Equipment - PG&E	Fuse				
2097	PG&E	6/11/19	17:16	Equipment - PG&E	Transformer				
2098	PG&E	6/12/19	7:55	Contact - Customer (Equip/Structure/Veg)		Contact from Object - O	Electric Facility		
2099	PG&E	6/12/19	6:12	Contact - 3rd Party		Balloon contact	Electric Facility	Human Error	
2100	PG&E	6/12/19	13:16	Equipment - PG&E	Transformer				
2101	PG&E	6/13/19	0:30	Vegetation		Veg. contact	Electric Facility		
2102	PG&E	6/14/19	4:38	Equipment - PG&E	Insulator				
2103	PG&E	6/14/19	14:34	Vegetation		Veg. contact	Electric Facility		
2104	PG&E	6/15/19	14:08	Contact - 3rd Party		Contact from Object - Other		Human Error	
2105	PG&E	6/16/19	11:28	Contact - 3rd Party		Balloon contact	Electric Facility	Human Error	
2106	PG&E	6/17/19	10:25	Vegetation		Veg. contact	Electric Facility		
2107	PG&E	6/17/19	16:37	Equipment - PG&E	Insulator				

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
2108	PG&E	6/17/19	18:07	Vegetation		Veg. contact	Electric Facility		
2109	PG&E	6/17/19	18:19	Vegetation		Veg. contact	Electric Facility		
2110	PG&E	6/17/19	23:31	Equipment - PG&E					
2111	PG&E	6/17/19	20:58	Equipment - PG&E	Other				
2112	PG&E	6/18/19	8:26	Equipment - PG&E	Transformer				
2113	PG&E	6/18/19	19:38	Equipment - PG&E	Crossarm				
2114	PG&E	6/18/19	19:49	Contact - Animal - Bird		Animal contact		Animal Contact	
2115	PG&E	6/18/19	13:05	Equipment - PG&E	Other				
2116	PG&E	6/19/19	9:02	Equipment - PG&E	Conductor				
2117	PG&E	6/19/19	11:44	Vegetation		Veg. contact	Electric Facility		
2118	PG&E	6/19/19	12:15	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2119	PG&E	6/19/19	8:31	Contact - Animal - Bird		Animal contact		Animal Contact	
2120	PG&E	6/20/19	5:58	Vegetation		Veg. contact	Electric Facility		
2121	PG&E	6/20/19	16:32	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2122	PG&E	6/21/19	2:37	Vegetation		Veg. contact	Pole		
2123	PG&E	6/21/19	10:56	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2124	PG&E	6/21/19	11:33	Weather - High Wind				High Winds	
2125	PG&E	6/22/19	23:30	Equipment - PG&E					
2126	PG&E	6/23/19	12:41	Equipment - Overloaded	Conductor				
2127	PG&E	6/23/19	14:43	Equipment - PG&E	Splice/Clamp/Connector				
2128	PG&E	6/24/19	9:53	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2129	PG&E	6/25/19	8:49	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2130	PG&E	6/25/19	16:32	Contact - Animal - Other		Animal contact	Electric Facility	Animal Contact	
2131	PG&E	6/26/19	7:48	Vegetation		Veg. contact	Electric Facility		
2132	PG&E	6/26/19	9:29	Equipment - PG&E	Pole				
2133	PG&E	6/26/19	13:14	Vegetation		Veg. contact	Electric Facility		
2134	PG&E	6/26/19	15:22	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2135	PG&E	6/27/19	2:23	Equipment - PG&E	Insulator				
2136	PG&E	6/28/19	13:45	Equipment - PG&E	Splice/Clamp/Connector				
2137	PG&E	6/29/19	11:41	Contact - 3rd Party		Balloon contact	Electric Facility	Human Error	
2138	PG&E	6/30/19	5:22	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2139	PG&E	6/30/19	17:30	Equipment - PG&E	Capacitor Bank				
2140	PG&E	6/30/19	18:02	Equipment - PG&E	Splice/Clamp/Connector				
2141	PG&E	7/1/19	2:15	Vegetation	Conductor	Veg. contact	Electric Facility		
2142	PG&E	7/1/19	13:51	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2143	PG&E	7/2/19	10:59	Equipment - PG&E					
2144	PG&E	7/2/19	11:48	Contact - Animal - Other		Animal contact	Electric Facility	Animal Contact	
2145	PG&E	7/2/19	22:51	Equipment - PG&E	Transformer				
2146	PG&E	7/4/19	16:44	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2147	PG&E	7/5/19	1:36	Vegetation		Veg. contact	Electric Facility		
2148	PG&E	7/5/19	16:49	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2149	PG&E	7/5/19	16:02	Vegetation		Veg. contact	Electric Facility		
2150	PG&E	7/5/19	8:15	Contact - 3rd Party		Balloon contact	Pole	Human Error	
2151	PG&E	7/5/19	15:10	Equipment - PG&E	Splice/Clamp/Connector				
2152	PG&E	7/6/19	15:34	Equipment - PG&E	Transformer				
2153	PG&E	7/6/19	14:22	Equipment - PG&E	Splice/Clamp/Connector				
2154	PG&E	7/7/19	19:14	Contact - 3rd Party		Balloon contact		Human Error	
2155	PG&E	7/7/19	18:23	Vegetation		Veg. contact	Electric Facility		
2156	PG&E	7/7/19	16:24	Equipment - PG&E	Other				
2157	PG&E	7/10/19	14:25	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2158	PG&E	7/11/19	15:27	Vegetation		Veg. contact	Pole		
2159	PG&E	7/12/19	14:18	Contact - 3rd Party		Conductor failure-all	Electric Facility	Human Error	
2160	PG&E	7/12/19	16:40	Equipment - PG&E	Conductor				
2161	PG&E	7/12/19	19:38	Vegetation		Veg. contact			
2162	PG&E	7/13/19	13:13	Equipment - PG&E	Splice/Clamp/Connector				
2163	PG&E	7/13/19	15:56	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2164	PG&E	7/13/19	12:43	Other Fire, Non-PG&E related					
2165	PG&E	7/13/19	12:04	Equipment - PG&E	Conductor				
2166	PG&E	7/13/19	22:16	Contact - 3rd Party	Conductor	Balloon contact	Electric Facility	Human Error	
2167	PG&E	7/15/19	7:51	Vegetation		Veg. contact	Electric Facility		
2168	PG&E	7/15/19	13:50	Contact - Animal - Other		Animal contact	Electric Facility	Animal Contact	
2169	PG&E	7/15/19	14:12	Equipment - PG&E	Crossarm				
2170	PG&E	7/15/19	16:31	Equipment - PG&E	Conductor				
2171	PG&E	7/16/19	17:31	Vegetation		Veg. contact	Electric Facility		
2172	PG&E	7/17/19	7:49	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2173	PG&E	7/17/19	18:00	Equipment - PG&E	Splice/Clamp/Connector				
2174	PG&E	7/18/19	12:10	Equipment - PG&E	Conductor				
2175	PG&E	7/18/19	15:23	Equipment - PG&E	Conductor				
2176	PG&E	7/18/19	19:57	Equipment - PG&E	Other				
2177	PG&E	7/18/19	10:27	Equipment - PG&E	Other				
2178	PG&E	7/18/19	19:12	Vegetation		Veg. contact	Electric Facility		
2179	PG&E	7/19/19	11:59	Vegetation		Veg. contact	Electric Facility		
2180	PG&E	7/21/19	15:22	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2181	PG&E	7/21/19	12:46	Vegetation		Veg. contact	Electric Facility		
2182	PG&E	7/21/19	10:19	Contact - 3rd Party		Contact from Object - Other		Human Error	
2183	PG&E	7/21/19	10:14	Equipment - PG&E	Splice/Clamp/Connector				
2184	PG&E	7/22/19	8:11	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2185	PG&E	7/22/19	21:39	Vegetation		Veg. contact	Electric Facility		
2186	PG&E	7/23/19	16:31	Vegetation		Veg. contact	Electric Facility		
2187	PG&E	7/23/19	16:55	Contact - 3rd Party		Contact from Object - O	Electric Facility	Human Error	
2188	PG&E	7/24/19	2:31	Equipment - PG&E					
2189	PG&E	7/24/19	5:09	Equipment - PG&E	Other				
2190	PG&E	7/24/19	15:38	Contact - Animal - Other		Animal contact	Electric Facility	Animal Contact	
2191	PG&E	7/25/19	0:15	Vegetation		Veg. contact	Electric Facility		

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
2192	PG&E	7/25/19	7:39	Vegetation		Veg. contact	Electric Facility		
2193	PG&E	7/25/19	15:47	Vegetation		Veg. contact	Electric Facility		
2194	PG&E	7/25/19	19:34	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2195	PG&E	7/26/19	12:03	Vegetation		Veg. contact	Electric Facility		
2196	PG&E	7/26/19	18:37	Equipment - PG&E	Pole				
2197	PG&E	7/27/19	15:30	Vegetation		Veg. contact	Pole		
2198	PG&E	7/27/19	8:22	Vegetation		Veg. contact	Electric Facility		
2199	PG&E	7/27/19	16:17	Vegetation		Veg. contact	Electric Facility		
2200	PG&E	7/27/19	3:43	Vegetation		Veg. contact	Electric Facility		
2201	PG&E	7/27/19	4:51	Vegetation		Veg. contact	Electric Facility		
2202	PG&E	7/28/19	23:13	Equipment - PG&E	Conductor				
2203	PG&E	7/29/19	15:11	Equipment - PG&E	Other				
2204	PG&E	7/30/19	0:17	Equipment - PG&E	Transformer				
2205	PG&E	7/30/19	15:15	Vegetation		Veg. contact	Electric Facility		
2206	PG&E	7/30/19	14:16	Contact - 3rd Party		Vehicle contact		Human Error	
2207	PG&E	7/30/19	15:24	Equipment - PG&E	Conductor				
2208	PG&E	7/31/19	18:34	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2209	PG&E	8/1/19	13:28	Contact - 3rd Party		Contact from Object - O	Electric Facility	Human Error	
2210	PG&E	8/2/19	3:28	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2211	PG&E	8/2/19	3:28	Vegetation		Veg. contact	Electric Facility		
2212	PG&E	8/2/19	4:51	Contact - Animal - Other		Animal contact	Electric Facility	Animal Contact	
2213	PG&E	8/3/19	13:30	Vegetation		Veg. contact	Electric Facility		
2214	PG&E	8/3/19	11:37	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2215	PG&E	8/5/19	11:55	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2216	PG&E	8/5/19	22:38	Equipment - Overloaded	Transformer				
2217	PG&E	8/5/19	23:32	Vegetation		Veg. contact	Electric Facility		
2218	PG&E	8/6/19	15:47	Contact - 3rd Party		Vehicle contact	Electric Facility	Human Error	
2219	PG&E	8/6/19	12:12	Vegetation		Veg. contact	Electric Facility		
2220	PG&E	8/6/19	18:33	Equipment - PG&E	Conductor				
2221	PG&E	8/7/19	7:29	Vegetation		Veg. contact	Electric Facility		
2222	PG&E	8/7/19	12:55	Contact - Animal - Bird		Animal contact	Pole	Animal Contact	
2223	PG&E	8/7/19	10:42	Equipment - PG&E	Splice/Clamp/Connector				
2224	PG&E	8/8/19	16:40	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2225	PG&E	8/10/19	7:26	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2226	PG&E	8/10/19	8:19	Contact - Animal - Other		Animal contact	Electric Facility	Animal Contact	
2227	PG&E	8/10/19	17:30	Equipment - PG&E	Conductor				
2228	PG&E	8/10/19	22:27	Equipment - PG&E	Conductor				
2229	PG&E	8/11/19	1:19	Vegetation		Veg. contact	Electric Facility		
2230	PG&E	8/11/19	16:56	Equipment - PG&E					
2231	PG&E	8/12/19	10:40	Contact - Animal - Other		Animal contact	Electric Facility	Animal Contact	
2232	PG&E	8/12/19	17:43	Equipment - PG&E	Conductor				
2233	PG&E	8/12/19	20:06	Vegetation		Veg. contact			
2234	PG&E	8/12/19	17:42	Vegetation		Veg. contact	Pole		
2235	PG&E	8/13/19	0:55	Equipment - PG&E	Capacitor Bank				
2236	PG&E	8/13/19	2:50	Contact - 3rd Party		Contact from Object - O	Electric Facility	Human Error	
2237	PG&E	8/13/19	10:30	Equipment - PG&E	Other				
2238	PG&E	8/14/19	19:42	Equipment - PG&E					
2239	PG&E	8/14/19	16:35	Contact - 3rd Party		Balloon contact	Electric Facility	Human Error	
2240	PG&E	8/14/19	14:04	Equipment - PG&E	Conductor				
2241	PG&E	8/14/19	10:16	Vegetation					
2242	PG&E	8/14/19	9:19	Vegetation		Veg. contact	Electric Facility		
2243	PG&E	8/14/19	7:56	Contact - Animal - Other		Animal contact	Electric Facility	Animal Contact	
2244	PG&E	8/15/19	12:24	Contact - 3rd Party		Vehicle contact	Electric Facility	Human Error	
2245	PG&E	8/15/19	12:10	Contact - 3rd Party		Contact from Object - O	Electric Facility	Human Error	
2246	PG&E	8/16/19	13:20	Vegetation					
2247	PG&E	8/16/19	8:19	Vegetation					
2248	PG&E	8/16/19	1:37	Contact - Animal - Other		Animal contact	Electric Facility	Animal Contact	
2249	PG&E	8/16/19	10:31	Vegetation		Veg. contact	Electric Facility		
2250	PG&E	8/16/19	18:11	Equipment - PG&E	Conductor				
2251	PG&E	8/18/19	8:20	Equipment - PG&E	Other				
2252	PG&E	8/18/19	15:46	Equipment - PG&E	Conductor				
2253	PG&E	8/19/19	17:27	Vegetation		Veg. contact	Electric Facility		
2254	PG&E	8/20/19	9:03	Vegetation	Conductor	Veg. contact	Electric Facility		
2255	PG&E	8/20/19	22:04	Equipment - PG&E	Fuse				
2256	PG&E	8/21/19	7:50	Equipment - PG&E	Conductor				
2257	PG&E	8/22/19	22:23	Vegetation		Veg. contact	Electric Facility		
2258	PG&E	8/23/19	21:39	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2259	PG&E	8/23/19	23:40	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2260	PG&E	8/23/19	17:54	Contact - 3rd Party		Contact from Object - Other		Human Error	
2261	PG&E	8/23/19	13:17	Vegetation		Veg. contact	Electric Facility		
2262	PG&E	8/24/19	20:26	Equipment - PG&E	Pole				
2263	PG&E	8/24/19	19:02	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2264	PG&E	8/25/19	13:13	Vegetation		Veg. contact	Electric Facility		
2265	PG&E	8/25/19	0:50	Equipment - PG&E	Other				
2266	PG&E	8/27/19	14:47	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2267	PG&E	8/28/19	2:15	Contact - Animal - Other		Animal contact	Electric Facility	Animal Contact	
2268	PG&E	8/28/19	16:43	Vegetation		Veg. contact	Electric Facility		
2269	PG&E	8/28/19	14:12	Contact - 3rd Party		Contact from Object - O	Electric Facility	Human Error	
2270	PG&E	8/30/19	16:37	Contact - 3rd Party		Vehicle contact	Electric Facility	Human Error	
2271	PG&E	8/31/19	10:20	Contact - 3rd Party		Vehicle contact	Electric Facility	Human Error	
2272	PG&E	9/1/19	16:50	Equipment - PG&E					
2273	PG&E	9/1/19	22:01	Vegetation		Veg. contact	Electric Facility		
2274	PG&E	9/1/19	6:59	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2275	PG&E	9/1/19	21:34	Equipment - PG&E	Other				

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
2276	PG&E	9/3/19	6:42	Equipment - PG&E	Conductor				
2277	PG&E	9/3/19	21:27	Equipment - PG&E	Conductor				
2278	PG&E	9/4/19	11:45	Contact - 3rd Party		Contact from Object - O	Electric Facility	Human Error	
2279	PG&E	9/5/19	13:53	Equipment - PG&E					
2280	PG&E	9/5/19	23:02	Vegetation		Veg. contact	Electric Facility		
2281	PG&E	9/6/19	19:16	Vegetation		Veg. contact	Electric Facility		
2282	PG&E	9/6/19	8:55	Equipment - PG&E	Capacitor Bank				
2283	PG&E	9/6/19	12:34	Equipment - PG&E	Capacitor Bank				
2284	PG&E	9/7/19	15:07	Vegetation		Veg. contact	Electric Facility		
2285	PG&E	9/7/19	11:42	Contact - 3rd Party		Contact from Object - O	Electric Facility	Human Error	
2286	PG&E	9/7/19	16:03	Vegetation		Veg. contact			
2287	PG&E	9/7/19	17:25	Equipment - PG&E	Conductor				
2288	PG&E	9/7/19	19:09	Vegetation		Veg. contact			
2289	PG&E	9/8/19	16:08	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2290	PG&E	9/8/19	12:14	Equipment - PG&E	Conductor				
2291	PG&E	9/9/19	12:38	Contact - 3rd Party		Balloon contact	Electric Facility	Human Error	
2292	PG&E	9/9/19	12:35	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2293	PG&E	9/10/19	7:13	Vegetation		Veg. contact	Electric Facility		
2294	PG&E	9/10/19	15:03	Equipment - PG&E	Conductor				
2295	PG&E	9/11/19	12:57	Equipment - PG&E	Recloser				
2296	PG&E	9/11/19	17:13	Equipment - PG&E					
2297	PG&E	9/11/19	18:28	Contact - Animal - Other		Contact from Object - O	Electric Facility	Animal Contact	
2298	PG&E	9/11/19	21:03	Vegetation		Veg. contact	Electric Facility		
2299	PG&E	9/11/19	18:58	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2300	PG&E	9/12/19	14:25	Vegetation		Veg. contact	Electric Facility		
2301	PG&E	9/13/19	8:30	Equipment - PG&E	Splice/Clamp/Connector				
2302	PG&E	9/13/19	16:38	Contact - 3rd Party		Vehicle contact		Human Error	
2303	PG&E	9/13/19	15:47	Equipment - PG&E	Transformer				
2304	PG&E	9/13/19	20:26	Vegetation		Veg. contact	Electric Facility		
2305	PG&E	9/13/19	8:53	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2306	PG&E	9/13/19	10:30	Contact - Animal - Bird		Animal contact		Animal Contact	
2307	PG&E	9/15/19	12:38	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2308	PG&E	9/15/19	12:58	Vegetation		Veg. contact	Pole		
2309	PG&E	9/16/19	14:39	Vegetation		Veg. contact	Electric Facility		
2310	PG&E	9/17/19	13:21	Contact - 3rd Party		Vehicle contact	Electric Facility	Human Error	
2311	PG&E	9/17/19	14:11	Contact - Animal - Other		Animal contact	Electric Facility	Animal Contact	
2312	PG&E	9/20/19	10:58	Vegetation		Veg. contact	Electric Facility		
2313	PG&E	9/22/19	11:45	Equipment - PG&E	Other				
2314	PG&E	9/22/19	11:34	Vegetation		Veg. contact	Pole		
2315	PG&E	9/22/19	11:58	Equipment - PG&E	Pole				
2316	PG&E	9/23/19	16:04	Contact - Animal - Other		Animal contact		Animal Contact	
2317	PG&E	9/23/19	16:39	Contact - 3rd Party		Vehicle contact	Electric Facility	Human Error	
2318	PG&E	9/23/19	19:13	Contact - Animal - Bird		Animal contact		Animal Contact	
2319	PG&E	9/24/19	13:13	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2320	PG&E	9/24/19	13:59	Equipment - PG&E	Conductor				
2321	PG&E	9/25/19	9:45	Equipment - PG&E	Fuse				
2322	PG&E	9/26/19	11:12	Equipment - PG&E					
2323	PG&E	9/26/19	13:47	Vegetation		Veg. contact			
2324	PG&E	9/26/19	14:12	Vegetation		Veg. contact			
2325	PG&E	9/26/19	17:54	Equipment - PG&E	Pole				
2326	PG&E	9/27/19	10:30	Vegetation		Veg. contact	Electric Facility		
2327	PG&E	9/27/19	14:25	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2328	PG&E	9/28/19	13:16	Equipment - PG&E	Conductor				
2329	PG&E	9/28/19	16:18	Equipment - PG&E	Pole				
2330	PG&E	9/28/19	19:24	Equipment - PG&E	Conductor				
2331	PG&E	9/29/19	13:30	Equipment - PG&E	Conductor				
2332	PG&E	9/29/19	15:04	Equipment - PG&E	Conductor				
2333	PG&E	9/29/19	20:06	Contact - 3rd Party		Balloon contact		Human Error	
2334	PG&E	9/29/19	20:29	Equipment - PG&E	Conductor				
2335	PG&E	9/29/19	22:06	Equipment - PG&E	Transformer				
2336	PG&E	9/30/19	14:29	Contact - 3rd Party		Contact from Object - O	Electric Facility	Human Error	
2337	PG&E	10/2/19	17:17	Contact - Animal - Bird		Animal contact		Animal Contact	
2338	PG&E	10/2/19	19:15	Contact - 3rd Party		Vehicle contact	Electric Facility	Human Error	
2339	PG&E	10/3/19	16:28	Equipment - PG&E	Insulator				
2340	PG&E	10/4/19	19:07	Equipment - Overloaded	Other				
2341	PG&E	10/5/19	5:48	Equipment - PG&E	Other				
2342	PG&E	10/5/19	16:46	Vegetation		Veg. contact	Electric Facility		
2343	PG&E	10/6/19	20:30	Equipment - PG&E	Transformer				
2344	PG&E	10/7/19	9:27	Equipment - PG&E	Splice/Clamp/Connector				
2345	PG&E	10/7/19	18:47	Contact - 3rd Party		Vehicle contact	Electric Facility	Human Error	
2346	PG&E	10/8/19	17:59	Equipment - PG&E	Conductor				
2347	PG&E	10/8/19	19:02	Equipment - PG&E	Recloser				
2348	PG&E	10/10/19	3:28	Equipment - PG&E	Conductor				
2349	PG&E	10/10/19	6:11	Equipment - PG&E	Conductor				
2350	PG&E	10/10/19	14:25	Equipment - PG&E	Conductor				
2351	PG&E	10/10/19	16:29	Equipment - PG&E	Conductor				
2352	PG&E	10/10/19	19:43	Equipment - PG&E	Conductor				
2353	PG&E	10/10/19	11:53	Contact - Animal - Bird		Animal contact		Animal Contact	
2354	PG&E	10/13/19	23:15	Vegetation		Veg. contact	Electric Facility		
2355	PG&E	10/14/19	3:27	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2356	PG&E	10/15/19	0:41	Equipment - PG&E	Insulator				
2357	PG&E	10/17/19	19:44	Contact - Animal - Bird		Animal contact		Animal Contact	
2358	PG&E	10/18/19	9:59	Contact - Animal - Bird		Animal contact		Animal Contact	
2359	PG&E	10/19/19	16:05	Contact - 3rd Party		Balloon contact		Human Error	

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
2360	PG&E	10/20/19	12:11	Contact - 3rd Party		Balloon contact		Human Error	
2361	PG&E	10/20/19	14:23	Equipment - PG&E					
2362	PG&E	10/20/19	17:09	Equipment - PG&E	Conductor				
2363	PG&E	10/22/19	15:06	Equipment - PG&E	Splice/Clamp/Connector				
2364	PG&E	10/22/19	14:44	Contact - Animal - Other		Animal contact		Animal Contact	
2365	PG&E	10/23/19	21:27	Under Investigation	Jumper				This ignition relates to
2366	PG&E	10/23/19	20:54	Vegetation		Veg. contact	Electric Facility		
2367	PG&E	10/24/19	11:44	Equipment - PG&E	Conductor				
2368	PG&E	10/24/19	7:38	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2369	PG&E	10/24/19	5:44	Vegetation		Veg. contact	Pole		
2370	PG&E	10/25/19	13:18	Contact - Animal - Other	Pole	Animal contact	Pole		
2371	PG&E	10/25/19	11:37	Equipment - PG&E	Pole				
2372	PG&E	10/26/19	23:27	Equipment - PG&E	Transformer				
2373	PG&E	10/26/19	4:26	Contact - 3rd Party		Vehicle contact	Pole	Human Error	
2374	PG&E	10/27/19	13:30	Equipment - PG&E	Pole				
2375	PG&E	10/27/19	14:55	Equipment - PG&E	Conductor				
2376	PG&E	10/27/19	14:55	Vegetation		Veg. contact	Electric Facility		
2377	PG&E	10/27/19	14:34	Vegetation		Veg. contact			
2378	PG&E	10/27/19	17:12	Vegetation		Veg. contact			
2379	PG&E	10/27/19	15:38	Contact - 3rd Party	Conductor	Contact from Object - O	Electric Facility	Human Error	
2380	PG&E	10/27/19	15:28	Vegetation		Veg. contact			
2381	PG&E	10/27/19	16:15	Contact - 3rd Party		Balloon contact		Human Error	
2382	PG&E	10/27/19	15:01	Vegetation		Veg. contact	Electric Facility		
2383	PG&E	10/27/19	14:41	Vegetation		Veg. contact	Electric Facility		
2384	PG&E	10/27/19	14:48	Vegetation		Veg. contact	Electric Facility		
2385	PG&E	10/27/19	13:32	Equipment - PG&E	Conductor				
2386	PG&E	10/27/19	11:01	Vegetation		Veg. contact	Electric Facility		
2387	PG&E	10/27/19	9:44	Other Fire: Non-PG&E related					
2388	PG&E	10/27/19	6:34	Equipment - PG&E	Conductor				
2389	PG&E	10/27/19	7:27	Equipment - PG&E	Line Recloser				
2390	PG&E	10/27/19	14:56	Equipment - PG&E	Conductor				
2391	PG&E	10/27/19	5:38	Vegetation		Veg. contact	Electric Facility		
2392	PG&E	10/27/19	3:16	Vegetation		Veg. contact	Pole		
2393	PG&E	10/27/19	1:42	Equipment - PG&E	Pole				
2394	PG&E	10/27/19	2:39	Equipment - PG&E	Other				
2395	PG&E	10/27/19	2:14	Vegetation		Veg. contact	Pole		
2396	PG&E	10/27/19	5:35	Equipment - PG&E	Conductor				
2397	PG&E	10/28/19	17:48	Vegetation		Veg. contact	Electric Facility		
2398	PG&E	10/28/19	18:46	Vegetation		Veg. contact	Electric Facility		
2399	PG&E	10/28/19	7:09	Equipment - PG&E	Fuse				
2400	PG&E	10/28/19	16:51	Equipment - PG&E	Conductor				
2401	PG&E	10/28/19	13:00	Vegetation		Veg. contact	Electric Facility		
2402	PG&E	10/28/19	11:34	Vegetation		Veg. contact	Electric Facility		
2403	PG&E	10/29/19	20:40	Vegetation		Veg. contact	Electric Facility		
2404	PG&E	10/29/19	12:57	Contact - Animal - Other		Animal contact	Electric Facility	Animal Contact	
2405	PG&E	10/29/19	3:29	Contact - Animal - Other		Animal contact		Animal Contact	
2406	PG&E	10/30/19	12:03	Contact - 3rd Party		Contact from Object - O	Electric Facility	Human Error	
2407	PG&E	10/30/19	14:29	Vegetation		Veg. contact			
2408	PG&E	10/30/19	8:47	Vegetation		Veg. contact			
2409	PG&E	10/30/19	13:32	Vegetation		Veg. contact			
2410	PG&E	10/30/19	10:02	Equipment - PG&E	Conductor				
2411	PG&E	10/31/19	21:21	Vegetation		Veg. contact	Electric Facility		
2412	PG&E	10/31/19	17:23	Equipment - PG&E	Conductor				
2413	PG&E	10/31/19	16:09	Vegetation		Veg. contact			
2414	PG&E	10/31/19	14:57	Vegetation		Veg. contact	Electric Facility		
2415	PG&E	11/1/19	11:33	Vegetation		Veg. contact	Electric Facility		
2416	PG&E	11/1/19	22:43	Unknown					
2417	PG&E	11/1/19	11:57	Contact - Animal - Other		Animal contact	Electric Facility	Animal Contact	
2418	PG&E	11/3/19	22:01	Equipment - Overloaded	Conductor				
2419	PG&E	11/3/19	18:26	Vegetation		Veg. contact			
2420	PG&E	11/4/19	9:48	Contact - 3rd Party		Balloon contact	Electric Facility	Human Error	
2421	PG&E	11/4/19	23:32	Equipment - PG&E	Conductor				
2422	PG&E	11/5/19	15:53	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2423	PG&E	11/6/19	18:13	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2424	PG&E	11/7/19	10:48	Equipment - PG&E	Lightning Arrestor				
2425	PG&E	11/8/19	7:22	Equipment - PG&E	Conductor				
2426	PG&E	11/9/19	22:02	Vegetation		Veg. contact	Electric Facility		
2427	PG&E	11/10/19	9:47	Contact - Animal - Bird		Animal contact		Animal Contact	
2428	PG&E	11/11/19	6:52	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2429	PG&E	11/11/19	9:46	Contact - 3rd Party		Vehicle contact	Electric Facility	Human Error	
2430	PG&E	11/13/19	15:43	Contact - Animal - Bird		Animal contact	Pole	Animal Contact	
2431	PG&E	11/13/19	17:26	Equipment - PG&E	Capacitor Bank				
2432	PG&E	11/15/19	2:55	Unknown					
2433	PG&E	11/15/19	4:10	Contact - 3rd Party		Contact from Object - O	Electric Facility	Human Error	
2434	PG&E	11/16/19	7:16	Equipment - PG&E	Conductor				
2435	PG&E	11/17/19	7:38	Vegetation		Veg. contact	Electric Facility		
2436	PG&E	11/18/19	15:38	Contact - 3rd Party		Vehicle contact	Electric Facility	Human Error	
2437	PG&E	11/20/19	12:31	Vegetation		Veg. contact	Electric Facility		
2438	PG&E	11/21/19	10:25	Equipment - PG&E	Other				
2439	PG&E	11/21/19	16:26	Vegetation		Veg. contact	Electric Facility		
2440	PG&E	11/22/19	5:57	Equipment - PG&E	Conductor				
2441	PG&E	11/22/19	4:43	Vegetation		Veg. contact			
2442	PG&E	11/25/19	16:42	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2443	PG&E	11/26/19	14:18	Equipment - PG&E	Other				

	A	B	C	S	T	U	V	W	X
1	Utility Name	Fire Start	Column1	Field Observations	Column13	Column14	Column15	Column16	Notes
2		Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
2444	PG&E	11/27/19	15:39	Other Fire: Non-PG&E related					
2445	PG&E	11/27/19	6:37	Vegetation		Veg. contact	Electric Facility		
2446	PG&E	11/29/19	20:18	Equipment - PG&E	Pole				
2447	PG&E	12/12/19	13:44	Equipment - PG&E	Transformer				
2448	PG&E	12/17/19	13:44	Contact - Animal - Bird		Animal contact	Electric Facility	Animal Contact	
2449	PG&E	12/18/19	5:25	Vegetation		Veg. contact	Pole		
2450	PG&E	12/23/19	22:49	Contact - 3rd Party		Other	Pole	Human Error	
2451	PG&E	12/29/19	0:58	Equipment - PG&E	Conductor				