MASTER COPY

Biomedical Limited, No 1 Ohimege Road, Industrial Estate, Ilorin Kwara State, PMB 1449.

RAW WATER ANALYSIS RECORD BOOK

DOC. NO.: BML/QA/24/RW001 **SOP. REF. NO.:** BML/QDF/CL/016

Sampling point: Borehole 1, overhead tank, Borehole 2, Sand filter and Carbon filter

QC AR NO: QC/WAR/24/

Date: /2024

Time:

Parameters	Limits	Borehole 1	Overhead tank	Borehole 2	Sand Filter	Carbon Filter
Description	Clear, Colourless, odourless, tasteless					
pH	6.5-8.5					
Conductivity	≤ 400µs					
Acidity/Alkalinity	≤ 1.5ml of NaOH/HCl					
Total Hardness	NMT 500ppm					
Chlorides	≤ 150ppm					
Sulphates	≤ 150ppm					
Nitrates	≤ 0.2ppm					
Heavy Metals	≤ 0.1ppm					
Oxidizable Substances	Faintly pink					
TDS	≤ 400ppm					

Sampling point: Post Softener 1, Post Softener 2, Post DM

Parameters	Limits	Post Softener 1	Post Softener 2	**Limits**	Post DM
Description	Colourless, odourless, tasteless			Colourless, odourless, tasteless	
pH	6.5-8.5			6.0 – 7.5	
Conductivity	≤ 300µs			≤ 10µs	
Acidity/Alkalinity	≤ 1.5ml of NaOH/HCl			≤1.0ml of 0.01M NaOH/HCl	
Total Hardness	NMT 500ppm			NMT 500ppm	
Chlorides	≤ 100ppm			≤50ppm	
Sulphates	≤ 50ppm			≤50ppm	
Nitrates	≤ 0.2ppm			≤ 0.2ppm	
Heavy Metals	≤ 0.1ppm			≤ 0.1ppm	
Oxidizable Substances	Faintly pink			Faintly Pink	
TDS	≤ 100ppm			≤ 50ppm	

Note: TDS: Total Dissolved Solid BDL: Below Detectable Limit

Quality Control Chemist *QC Head/ QA Manager*

CONTROL COPY