MASTER COPY

biomedical Limited pioneer manufacturers of intravenous fluids	BIOMEDICAL LIMITED, NO 1 OHIMEGE ROAD, INDUSTRIAL ESTATE, ILORIN KWARA STATE, PMB 1499 WATER FOR INJECTION CERTIFICATE OF ANALYSIS **BML/QA/STP/WT/001/F02**

Water for Injection	Reference : BP 2023/NIS 554:2007
Analysis Date : /2024	Analysis complete Date: 2024
Sampling point: WFI Storage Tank	Volume sampled: 500ml
Sampled by:	Analysed by:
Q.C Ref. No: QC/WFI/24/	

S/No.	Test	Specification	Result
1.	Description	Clear, colourless, odourless, tasteless liquid	
2.	pH	5.0– 7.0	
3.	Conductivity	≤ 1.3µs/cm^3@ 25^{0}c	
4.	Acidity /Alkalinity	NMT 0.1ml of 0.01M HCL/NaOH is required to change the colour of indicator to pink.	
5.	Total hardness	Blue colour is produced	
6.	Limit test for chlorides	No change in appearance after 15min	
7.	Limit test for sulphates	Solution shows no change in appearance after 1 h	
8.	Limit test for Nitrate	Blue colour not more intensely coloured than standard	
9.	Limit test for Ammonium	≤0.2ppm	
10.	Limit test for Aluminium	Must Conform: 10ppb	
11.	Residue on Evaporation	≤0.003%	
12.	TOC	NMT 500µg/L	
13.	Oxidisable substance	The colour remains faintly pink on boiling for five minutes	
14.	Bacteria Endotoxin	≤0.25EU/ml	
15.	Total Bacteria count Total Yeast/ Moulds count Pathogens	00 CFU/ML 00 CFU/ML Must be absent	

NMT= Not More Than, EU/ml = Endotoxin units per millilitre, ml = millilitre, CFU/ml = Colony Forming Unit per millilitre, µg/L=microgram per litre, ppb= part per billion, µs/cm^3= microsiemens per cube centimetre

CHECKER's VERDICT (box option) : **RELEASED / FAILED / HOLD / REPEAT**
Remark:

Analyst(chemist):	Analyst(microbiologist):	Reviewed By: QCH	Approved By: QAM
Sign:	Sign:	Sign:	Sign:
Date:	Date:	Date:	Date:

CONTROL COPY