MASTER COPY

Biomedical Limited, No 1 Ohimege Road, Industrial Estate, Ilorin
Kwara State, PMB 1449.

WFI ANALYSIS RECORD BOOK

Doc. No.: BML/QA/24/WRB/001
SOP Ref No: BML/QDF/CL/016

Sampling point: WFI storage tank

QC AR NO: QC/WFI/24/

Date: /2024

Time:

Parameters	Limits	Results
pH	5.0 – 7.0	
Conductivity	≤1.3µS	
Acidity & Alkalinity	0.1mL NaOH/0.15mL HCl to changes the colour	
Total hardness	Blue colour is produced	
Chlorides	No change in appearance after 15min	
Residue on Evaporation	≤0.003%	
Nitrates	Blue colour not more intensely coloured than standard	
TOC	NMT 500µg/L	
Oxidizable Substance	Solution remains faintly pink	
Sulphate	Solution shows no change in appearance after 1 h	
Aluminium	Must Conform: 10ppb	
Ammonium	≤ 0.2ppm	

Time:

Parameters	Limits	Results
pH	5.0 – 7.0	
Conductivity	≤1.3µS	
Acidity & Alkalinity	0.1mL NaOH/0.15mL HCl to change the colour	
Total hardness	Blue colour is produced	
Chlorides	No change in appearance after 15min	
Residue on Evaporation	≤0.003%	
Nitrates	Blue colour not more intensely coloured than standard	
TOC	NMT 500µg/L	
Oxidizable Substance	Solution remains faintly pink	
Sulphate	Solution shows no change in appearance after 1 h	
Heavy Metals	Must Conform: 10ppb	
Ammonium	≤ 0.2ppm	

Quality Control Chemist

QC Head/QA Manager

CONTROL COPY