MASTER COPY

Biomedical Limited. No 1 Ohimege Road, Industrial Estate, Ilorin, Kwara State. PMB 1449.

MCDP WATER ANALYSIS RECORD SHEET

Sampling point: MCDP
QC AR NO: QC/MCDP/26/

Doc. No: BML/QA/26/MCDP001
SOP Ref No: BML/QDF/CL/016

Date:

Parameters	Limits	Results
pH	5.0 – 7.0	
Conductivity	≤1.3µS/cm	
Acidity & Alkalinity	0.1mL NaOH/0.15mL HCl to changes the colour	
Total hardness	Blue colour is produced	
Chlorides	No change in appearance after 15min	
Residues on evaporation	≤0.003%	
Nitrates	Any blue colour not more intensely coloured than standard	
TOC	NMT 500µg/L	
Oxidizable Substance	Solution remains faintly pink	
Sulphate	Solution shows no change in appearance after 1 h	
Aluminium	Must Conform: 10ppb	
Ammonium	≤ 0.2ppm	

Sampling point: MCDP
QC AR NO: QC/MCDP/26/

Doc. No: BML/QA/26/MCDP001
SOP Ref No: BML/QDF/CL/016

Date:

Parameters	Limits	Results
pH	5.0 – 7.0	
Conductivity	≤1.3µS/cm	
Acidity & Alkalinity	0.1mL NaOH/0.15mL HCl to changes the colour	
Total hardness	Blue colour is produced	
Chlorides	No change in appearance after 15min	
Residues on evaporation	≤0.003%	
Nitrates	Any blue colour not more intensely coloured than standard	
TOC	NMT 500µg/L	
Oxidizable Substance	Solution remains faintly pink	
Sulphate	Solution shows no change in appearance after 1 h	
Aluminium	Must Conform: 10ppb	
Ammonium	≤ 0.2ppm	

Quality Control Chemist

QC Head/QA Manager

CONTROL COPY