MASTER COPY

biomedical Limited pioneer manufacturers of intravenous fluids	**BIOMEDICAL LIMITED, NO 1 OHIMEGE ROAD, INDUSTRIAL ESTATE, ILORIN KWARA STATE, PMB 1499** **DEMINERALIZED WATER CERTIFICATE OF ANALYSIS** **BML/QA/STP/WT/002/F02**

Demineralized Water	Reference: BP 2025
Analysis Date: /2026	Analysis complete Date: /2026
Sampling point: DM Storage Tank	Volume sampled: 2000ml
Sampled by:	Analysed by:
Q.C Ref. No: QC/DM/26/SYP/	

S/NO	TEST	SPECIFICATION	RESULT
1	Description	Clear, colourless, odourless, tasteless liquid	
2	pH	5.5 – 7.5	
3	Conductivity	≤5.1µS/cm at 25°C	
4	Acidity/Alkalinity	≤0.5mL of 0.01M NaOH/HCl is required to change the colour of the indicator to pink	
5	Total Hardness	≤5ppm	
6	Limit test for Chlorides	≤0.2ppm	
7	Limit test for Sulphates	The turbidity produced in test solution for at least 1 hour should not be greater than standard solution	
8	Limit test for Nitrates	≤0.2ppm	
9	Limit test for Ammonium	≤0.2ppm	
10	Limit test for Heavy Metals	≤0.1ppm	
11	Total Dissolved Solid	≤50ppm	
12	Residue on evaporation	≤0.003%	
13	Oxidisable substances	The colour remains faintly pink	
14	Total Bacteria count Total Yeast/ Mould count Pathogens	10^2 cfu/mL 10^2 cfu/mL Must be absent	

≤ = Less Than or Equal to, ml = millilitre, CFU/ml = Colony Forming Unit per millilitre, ppm= part per million, µs/cm= microsiemens per centimetre

CHECKER's VERDICT (box option): **RELEASED / FAILED / HOLD / REPEAT**
Remark:

Analyst(chemist):	**Analyst(microbiologist):**	**Reviewed By: QCH**	**Approved By: QAM**
Sign:	**Sign:**	**Sign:**	**Sign:**
Date:	**Date:**	**Date:**	**Date:**

CONTROL COPY

MASTER COPY

biomedical Limited pioneer manufacturers of intravenous fluids	BIOMEDICAL LIMITED, NO 1 OHIMEGE ROAD, INDUSTRIAL ESTATE, ILORIN KWARA STATE, PMB 1499 DEMINERALIZED WATER CERTIFICATE OF ANALYSIS **BML/QA/STP/WT/002/F02**

Analyst(chemist):	Analyst(microbiologist):	Reviewed By: QCH	Approved By: QAM
Sign:	Sign:	Sign:	Sign:
Date:	Date:	Date:	Date:

CONTROL COPY