	Biomedical Limited, No 1 Ohimege Road, Industrial Estate, Ilorin Kwara State, PMB 1449			MASTER COPY STAMP HERE
	Title: **Standard Operating Procedure for Cleaning Air Handling Unit Pre-Filter/Foam**			
Department	**Unit**	**BML-ENG-NG-007**	**Revision No.:**	02
			Effective Date:	**April, 2025**
ENGINEERING	ENGINEERING GENERAL		**Next Review Date:**	**March, 2027**

Prepared By:	**Checked By:**	**Approved By:**
sign/date	**sign/date**	**sign/date**

1.0 PURPOSE: This SOP established the procedure for cleaning the fan filter unit foam.

2.0 SCOPE: This SOP applies to all trained and qualified biomedical limited staff and contractors cleaning the fan filter unit foam.

3.0 RESPONSIBILITY:

- It is the responsibility of any qualified personnel
- It is the responsibility of Biomedical Limited to provide the PPE for the qualified employee performing the task
- It is the responsibility of contactors to provide the PPE for their qualified staff
- It is the responsibility of the Engineering head to ensure that the SOP is strictly followed

4.0 ABBREVIATIONS AND DEFINITION

PPE – Personnel Protective Equipment

SOP – Standard Operating Procedure

5.0 PROCEDURE:

POTENTIAL RISK: Shock, burn, fall

Procedure:

- Gain access to the fan filter unit safely
- Disconnect the unit from electrical power source before attempting any service. The standard filter is protected with an expanded metal face screen. This is never to be used to handle the filter. It is only for protection against an accidental touch of the filter. Only handle the filter by the frame.
- Un-hooks the expanded metal face screen completely with the foam from the filter unit
- Remove the prefilter from the expanded metal face screen.
- Clean the prefilter by hand washing in water with mild detergent or by using a vacuum cleaner. Allow prefilter to dry before replacing it.
- Reassemble by reversing the above steps

- NOTE: To keep the filter in top operating condition, washing prefilter foam is recommended every two weeks.
- Update the prefilter Cleaning and inspection checklist

6.0 REFERENCES AND ENCLOSURE:

Nil

7.0 TRAINING INVOLVEMENT:

All Engineering staff
All machine Operators

8.0 DISTRIBUTION AND COPY CONTROL:

- This is the various department/section where the SOP copies will be utilized.

MASTER COPY	QUALITY
CONTROLLED COPY	QUALITY, ENGINEERING, PRODUCTION

9.0 CHANGE HISTORY:

CURRENT REVISION	SUPERSEDE	REASON FOR REVIEW
00	Nil	First issue
01	00	To Update
02	01	• Change in sop format. Inclusion of traceability of enclosures to parent SOP