LINKWARE™ PC
CABLE TEST MANAGEMENT SOFTWARE

Cable ID	Summary	Test Limit	Length	Headroom	Date / Time
Fiber To Data Center 1	PASS	TIA-568-C Multimode	50.3 m	6.03 dB (Loss Margin)	12/22/2020 11:32 PM
Fiber To Data Center 2	PASS	TIA-568-C Multimode	50.3 m	5.29 dB (Loss Margin)	12/22/2020 11:32 PM
Fiber To Data Center 3	PASS	TIA-568-C Multimode	50.1 m	5.93 dB (Loss Margin)	12/22/2020 11:33 PM
Fiber To Data Center 4	PASS	TIA-568-C Multimode	50.1 m	5.38 dB (Loss Margin)	12/22/2020 11:33 PM

FLUKE networks

Total Length:	200.8 m
Number of Reports:	4
Number of Passing Reports:	4
Number of Failing Reports:	0
Number of Warning Reports:	0
Documentation Only:	0

LINKWARE™ PC
CABLE TEST MANAGEMENT SOFTWARE

Cable ID: Fiber To Data Center 1

Test Summary: PASS

Date / Time: 12/22/2020 11:32:46 PM
Cable Type: OM2 Multimode 50

n = 1.483500 (850 nm)
n = 1.478500 (1300 nm)

Modal Bandwidth: 500MHz-km

Loss (R->M)

PASS

Date / Time: 12/22/2020 11:32:46 PM
Test Limit: TIA-568-C Multimode
Limits Version: 1.9300
Operator: STS
DTX-1800 (1246007 v2.7400)
Module: DTX-MFM2(1244325)
Calibration Date: 03/03/2010
DTX-1800R (1246008 v2.7400)
Module: DTX-MFM2(1244302)
Calibration Date: 03/03/2010

Propagation Delay (ns)	248	
Length m	50.3	PASS
Limit 2000.0		
	850 nm	1300 nm
Result	PASS	PASS
Loss (dB)	0.55	0.65
Limit (dB)	6.78	6.68
Margin (dB)	6.23	6.03
Reference (dBm)	-23.97	-23.85

Number of Adapters: 8
Number of Splices: 2
Patch Type: OM2 Multimode 50
Patch Length1 (m): 1.0
Patch Length2 (m): 1.0
Reference Date: 12/22/2020 11:06:51 PM
2 Jumper

Compliant Network Standards:

10/100BASE-SX	1000BASE-LX	1000BASE-SX
100BASE-FX	10BASE-FL	10GBASE-LRM
10GBASE-LX4	10GBASE-SR	ATM155
ATM155SWL	ATM52	ATM622 Fiber Optic
ATM622SWL Fiber Optic	FDDI Fiber Optic	Fibre Channel 100-M5-SN-I
Fibre Channel 100-M5E-SN-I	Fibre Channel 1200-M5-SN-I	Fibre Channel 1200-M5E-SN-I
Fibre Channel 133	Fibre Channel 200-M5-SN-I	Fibre Channel 200-M5E-SN-I
Fibre Channel 266	Fibre Channel 266SWL	Fibre Channel 400-M5-SN-I

Project: MOI
Floor: Sixth Floor
Patch: Fiber

MOI.flw
Rack: Cabinet 2

FLUKE networks

LINKWARE™ PC
CABLE TEST MANAGEMENT SOFTWARE

Cable ID: Fiber To Data Center 2

Test Summary: PASS

Date / Time: 12/22/2020 11:32:46 PM
Cable Type: OM2 Multimode 50

n = 1.483500 (850 nm)
n = 1.478500 (1300 nm)

Modal Bandwidth: 500MHz-km

Loss (M->R)

PASS

Date / Time: 12/22/2020 11:32:46 PM
Test Limit: TIA-568-C Multimode
Limits Version: 1.9300
Operator: STS
DTX-1800 (1246007 v2.7400)
Module: DTX-MFM2(1244325)
Calibration Date: 03/03/2010
DTX-1800R (1246008 v2.7400)
Module: DTX-MFM2(1244302)
Calibration Date: 03/03/2010

Propagation Delay (ns)	248	
Length m	50.3	PASS
Limit 2000.0		
	850 nm	1300 nm
Result	PASS	PASS
Loss (dB)	1.03	1.39
Limit (dB)	6.78	6.68
Margin (dB)	5.75	5.29
Reference (dBm)	-24.53	-23.97

Number of Adapters: 8
Number of Splices: 2
Patch Type: OM2 Multimode 50
Patch Length1 (m): 1.0
Patch Length2 (m): 1.0
Reference Date: 12/22/2020 11:06:51 PM
2 Jumper

Compliant Network Standards:

10/100BASE-SX	1000BASE-LX	1000BASE-SX
100BASE-FX	10BASE-FL	10GBASE-LRM
10GBASE-LX4	10GBASE-SR	ATM155
ATM155SWL	ATM52	ATM622 Fiber Optic
ATM622SWL Fiber Optic	FDDI Fiber Optic	Fibre Channel 100-M5-SN-I
Fibre Channel 100-M5E-SN-I	Fibre Channel 1200-M5-SN-I	Fibre Channel 1200-M5E-SN-I
Fibre Channel 133	Fibre Channel 200-M5-SN-I	Fibre Channel 200-M5E-SN-I
Fibre Channel 266	Fibre Channel 266SWL	Fibre Channel 400-M5-SN-I

Project: MOI
Floor: Sixth Floor
Patch: Fiber

MOI.flw
Rack: Cabinet 2

FLUKE networks

LINKWARE™ PC
CABLE TEST MANAGEMENT SOFTWARE

Cable ID: Fiber To Data Center 3

Test Summary: PASS

Date / Time: 12/22/2020 11:33:21 PM
Cable Type: OM2 Multimode 50

n = 1.483500 (850 nm)
n = 1.478500 (1300 nm)

Modal Bandwidth: 500MHz-km

Loss (R->M)

PASS

Date / Time: 12/22/2020 11:33:21 PM
Test Limit: TIA-568-C Multimode
Limits Version: 1.9300
Operator: STS
DTX-1800 (1246007 v2.7400)
Module: DTX-MFM2(1244325)
Calibration Date: 03/03/2010
DTX-1800R (1246008 v2.7400)
Module: DTX-MFM2(1244302)
Calibration Date: 03/03/2010

Propagation Delay (ns)	247	
Length m	50.1	PASS
Limit 2000.0		
	850 nm	1300 nm
Result	PASS	PASS
Loss (dB)	0.68	0.75
Limit (dB)	6.78	6.68
Margin (dB)	6.10	5.93
Reference (dBm)	-23.97	-23.85

Number of Adapters: 8
Number of Splices: 2
Patch Type: OM2 Multimode 50
Patch Length1 (m): 1.0
Patch Length2 (m): 1.0
Reference Date: 12/22/2020 11:06:51 PM
2 Jumper

Compliant Network Standards:

10/100BASE-SX	1000BASE-LX	1000BASE-SX
100BASE-FX	10BASE-FL	10GBASE-LRM
10GBASE-LX4	10GBASE-SR	ATM155
ATM155SWL	ATM52	ATM622 Fiber Optic
ATM622SWL Fiber Optic	FDDI Fiber Optic	Fibre Channel 100-M5-SN-I
Fibre Channel 100-M5E-SN-I	Fibre Channel 1200-M5-SN-I	Fibre Channel 1200-M5E-SN-I
Fibre Channel 133	Fibre Channel 200-M5-SN-I	Fibre Channel 200-M5E-SN-I
Fibre Channel 266	Fibre Channel 266SWL	Fibre Channel 400-M5-SN-I

Project: MOI
Floor: Sixth Floor
Patch: Fiber

MOI.flw
Rack: Cabinet 2

FLUKE networks

LINKWARE™ PC
CABLE TEST MANAGEMENT SOFTWARE

Cable ID: Fiber To Data Center 4

Test Summary: PASS

Date / Time: 12/22/2020 11:33:21 PM
Cable Type: OM2 Multimode 50

n = 1.483500 (850 nm)
n = 1.478500 (1300 nm)

Modal Bandwidth: 500MHz-km

Loss (M->R)

PASS

Date / Time: 12/22/2020 11:33:21 PM
Test Limit: TIA-568-C Multimode
Limits Version: 1.9300
Operator: STS
DTX-1800 (1246007 v2.7400)
Module: DTX-MFM2(1244325)
Calibration Date: 03/03/2010
DTX-1800R (1246008 v2.7400)
Module: DTX-MFM2(1244302)
Calibration Date: 03/03/2010

Propagation Delay (ns)	247	
Length m	50.1	PASS
Limit 2000.0		
	850 nm	1300 nm
Result	PASS	PASS
Loss (dB)	0.89	1.30
Limit (dB)	6.78	6.68
Margin (dB)	5.89	5.38
Reference (dBm)	-24.53	-23.97

Number of Adapters: 8
Number of Splices: 2
Patch Type: OM2 Multimode 50
Patch Length1 (m): 1.0
Patch Length2 (m): 1.0
Reference Date: 12/22/2020 11:06:51 PM
2 Jumper

Compliant Network Standards:

10/100BASE-SX	1000BASE-LX	1000BASE-SX
100BASE-FX	10BASE-FL	10GBASE-LRM
10GBASE-LX4	10GBASE-SR	ATM155
ATM155SWL	ATM52	ATM622 Fiber Optic
ATM622SWL Fiber Optic	FDDI Fiber Optic	Fibre Channel 100-M5-SN-I
Fibre Channel 100-M5E-SN-I	Fibre Channel 1200-M5-SN-I	Fibre Channel 1200-M5E-SN-I
Fibre Channel 133	Fibre Channel 200-M5-SN-I	Fibre Channel 200-M5E-SN-I
Fibre Channel 266	Fibre Channel 266SWL	Fibre Channel 400-M5-SN-I

Project: MOI
Floor: Sixth Floor
Patch: Fiber

MOI.flw
Rack: Cabinet 2

FLUKE networks