Cable ID	Summary	Test Limit	Length	Headroom	Date / Time
Old Network1	N/A	TIA Cat 6 Channel	17.6 m	N/A	12/22/2020 08:11 PM
Old Network2	N/A	TIA Cat 6 Channel	18.7 m	N/A	12/22/2020 08:12 PM
Old Network3	N/A	TIA Cat 6 Channel	16.1 m	N/A	12/22/2020 08:12 PM
Old Network4	N/A	TIA Cat 6 Channel	20.9 m	N/A	12/22/2020 08:13 PM
Old Network5	N/A	TIA Cat 6 Channel	22.8 m	N/A	12/22/2020 08:32 PM
Old Network6	N/A	TIA Cat 6 Channel	23.0 m	N/A	12/22/2020 08:32 PM
Old Network7	N/A	TIA Cat 6 Channel	24.9 m	N/A	12/22/2020 10:16 PM
Old Network8	N/A	TIA Cat 6 Channel	25.6 m	N/A	12/22/2020 10:17 PM
Old Network9	N/A	TIA Cat 6 Channel	22.1 m	N/A	12/22/2020 10:33 PM

Total Length:	191.7 m
Number of Reports:	9
Number of Passing Reports:	0
Number of Failing Reports:	0
Number of Warning Reports:	0
Documentation Only:	9

LINKWARE™PC
CABLE TEST MANAGEMENT SOFTWARE

Cable ID: Old Network1


Date / Time: 12/22/2020 08:11:03 PM
Test Limit: TIA Cat 6 Channel
Cable Type: Cat 6 FTP
NVP: 71.7%

Operator: STS
Software Version: 2.7400
Limits Version: 1.9300
Calibration Date:
Main (Tester): 03/04/2010
Remote (Tester): 03/04/2010


Test Summary: N/A

Model: DTX-1800
Main S/N: 1246007
Remote S/N: 1246008
Main Adapter: DTX-PLA002
Remote Adapter: DTX-CHA002

Length (m)		N/A
Prop. Delay (ns)	[Pair 1,2]	86
Delay Skew (ns)	[Pair 1,2]	4
Resistance (ohms)	[Pair 1,2]	3.5



Wire Map (T568B)
FAIL



LinkWare™ PC Version 10.4

Project: MOI
Floor: Sixth Floor
Patch: Old Network

MOI.flw
Rack: Cabinet 2

FLUKE networks

LINKWARE™PC
CABLE TEST MANAGEMENT SOFTWARE

Cable ID: Old Network2


Date / Time: 12/22/2020 08:12:04 PM
Test Limit: TIA Cat 6 Channel
Cable Type: Cat 6 FTP
NVP: 71.7%

Operator: STS
Software Version: 2.7400
Limits Version: 1.9300
Calibration Date:
Main (Tester): 03/04/2010
Remote (Tester): 03/04/2010


Test Summary: N/A

Model: DTX-1800
Main S/N: 1246007
Remote S/N: 1246008
Main Adapter: DTX-PLA002
Remote Adapter: DTX-CHA002

Length (m)		N/A
Prop. Delay (ns)	[Pair 1,2]	90
Delay Skew (ns)	[Pair 1,2]	3
Resistance (ohms)	[Pair 1,2]	3.7



Wire Map (T568B)
FAIL



LinkWare™ PC Version 10.4

Project: MOI
Floor: Sixth Floor
Patch: Old Network

MOI.flw
Rack: Cabinet 2

FLUKE networks

LINKWARE™PC
CABLE TEST MANAGEMENT SOFTWARE

Cable ID: Old Network3


Test Summary: N/A

Date / Time: 12/22/2020 08:12:43 PM
Test Limit: TIA Cat 6 Channel
Cable Type: Cat 6 FTP
NVP: 71.7%


Operator: STS
Software Version: 2.7400
Limits Version: 1.9300
Calibration Date:
Main (Tester): 03/04/2010
Remote (Tester): 03/04/2010

Model: DTX-1800
Main S/N: 1246007
Remote S/N: 1246008
Main Adapter: DTX-PLA002
Remote Adapter: DTX-CHA002

Length (m)		N/A
Prop. Delay (ns)	[Pair 1,2]	78
Delay Skew (ns)	[Pair 1,2]	3
Resistance (ohms)	[Pair 7,8]	3.3



Wire Map (T568B)
FAIL



LinkWare™ PC Version 10.4

Project: MOI
Floor: Sixth Floor
Patch: Old Network

MOI.flw
Rack: Cabinet 2

FLUKE networks

LINKWARE™PC
CABLE TEST MANAGEMENT SOFTWARE

Cable ID: Old Network4


Date / Time: 12/22/2020 08:13:32 PM
Test Limit: TIA Cat 6 Channel
Cable Type: Cat 6 FTP
NVP: 71.7%

Operator: STS
Software Version: 2.7400
Limits Version: 1.9300
Calibration Date:
Main (Tester): 03/04/2010
Remote (Tester): 03/04/2010


Test Summary: N/A

Model: DTX-1800
Main S/N: 1246007
Remote S/N: 1246008
Main Adapter: DTX-PLA002
Remote Adapter: DTX-CHA002

Length (m)		N/A
Prop. Delay (ns)	[Pair 3,6]	100
Delay Skew (ns)	[Pair 3,6]	3
Resistance (ohms)	[Pair 7,8]	4.2



Wire Map (T568B)
FAIL



LinkWare™ PC Version 10.4

Project: MOI
Floor: Sixth Floor
Patch: Old Network

MOI.flw
Rack: Cabinet 2

FLUKE networks

LINKWARE™PC
CABLE TEST MANAGEMENT SOFTWARE

Cable ID: Old Network5


Date / Time: 12/22/2020 08:32:12 PM
Test Limit: TIA Cat 6 Channel
Cable Type: Cat 6 FTP
NVP: 71.7%

Operator: STS
Software Version: 2.7400
Limits Version: 1.9300
Calibration Date:
Main (Tester): 03/04/2010
Remote (Tester): 03/04/2010


Test Summary: N/A

Model: DTX-1800
Main S/N: 1246007
Remote S/N: 1246008
Main Adapter: DTX-PLA002
Remote Adapter: DTX-CHA002

Length (m)		N/A
Prop. Delay (ns)	[Pair 1,2]	110
Delay Skew (ns)	[Pair 1,2]	4
Resistance (ohms)	[Pair 1,2]	4.4



Wire Map (T568B)
FAIL



Project: MOI
Floor: Sixth Floor
Patch: Old Network

MOI.flw
Rack: Cabinet 2

FLUKE networks

LINKWARE™PC
CABLE TEST MANAGEMENT SOFTWARE

Cable ID: Old Network6


Date / Time: 12/22/2020 08:32:31 PM
Test Limit: TIA Cat 6 Channel
Cable Type: Cat 6 FTP
NVP: 71.7%

Operator: STS
Software Version: 2.7400
Limits Version: 1.9300
Calibration Date:
Main (Tester): 03/04/2010
Remote (Tester): 03/04/2010


Test Summary: N/A

Model: DTX-1800
Main S/N: 1246007
Remote S/N: 1246008
Main Adapter: DTX-PLA002
Remote Adapter: DTX-CHA002

Length (m)		N/A
Prop. Delay (ns)	[Pair 1,2]	111
Delay Skew (ns)	[Pair 1,2]	4
Resistance (ohms)	[Pair 1,2]	4.4



Wire Map (T568B)
FAIL



Project: MOI
Floor: Sixth Floor
Patch: Old Network

MOI.flw
Rack: Cabinet 2

FLUKE networks

LINKWARE™PC
CABLE TEST MANAGEMENT SOFTWARE

Cable ID: Old Network7


Test Summary: N/A

Date / Time: 12/22/2020 10:16:50 PM
Test Limit: TIA Cat 6 Channel
Cable Type: Cat 6 FTP
NVP: 71.7%


Operator: STS
Software Version: 2.7400
Limits Version: 1.9300
Calibration Date:
Main (Tester): 03/04/2010
Remote (Tester): 03/04/2010

Model: DTX-1800
Main S/N: 1246007
Remote S/N: 1246008
Main Adapter: DTX-PLA002
Remote Adapter: DTX-CHA002

Length (m)		N/A
Prop. Delay (ns)	[Pair 1,2]	122
Delay Skew (ns)	[Pair 1,2]	6
Resistance (ohms)	[Pair 1,2]	4.7



Wire Map (T568B)
FAIL



LinkWare™ PC Version 10.4

Project: MOI
Floor: Sixth Floor
Patch: Old Network

MOI.flw
Rack: Cabinet 2

FLUKE networks

LINKWARE™PC
CABLE TEST MANAGEMENT SOFTWARE

Cable ID: Old Network8


Test Summary: N/A

Date / Time: 12/22/2020 10:17:54 PM
Test Limit: TIA Cat 6 Channel
Cable Type: Cat 6 FTP
NVP: 71.7%


Operator: STS
Software Version: 2.7400
Limits Version: 1.9300
Calibration Date:
Main (Tester): 03/04/2010
Remote (Tester): 03/04/2010

Model: DTX-1800
Main S/N: 1246007
Remote S/N: 1246008
Main Adapter: DTX-PLA002
Remote Adapter: DTX-CHA002

Length (m)		N/A
Prop. Delay (ns)	[Pair 1,2]	124
Delay Skew (ns)	[Pair 1,2]	5
Resistance (ohms)	[Pair 1,2]	4.8



Wire Map (T568B)
FAIL



LinkWare™ PC Version 10.4

Project: MOI
Floor: Sixth Floor
Patch: Old Network

MOI.flw
Rack: Cabinet 2

FLUKE networks

LINKWARE™PC
CABLE TEST MANAGEMENT SOFTWARE

Cable ID: Old Network9


Test Summary: N/A

Date / Time: 12/22/2020 10:33:59 PM
Test Limit: TIA Cat 6 Channel
Cable Type: Cat 6 FTP
NVP: 71.7%


Operator: STS
Software Version: 2.7400
Limits Version: 1.9300
Calibration Date:
Main (Tester): 03/04/2010
Remote (Tester): 03/04/2010

Model: DTX-1800
Main S/N: 1246007
Remote S/N: 1246008
Main Adapter: DTX-PLA002
Remote Adapter: DTX-CHA002

Length (m)		N/A
Prop. Delay (ns)	[Pair 1,2]	108
Delay Skew (ns)	[Pair 1,2]	5
Resistance (ohms)	[Pair 1,2]	4.2



Wire Map (T568B)
FAIL



LinkWare™ PC Version 10.4

Project: MOI
Floor: Sixth Floor
Patch: Old Network

MOI.flw
Rack: Cabinet 2

FLUKE networks