Water Quality Analysis Report

Sample ID WQ-0142-A
Collected 4 February 2026, 09:40
Site Treatment works outlet, Cedar Hill
Analyst K. Brandt
Method Standard methods, 24th edition

1. Summary

All parameters measured were within the limits set by the drinking-water regulations. The sample was received in good condition and analysed within 24 hours of collection.

2. Results

Parameter	Result	Unit	Limit	Status
pH	7.42	-	6.5 to 9.5	Pass
Turbidity	0.8	NTU	1.0	Pass
Conductivity	612	µS/cm	2500	Pass
Nitrate	38.2	mg/L	50	Pass
Nitrite	<0.05	mg/L	0.5	Pass
Ammonium	0.31	mg/L	0.5	Pass
Iron	142	µg/L	200	Pass
Lead	4.1	µg/L	10	Pass
Coliform bacteria	0	per 100 mL	0	Pass
E. coli	0	per 100 mL	0	Pass

Interpretation

Nitrate is the highest value relative to its limit, at 76 percent. Iron and lead are well below their limits. No indicator organisms were detected.

Recommendations

- Repeat nitrate testing in the spring.
- Keep the monthly iron check in the routine programme.
- File this report with the works register.

3. Calculation

Total hardness was calculated from the calcium and magnesium results:

```
Hardness (mg/L CaCO3) = 2.497 * Ca + 4.118 * Mg
Ca = 62.4 mg/L, Mg = 11.8 mg/L  ->  204.4 mg/L
```

This report relates only to the sample received and may not be reproduced except in full.