Fernhill Analytical Laboratories
Accredited testing laboratory No. 4471

Unit 9, Brookside Science Park, Fernhill FH2 6LQ
lab@fernhill-analytical.example · 01632 960 552

Water Quality Test Report

Client details	
Client	Ashgrove Farm Holidays
Address	Ashgrove Lane, Upper Wyke UW3 8NB
Contact	Site manager
Order no.	AFH-0926

Sample details	
Sample ID	WQ-26-1187-01
Source	Private borehole, kitchen tap
Collected	14 Oct 2026, 09:40
Received	14 Oct 2026, 13:15
Condition	Chilled, intact seal

The sample was analysed in the condition in which it was received. Results relate only to the sample tested and are compared with the limits for drinking water supplies.

Results

Parameter	Method	Result	Unit	Limit	Assessment
Microbiological					
Escherichia coli	ISO 9308-1 membrane filtration	0	cfu/100 ml	0	Complies
Coliform bacteria	ISO 9308-1 membrane filtration	**3**	cfu/100 ml	0	**Does not comply (see remark 1)**
Chemical					
Nitrate (as NO3)	Ion chromatography	38.2	mg/l	50	Complies
Iron	ICP-OES	**0.41**	mg/l	0.20	**Does not comply (see remark 2)**
Manganese	ICP-OES	0.032	mg/l	0.050	Complies
Fluoride	Ion-selective electrode	0.6	mg/l	1.5	Complies
Physical					
pH at 20 °C	Electrometric	**6.4**	pH units	6.5 – 9.5	**Does not comply (see remark 3)**
Turbidity	Nephelometric	2.8	NTU	4	Complies

Remarks

1. Coliform bacteria were detected while E. coli was absent, which points to surface ingress rather than faecal contamination.
2. Iron above the indicator value can stain sanitary ware and laundry.
3. Slightly acidic water can dissolve copper and lead from older pipework.

Interpretation

The sample does not meet the drinking water limits for coliform bacteria, iron and pH. We recommend disinfecting the borehole and taking a repeat sample after 14 days. Until a satisfactory result is obtained, water for drinking should be boiled or taken from a bottled supply.

Authorised by: Senior Analyst, Water Section
Date of issue: 22 October 2026

APPROVED