

DOVECOTE SYSTEMS LTD

Company No. 17160178 | matt.brander@gmail.com | 179 King Georges Avenue, Southampton
SO15 4LD

14 May 2026

To: SSEN Distribution / NorthMicroGen G99 Portal
Your Reference: 260420-000198
Application: G99 Fast-Track — 10.5kW BESS Installation
Site Address: 179 King Georges Avenue, Southampton SO15 4LD
MPAN: 2000022678841

RESPONSE TO REQUEST FOR FURTHER INFORMATION

Dear SSEN Distribution / NorthMicroGen Team,

Thank you for reviewing our G99 Fast-Track application (ref: 260420-000198) for the installation of a 10.5kW Battery Energy Storage System (FoxESS KH10.5 HV, 72kWh) at the above address. I write in response to your request for additional information, received 14 May 2026.

Please find enclosed the following supporting documents in response to your request:

Document	Reference	Revision	Notes
Annotated Site Location Plan	DSL-SP-001	Rev B — 14 May 2026	Shows property boundary, building footprint, driveway (right/east side), electricity meter on internal face of right side wall at half-depth, and Node-3 BESS hard against external face of same wall. Front elevation faces King Georges Avenue. Semi-detached — party wall on left/ west.
Electrical Single Line Diagram (G99 SLD)	DSL-SLD-001	Rev A — 29 April 2026	Full G99 connection schematic. AC-coupled BESS via FoxESS KH10.5 HV inverter. Protection relay, export limitation, isolation per ENA ER G99.

Key site details relevant to your assessment:

Property type: Semi-detached residential. The right-hand wall (as viewed from the driveway) is a shared party wall.

Electricity meter: SMETS2 smart meter, located internally on the *right side wall* of the dwelling (the wall facing the driveway), approximately halfway along the building depth. MPAN: 2000022678841.

G99 plant location (Node-3 BESS): Externally mounted hard against the right side wall on the driveway, directly opposite the electricity meter. The FoxESS KH10.5 HV inverter and battery enclosure sit at ground level against the wall face, weather-protected and secured. AC cable passes through the wall to the meter/consumer unit.

Grid connection point: AC coupling at the consumer unit / meter tail inside the property. No additional service reinforcement anticipated.

I confirm that the boundary map attached to your notification email (BoundaryMap_1479387.png) correctly identifies the plot at 179 King Georges Avenue, Southampton SO15 4LD, MPAN 2000022678841. The annotated site plan enclosed (DSL-SP-001 Rev B) provides additional detail on the G99 plant position within that boundary.

Please do not hesitate to contact me if you require any further information, equipment datasheets, or protection coordination data to progress this application to the quotation stage.

Yours faithfully,

Matthew Brander

Director, Dovecote Systems Ltd (Company No. 17160178)
matt.brander@gmail.com