

June 15, 2015

To whom it may concern,

On March 23, 2015 JRG Building Engineering was retained as an independent contractor to conduct a Building Envelope Investigation on one of the finished Trinity houses in Sparwood, British Columbia.

An air infiltration test, by means of a door blower, was conducted to measure the effectiveness of the air tightness of the building envelope. The test provided a rating of 1.94 ACH₅₀. The closer the number is to zero (0), the better the result.

The rating obtained yielded a value acceptable to the Energy Star for New Homes air infiltration requirements.

Yours truly



Julio Reynel-Gracia. P.Eng.