

1. (35 points) An open-loop transfer function is given by,


$$G(s) = \frac{1}{s^3 + 2.0s^2 + 3.26262s + 7.26262}$$

Which of the following PI controllers stabilizes the system in a unit-feedback closed-loop configuration?


- A.  $F(s) = -8.42426 + \frac{3.02524}{s}$
- B.  $F(s) = 2.07574 + \frac{1.52524}{s}$
- C.  $F(s) = -8.94951 + \frac{1.52524}{s}$
- D.  $F(s) = 1.55049 + \frac{3.02524}{s}$
- E.**  $F(s) = -3.02524 + \frac{0.76262}{s}$

2. (35 points) Which one of the following unit impulse responses corresponds to a system that does not overshoot when subjected to a unit step input?


A.



B.




3. (30 points) A design point on the root-locus plot for a P-type controller is shown below.




A zero is added so that the root-locus passes through this design point. Which of the following represents the correct angle condition for this design?


$$\sum \theta = 116.4^\circ + 99.5^\circ + 144.1^\circ = 360.0^\circ$$




$$\sum \theta = 63.6^\circ + 99.5^\circ + 35.9^\circ = 199.0^\circ$$



$$\sum \theta = 116.4^\circ + 80.5^\circ + 35.9^\circ = 232.7^\circ$$



$$\sum \theta = 116.4^{\circ} + 99.5^{\circ} - 35.9^{\circ} = 180.0^{\circ}$$



Q	A
1	E
2	A
3	D