



1. (35 points) An open-loop transfer function is given by,

$$G(s) = \frac{1}{s^3 + 2.0s^2 + 3.18181s + 7.18181}$$


Which of the following PI controllers stabilizes the system in a unit-feedback closed-loop configuration?

- A. $F(s) = -9.27274 + \frac{1.36363}{s}$
- B. $F(s) = -8.9091 + \frac{2.86363}{s}$
- C. $F(s) = 1.5909 + \frac{1.36363}{s}$
- D.** $F(s) = -2.86363 + \frac{0.68181}{s}$
- E. $F(s) = 1.22726 + \frac{2.86363}{s}$

2. (35 points) Which one of the following unit impulse responses corresponds to a system that does not overshoot when subjected to a unit step input?




3. (30 points) A design point on the root-locus plot for a P-type controller is shown below.




A zero is added so that the root-locus passes through this design point. Which of the following represents the correct angle condition for this design?


$$\sum \theta = 115.8^\circ + 98.6^\circ - 34.4^\circ = 180.0^\circ$$




$$\sum \theta = 64.2^\circ + 98.6^\circ + 34.4^\circ = 197.2^\circ$$



$$\sum \theta = 115.8^\circ + 98.6^\circ + 145.6^\circ = 360.0^\circ$$



$$\sum \theta = 115.8^{\circ} + 81.4^{\circ} + 34.4^{\circ} = 231.7^{\circ}$$



Q	A
1	D
2	A
3	A