



1. (35 points) An open-loop transfer function is given by,

$$G(s) = \frac{1}{s^3 + 2.0s^2 + 3.33333s + 7.33333}$$


Which of the following PI controllers stabilizes the system in a unit-feedback closed-loop configuration?

- A. $F(s) = -8.66667 + \frac{1.66666}{s}$
- B. $F(s) = 1.83333 + \frac{3.16666}{s}$
- C. $F(s) = -8.0 + \frac{3.16666}{s}$
- D. $F(s) = 2.5 + \frac{1.66666}{s}$
- E. $F(s) = -3.16666 + \frac{0.83333}{s}$

2. (35 points) Which one of the following unit impulse responses corresponds to a system that does not overshoot when subjected to a unit step input?




3. (30 points) A design point on the root-locus plot for a P-type controller is shown below.




A zero is added so that the root-locus passes through this design point. Which of the following represents the correct angle condition for this design?


$$\sum \theta = 116.9^\circ + 100.3^\circ + 142.9^\circ =$$



$$\sum \theta = 63.1^\circ + 100.3^\circ + 37.1^\circ =$$



$$\sum \theta = 116.9^\circ + 79.7^\circ + 37.1^\circ =$$



$$\sum \theta = 116.9^\circ + 100.3^\circ - 37.1^\circ =$$

